

DUKE POWER COMPANY

NDE-91-1

Limited Examination Coverage Worksheet

Revision 0

Examination Volume/Area Defined

Base Metal Weld Near Surface Bolting Inner Radius

Area Calculation

Volume Calculation

$$.8 \times 2.5 \times 106.5 = 213 \text{ cu. in.}$$

Coverage Calculations

Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	45L	CCW	2.0	106.5	213	213	100%
2	45L	CW	2.0	106.5	213	213	100%
3	45L	1	2.0	99	198	198.6 ÷ 213	93.24%
3	45L	1	.08	7.5	.6		
4	45L	2	0	0	0	213	0
					<u>624.6</u>	<u>852</u>	<u>73.31%</u>

Aggregate % 73.30%

9603110399 960229
PDR ADOCK 05000414
P PDR

SHEET 4 OF 4

Item No: B09.011.019

Prepared BY: *Winfred C. Leeper*

Level: *A*

Date: 10-24-95

Reviewed By: *Greg H. Babb*

Level: *III*

Date: 10-25-95

DUKE POWER COMPANY

ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS

Exam Start: 1450 Form NDE-UT-2A

Exam Finish: 1518 Revision 4

Station: CATAWBA Unit: Z Component/Weld ID: ZND-37A Date: 10/25/95

Weld Length (in.): 63" Surface Condition: AS GROUNDED *ZZZ
 L0: 9.1.1.6
 9/10/25/95

Surface Temperature: 20 ° C

Pyrometer S/N: MCNDE27011

Cal Due: 960614

Examiner: [Signature] Level: II

Scans:
 45 58 dB 70 _____ dB

Examiner: [Signature] Level: II

45T 58 dB 70T _____ dB

Configuration: CIRC.

VALVE BODY Flow BOUNDET

SZ to SI

Procedure: NDE-630 Rev: 1 FC: _____

60 69 dB

Scan Surface: OD

Calibration Sheet No: 9502053 95-02
9502054, 55 & 56

60T _____ dB
 Other: 45° L - 72 dB

Applies to NDE-680 only

Skew Angle: N/A

IND #	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir	Exam surf.	Scan	Clamps
					20% dac HMA	20% dac HMA	20% dac HMA	20% dac HMA	20% dac HMA	20% dac HMA				
DO NOT WRITE IN THIS SPACE					50% dac	50% dac	50% dac	50% dac	50% dac	50% dac		DO NOT WRITE IN THIS	SPACE	
					100% dac	100% dac	100% dac	100% dac	100% dac	100% dac				
<u>45°</u>	<u>NO</u>	<u>RECORDABLE</u>	<u>INDICATIONS (CIRC. & AXIAL)</u>											
<u>45° L-WAVE</u>	<u>NO</u>	<u>RECORDABLE</u>	<u>INDICATIONS (AXIAL)</u>											
<u>60°</u>	<u>NO</u>	<u>RECORDABLE</u>	<u>INDICATIONS (AXIAL)</u>											

Remarks: * B&W #5 - UPSTREAM APEX OF BRANCH CONNECTION

Limitations: (see NDE-UT-4) 90% or greater coverage obtained: yes no

Reviewed By: [Signature] Level: III Date: 10-27-95 Authorized Inspector: [Signature] Date: _____

Sheet 1 of 6 Item No: BIZ.040.002D


DUKE POWER COMPANY

ISI LIMITATION REPORT

FORM NDE- UT-4


Revision 1

Component/Weld ID: <u>ZND-37A</u> Item No: <u>B12.040.002D</u>		remarks:
<input checked="" type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM <u>L 0+0"</u> to <u>L 0+63"</u> INCHES FROM <u>WO 1.5"</u> to <u>BEYOND</u> ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other _____ FROM <u>0</u> DEG to <u>360</u> DEG		<u>← VALVE BODY</u>
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input checked="" type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM <u>L 0+0"</u> to <u>L 0+63"</u> INCHES FROM <u>WO 0</u> to <u>1.5"</u> ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other _____ FROM <u>0</u> DEG to <u>360</u> DEG		<u>← VALVE BODY</u>
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input checked="" type="checkbox"/> LIMITED SCAN <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM <u>L 0+0"</u> to <u>L 0+63"</u> INCHES FROM <u>WO +1"</u> to <u>+2.2"</u> ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 other _____ FROM <u>0</u> DEG to <u>360</u> DEG		<u>← TAPER OF BONNET</u>
<input type="checkbox"/> NO SCAN SURFACE BEAM DIRECTION <input type="checkbox"/> LIMITED SCAN <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM <u>L _____</u> to <u>L _____</u> INCHES FROM <u>WO _____</u> to <u>_____</u> ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 other _____ FROM _____ DEG to _____ DEG		Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> no
Prepared By: <u>[Signature]</u> Level: <u>II</u> Date: <u>10/26/95</u>	Sheet <u>2</u> of <u>6</u>	
Reviewed By: <u>Suey J. Bult III</u> Date: <u>10-27-95</u>	Authorized Inspector: <u>[Signature]</u>	Date: <u>11-1-95</u>




45° SURFACE 2
BEAM DIR. 1
3 of 6

B12.040.002D
WELD# ZJD-37A



60° SURFACE 1
BEAM DIRECTION 2
4 of 6

B1Z.040.002D
WELD# ZND-37A



45° SURFACE 1
BEAM DIRECTION Z

5 of 6

B12.040.002D
WELD# ZJD-37A

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
	Revision 0

Examination Volume/Area Defined

Base Metal Weld Near Surface Bolting Inner Radius

Area Calculation	Volume Calculation
$2.35" \times 3" = 7.05 \text{ in}^2$	Weld Length = 63" $V = 7.05 \text{ in}^2 \times 63 \text{ in}$ $V = 444.15 \text{ in}^3$

Coverage Calculations

Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
①	45°	S2	4.3	63"	370.9 269.32 92.10/26/95	444.15	60.9% 60.6% 9.19/26/95
②	45°	S1	3.6	63"	226.8	444.15	51.1%
③	45°	CW	7.05 in ²	63"	444.15	444.15	100%
④	45°	CCW	7.05 in ²	63"	444.15	444.15	100%
⑤	60°	S2	2.0	63"	$\frac{126"}{1512}$	$\frac{444.15}{2220.75}$	28.4%

Aggregate % 68.08%

6 of 6

Item No: B12.040.002D

Prepared BY: <i>DE Heuser</i>	Level: <i>II</i>	Date: <i>10/24/95</i>
Reviewed By: <i>Jay S. Bull</i>	Level: <i>III</i>	Date: <i>10-27-95</i>

DUKE POWER COMPANY

ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS

 Exam Start: 1201

Form NDE-UT-2A

 Exam Finish: 1256

Revision 4

 Station: CATAWBA

 Unit: II

 Component/Weld ID: 25GD-UH-15

 Date: 10-15-95

 Weld Length (in.): 94.2"

 Surface Condition: AS GROUND

 L: ^WAXIS

 Surface Temperature: 69 ° F

 Pyrometer S/N: MCNDE 27016

 Examiner: James W. Steyer

 Level: III

Scans:

 45 _____ dB 70 73.5 dB

 Cal Due: 960712

 Examiner: David K. Zinger

 Level: II

 45T _____ dB 70T _____ dB

 Configuration: INNER RADIUS
N/A Flow N/A

 Procedure: NDE 680 Rev: 1

FC:

 60 _____ dB

_____ to _____

Calibration Sheet No:

95-16

 60T _____ dB

 Scan Surface: OD

Applies to NDE-680 only

9502026

Other: _____ dB

 Skew Angle: 18°

IND #	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir	Exam surf.	Scan	Damps
<u>4</u>					20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA				
DO NOT WRITE IN THIS SPACE					50%dac	50%dac	50%dac	50%dac	50%dac	50%dac				
NO RECORDED INDICATIONS.					100% dac	100% dac	100% dac	100% dac	100% dac	100% dac				
DO NOT WRITE IN THIS SPACE														

Remarks:

 Limitations: (see NDE-UT-4)

 90% or greater coverage obtained: yes no

 Sheet 1 of 3
10-31-95

Reviewed By:

Level:

Date:

Authorized Inspector

Date

Item No:

Greg S. Bibb
III
10-17-95
Robert M. Bell
10-26-95
CO2.022.007

106

DUKE POWER COMPANY

ISI LIMITATION REPORT

FORM NDE-UT-4

Revision 1

Component/Weld ID: 254D-UH-15 Item No: CO2.022.007

remarks:

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO +3.0 to Beyond
 ANGLE: 0 45 60 other 70 FROM 0 DEG to 360 DEG

NOZZLE GEOMETRY

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 other FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 other FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 other FROM _____ DEG to _____ DEG

Sketch(s) attached
 yes no

Prepared By: James W. Setzer Level: III Date: 10-16-95 Sheet 2 of 34 add
10-31-95

Reviewed By: Doug L. Babb III Date: 10-17-95 Authorized Inspector: Robert M. Sell Date: 10-26-95

(106)

DUKE POWER COMPANY

NDE-91-1

Limited Examination Coverage Worksheet

Revision 0

Examination Volume/Area Defined

Base Metal Weld Near Surface Bolting Inner Radius

Area Calculation

Volume Calculation

SEE ATTACHED SKETCH

$$\frac{2.0 \times 2.0}{2} \times 2 + \frac{2.0^2 \times \pi}{4} = 7.14 \text{ IN}^2$$

$$7.14 \text{ IN}^2 \times 94.2 \text{ IN} = 672.6 \text{ CU IN}$$

Coverage Calculations

Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
IR	70	CW	3.61	94.2	340.1	672.6	51%
IR	70	CCW	3.61	94.2	340.1	672.6	51%

Aggregate % 51%

Item No: C02.022.007

Prepared BY: James W. Sitzer

Level: III

Date: 10-16-95

Reviewed By: Lucy L. Bubb

Level: IV

Date: 10-17-95

MAIN - STEAM OUTLET NOZZLE
NOZZLE & SHELL 1/2 INNER RADIUS.

1/2 SCALE


70° INNER RADIUS.

EXAM AREA = $\frac{2.0 \times 2.0}{2} + \frac{2.0 \times 2.0}{2} + \frac{2.0^2 \times \pi}{4} = 7.14 \text{ sq in}$

AREA COVERED	
1.)	$\frac{1.9 \times .85}{2} = .81$
2.)	$\frac{1.9 \times 2.0}{2} = 1.9$
3.)	$3.0 \times .30 = .9$
TOTAL = 3.61 sq in	

AREA LOSS
 3.53 sq in

AREA LOSS = EXAM AREA - AREA COVERED
 7.14 - 3.61
 3.53 sq in



J.W. Setzer III
 10-16-95
 COZ.022.007