

## UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

March 1, 1996

Mr. Paul Gunter, Director Reactor Watchdog Project Nuclear Information and Resource Service 1424 16th Street, N.W., Suite 404 Washington, DC 20036

Mr. Shean H. Bjoralt, Director Communications and Logistics Prairie Island Coalition 212 N. 3rd Avenue, #350 Minneapolis, MN 55401

Dear Messrs. Gunter and Bjoralt:

This letter acknowledges receipt of an addendum dated February 19, 1996, to your Petition of June 5, 1995, in which you raised further concerns regarding intergranular stress-corrosion cracking (IGSCC) of steam generator tubes at Northern States Power Company's Prairie Island Nuclear Generating Plant, Units 1 and 2.

In the addendum of February 19, 1996, you quoted a statement I made in a briefing to the Commission on January 31, 1996, in which I discussed experience from 1995 reactor refueling outages with respect to steam generator inspections. I had stated that there were a few isolated cases of free span cracking in steam generator tubes, that is, cracks not located within the tube support plate or the tube sheet regions. In your addendum, you requested that Prairie Island Unit 1 not be allowed to return to operation until a full-length inspection of all steam generator tubes is conducted using the state-of-the-art Zetec Plus Point probe, based on the information made available at the Commission briefing on January 31, 1996.

Your addendum provided no new information to the staff. The instances of free span cracking that I referred to were axially oriented. Inspections with the bobbin coil probe alerted the affected licensees to the presence of free span axial indications. The bobbin coil probe is an appropriate probe for performing the general-purpose, full-length inspection of the tubing because of its capability to detect flaw geometries exhibiting an axial component. Northern States Power Company has conducted full-length inspections using the bobbin coil probe of all steam generator tubes that have not been plugged during the current outage on Unit 1, except for the U-bends of row 1 and row 2 tubes where the bobbin coil probe cannot travel. All row 1 and row 2 tubes were inspected in the U-bends with rotating coil probes, including the Zetec Plus Point probe. These inspections were adequate to identify axial indications.

The NRC staff's review of the information provided in the addendum to your Petition has not identified any safety issues warranting immediate action at the Prairie Island Nuclear Generating Plant. Consequently, your request to

9603110413 960301 PDR ADOCK 05000282 H PDR NING FILE GENTER COPY

DFOI

not allow Prairie Island Unit 1 to be returned to operation until a fulllength inspection of all steam generator tubes is conducted using the Plus Point probe is denied.

As provided by 10 CFR 2.206, the NRC will take appropriate action on your Petition within a reasonable time. I have enclosed for your information a copy of the notice that is being filed with the Office of the Federal Register for publication.

Sincerely,

Original Signed By

William T. Russell, Director Office of Nuclear Reactor Regulation

Docket Nos. 50-282/50-306

Enclosure: FR Notice

cc w/encl: See next page

DISTRIBUTION: See attached list

DOCUMENT NAME: G:\WPDOCS\PRAIRIE\PI2206.LTR To receive a copy of this document, indicute in the box: "C" = Copy with OFFICE LA:PD3-1 N PM:PD3-1 C TECH ED D: PD3-1-N EMCB NAME CJamerson \* RBywater \* JHannon V JStrosnider DATE 3///96 3 / 1/96 5 /1 /96 / 1/96 3/1/96 OFFICE OGC C D:DRPW, R N ADP RIZ D:NRRW/ NAME RHoefling & JRoe & for RZimmerman WRussell DATE 3/1/96 3/1/96 2/1/96 2 // /36 See previous concurrence OFFICIAL RECORD COPY

\* telecon w

P. Gunter & S. Bjoralt

J. E. Silberg, Esq. Shaw, Pittman, Potts and Trowbridge 2300 N Street, NW Washington, DC 20037

Plant Manager Prairie Island Nuclear Generating Plant Northern States Power Co. 1717 Wakonade Drive East Welch, MN 55089

Adonis A. Weblett Assistant Attorney General Office of the Attorney General 455 Minnesota Street Suite 900 St. Paul, MN 55101-2127

U.S. Nuclear Regulatory Commission Resident Inspector's Office 1719 Wakonade Drive East Welch, MN 55089-9642

Regional Administrator, Region III U.S. Nuclear Regulatory Commission 801 Warrenville Road Lisle, IL 60532-4351

Mr. Jeff Cole, Auditor/Treasurer Goodhue County Courthouse Box 408 Red Wing, MM 55066-0408

Site Licensing
Prairie Island Nuclear Generating
Plant
Northern States Power Company
1717 Wakonade Drive East
Welch, MN 55089

Kris Sanda, Commissioner Department of Public Health 121 Seventh Place East, Ste. 200 St. Paul, MN 55101-2145 Ms. Myrna M. Halbach Goodhue County Solid Waste Administrator P.O. Box 408 Red Wing, MN 55066

Tribal Council
Prairie Island Dakota
Indian Community
5750 Sturgeon Lake Rd.
Welch, MN 55089

Ms. Mary Jo Murray Minnesota Office of the Attorney General 525 Park Street Suite 500 St. Paul, MN 55103

Mr. Michael E. McCarthy Minnesota Dept. of Public Services 121 Seventh Place East St. Paul, MN 55101-2145

Ms. Gretchen Sable Minnesota State Planning 300 Centennial Bldg. 658 Cedar Street St. Paul, MN 55155

Mr. Richard Duncan Faegre and Benson Law Firm 2200 Norwest Center 90th South Seventh Street Minneapolis, MN 55402

City of Red Wing Council Administrator Box 34 Red Wing, MN 55066

cc w/encl & incoming:

Mr. Roger O. Anderson, Director Licensing and Management Issues Northern States Power Company 414 Nicollet Mall Minneapolis, MN 55401 DISTRIBUTION:

2.206 Acknowledgement to Gunter and Bjoralt Petition

Addendum of 2/19/96 Dated: March 1, 1996

Docket File (w/incoming) (50-282/50-306)

PUBLIC (w/incoming letter)

EDO #0000433 EDO Reading File

J. Taylor J. Milhoan

H. Thompson

J. Blaha

J. Lieberman

W. Russell/F. Miraglia H. Miller, RIII/ORA

C. Paperiello

K. Cyr

R. Zimmerman

A. Thadani

J. Roe

E. Adensam (EGA1)

D. Crutchfield

J. Goldberg

NRR Mail Room (EDO #0000433 w/incoming), 0-12G18

PDIII-1 Reading File (w/incoming)

J. Hannon

C. Jamerson

B. Wetzel/R. Bywater

J. Strosnider

OPA OCA

N. Olson

C. Morris

W. Axelson, RIII

M. Jordan, RIII