



Duquesne Light

Health Physics Department

A9.621

REVISION

0 1 2 3

PAGE 1 OF

ERS-MPD-91-035

56

Subject: Assessment Of The Doses In The Unit 2 Control Room Due To A Locked Rotor Accident At Unit 2 Assuming 18% Failed Fuel

Reference

RCM RP _____ EPP _____ T/S _____ EM _____ DCP _____ Other _____
RIP _____

Review Category RSC Req'd RSC Not Req'd

10 CFR 50.59
 Required

Purpose: To calculate the doses to the control room personnel resulting from the Locked Rotor Accident at Unit 2. Assumption of 18% fuel damage and the use of the new fuel is made.

| | | | |
|---|------------------|------|--|
| 3 | by | date | |
| | chk | date | |
| | app | date | |
| 2 | by | date | |
| | chk | date | |
| | app | date | |
| 1 | by | date | |
| | chk | date | |
| | app | date | |
| 0 | by | date | |
| | chk | date | |
| | app (or RSC H-9) | date | |

Mark Duranko 10/24/91
date
Dan Gurniak 10/24/91
date
app (or RSC H-9) 10/24/91
date

Checklist

- Purpose
- Assumptions
- Methodology

- Input Data
- Results
- References

Attachments

- Data Sheets
- Illustrations
- Printouts
- Code Listings

- BV RECORDS CENTER
- CALCULATION FILE
- MGR, Health Physics
- DIR, RadEng

- DIR, RadOps-1
- DIR, RadOps-2
- DIR, RadHealth
- DIR, EnvSvcs.

 Trng Dept. Author: M. Duranko R. Ireland _____

DISCUSSION

This analysis is made to document the Control Room (CR) dose estimate for a Locked Rotor Accident (LRA) at Unit 2.

This analysis is similar to that done for the Unit 1 LRA, documented in Reference [1], except that the offsite doses are not included in this analysis. They were documented in Calculation ERS-MPD-91-022, Reference [2]. References [1] and [2] should be consulted for further information concerning the background for this calculation.

METHODOLOGY

This analysis will be performed using the TRAILS code documented in Reference [3]. TRAILS is a simple FORTRAN program that mechanizes the solution of first order linear equations and dose calculations. Although the code is documented in detail in Reference [3], the more significant methodologies, constants, and assumptions incorporated into the code are listed below:

The code implements a model of the release that incorporates one or two compartments (or nodes) prior to the release to the environment. The transport of radioactive material through the system is governed by simple first order linear equations based on the postulated flow rates and the radionuclide decay constants.

The offsite dose calculational methods are those provided in Regulatory Guide 1.4 [Ref: 4]. Thyroid dose conversion factors and breathing rates are those provided in TID14844 [Ref: 5] and Regulatory Guide 1.4. The average energy per disintegration for included isotopes (Kr, Xe, I) were calculated from the spectra data provided in the DRALIST data library [Ref: 6], which is a subset of the ORNL Evaluated Nuclear Structure Data File, and which is available in hardcopy as DOE/TIC-11026 [Ref: 7]. This data source was used in lieu of the suggested 6th Edition, Table Of Isotopes, which is no longer in print.

The Control Room is treated as a compartment with variable (by time step) intake, filtration, X/Q, breathing rate, and exhaust rates.

For this analysis the duration Control Room doses (30 days) will be analyzed.

The release modeling that will be utilized is similar to that used by SWEC in the evaluation of the combined Control Room habitability in 1987 [Ref: 8,9]. In that analysis, SWEC performed an evaluation of Control Room doses due to a locked rotor accident at Unit 1 in order to meet Unit 2 licensing commitments, assuming no fuel failures.

Since the Control Room doses are sensitive to the timing of Control Room isolation initiated by area radiation monitors, an evaluation of the Control Room dose rate at various times post-accident is assessed first.

Based on these results, an isolation time is postulated and included as an analysis assumption during evaluation of Control Room dose over the duration of the accident.



The analyses address the following release components:

1. Release of iodine activity from the three steam generators due to technical specification primary-to-secondary leakage. Iodine partitioning is assumed. The activity is based on 18% fuel clad failure, with the fuel clad activity based on St. Jard Review Plan assumptions (i.e., 30% Kr-85, 10% all others), with the exception of I-131, which is assumed to be 12% in keeping with the conclusions of NUREG/CR-5009 (Ref: 10).
2. Same as #1, but for noble gases with no credit for partitioning.
3. Release of activity released into the RCS and hence to the three steam generators by an iodine spike that occurs concurrent with the locked rotor. RCS leak rate based on technical specifications.
4. Release of the initial activity contained in the steam in all three steam generators at time =0. This activity based on technical specifications.
5. Release of the initial activity of iodine contained in the secondary liquid in all three steam generators at time = 0. (Noble gases are assumed to be in the steam space). This activity based on technical specifications.

Releases from steam generators are based on the steam mass releases described in Reference 11.

INPUT DATA/ASSUMPTIONS

1. General Methodology Based On SRP 15.3.3-15.3.4 [10]
2. Core Inventory From Table 11.1-1 Based On 2766 MWT [11]
3. Core-Gap Fractions
 - Kr-85 0.30 [11]
 - I-131 0.12 [12]
 - Other 0.10 [11]
4. Fraction Of Rods In DNB = 18% [13]
5. Fraction of Rods Assumed Failed = 18% (Section 15.3.3) [10]
6. Concurrent Spike Appearance Rates, uCi/sec (Tbl. 15.0-10) [11]
 - I-131 1.36E6
 - I-132 2.52E6
 - I-133 3.08E6
 - I-134 3.68E6
 - I-135 2.81E6
7. Concurrent Spike Duration 0-4 Hours (Tbl. 15.3-3) [11]
 - Assume appearance rates are 1/500 for 4-8 hours
8. RCS Volume = 4.2E5 lbs. (Tbl. 11.1-3) [11]
9. RCS Primary-To-Secondary Leakage = 1 gpm Total (Tbl. 15.3-3) [11]
10. Steam Generator Mass (Tbl. 15.3-3) [11]
 - Liquid = 99300 lbs.
 - Steam = 8700 lbs.

- | | |
|--|------|
| 11. Steam Generator Mass Release (Tbl. 15.3-3) | [11] |
| 0-2 hours = 443,878 lbs. | |
| 2-8 hours = 793,644 lbs. | |
| 12. Iodine Partitioning In Steam Generators = 0.01 (Tbl. 15.3-3) | [11] |
| 13. Duration Of Plant Cooldown By Secondary System (Tbl. 15.3-3) | [11] |
| i.e., duration of release = 8 hours | |
| 14. X/Q Values For The Control Room (Sec/M ³) | [14] |
| 0-8 hr - 1.59E-4 24-96 hr - 5.96E-5 | |
| 8-24 hr - 7.86E-5 96-720 hr - 3.76E-5 | |
| 15. Control Room Volume: 1.73E5 cu.ft. (Sec. 5.4) | [11] |
| 16. Control Room Normal Intake: 500 cu.ft./min. (Sec. 6.4) | [11] |
| 300 cu.ft./min. From Unit 1 And 200 cu.ft./min. From Unit 2 | |
| 17. Control Room Pressurization Rate: 690 cu.ft./min. (Sec. 6.4) | [11] |
| 18. Control Room Infiltration: 10 cu.ft./min. (Sec. 6.4) | [11] |
| 19. Control Room Filter Efficiency: 95% | [15] |
| To account for the filter bypass indicated in Item 18, this | |
| is modified by: | |
| $\frac{690(.95) + 10(0)}{690 + 10} = .936$ | |
| 20. Control Room Purge Flow: 19800 cu.ft./min. (based on the | [11] |
| recirculation fan flow rate which can be used to purge the CR) | |
| 21. Purge Initiation At 8 Hours | [11] |
| 22. Purge Duration .5 Hours | [9] |

CONTROL ROOM MODELING, DOSE RATE EVALUATION

For the dose rate evaluation, the Control Room intake and exhaust are set to 500 cu.ft./min., with no filtration. Time steps selected were based on trial calculations which identified the most likely times for the dose rate to reach the safety limit of 1 mR/hr. Note that this value is different than the alarm setpoint of the Control Room monitors. This is explained in Reference [17].


A chart showing the dose rate versus time was prepared. It is included as Attachment 1. The print outs from the TRAILS runs are included as Attachment 2.

The chart shows that the safety limit of 1 mrem/hour is reached at about 2320 seconds (~40 minutes) after the start of the accident. Since it is reasonable to assume operator manual actions after 30 minutes, it will be assumed that the operators will manually initiate isolation at T = 30 minutes.

CONTROL ROOM MODELING, DOSE EVALUATION

In order to be consistent with the results above, the Control Room isolation was assumed to occur at 1800 seconds or 30 minutes.

For the one hour period after isolation the only intake is the unfiltered 10 cu.ft./min. infiltration. The exhaust is equal to the pressurization rate of 690 cu.ft./min. plus the infiltration for a total of 700 cu.ft./min.



Health Physics Department

ERS-MPD-91-035

Page 5 of 56

At one hour following isolation, the Control Room ventilation realigns for filtered intake up to 1000 cu.ft./min. In accordance with the U2 UFSAR, the clean-up rate is 690 cu.ft./min. This is added to the 10 cu.ft./min. infiltration to yield 700 cu.ft./min. exfiltration. The air intake necessary to maintain this is the same 700 cu.ft./min. This ventilation continues until eight hours after the start of the accident.

At eight hours a Control Room purge is initiated. It continues until 8.5 hours at which time the normal system arrangement is restored.

CALCULATION

Source term development, determination of transfer lambdas, and release modeling is the same as in Reference [1] and are not repeated here.

The addition of the CR to the calculation is accomplished by insertion of suitable parameters for the flows, volumes, filtration rates, and X/Q values.

The X/Q parameters were determined by NUS Corporation using the methodology in Reference [14].

The print outs from the cases are included as Attachment 3.

RESULTS

The results and total from the five cases are as follows:


| | Gamma Dose (mrem) | Beta Dose (mrem) | Thyroid Dose (mrem) |
|--------------|----------------------|---------------------|------------------------|
| Case 1 | 6.23E-2 | 4.31E-1 | 1.07E+3 |
| 2 | 1.07E+1 | 1.48E+2 | 0 |
| 3 | 5.16E-4 | 3.41E-3 | 7.39E0 |
| 4 | 1.74E-5 | 1.23E-4 | 4.44E-1 |
| 5 | 1.34E-4 | 1.08E-3 | 3.58E0 |
| Total (mrem) | 1.08E+1 | 1.48E+2 | 1.08E+3 |

CONCLUSION

The dose limits in GDC 19, Reference [16] and the Standard Review Plan, Reference [10] are : Whole Body gamma - 5 rem

Thyroid - 30 rem


Beta Skin dose - 30 rem



The doses developed in this package are:

| | |
|------------------|---------------|
| Whole Body gamma | - 1.08E-2 rem |
| Thyroid | - 1.08 rem |
| Beta Skin dose | - 1.48E-1 rem |

The analysis of the Locked Rotor Accident shows that the Control Room doses are acceptable and the new fuel can be used, but requires that manual isolation of the Control Room occur at 30 minutes after the start of the accident.




Health Physics Department

ERS-MPD-91-035

Page 7 of 56

REFERENCES

1. ERS-SFL-89-021, Safety Analysis Of The Dose Consequences Of A Locked Rotor Accident At BVPS-1 With 18% Fuel Failure -- EAB, LPZ, Control Room, 1989
2. ERS-MPD-91-022, Ofisite Dose Consequences Of A Locked Rotor Accident At Unit 2 With 18% Failed Fuel
3. DLC, Calculation ERS-SFL-089-020, TRAILS: Transport Of Radioactive Material In Linear Systems, 1989
4. NRC, Assumptions Used For Evaluating The Potential Radiological Consequences Of A Loss Of Coolant Accident For Pressurized Water Reactors, Regulatory Guide 1.4, 1974
5. USAEC, Calculation Of Distance Factors For Power And Test Reactor Sites, TID-14844, 1962
6. ORNL, DRALIST: Radioactive Decay Data For Application To Radiation Dosimetry And Radiological Assessments, DLC-80, 1981
7. D. C. Kocher, Radioactive Decay Data Tables, DOE/TIC-11026, 1981
8. SWEC, Calculation 12241-UR(B)-449, Doses In The BV1 And BV2 Combined Control Room Due To A Locked Rotor Accident And A Loss Of Non-Emergency AC Power To Station Auxiliaries Accident At Unit 1 With 500 cfm Normal Ventilation, 1987
9. SWEC, Calculation 12241-UR(VB)-456, Combined BV1-BV2 Control Room Habitability Due To Design Basis Accidents (Except LOCA) At BV1, 1987
10. NRC, Standard Review Plan For The Review Of Safety Analysis Reports For Nuclear Power Plants, LWR Edition, NUREG-0800, 1984
11. DLC, Unit 2 Updated Final Safety Analysis Report
12. NRC, Assessment Of The Use Of Extended Burnup Fuel In Light Water Power Reactors, NUREG/CR-5009, 1988
13. Westinghouse, ltr 89DL*-G-0055, dtd 7/13/89, Rods In DNB For Locked Rotor Event
14. Halliburton NUS Environmental Corporation ltr ARP-91-444, dtd 10/8/91, Control Room X/Q Values For BVPS (Attachment 4)
15. USNRC, Safety Evaluation Report, related to the operation of BVPS, Unit 2



Health Physics Department


ERS-MPO-91-035

ATTACHMENT 1

Page 8 of 56

CONTROL ROOM ALARM RESPONSE

mrem / hr vs. seconds



Total from all cases for times shown.

CONTROL ROOM ALARM RESPONSE TABLE

Doses obtained from the calculations shown in Attachment 2.
Units are mrem/hr and seconds.

| TIME | CASE 1 | CASE 2 | CASE 3 | CASE 4 | CASE 5 | TOTAL |
|------|----------|----------|----------|----------|----------|----------|
| 60 | 7.97E-06 | 7.19E-02 | 3.12E-10 | 7.04E-06 | 1.17E-06 | 7.19E-02 |
| 300 | 1.92E-04 | 2.74E-01 | 2.31E-08 | 6.86E-06 | 5.79E-06 | 2.74E-01 |
| 600 | 7.39E-04 | 4.36E-01 | 1.78E-07 | 6.64E-06 | 1.14E-05 | 4.37E-01 |
| 900 | 1.60E-03 | 5.63E-01 | 5.82E-07 | 6.44E-06 | 1.68E-05 | 5.65E-01 |
| 1200 | 2.73E-03 | 6.74E-01 | 1.34E-06 | 6.24E-06 | 2.20E-05 | 6.77E-01 |
| 1500 | 4.11E-03 | 7.72E-01 | 2.54E-06 | 6.05E-06 | 2.70E-05 | 7.76E-01 |
| 1800 | 5.69E-03 | 8.60E-01 | 4.27E-06 | 5.88E-06 | 3.19E-05 | 8.66E-01 |
| 2100 | 7.47E-03 | 9.40E-01 | 6.59E-06 | 5.70E-06 | 3.66E-05 | 9.48E-01 |
| 2400 | 9.40E-03 | 1.01E+00 | 9.57E-06 | 5.54E-06 | 4.11E-05 | 1.02E+00 |
| 2700 | 1.15E-02 | 1.08E+00 | 1.33E-05 | 5.38E-06 | 4.55E-05 | 1.09E+00 |

F. THICK DATE

Page 1

15 OCT 1991 11:06

THAIIS - Transport of Radioactive Material in Nuclear Systems, v1.1
 Case 1 P to S leak. Isotopes: HZ FF - CR Dose Rate w/o 1501

(1000) RCS

COPP 3 SGs

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room


VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff

COPP Control Room

VR UME 1 / 30E +05 Cuff



Health Physics Department

ERS-MPO-91-035

ATTACHMENT 2

Page 9 of 56

REMOVAL
 1-34 REL FF
 1-20 REL FF
 1-20 REL FF

3 30%E-07 1/sec
 0 000E+00
 0 000E+00

2 0.69E-06 1/sec
 0 000E+00
 0 000E+00

1 0.00E+00 1/sec
 12 TARE REDUC 0 000E+00
 12 TARE FITTER 0 000E+00

1.000E DAT 1

Page 3

15 OCT 1991 11:06

TRANSPORT Radioactive Material in Linear Systems v1
Case 1 P to S leak Iodines 1BZ F F CH Dose Rate w/o Isot

| STEP | TIME | CURRENT | INTEGRD | CURRENT | INTEGRD | AVERAGE | RELEASE | RELEASE | CURRENT | CURRENT | INTEGRD |
|--------|-----------|-----------|---------|-----------|---------|-----------|---------|-----------|---------|---------|---------|
| | | uC1 | uC1-Sec | uC1 | uC1-Sec | uC1 | uC1/sec | uC1 | uC1 | uC1-Sec | uC1-Sec |
| 1 3 11 | INITIAL | 1 490E+12 | | 0 000E+00 | | | | 0 000E+00 | | | |
| 1 2 11 | TOTALS | 4 016E+12 | | 3 790E+12 | | 3 704E+06 | | 0 000E+00 | | | |
| 1 1 17 | INITIAL | 1 790E+12 | | 0 000E+00 | | 1 645E+12 | | 3 818E+06 | | | |
| 1 1 17 | TOTALS | 4 300E+15 | | 0 000E+00 | | | | 0 000E+00 | | | |
| 1 1 17 | INITIAL | 2 000E+12 | | 0 000E+00 | | 3 409E+12 | | 7 053E+06 | | | |
| 1 1 17 | TOTALS | 7 676E+15 | | | | | | | | | |
| 1 1 34 | INITIAL | 1 740E+12 | | 0 000E+00 | | 2 653E+12 | | 5 489E+06 | | | |
| 1 1 34 | TOTALS | 6 597E+15 | | | | | | | | | |
| 1 1 35 | INITIAL | 2 520E+12 | | 0 000E+00 | | 2 878E+12 | | 5 955E+06 | | | |
| 1 1 35 | TOTALS | 6 540E+15 | | | | | | | | | |
| 0 1 10 | FACULTIES | 9 826E+12 | | 8 758E+09 | | | | | | | |
| 0 1 10 | SLP | 10 | | | | | | | | | |

Duquesne
Light
Health Physics Department

ERS-MPO-91-035

ATTACHMENT 2

Page 11 of 56

卷之三

Transport of Radiopharmaceuticals in Linear Systems - 1

Page 12 of 56

FIRING DATE: 3

15 OCT 1991 11 05

1.5 Transport of Radioactive Material in Linear Systems - v1
 1.5.1 Pro-Safe Rel. Gases RCS, FF, non-equil., CR Dose Rate w/o isosol

CUMF Not used FOR ZA

| | CUMF | RCS | 1B2 | F | F | 3 | SGs | VDR, API | CUMF | Control Room |
|-----------------------|------|----------|----------|---|----------|----------|-----|----------|----------|----------------|
| INITIAL | 0 | 000E+00 | KR-B3m | | | | | | 3 | 7.30E+05 Cu Ft |
| | 0 | 000E+00 | KR-B5m | 2 | 1.50E+05 | KR-B3m | C4 | 0 | 000E+00 | KR-B3m |
| | 0 | 000E+00 | KR-B5 | 5 | 4.00E+05 | KR-B5m | | 0 | 000E+00 | KR-B5m |
| | 0 | 000E+00 | KR-B7 | 3 | 7.30E+04 | KR-B5 | | 0 | 000E+00 | KR-B5 |
| | 0 | 000E+00 | KR-B8 | 1 | 0.60E+06 | KR-B7 | | 0 | 000E+00 | KR-B7 |
| | 0 | 000E+00 | KR-B9 | 1 | 4.90E+06 | KR-B8 | | 0 | 000E+00 | KR-B8 |
| | 0 | 000E+00 | KR-B9 | 1 | 9.80E+06 | KR-B9 | | 0 | 000E+00 | KR-B9 |
| | 0 | 000E+00 | KR-90 | 0 | 0.90E+00 | KR-90 | | 0 | 000E+00 | KR-90 |
| | 0 | 000E+00 | XE-1.31M | 7 | 5.70E+03 | XE-1.31M | | 0 | 000E+00 | XE-1.31M |
| | 0 | 000E+00 | XE-1.33M | 6 | 6.80E+04 | XE-1.33M | | 0 | 000E+00 | XE-1.33M |
| | 0 | 000E+00 | XE-1.33 | 2 | 8.60E+06 | XE-1.33 | | 0 | 000E+00 | XE-1.33 |
| | 0 | 000E+00 | XE-1.35M | 7 | 5.60E+05 | XE-1.35M | | 0 | 000E+00 | XE-1.35M |
| | 0 | 000E+00 | XE-1.35 | 7 | 3.80E+05 | XE-1.35 | | 0 | 000E+00 | XE-1.35 |
| | 0 | 000E+00 | XE-1.37 | 2 | 5.20E+06 | XE-1.37 | | 0 | 000E+00 | XE-1.37 |
| | 0 | 000E+00 | XE-1.38 | 2 | 5.20E+06 | XE-1.38 | | 0 | 000E+00 | XE-1.38 |
| | 0 | 000E+00 | I-1.31 | 0 | 0.00E+00 | I-1.31 | | 0 | 000E+00 | I-1.31 |
| | 0 | 000E+00 | I-1.32 | 0 | 0.00E+00 | I-1.32 | | 0 | 000E+00 | I-1.32 |
| | 0 | 000E+00 | I-1.33 | 0 | 0.00E+00 | I-1.33 | | 0 | 000E+00 | I-1.33 |
| | 0 | 000E+00 | I-1.34 | 0 | 0.00E+00 | I-1.34 | | 0 | 000E+00 | I-1.34 |
| | 0 | 000E+00 | I-1.35 | 0 | 0.00E+00 | I-1.35 | | 0 | 000E+00 | I-1.35 |
| | 1 | 0.00E+00 | | 1 | 0.00E+00 | | | 1 | 0.00E+00 | |
| PROTECTIVE ACTIVITIES | | | | | | | | | | |
| | 0 | 000E+00 | Y9-B3m | 0 | 0.00E+00 | KR-B3m | | 0 | 000E+00 | KR-B3m |
| | 0 | 000E+00 | KR-B5m | 0 | 0.00E+00 | KR-B5m | | 0 | 000E+00 | KR-B5m |
| | 0 | 000E+00 | KR-B5 | 0 | 0.00E+00 | KR-B5 | | 0 | 000E+00 | KR-B5 |
| | 0 | 000E+00 | KR-B7 | 0 | 0.00E+00 | KR-B7 | | 0 | 000E+00 | KR-B7 |
| | 0 | 000E+00 | KR-B8 | 0 | 0.00E+00 | KR-B8 | | 0 | 000E+00 | KR-B8 |
| | 0 | 000E+00 | KR-B9 | 0 | 0.00E+00 | KR-B9 | | 0 | 000E+00 | KR-B9 |
| | 0 | 000E+00 | KR-90 | 0 | 0.00E+00 | KR-90 | | 0 | 000E+00 | KR-90 |
| | 0 | 000E+00 | XE-1.31M | 0 | 0.00E+00 | XE-1.31M | | 0 | 000E+00 | XE-1.31M |
| | 0 | 000E+00 | XE-1.33M | 0 | 0.00E+00 | XE-1.33M | | 0 | 000E+00 | XE-1.33M |
| | 0 | 000E+00 | XE-1.35M | 0 | 0.00E+00 | XE-1.35M | | 0 | 000E+00 | XE-1.35M |
| | 0 | 000E+00 | XE-1.35 | 0 | 0.00E+00 | XE-1.35 | | 0 | 000E+00 | XE-1.35 |
| | 0 | 000E+00 | I-1.37 | 0 | 0.00E+00 | I-1.37 | | 0 | 000E+00 | I-1.37 |
| | 0 | 000E+00 | I-1.38 | 0 | 0.00E+00 | I-1.38 | | 0 | 000E+00 | I-1.38 |
| | 0 | 0.00E+00 | I-1.31 | < | 0.00E+00 | I-1.31 | | 0 | 0.00E+00 | I-1.31 |
| | 0 | 0.00E+00 | I-1.32 | < | 0.00E+00 | I-1.32 | | 0 | 0.00E+00 | I-1.32 |
| | 0 | 0.00E+00 | I-1.33 | < | 0.00E+00 | I-1.33 | | 0 | 0.00E+00 | I-1.33 |
| | 0 | 0.00E+00 | I-1.34 | < | 0.00E+00 | I-1.34 | | 0 | 0.00E+00 | I-1.34 |
| | 0 | 0.00E+00 | I-1.35 | < | 0.00E+00 | I-1.35 | | 0 | 0.00E+00 | I-1.35 |
| REMOVAL | | | | | | | | | | |
| NUC 1-14 REL FR | 0 | 0.00E+00 | 1/s**c | 3 | 3.09E-07 | 1/sec | | 1 | 0.00E+01 | CFM |
| NUC 15-20 REL FR | 0 | 0.00E+00 | | 0 | 0.00E+00 | | | 0 | 0.00E+00 | |

Page 13 of 56

TRANSPORT OF Radioactive Material in Linear Systems. v1
Assume to 5 years hot Gases. 1B2 F.F. non equil. CR Dose Rate w/o 1501

MULTIPLIER:

| STEP | TIME | XPR | XREM | XRF | XPR | XREM | XRF | XPR | XREM | XRF | XPR | XREM | XRF |
|------|----------|----------|------|----------|----------|------|----------|------|----------|------|------|----------|------|
| 1 | 0.00E+01 | 0.00E+00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 50.0 | 0.00E+00 | 50.0 |
| 2 | 3.00E+02 | 0.00E+00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 50.0 | 0.00E+00 | 50.0 |
| 3 | 6.00E+02 | 0.00E+00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 50.0 | 0.00E+00 | 50.0 |
| 4 | 9.00E+02 | 0.00E+00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 50.0 | 0.00E+00 | 50.0 |
| 5 | 1.20E+03 | 0.00E+00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 50.0 | 0.00E+00 | 50.0 |
| 6 | 1.50E+03 | 0.00E+00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 50.0 | 0.00E+00 | 50.0 |
| 7 | 1.80E+03 | 0.00E+00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 50.0 | 0.00E+00 | 50.0 |
| 8 | 2.10E+03 | 0.00E+00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 50.0 | 0.00E+00 | 50.0 |
| 9 | 2.40E+03 | 0.00E+00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 50.0 | 0.00E+00 | 50.0 |
| 10 | 2.70E+03 | 0.00E+00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 50.0 | 0.00E+00 | 50.0 |

----- CONTROL ROOM -----

| STEP | TIME | X/G Breathing Occupancy | X/H3 H3/S |
|------|----------|-------------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 1 | 0.00E+00 | 3.470E-04 | 1.000E+00 |
| 2 | 3.00E+02 | 1.590E-04 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| 3 | 6.00E+02 | 1.590E-04 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| 4 | 9.00E+02 | 1.590E-04 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| 5 | 1.20E+03 | 1.590E-04 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| 6 | 1.50E+03 | 1.590E-04 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| 7 | 1.80E+03 | 1.590E-04 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| 8 | 2.10E+03 | 1.590E-04 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| 9 | 2.40E+03 | 1.590E-04 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| 10 | 2.70E+03 | 1.590E-04 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |

ERS-MPO-91-035

ATTACHMENT 2

Page 14 of 56

EUDOR DAT.3

15-OCT-1991 11:05

Page 3

TRAILS - Transport of Radioactive Material in Linear Systems. v1.1
 Case 2 P to S leak. NBI Cases. 1B% F/F, non-equil., CR Dose Rate w/o isos

| STEP | TIME | Not used For ZA | | RCS 1B% F/F .3 SECs | | AVERAGE | | CONTROL ROOM | | |
|--------------|---------|-----------------|-----------|---------------------|---------|-----------|---------|--------------|-----------|-----------|
| | | CURRENT | INTEGRD | CURRENT | INTEGRD | RELEASED | RELEASE | CURRENT | CURRENT | INTEGRD |
| KR-B3m | INITIAL | 0.000E+00 | 0.000E+00 | 2.160E+11 | | | | 0.000E+00 | 0.000E+00 | 7.769E+06 |
| KR-B3m | TOTALS | | | 5.075E+14 | | 1.679E+08 | | | | |
| KR-B5m | INITIAL | 0.000E+00 | 0.000E+00 | 5.400E+11 | | | | 0.000E+00 | 0.000E+00 | 2.167E+07 |
| KR-B5m | TOTALS | | | 1.376E+15 | | 4.553E+08 | | | | |
| KR-B5 | INITIAL | 0.000E+00 | 0.000E+00 | 3.730E+10 | | | | 0.000E+00 | 0.000E+00 | 1.617E+06 |
| KR-B5 | TOTALS | | | 1.007E+14 | | 3.331E+07 | | | | |
| KR-B7 | INITIAL | 0.000E+00 | 0.000E+00 | 1.060E+12 | | | | 0.000E+00 | 0.000E+00 | 3.518E+07 |
| KR-B7 | TOTALS | | | 2.348E+15 | | 7.770E+08 | | | | |
| KR-B7- | INITIAL | 0.000E+00 | 0.000E+00 | 1.490E+12 | | | | 0.000E+00 | 0.000E+00 | 5.723E+07 |
| KR-B9 | INITIAL | 0.000E+00 | 0.000E+00 | 1.980E+12 | | | | 0.000E+00 | 0.000E+00 | 1.814E+06 |
| KR-B9 | TOTALS | | | 5.415E+14 | | 1.792E+08 | | | | |
| XE-131M | INITIAL | 0.000E+00 | 0.000E+00 | 7.570E+09 | | | | 0.000E+00 | 0.000E+00 | 3.277E+05 |
| XE-131M | TOTALS | | | 2.041E+13 | | 6.754E+06 | | | | |
| XE-133M | INITIAL | 0.000E+00 | 0.000E+00 | 5.680E+10 | | | | 0.000E+00 | 0.000E+00 | 2.876E+06 |
| XE-133M | TOTALS | | | 1.794E+14 | | 5.936E+07 | | | | |
| XE-133 | INITIAL | 0.000E+00 | 0.000E+00 | 2.880E+12 | | | | 0.000E+00 | 0.000E+00 | 1.245E+08 |
| XE-133 | TOTALS | | | 7.756E+15 | | 2.567E+09 | | | | |
| XE-135M | INITIAL | 0.000E+00 | 0.000E+00 | 7.560E+11 | | | | 0.000E+00 | 0.000E+00 | 9.631E+06 |
| XE-135M | TOTALS | | | 8.730E+14 | | 2.889E+08 | | | | |
| XE-135 | INITIAL | 0.000E+00 | 0.000E+00 | 7.380E+11 | | | | 0.000E+00 | 0.000E+00 | 3.080E+07 |
| XE-135 | TOTALS | | | 1.936E+15 | | 6.406E+08 | | | | |
| XE-137 | INITIAL | 0.000E+00 | 0.000E+00 | 2.520E+12 | | | | 0.000E+00 | 0.000E+00 | 3.176E+06 |
| XE-137 | TOTALS | | | 8.352E+14 | | 2.764E+08 | | | | |
| XE-138 | INITIAL | 0.000E+00 | 0.000E+00 | 2.520E+12 | | | | 0.000E+00 | 0.000E+00 | 2.922E+07 |
| XE-138 | TOTALS | | | 2.742E+15 | | 9.075E+08 | | | | |
| ALL NUCLIDES | | 0.000E+00 | | 6.636E+12 | | | | 2.087E+05 | 4.261E-05 | |
| @ STEP 10 | | | | | | | | | | |

ERS-NPO-91-035

ATTACHMENT 2

Page 15 of 56

TRANSPORT OF RADIOACTIVE MATERIAL IN LINEAR SYSTEMS - VI
P-TO-S LEAK: NBT GASES 16% F₂ non-equil.: CR DOSE RATE w/o 15001

| PHOTON SOURCE | | Emissions | | THYROID-BETA-SUBBG | | THYROID-BETA | |
|----------------|----------------------|--------------|----------------------|--------------------|----------------------|--------------|----------------------|
| DOSE mrem | DOSE RATE mrem/hr | DOSE mrem | DOSE RATE mrem/hr | DOSE mrem | DOSE RATE mrem/hr | DOSE mrem | DOSE RATE mrem/hr |
| NR-1301 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 5.10E-05 | 1.39E-02 | 0.00E+00 | 0.00E+00 |
| KR-1301 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 8.77E-03 | 2.60E-01 | 0.00E+00 | 0.00E+00 |
| KR-1302 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 9.12E-06 | 1.90E-02 | 0.00E+00 | 0.00E+00 |
| TOTAL | 0.00E+00 | 0.00E+00 | 0.00E+00 | 7.16E-02 | 1.94E+00 | 0.00E+00 | 0.00E+00 |
| KR-1307 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.69E-05 | 2.19E-03 | 0.00E+00 | 0.00E+00 |
| TOTAL | 0.00E+00 | 0.00E+00 | 0.00E+00 | 2.69E-01 | 9.00E-04 | 0.00E+00 | 0.00E+00 |
| KR-1308 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.54E-03 | 1.16E-01 | 0.00E+00 |
| TOTAL | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.69E-05 | 2.19E-03 | 0.00E+00 |
| KR-1314 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 3.06E-04 | 2.57E-02 | 0.00E+00 |
| TOTAL | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.45E-02 | 7.92E-01 | 0.00E+00 |
| KR-1334 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.06E-02 | 4.33E-02 | 0.00E+00 |
| TOTAL | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.45E-02 | 7.92E-01 | 0.00E+00 |
| KR-1338 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.96E-02 | 4.63E-01 | 0.00E+00 |
| TOTAL | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.63E-03 | 2.82E-01 | 0.00E+00 |
| KR-1339 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| TOTAL | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| All. RAD/110ES | 0.01E-01 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 6.00E-04 | 7.19E-02 | 1.09E-02 |
| 0.00333 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.17E-02 | 2.74E-01 | 1.90E-01 |
| 0.1667 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 4.16E-02 | 5.63E-01 | 4.19E-01 |
| 0.2500 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 5.29E-01 | 6.92E+00 | 5.03E+00 |
| 0.3333 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 5.74E-02 | 6.17E-01 | 7.94E-01 |
| 0.4167 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 6.32E-02 | 7.72E-01 | 8.93E+00 |
| 0.5000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 6.50E-02 | 8.60E-01 | 7.83E-01 |
| 0.5833 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 7.50E-02 | 9.40E-01 | 8.61E-01 |
| 0.6667 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 8.14E-02 | 1.01E+00 | 9.33E-01 |
| 0.7500 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 8.72E-02 | 1.09E+00 | 9.66E+00 |
| TOTAL | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 5.07E-01 | 6.04E+00 | 5.07E+00 |

FROM DAY 5

15-OCT-1991 11:04

Page 1

TABLE --- Transport of Radioactive Material in Linear Systems. v1.1
Case 3 CONCURRENT SPIKE Iodines only CR Dose Rate w/o intal

COMP RCS

CDHP 3 SGs

COMP Control Room

Duquesne
Light
Health Physics DepartmentERS-MPO-91-035
ATTACHMENT 2

Page 17 of 56

| | VOL UNR | 1 7.30E+05 Cu F: | INTAKE | 1 000E+01 CFM |
|-------------------|-------------------|-------------------|-------------------------|-----------------------|
| INITIAL | 0 000E+00 KR-B3m | 0 000E+00 KR-B3m | 0 000E+00 KR-B3m | 0 000E+00 KR-B3m |
| | 0 000E+00 KR-B5m | 0 000E+00 KR-B5m | 0 000E+00 KR-B5m | 0 000E+00 KR-B5m |
| | 0 000E+00 KR-B5 | 0 000E+00 KR-B5 | 0 000E+00 KR-B5 | 0 000E+00 KR-B5 |
| | 0 000E+00 KR-B7 | 0 000E+00 KR-B7 | 0 000E+00 KR-B7 | 0 000E+00 KR-B7 |
| | 0 000E+00 KR-BB | 0 000E+00 KR-BB | 0 000E+00 KR-BB | 0 000E+00 KR-BB |
| | 0 000E+00 KR-B9 | 0 000E+00 KR-B9 | 0 000E+00 KR-B9 | 0 000E+00 KR-B9 |
| | 0 000E+00 KR-90 | 0 000E+00 KR-90 | 0 000E+00 KR-90 | 0 000E+00 KR-90 |
| | 0 000E+00 XE-131m | 0 000E+00 XE-131m | 0 000E+00 XE-131m | 0 000E+00 XE-131m |
| | 0 000E+00 XE-133m | 0 000E+00 XE-133m | 0 000E+00 XE-133m | 0 000E+00 XE-133m |
| | 0 000E+00 XE-133 | 0 000E+00 XE-133 | 0 000E+00 XE-133 | 0 000E+00 XE-133 |
| | 0 200E+00 XE-135m | 0 200E+00 XE-135m | 0 200E+00 XE-135m | 0 200E+00 XE-135m |
| | 0 000E+00 XE-135 | 0 000E+00 XE-135 | 0 000E+00 XE-135 | 0 000E+00 XE-135 |
| | 0 000E+00 XE-137 | 0 000E+00 XE-137 | 0 000E+00 XE-137 | 0 000E+00 XE-137 |
| | 0 000E+00 XE-138 | 0 000E+00 XE-138 | 0 000E+00 XE-138 | 0 000E+00 XE-138 |
| | 0 000E+00 I-131 | 0 000E+00 I-131 | 0 000E+00 I-131 | 0 000E+00 I-131 |
| | 0 000E+00 I-132 | 0 000E+00 I-132 | 0 000E+00 I-132 | 0 000E+00 I-132 |
| | 0 000E+00 I-133 | 0 000E+00 I-133 | 0 000E+00 I-133 | 0 000E+00 I-133 |
| | 0 000E+00 I-134 | 0 000E+00 I-134 | 0 000E+00 I-134 | 0 000E+00 I-134 |
| | 0 000E+00 I-135 | 0 000E+00 I-135 | 0 000E+00 I-135 | 0 000E+00 I-135 |
| ACT HULF (to UC2) | 1 000E+00 | 1 000E+00 | 1 000E+00 | 1 000E+00 |
| PRODUCTION UC2's | 0 000E+00 KR-B3m | 0 000E+00 KR-B3m | 0 000E+00 KR-B3m | 0 000E+00 KR-B3m |
| | 0 000E+00 KR-B5m | 0 000E+00 KR-B5m | 0 000E+00 KR-B5m | 0 000E+00 KR-B5m |
| | 0 000E+00 KR-B5 | 0 000E+00 KR-B5 | 0 000E+00 KR-B5 | 0 000E+00 KR-B5 |
| | 0 000E+00 KR-B7 | 0 000E+00 KR-B7 | 0 000E+00 KR-B7 | 0 000E+00 KR-B7 |
| | 0 000E+00 KR-BB | 0 000E+00 KR-BB | 0 000E+00 KR-BB | 0 000E+00 KR-BB |
| | 0 000E+00 KR-B9 | 0 000E+00 KR-B9 | 0 000E+00 KR-B9 | 0 000E+00 KR-B9 |
| | 0 000E+00 KR-90 | 0 000E+00 KR-90 | 0 000E+00 KR-90 | 0 000E+00 KR-90 |
| | 0 000E+00 XE-131m | 0 000E+00 XE-131m | 0 000E+00 XE-131m | 0 000E+00 XE-131m |
| | 0 000E+00 XE-133m | 0 000E+00 XE-133m | 0 000E+00 XE-133m | 0 000E+00 XE-133m |
| | 0 000E+00 XE-133 | 0 000E+00 XE-133 | 0 000E+00 XE-133 | 0 000E+00 XE-133 |
| | 0 200E+00 XE-135m | 0 200E+00 XE-135m | 0 200E+00 XE-135m | 0 200E+00 XE-135m |
| | 0 000E+00 XE-135 | 0 000E+00 XE-135 | 0 000E+00 XE-135 | 0 000E+00 XE-135 |
| | 0 000E+00 XE-137 | 0 000E+00 XE-137 | 0 000E+00 XE-137 | 0 000E+00 XE-137 |
| | 0 000E+00 XE-138 | 0 000E+00 XE-138 | 0 000E+00 XE-138 | 0 000E+00 XE-138 |
| | 1 360E+06 I-131 | 1 360E+06 I-131 | 0 000E+00 I-131 | 0 000E+00 I-131 |
| | 2 520E+06 I-132 | 2 520E+06 I-132 | 0 000E+00 I-132 | 0 000E+00 I-132 |
| | 3 680E+06 I-133 | 3 680E+06 I-133 | 0 000E+00 I-133 | 0 000E+00 I-133 |
| | 2 610E+06 I-135 | 2 610E+06 I-135 | 0 000E+00 I-135 | 0 000E+00 I-135 |
| RETRIVAL | 3 309E-07 175PC | 2 069E-06 1/sec | 1 000E+01 CFM | 1 000E+01 CFM |
| NUC 1-14 REL FR | 0 000E+00 | 0 000E+00 | INTAKE REDUCT 0 000E+00 | INTAKE FILT 0 000E+00 |
| NUC 18-20 REL FR | 0 000E+00 | 0 000E+00 | INTAKE FILT 0 000E+00 | INTAKE FILT 0 000E+00 |

TRAILS - Transport of Radioactive Material in Linear Systems, v1
Case 3: TRANSPORT SPOT, DODGES only, Dose Rate w/o isol.

ROUTINE PERSONNEL

| STEP | TIME | XPR | XREM | XPR | XREM | XPR | XREM | XPR | XREM | XPR | XREM |
|------|-----------|------|----------|----------|----------|------|----------|------|----------|------|----------|
| 1 | 6.000E+01 | 1.00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |
| 2 | 7.000E+02 | 1.00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |
| 3 | 8.000E+02 | 1.00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |
| 4 | 9.000E+02 | 1.00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |
| 5 | 1.200E+03 | 1.00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |
| 6 | 1.500E+03 | 1.00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |
| 7 | 1.800E+03 | 1.00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |
| 8 | 2.100E+03 | 1.00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |
| 9 | 2.400E+03 | 1.00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |
| 10 | 2.700E+03 | 1.00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |

ROUTINE PERSONNEL

| STEP | TIME | XPR | XREM | XPR | XREM | XPR | XREM | XPR | XREM | XPR | XREM |
|------|-----------|------|----------|----------|----------|------|----------|------|----------|------|----------|
| 1 | 6.000E+01 | 1.00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |
| 2 | 7.000E+02 | 1.00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |
| 3 | 8.000E+02 | 1.00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |
| 4 | 9.000E+02 | 1.00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |
| 5 | 1.200E+03 | 1.00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |
| 6 | 1.500E+03 | 1.00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |
| 7 | 1.800E+03 | 1.00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |
| 8 | 2.100E+03 | 1.00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |
| 9 | 2.400E+03 | 1.00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |
| 10 | 2.700E+03 | 1.00 | 1.00 | 0.00E+00 | 0.00E+00 | 1.00 | 0.00E+00 | 50.0 | 0.00E+00 | 50.0 | 0.00E+00 |

| ROUTINE PERSONNEL | | | ENVIRONMENT | | | |
|-------------------|----------|-----------|-------------|-----------|----------|------|
| | X/R | Breathing | X/R | Breathing | X/R | |
| 1 | 0.00E+00 | M3/S | 0.00E+00 | M3/S | 1.00E+00 | M3/S |

Duquesne
Light
Health Physics Department

ERS-MPO-91-035

ATTACHMENT 2

Page 18 of 56

TRANSPORT OF CERAMICURE PLATEAU ON LINAC SYSTEMS - v1.1
Case 3: CERAMICURE SPIKE. Dose rate only - OR Dose Rate w/o isol

| | | SGS | | AVERAGE | | COMBINED, REURN | |
|---------------|---------|-----------|-----------|-----------|-----------|-----------------|-----------|
| STEP | TIME | CURRENT | INTEGRAL | CURRENT | INTEGRAL | CURRENT | INTEGRAL |
| | | uC.I. | uC.I.-SEC | uC.I. | uC.I.-SEC | uC.I. | uC.I.-SEC |
| 1-131 | INITIAL | 0.000E+00 | 4.951E+12 | 0.000E+00 | 1.461E+09 | 3.022E+03 | 7.520E+01 |
| 1-131 | TOTALS | | | | | | |
| 1-132 | INITIAL | 0.000E+00 | 8.508E+12 | 0.000E+00 | 2.443E+09 | 5.054E+03 | 0.000E+00 |
| 1-132 | TOTALS | | | | | | |
| 1-133 | INITIAL | 0.000E+00 | 1.113E+13 | 0.000E+00 | 3.299E+09 | 6.826E+03 | 0.000E+00 |
| 1-133 | TOTALS | | | | | | |
| 1-134 | INITIAL | 0.000E+00 | 1.113E+13 | 0.00 | 2.991E+09 | 6.189E+03 | 0.000E+00 |
| 1-134 | TOTALS | | | | | | |
| 1-135 | INITIAL | 0.000E+00 | 9.976E+12 | 0.000E+00 | 2.931E+09 | 6.034E+03 | 0.000E+00 |
| 1-135 | TOTALS | | | | | | |
| All. NeUTIDES | | 3.275E+10 | | 1.412E+07 | | 9.384E-01 | 1.916E-10 |
| # STEP | 10 | | | | | | |

ERS-MPO-91-035

ATTACHMENT 2

Page 19 of 56

EMISSION DAY 5

15-OCT-1991 11:04

page 4

TRAILS - Transport of Radioactive Material in Linear Systems, v1.1
 NAME - CONNECTIVE TISSUE - Dose rates on 1 - CR Dose Rate w/o tool

| | PHOTON-SUBSTRATE DOSE RATE mrem/min | BETA-SUBSTRATE DOSE RATE mrem/min | THYROID-HAEMAL DOSE RATE mrem/min | PHOTON-SUBSTRATE DOSE RATE mrem/min | BETA-SUBSTRATE DOSE RATE mrem/min | THYROID-HAEMAL DOSE RATE mrem/min |
|--------------|---|---|---|---|---|---|
| I-131 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| I-132 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| I-133 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| I-134 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| I-135 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| All TRAILERS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| 0.167 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| 0.333 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| 0.667 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| 1.333 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| 2.500 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| 5.000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| 0.5033 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| 0.6667 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| 0.7500 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |

| |
|--|
| Duquesne Light Health Physics Department ERS-MPO-91-035 ATTACHMENT A |
| Page 20 of 56 |

TABLE 4 - Calculations of Radiation Dose Rate for Various Protection Measures at Inducor's Dose Rate w/o Shield

C-100 - not used for 4

| Material | C-100 | C-100, Stream 9+1 | C-100, Stream 9+1, Room Vol. 1000 | C-100, C-100, Room Vol. 1000 |
|---------------------|---------------------|---------------------|-----------------------------------|------------------------------|
| 0.000E+00 KR-B3m | 5.770E-05 KR-B3m | 0.000E+00 KR-B3m | 0.000E+00 KR-B3m | 0.000E+00 KR-B3m |
| 0.000E+00 KR-B5m | 2.810E-04 KR-B5m | 0.000E+00 KR-B5m | 0.000E+00 KR-B5m | 0.000E+00 KR-B5m |
| 0.000E+00 KR-B5 | 1.490E-03 KR-B5 | 0.000E+00 KR-B5 | 0.000E+00 KR-B5 | 0.000E+00 KR-B5 |
| 0.000E+00 KR-B7 | 3.610E-04 KR-B7 | 0.000E+00 KR-B7 | 0.000E+00 KR-B7 | 0.000E+00 KR-B7 |
| 0.000E+00 KR-B9B | 4.290E-04 KR-B9B | 0.000E+00 KR-B9B | 0.000E+00 KR-B9B | 0.000E+00 KR-B9B |
| 0.000E+00 KR-B9 | 1.750E-05 KR-B9 | 0.000E+00 KR-B9 | 0.000E+00 KR-B9 | 0.000E+00 KR-B9 |
| 0.000E+00 KR-B90 | 0.000E+00 KR-B90 | 0.000E+00 KR-B90 | 0.000E+00 KR-B90 | 0.000E+00 KR-B90 |
| 0.000E+00 KR-E-131m | 1.460E-05 KR-E-131m | 0.000E+00 KR-E-131m | 0.000E+00 KR-E-131m | 0.000E+00 KR-E-131m |
| 0.000E+00 KR-E-133m | 4.120E-04 KR-E-133m | 0.000E+00 KR-E-133m | 0.000E+00 KR-E-133m | 0.000E+00 KR-E-133m |
| 0.000E+00 KR-E-135m | 3.520E-03 KR-E-133 | 0.000E+00 KR-E-133 | 0.000E+00 KR-E-133 | 0.000E+00 KR-E-133 |
| 0.000E+00 KR-E-135 | 4.650E-04 KR-E-135m | 0.000E+00 KR-E-135m | 0.000E+00 KR-E-135m | 0.000E+00 KR-E-135m |
| 0.000E+00 KR-E-137 | 4.310E-04 KR-E-135 | 0.000E+00 KR-E-135 | 0.000E+00 KR-E-135 | 0.000E+00 KR-E-135 |
| 0.000E+00 KR-E-138 | 2.190E-05 KR-E-137 | 0.000E+00 KR-E-137 | 0.000E+00 KR-E-137 | 0.000E+00 KR-E-137 |
| 0.000E+00 I-131 | 9.260E-05 KR-E-138 | 0.000E+00 KR-E-138 | 0.000E+00 KR-E-138 | 0.000E+00 KR-E-138 |
| 0.000E+00 I-132 | 8.130E-03 I-131 | 0.000E+00 I-131 | 0.000E+00 I-131 | 0.000E+00 I-131 |
| 0.000E+00 I-133 | 2.400E-03 I-132 | 0.000E+00 I-132 | 0.000E+00 I-132 | 0.000E+00 I-132 |
| 0.000E+00 I-134 | 1.160E-03 I-133 | 0.000E+00 I-133 | 0.000E+00 I-133 | 0.000E+00 I-133 |
| 0.000E+00 I-135 | 5.260E-04 I-134 | 0.000E+00 I-134 | 0.000E+00 I-134 | 0.000E+00 I-134 |
| I-136 | 5.210E-03 I-135 | 0.000E+00 I-135 | 0.000E+00 I-135 | 0.000E+00 I-135 |
| | 1.050E+05 | 0.000E+05 | 0.000E+05 | 0.000E+05 |

ACCT (W.L.T. / 1000000000000000)

PROT1000000000000000

| | | | | |
|---------------------|---------------------|---------------------|---------------------|---------------------|
| 0.000E+00 KR-B3m |
| 0.000E+00 KR-B5m |
| 0.000E+00 KR-B5 |
| 0.000E+00 KR-B7 |
| 0.000E+00 KR-B9B |
| 0.000E+00 KR-B9 |
| 0.000E+00 KR-90 |
| 0.000E+00 KR-E-131m |
| 0.000E+00 KR-E-133m |
| 0.000E+00 KR-E-135m |
| 0.000E+00 KR-E-137 |
| 0.000E+00 KR-E-138 |
| 0.000E+00 I-131 |
| 0.000E+00 I-132 |
| 0.000E+00 I-133 |
| 0.000E+00 I-134 |
| 0.000E+00 I-135 |
| | 1.285E-01 I-136 | 0.000E+00 I-136 | 0.000E+00 I-136 | 0.000E+00 I-136 |

REMOVIAL
REL. F.R.
REL. F.R.

0.000E+00 I-136
0.000E+00 I-136
0.000E+00 I-136

ERS-MPD-91-035
ATTACHMENT 2
Page 21 of 56

TRANSPORT OF RADON-40 IN PLATEAU LINEAR SYSTEMS. VI
TYPE 4. INERT STEAM RELEASE: NO. 1, GASES & ISOTINES. CR Dose Rate w/o 1901

ENDJOB DAT. 6

15 Oct 1991 11:04

Page 3

TRAIL: Case 4 Initial Steam Release, Noble Gases & Iodines OR Dose Rate w/o isol

| STEP | TIME | TRANSPORT OF Radioactive Material in Linear Systems v1.1 | | | AVERAGE RELEASE | CONTINUOUS RELEASE |
|----------|---------|--|--------------------------|--|-----------------|--------------------|
| | | NOT USED | OR 4 CURRENT uCi/s | 3 564- INITIAL STEAM CURRENT uCi/s | | |
| uR-0.2m | INITIAL | 0.000E+00 | 5.770E+01 | 4.487E+02 | 5.762E+01 | 0.000E+00 |
| uR-0.3m | TOTALS | 0.000E+00 | | | | 4.737E+00 |
| uR-0.5m | INITIAL | 0.000E+00 | 2.810E+02 | 2.186E+03 | 2.809E+02 | 0.000E+00 |
| uR-0.5m | TOTALS | 0.000E+00 | | | | 2.498E+01 |
| uR-0.75 | INITIAL | 0.000E+00 | 1.480E+03 | 1.152E+04 | 1.480E+02 | 0.000E+00 |
| uR-0.75 | TOTALS | 0.000E+00 | | | | 1.391E+02 |
| uR-0.77 | INITIAL | 0.000E+00 | 1.610E+02 | 1.251E+03 | 1.608E+02 | 0.000E+00 |
| uR-0.77 | TOTALS | 0.000E+00 | | | | 1.249E+01 |
| uR-0.92 | INITIAL | 0.000E+00 | 4.290E+02 | 3.337E+03 | 4.288E+02 | 0.000E+00 |
| uR-0.92 | TOTALS | 0.000E+00 | | | | 3.694E+01 |
| uR-0.99 | INITIAL | 0.000E+00 | 1.350E+01 | 1.022E+02 | 1.313E+01 | 0.000E+00 |
| uR-0.99 | TOTALS | 0.000E+00 | | | | 1.330E+01 |
| uE-1.34H | INITIAL | 0.000E+00 | 1.440E+01 | 1.121E+02 | 1.440E+01 | 0.000E+00 |
| uE-1.34H | TOTALS | 0.000E+00 | | | | 1.355E+00 |
| uE-1.33H | INITIAL | 0.000E+00 | 4.130E+02 | 3.214E+03 | 4.130E+02 | 0.000E+00 |
| uE-1.33H | TOTALS | 0.000E+00 | | | | 3.664E+01 |
| uE-1.325 | INITIAL | 0.000E+00 | 3.520E+03 | 2.739E+04 | 3.520E+03 | 0.000E+00 |
| uE-1.325 | TOTALS | 0.000E+00 | | | | 3.302E+02 |
| uE-1.35H | INITIAL | 0.000E+00 | 1.460E+02 | 1.130E+03 | 1.452E+02 | 0.000E+00 |
| uE-1.35H | TOTALS | 0.000E+00 | | | | 6.000E+00 |
| uE-1.35 | INITIAL | 0.000E+00 | 4.310E+02 | 3.354E+03 | 4.309E+02 | 0.000E+00 |
| uE-1.35 | TOTALS | 0.000E+00 | | | | 3.941E+01 |
| uE-1.37 | INITIAL | 0.000E+00 | 2.190E+01 | 1.665E+02 | 2.140E+01 | 0.000E+00 |
| uE-1.37 | TOTALS | 0.000E+00 | | | | 2.134E+01 |
| uE-1.38 | INITIAL | 0.000E+00 | 9.030E+01 | 6.993E+02 | 8.973E+01 | 0.000E+00 |
| uE-1.38 | TOTALS | 0.000E+00 | | | | 3.503E+00 |
| uE-1.39 | INITIAL | 0.000E+00 | 8.130E+03 | 6.327E+04 | 8.120E+03 | 0.000E+00 |
| uE-1.39 | TOTALS | 0.000E+00 | | | | 7.632E+02 |
| 1-1.32 | INITIAL | 0.000E+00 | 2.400E+03 | 1.966E+04 | 2.399E+03 | 0.000E+00 |
| 1-1.32 | TOTALS | 0.000E+00 | | | | 2.027E+02 |
| 1-1.33 | INITIAL | 0.000E+00 | 1.160E+03 | 9.027E+03 | 1.160E+03 | 0.000E+00 |
| 1-1.33 | TOTALS | 0.000E+00 | | | | 1.077E+02 |
| 1-1.34 | INITIAL | 0.000E+00 | 5.360E+02 | 4.164E+03 | 5.351E+02 | 0.000E+00 |
| 1-1.34 | TOTALS | 0.000E+00 | | | | 3.836E+01 |
| 1-1.35 | INITIAL | 0.000E+00 | 5.210E+03 | 4.054E+04 | 5.209E+03 | 0.000E+00 |
| 1-1.35 | TOTALS | 0.000E+00 | | | | 4.717E+01 |

Duquesne
Light
Health Physics Department

ERS-MPO-91-035
ATTACHMENT 2


Page 23 of 56

18 OCT 1991 11:04

page 4

1991, Transportation & Radiotracer Material in Urethane Systems, v. 1
Initial Steam Release Mobile Games, S. Industries, CR Dose Rate w/o skin

| NOT USED FOR | 4 | 3 SEC. | INITIAL STEAM | AVERAGE | CURRENT | CURRENT | CURRENT | INTEGRAL |
|--------------|------------|----------|---------------|----------|----------|----------|----------|----------|
| CURRENT | INTEGRAL | RELEASE | RELEASE | RELEASE | RELEASE | RELEASE | RELEASE | RELEASE |
| uCi | uCi | uCi/sec | uCi/sec | uCi/sec | uCi/sec | uCi/sec | uCi/sec | uCi/sec |
| STEP | TIME | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| All | Final Dose | | | | | | | |
| 8 | STEP | 1.0 | | | | | | |



ERS-MPO-91-035
ATTACHMENT 2

Page 24 of 56

TRANSPORT OF Radioactive Material in Transfer Systems - v1
Section 4. Initial Steam Release Nuclei Gases & Fission CR Dose Rate w/o 1501

| | | E N V I R O N M E N T | | T H Y R O I D - I N H A L | | C O N T R O L | |
|---------|----------|-------------------------------|-----------------------------|-------------------------------------|-----------------------------------|-------------------------------|-----------------------------------|
| | | PHOTON SOURCE DOSE mR/m | BETA SOURCE DOSE mR/m | PHOTON SOURCE DOSE RATE mR/hr | BETA SOURCE DOSE RATE mR/hr | PHOTON SOURCE DOSE mR/m | BETA SOURCE DOSE RATE mR/hr |
| HE-3.06 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 3.16E-11 | 8.50E-109 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.01E-08 | 2.99E-07 |
| HE-3.17 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 7.05E-10 | 1.64E-06 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 2.54E-09 | 7.76E-07 |
| HE-3.24 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.02E-07 | 3.32E-07 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 6.28E-10 | 0.00E+00 |
| HE-3.24 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 6.97E-11 | 9.03E-09 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 4.11E-09 | 3.49E-07 |
| HE-3.24 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 3.64E-09 | 2.30E-06 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 2.70E-08 | 0.00E+00 |
| HE-3.24 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 5.08E-07 | 0.00E+00 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.26E-10 | 2.19E-08 |
| HE-3.24 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.01E-08 | 1.04E-07 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 7.46E-07 | 0.00E+00 |
| I-1.31 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 6.80E-06 | 6.00E-06 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 2.59E-05 | 2.09E-05 |
| I-1.31 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.01E-05 | 1.01E-05 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 2.59E-05 | 2.09E-05 |
| I-1.31 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.01E-05 | 1.01E-05 |

ERS-MPO-91-035
ATTACHMENT 2

Page 25 of 56



Research Physics Department

Table: Transport of Radioactive Material in Lumen System, v1.1
 Case: Initial Stem Reversable Gases & Iodine, (p) Dose Rate w/o Iso

| POSITION SUBNO | | BETA-SUBNO | | THYROID-THAL | | PHOTON-SUBNO | | BETA-SUBNO | | THYROID-THAL | |
|----------------|----------------------|--------------|----------------------|--------------|----------------------|--------------|----------------------|--------------|----------------------|--------------|----------------------|
| DOSE mrem | DOSE RATE mrem/hr | DOSE mrem | DOSE RATE mrem/hr | DOSE mrem | DOSE RATE mrem/hr | DOSE mrem | DOSE RATE mrem/hr | DOSE mrem | DOSE RATE mrem/hr | DOSE mrem | DOSE RATE mrem/hr |
| 1-1 P | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| All Sublines | | | | | | | | | | | |
| 0.0167 h | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| 0.0433 h | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| 0.1667 h | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| 0.2500 h | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| 0.3333 h | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| 0.4167 h | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| 0.5000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| 0.5833 h | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| 0.6667 h | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| 0.7500 h | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 |

Duquesne
Light
Health Physics Department
ERS-MPO-91-035
ATTACHMENT 2

Page 26 of 56

TRANSPORT OF RADIONUCLIDES IN LIQUID SYSTEMS
INITIAL SIZE, LIQUID AND LIQUID/CR Dose Rate w/o and

TABLE 5 - Transport of Radioactive Material in Linear Systems - v1.1
Case 4. Initial Set Liquid Toxins CR Dose Rate w/o x501

| MULTIPLIERS | | X/R | | X/R | | X/R | | X/R | | X/R | |
|-------------|-----------|-----------|------|-----------|------|-----------|------|-----------|------|------|------|
| STEP | TIME | X/R | X/R | X/R | X/R | X/R | X/R | X/R | X/R | X/R | X/R |
| 1 | 6.000E+01 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | C.000E+00 | 1.00 | G.000E+00 | 1.00 | 20.0 | 20.0 |
| 2 | 7.000E+01 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 50.0 | 50.0 |
| 3 | 6.000E+02 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 50.0 | 50.0 |
| 4 | 9.000E+02 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 50.0 | 50.0 |
| 5 | 1.200E+03 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 50.0 | 50.0 |
| 6 | 1.500E+03 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 50.0 | 50.0 |
| 7 | 1.800E+03 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 50.0 | 50.0 |
| 8 | 2.100E+03 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 50.0 | 50.0 |
| 9 | 2.400E+03 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 50.0 | 50.0 |
| 10 | 2.700E+03 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 50.0 | 50.0 |

----- ENVIRONMENT -----

| CONTROLL ROOM | |
|---------------|-----------|
| X/G | Breathing |
| S/M3 | M3/s |
| 1.000E+00 | 3.470E-04 |
| 1.000E+00 | 3.470E-04 |

| MULTIPLIERS | | X/R | | X/R | | X/R | | X/R | | X/R | |
|-------------|-----------|-----------|------|------|------|-----------|------|-----------|------|------|------|
| STEP | TIME | X/R | X/R | X/R | X/R | X/R | X/R | X/R | X/R | X/R | X/R |
| 1 | 6.000E+01 | 1.590E-04 | 1.00 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 1.00 | 1.00 |
| 2 | 7.000E+01 | 1.590E-04 | 1.00 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 1.00 | 1.00 |
| 3 | 6.000E+02 | 1.590E-04 | 1.00 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 1.00 | 1.00 |
| 4 | 9.000E+02 | 1.590E-04 | 1.00 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 1.00 | 1.00 |
| 5 | 1.200E+03 | 1.590E-04 | 1.00 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 1.00 | 1.00 |
| 6 | 1.500E+03 | 1.590E-04 | 1.00 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 1.00 | 1.00 |
| 7 | 1.800E+03 | 1.590E-04 | 1.00 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 1.00 | 1.00 |
| 8 | 2.100E+03 | 1.590E-04 | 1.00 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 1.00 | 1.00 |
| 9 | 2.400E+03 | 1.590E-04 | 1.00 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 1.00 | 1.00 |
| 10 | 2.700E+03 | 1.590E-04 | 1.00 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 1.00 | 1.00 |

Duquesne
Light
Health Physics Department

ERS-MPO-91-035
ATTACHMENT 2

Page 28 of 56


Transport of radioactive material in linear systems via liquid droplets. CR Dose Rate analysis

| Not used for S | | SGs- INITIAL | INITIAL SPEC. | AVERAGE RELEASED | CURRENT RELEASED | CURRENT SPEC | INITIAL SPEC |
|----------------|--------------------|-----------------|----------------|---------------------|---------------------|-----------------|---------------------|
| TIME | CURRENT INTENGD | CURRENT uC1 | INTENGD uC1 | uC1 | uC1 | uC1 | uC1 |
| 1 - 1.31 | INITIAL | 0 000E+00 | 0 300E+03 | 9 2B9E+06 | 2 495E+10 | 5 163E+04 | 2 500E+03 |
| 1 - 1.31 | TOTALS | | | | | | |
| 1 - 1.32 | INITIAL | 0 000E+00 | 0 000E+00 | 2 740E+06 | 6 604E+09 | 1 366E+04 | 0 000E+00 |
| 1 - 1.32 | TOTALS | | | | | | |
| 1 - 1.33 | INITIAL | 0 000E+00 | 0 000E+00 | 1 330E+07 | 3 537E+10 | 7 317E+04 | 0 000E+00 |
| 1 - 1.33 | TOTALS | | | | | | |
| 1 - 1.34 | INITIAL | 0 000E+00 | 0 000E+00 | 6 120E+04 | 1 243E+08 | 2 573E+02 | 0 000E+00 |
| 1 - 1.34 | TOTALS | | | | | | |
| 1 - 1.35 | INITIAL | 0 000E+00 | 0 000E+00 | 5 950E+06 | 1 541E+10 | 3 188E+04 | 0 000E+00 |
| 1 - 1.35 | TOTALS | | | | | | |
| 1 - 1.36 | INITIAL | 0 000E+00 | 0 000E+00 | 2 978E+07 | | | 5 889E+00 1 109E+03 |
| 1 - 1.36 | TOTALS | | | | | | |

ERS-MPO-91-035
ATTACHMENT 2

Page 29 of 56

TRANSPORT OF MATERIAL IN LUMBAR SYSTEM. VI




TRAITS --- Transport of Radioactive Material in Linear Systems: v1.1
1 18% F F p-S Isotopes

| | CMP | RCS | CMP | 3 SD% | VOLUME | COMP | Control Room |
|-------------------|-----------|---------|-----|-----------|---------|---------------|--------------|
| INITIAL | 0.000E+00 | KR-B3m | C.1 | 0.000E+00 | KR-B3m | 0.000E+00 | KR-B3m |
| | 0.000E+00 | KR-B5m | | 0.000E+00 | KR-B5m | 0.000E+00 | KR-B5m |
| | 0.000E+00 | KR-B5 | | 0.000E+00 | KR-B5 | 0.000E+00 | KR-B5 |
| | 0.000E+00 | KR-B7 | | 0.000E+00 | KR-B7 | 0.000E+00 | KR-B7 |
| | 0.000E+00 | KR-BB | | 0.000E+00 | KR-BB | 0.000E+00 | KR-BB |
| | 0.000E+00 | KR-B9 | | 0.000E+00 | KR-B9 | 0.000E+00 | KR-B9 |
| | 0.000E+00 | KR-90 | | 0.000E+00 | KR-90 | 0.000E+00 | KR-90 |
| | 0.000E+00 | XE-131m | | 0.000E+00 | XE-131m | 0.000E+00 | XE-131m |
| | 0.000E+00 | XE-133m | | 0.000E+00 | XE-133m | 0.000E+00 | XE-133m |
| | 0.000E+00 | XE-133 | | 0.000E+00 | XE-133 | 0.000E+00 | XE-133 |
| | 0.000E+00 | XE-133m | | 0.000E+00 | XE-135m | 0.000E+00 | XE-135m |
| | 0.000E+00 | XE-135 | | 0.000E+00 | XE-135 | 0.000E+00 | XE-135 |
| | 0.000E+00 | XE-137 | | 0.000E+00 | XE-137 | 0.000E+00 | XE-137 |
| | 0.000E+00 | XE-138 | | 0.000E+00 | XE-138 | 0.000E+00 | XE-138 |
| | 1.490E+06 | I-131 | | 0.000E+00 | I-131 | 0.000E+00 | I-131 |
| | 1.780E+06 | I-132 | | 0.000E+00 | I-132 | 0.000E+00 | I-132 |
| | 2.880E+06 | I-133 | | 0.000E+00 | I-133 | 0.000E+00 | I-133 |
| | 3.240E+06 | I-134 | | 0.000E+00 | I-134 | 0.000E+00 | I-134 |
| | 2.520E+06 | I-135 | | 0.000E+00 | I-135 | 0.000E+00 | I-135 |
| ACT MULT (to uC1) | 1.000E+06 | | | 1.000E+00 | | 1.000E+00 | |
| PRODUCTION, uC1/s | | | | | | | |
| | 0.000E+00 | KR-B3m | | 0.000E+00 | KR-B3m | 0.000E+00 | KR-B3m |
| | 0.000E+00 | KR-B5m | | 0.000E+00 | KR-B5m | 0.000E+00 | KR-B5m |
| | 0.000E+00 | KR-B5 | | 0.000E+00 | KR-B5 | 0.000E+00 | KR-B5 |
| | 0.000E+00 | KR-B7 | | 0.000E+00 | KR-B7 | 0.000E+00 | KR-B7 |
| | 0.000E+00 | KR-BB | | 0.000E+00 | KR-BB | 0.000E+00 | KR-BB |
| | 0.000E+00 | KR-B9 | | 0.000E+00 | KR-B9 | 0.000E+00 | KR-B9 |
| | 0.000E+00 | KR-90 | | 0.000E+00 | KR-90 | 0.000E+00 | KR-90 |
| | 0.000E+00 | XE-131m | | 0.000E+00 | XE-131m | 0.000E+00 | XE-131m |
| | 0.000E+00 | XE-133m | | 0.000E+00 | XE-133m | 0.000E+00 | XE-133m |
| | 0.000E+00 | XE-133 | | 0.000E+00 | XE-133 | 0.000E+00 | XE-133 |
| | 0.000E+00 | XE-135m | | 0.000E+00 | XE-135m | 0.000E+00 | XE-135m |
| | 0.000E+00 | XE-135 | | 0.000E+00 | XE-135 | 0.000E+00 | XE-135 |
| | 0.000E+00 | XE-137 | | 0.000E+00 | XE-137 | 0.000E+00 | XE-137 |
| | 0.000E+00 | XE-138 | | 0.000E+00 | XE-138 | 0.000E+00 | XE-138 |
| | 0.000E+00 | I-131 | | 0.000E+00 | I-131 | 0.000E+00 | I-131 |
| | 0.000E+00 | I-132 | | 0.000E+00 | I-132 | 0.000E+00 | I-132 |
| | 0.000E+00 | I-133 | | 0.000E+00 | I-133 | 0.000E+00 | I-133 |
| | 0.000E+00 | I-134 | | 0.000E+00 | I-134 | 0.000E+00 | I-134 |
| | 0.000E+00 | I-135 | | 0.000E+00 | I-135 | 0.000E+00 | I-135 |
| ACT MULT (to uC1) | 3.000E-07 | 1./sec | | 2.049E-06 | 1./sec | 1.000E+01 | CFM |
| REMOVAL | | | | | | | |
| Nu/C 1-14 REL FR | | | | 1.000E+00 | | INTAKE REDUCT | 0.000E+00 |
| Nu/C 15-20 REL FR | | | | 1.000E+00 | | INTAKE FILTER | 9.360E-01 |

Page 31 of 56

ERS-APO-9L-035

ATTACHMENT 3



Health Physics Department

MULTIPLERS>

| STEP | TIME | XPR | XREM | XRF | XPR | XREM | XRF | XPR | XREM | XRF |
|------|-----------|-----------|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 1 | 1.800E+03 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 50.0 | 50.0 | 0.000E+00 |
| 2 | 5.400E+03 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 70.0 | 70.0 | 0.000E+00 |
| 3 | 7.200E+03 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 70.0 | 70.0 | 1.00 |
| 4 | 9.000E+03 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 70.0 | 70.0 | 1.00 |
| 5 | 1.440E+04 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 70.0 | 70.0 | 1.00 |
| 6 | 2.880E+04 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 70.0 | 70.0 | 1.00 |
| 7 | 3.040E+04 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.980E+03 | 1.980E+03 | 0.000E+00 |
| 8 | 6.640E+04 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 50.0 | 50.0 | 0.000E+00 |
| 9 | 3.456E+05 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 50.0 | 50.0 | 0.000E+00 |
| 10 | 2.592E+06 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 50.0 | 50.0 | 0.000E+00 |

MULTIPLERS>

| STEP | TIME | X/10 | Breathing Occupancy | CONTROL ROOM | X/10 | Breathing | ENVIRONMENT |
|------|-----------|-----------|---------------------|--------------|-----------|-----------|-------------|
| 1 | 1.800E+03 | 8/M3 | M3/s | 1.000E+00 | 8/M3 | M3/s | 1.000E+00 |
| | | 1.000E+00 | 3.470E-04 | 1.000E+00 | 1.000E+00 | 3.470E-04 | 1.000E+00 |

MULTIPLERS>

| STEP | TIME | X/10 | Breathing Occupancy | CONTROL ROOM | X/10 | Breathing | ENVIRONMENT |
|------|-----------|-----------|---------------------|--------------|-----------|-----------|-------------|
| 1 | 1.800E+03 | 1.590E-04 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 1.00 |
| 2 | 5.400E+03 | 1.590E-04 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 1.00 |
| 3 | 7.200E+03 | 1.590E-04 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 1.00 |
| 4 | 9.000E+03 | 1.590E-04 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 1.00 |
| 5 | 1.440E+04 | 1.590E-04 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 1.00 |
| 6 | 2.880E+04 | 1.590E-04 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 1.00 |
| 7 | 3.040E+04 | 7.860E-05 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 1.00 |
| 8 | 6.640E+04 | 7.860E-05 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 1.00 |
| 9 | 3.456E+05 | 5.960E-05 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 1.00 |
| 10 | 2.592E+06 | 3.760E-05 | 1.00 | 1.00 | 0.000E+00 | 1.00 | 1.00 |




ERS-APO-9L 035

ATTACHMENT 3

Page 32 of 56

TRAILS --- Transport of Radioactive Material in Linear Systems: v1.1
 1 18L FF P-S Iodines

| | RCS | 3 SGs | AVERAGE | CURRENT | RELEASED | RELEASE | CURRENT | CURRENT | CURRENT | CURRENT | INITIAL |
|--------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| STEP | TIME | CURRENT | INTEGRD | uCi | uCi | uCi/sec | uCi/sec | uCi/sec | uCi/sec | uCi/sec | uCi/sec |
| I-131 | INITIAL | 1. 490E+12 | 1. 0B6E+18 | 0. 000E+00 | 2. 950E+17 | 2. 540E+08 | 0. 000E+00 | 0. 000E+00 | 0. 000E+00 | 0. 000E+00 | 6. 708E+06 |
| I-131 | TOTALS | | | | | | | | | | |
| I-132 | INITIAL | 1. 780E+12 | 2. 118E+16 | 0. 000E+00 | 8. 277E+13 | 7. 938E+07 | 0. 000E+00 | 0. 000E+00 | 0. 000E+00 | 0. 000E+00 | 3. 643E+06 |
| I-132 | TOTALS | | | | | | | | | | |
| I-133 | INITIAL | 2. 880E+12 | 3. 004E+17 | 0. 000E+00 | 1. 067E+16 | 4. 220E+08 | 0. 000E+00 | 0. 000E+00 | 0. 000E+00 | 0. 000E+00 | 1. 078E+07 |
| I-133 | TOTALS | | | | | | | | | | |
| I-134 | INITIAL | 3. 240E+12 | 1. 473E+16 | 0. 000E+00 | 2. 204E+13 | 3. 549E+07 | 0. 000E+00 | 0. 000E+00 | 0. 000E+00 | 0. 000E+00 | 6. 261E+05 |
| I-134 | TOTALS | | | | | | | | | | |
| I-135 | INITIAL | 2. 920E+12 | 8. 554E+16 | 0. 000E+00 | 9. 627E+14 | 2. 604E+08 | 0. 000E+00 | 0. 000E+00 | 0. 000E+00 | 0. 000E+00 | 6. 209E+06 |
| I-135 | TOTALS | | | | | | | | | | |
| ALL NUCLIDES | 6. 759E+10 | | | 6. 459E+10 | | | 0. 000E+00 | 0. 000E+00 | 0. 000E+00 | 0. 000E+00 | |
| @ STEP 10 | | | | | | | | | | | |



Health Physics Department

ERS-APO-91-035

ATTACHMENT 3

Page 33 of 56

TRAITS ---- Transport of Radioactive Material in Linear Systems - v1.1
 I-182 F F P-S Iodines

| ENVIRONMENT | | | | | | CONTROLS | | | | | |
|--------------|-----------|----------|------------|----------|-----------|---------------|-----------|----------|------------|----------|-----------|
| PHOTON-SUBNO | | | BETA-SUBNO | | | THYROID-INHAL | | | BETA-SUBNO | | |
| DOSE | DOSE RATE | DOSE | DOSE RATE | DOSE | DOSE RATE | DOSE | DOSE RATE | DOSE | DOSE RATE | DOSE | DOSE RATE |
| rem | rem/hr | rem | rem/hr | rem | rem/hr | rem | rem/hr | rem | rem/hr | rem | rem/hr |
| I-131 | | | | | | | | | | | |
| TOTALS | 0.00E+00 | | 0.00E+00 | | | 0.00E+00 | | 0.00E+00 | | 0.00E+00 | |
| I-132 | | | | | | | | | | | |
| TOTALS | 0.00E+00 | | 0.00E+00 | | | 0.00E+00 | | 0.00E+00 | | 0.00E+00 | |
| I-133 | | | | | | | | | | | |
| TOTALS | 0.00E+00 | | 0.00E+00 | | | 0.00E+00 | | 0.00E+00 | | 0.00E+00 | |
| I-134 | | | | | | | | | | | |
| TOTALS | 0.00E+00 | | 0.00E+00 | | | 0.00E+00 | | 0.00E+00 | | 0.00E+00 | |
| I-135 | | | | | | | | | | | |
| TOTALS | 0.00E+00 | | 0.00E+00 | | | 0.00E+00 | | 0.00E+00 | | 0.00E+00 | |
| ALL NUCLIDES | | | | | | | | | | | |
| 0.5000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.43E-03 | 5.47E-03 | 7.54E-03 | 2.90E-02 |
| 5000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 3.64E-03 | 2.43E-03 | 2.43E-02 | 3.61E+01 |
| 6000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 2.15E-03 | 4.93E-03 | 3.25E-02 | 2.18E+01 |
| 75000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 2.56E-03 | 5.20E-03 | 1.53E-02 | 2.28E+01 |
| 400000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 9.28E-03 | 6.99E-03 | 5.94E-02 | 6.25E+02 |
| 800000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 3.93E-02 | 1.18E-02 | 2.88E-02 | 3.27E+02 |
| B5000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 3.65E-03 | 3.65E-04 | 1.25E-02 | 3.57E+02 |
| 240000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 3.45E-03 | 3.04E-05 | 1.22E-02 | 4.08E+01 |
| 960000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 5.05E-05 | 2.14E-11 | 5.03E-04 | 3.10E-17 |
| 7200000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 6.29E-12 | 0.00E+00 | 6.02E-29 | 0.00E+00 |
| TOTALS | 0.00E+00 | | 0.00E+00 | | | 0.00E+00 | | 6.23E-02 | 4.31E-01 | 1.07E+03 | |

| |
|--|
| Duquesne Light HEALTH PHYSICS DEPARTMENT ERS-MPD-91-035 ATTACHMENT 3 |
|--|


Page 34 of 56

COMP NOT USED IN THIS CASE

COMP 3 SCS

VOLUME: 1.730E+075 Cu ft

COMP Control Room



Health Physics Department

ERS-APO-9L035

ATTACHMENT 3

Page 35 of 56

| | INITIAL | COMP 3 SCS | VOLUME: 1.730E+075 Cu ft | COMP Control Room |
|--|--------------------|----------------------|--------------------------|-------------------------|
| | 0.000E+000 KR-B3m | 2.160E+075 KR-B3m C1 | 0.000E+000 KR-B3m | 0.000E+000 KR-B3m |
| | 0.000E+000 KR-B5m | 5.400E+075 KR-B5m | 0.000E+000 KR-B5m | 0.000E+000 KR-B5m |
| | 0.000E+000 KR-B5 | 3.720E+074 KR-B5 | 0.000E+000 KR-B5 | 0.000E+000 KR-B5 |
| | 0.000E+000 KR-B7 | 1.072E+076 KR-B7 | 0.000E+000 KR-B7 | 0.000E+000 KR-B7 |
| | 0.000E+000 KR-B8 | 1.490E+076 KR-B8 | 0.000E+000 KR-B8 | 0.000E+000 KR-B8 |
| | 0.000E+000 KR-B9 | 1.980E+076 KR-B9 | 0.000E+000 KR-B9 | 0.000E+000 KR-B9 |
| | 0.000E+000 KR- | 0.000E+000 KR- | 0.000E+000 KR- | 0.000E+000 KR- |
| | 0.000E+000 XE-131m | 7.570E+073 XE-131m | 0.000E+000 XE-131m | 0.000E+000 XE-131m |
| | 0.000E+000 XE-133m | 6.480E+074 XE-133m | 0.000E+000 XE-133m | 0.000E+000 XE-133m |
| | 0.000E+000 XE-135m | 2.880E+075 XE-133 | 0.000E+000 XE-135m | 0.000E+000 XE-135m |
| | 0.000E+000 XE-135 | 7.560E+075 XE-135m | 0.000E+000 XE-135 | 0.000E+000 XE-135 |
| | 0.000E+000 XE-137 | 7.280E+075 XE-135 | 0.000E+000 XE-137 | 0.000E+000 XE-137 |
| | 0.000E+000 XE-138 | 2.520E+076 XE-137 | 0.000E+000 XE-138 | 0.000E+000 XE-138 |
| | 0.000E+000 I-131 | 0.000E+00 I-131 | 0.000E+00 I-131 | 0.000E+00 I-131 |
| | 0.000E+000 I-132 | 0.000E+00 I-132 | 0.000E+00 I-132 | 0.000E+00 I-132 |
| | 0.000E+000 I-133 | 0.000E+00 I-133 | 0.000E+00 I-133 | 0.000E+00 I-133 |
| | 0.000E+000 I-134 | 0.000E+00 I-134 | 0.000E+00 I-134 | 0.000E+00 I-134 |
| | 0.000E+000 I-135 | 0.000E+00 I-135 | 0.000E+00 I-135 | 0.000E+00 I-135 |
| | 1.000E+002 | 1.000E+005 | 1.000E+00 | 1.000E+00 |
| | ACT MULT (to uCi) | | | |
| | PRODUCTION: uCi/s | | | |
| | 0.000E+000 KR-B3m | 0.000E+000 KR-B3m | 0.000E+000 KR-B3m | 0.000E+000 KR-B3m |
| | 0.000E+000 KR-B5m | 0.000E+000 KR-B5m | 0.000E+000 KR-B5m | 0.000E+000 KR-B5m |
| | 0.000E+000 KR-B5 | 0.000E+000 KR-B7 | 0.000E+000 KR-B7 | 0.000E+000 KR-B7 |
| | 0.000E+000 KR-B7 | 0.000E+000 KR-BB | 0.000E+000 KR-BB | 0.000E+000 KR-BB |
| | 0.000E+000 KR-BB | 0.000E+000 KR-B9 | 0.000E+000 KR-B9 | 0.000E+000 KR-B9 |
| | 0.000E+000 KR-B9 | 0.000E+000 KR-90 | 0.000E+000 KR-90 | 0.000E+000 KR-90 |
| | 0.000E+000 KR-90 | 0.000E+000 RE-131m | 0.000E+000 RE-131m | 0.000E+000 RE-131m |
| | 0.000E+000 RE-131m | 0.000E+000 RE-133m | 0.000E+000 RE-133m | 0.000E+000 RE-133m |
| | 0.000E+000 RE-133m | 0.000E+000 XE-133 | 0.000E+000 XE-133 | 0.000E+000 XE-133 |
| | 0.000E+000 XE-133 | 0.000E+000 XE-135m | 0.000E+000 XE-135m | 0.000E+000 XE-135m |
| | 0.000E+000 XE-135m | 0.000E+000 XE-137 | 0.000E+000 XE-137 | 0.000E+000 XE-137 |
| | 0.000E+000 XE-137 | 0.000E+000 XE-138 | 0.000E+000 XE-138 | 0.000E+000 XE-138 |
| | 0.000E+000 XE-138 | 0.000E+000 I-131 | 0.000E+000 I-131 | 0.000E+000 I-131 |
| | 0.000E+000 I-131 | 0.000E+000 I-132 | 0.000E+000 I-132 | 0.000E+000 I-132 |
| | 0.000E+000 I-132 | 0.000E+000 I-133 | 0.000E+000 I-133 | 0.000E+000 I-133 |
| | 0.000E+000 I-133 | 0.000E+000 I-134 | 0.000E+000 I-134 | 0.000E+000 I-134 |
| | 0.000E+000 I-134 | 0.000E+000 I-135 | 0.000E+000 I-135 | 0.000E+000 I-135 |
| | 0.000E+000 I-135 | 1.000E+005 | 1.000E+00 | 1.000E+00 |
| | REMOVAL | | | |
| | NUC 1-14 REL FR | 0.000E+000 1.000E-07 | 1.000E-07 | 1.000E+01 cPm |
| | NUC 15-20 REL FR | 0.000E+000 | 0.000E+000 | INTAKE REDUCT 0.000E+00 |
| | | | | INTAKE FILTER 0.360E-01 |

TRAITS --- Transport of Radioactive Material in Linear Systems. v1.1

2 18% F F P-S Noble Gases in 3 Secs

MULTIPLIERS<---->


| STEP | TIME | XPR | XREM | XRF | XPR | XREM | XRF | SIR | TIME |
|------|-----------|-----------|------|-----------|-----------|------|-----------|-----------|-----------|
| 1 | 1.0E+03 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00E+00 |
| 2 | 5.400E+03 | 0.000E+03 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| 3 | 200E+03 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00E+00 |
| 4 | 9.000E+03 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00E+00 |
| 5 | 4.40E+04 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00E+00 |
| 6 | 2.880E+04 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00E+00 |
| 7 | 3.060E+04 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00E+00 |
| 8 | 8.640E+04 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00E+00 |
| 9 | 3.456E+05 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00E+00 |
| 10 | 2.592E+06 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00E+00 |

MULTIPLIERS<---->

| STEP | TIME | X/G | Breathing Occupancy | X/G | Breathing |
|------|---------|-----------|---------------------|-----------|-----------|
| 1 | 1.0E+03 | 1.0E+03 | 1.0E+03 | 1.0E+03 | 1.0E+03 |
| 2 | 1.0E+00 | 3.470E-04 | 1.000E+00 | 1.000E+00 | 3.470E-04 |

MULTIPLIERS<---->

| STEP | TIME | X/G | Breathing Occupancy | X/G | Breathing |
|------|-----------|-----------|---------------------|------|-----------|
| 1 | 1.800E+03 | 1.590E-04 | 1.00 | 1.00 | 0.000E+00 |
| 2 | 5.400E+03 | 1.590E-04 | 1.00 | 1.00 | 0.000E+00 |
| 3 | 2.00E+03 | 1.590E-04 | 1.00 | 1.00 | 0.000E+00 |
| 4 | 9.000E+03 | 1.590E-04 | 1.00 | 1.00 | 0.000E+00 |
| 5 | 4.400E+04 | 1.590E-04 | 1.00 | 1.00 | 0.000E+00 |
| 6 | 2.880E+04 | 1.590E-04 | 1.00 | 1.00 | 0.000E+00 |
| 7 | 3.060E+04 | 1.590E-04 | 1.00 | 1.00 | 0.000E+00 |
| 8 | 8.640E+04 | 1.590E-04 | 1.00 | 1.00 | 0.000E+00 |
| 9 | 3.456E+05 | 1.590E-04 | 1.00 | 1.00 | 0.000E+00 |
| 10 | 2.592E+06 | 1.590E-04 | 1.00 | 1.00 | 0.000E+00 |



Health Physics Department

ERS-APO-9L-035

ATTACHMENT 3

Page 36 of 56

TRAILS -- Transport of Radioactive Material in Linear Systems v1.1
 2 187 F F P-S Noble Gases in 3 SCs


| | | NOT USED IN THIS CAS | | 3 SCs | | AVERAGE | | CENTRIL. RADI | | INTEGRAL | |
|--------------|---------|----------------------|-----------|-----------|-----------|-----------|-----------|---------------|-----------|-----------|-----------|
| STEP | TIME | CURRENT | INTEGRAL | CURRENT | INTEGRAL | RELEASE | RELEASE | CURRENT | CURRENT | 0.00E+00 | 0.00E+00 |
| HR-83m | INITIAL | 0.000E+00 | 0.000E+00 | 2.160E+11 | 0.718E+00 | 6.249E+03 | 6.249E+03 | 0.000E+00 | 0.000E+00 | 1.197E+03 | 1.197E+03 |
| HR-83m | TOTALS | 0.000E+00 | 0.000E+00 | - | - | - | - | - | - | - | - |
| HR-85m | INITIAL | 0.000E+00 | 0.000E+00 | 5.400E+11 | 1.250E+00 | 2.941E+09 | 2.941E+09 | 0.000E+00 | 0.000E+00 | 8.159E+02 | 8.159E+02 |
| HR-85m | TOTALS | 0.000E+00 | 0.000E+00 | - | - | - | - | - | - | - | - |
| HR-85 | INITIAL | 0.000E+00 | 0.000E+00 | 3.730E+10 | 9.552E+00 | 3.938E+09 | 3.938E+09 | 0.000E+00 | 0.000E+00 | 1.314E+02 | 1.314E+02 |
| HR-85 | TOTALS | 0.000E+00 | 0.000E+00 | - | - | - | - | - | - | - | - |
| HR-87 | INITIAL | 0.000E+00 | 0.000E+00 | 1.040E+12 | 6.996E+13 | 2.286E+09 | 2.286E+09 | 0.000E+00 | 0.000E+00 | 3.129E+02 | 3.129E+02 |
| HR-87 | TOTALS | 0.000E+00 | 0.000E+00 | - | - | - | - | - | - | - | - |
| HR-89 | INITIAL | 0.000E+00 | 0.000E+00 | 1.490E+12 | 2.163E+16 | 6.420E+09 | 6.420E+09 | 0.000E+00 | 0.000E+00 | 1.464E+02 | 1.464E+02 |
| HR-89 | TOTALS | 0.000E+00 | 0.000E+00 | - | - | - | - | - | - | - | - |
| HR-89 | INITIAL | 0.000E+00 | 0.000E+00 | 1.980E+12 | 5.415E+14 | 1.792E+09 | 1.792E+09 | 0.000E+00 | 0.000E+00 | 1.911E+02 | 1.911E+02 |
| HR-89 | TOTALS | 0.000E+00 | 0.000E+00 | - | - | - | - | - | - | - | - |
| HE-131m | INITIAL | 0.000E+00 | 0.000E+00 | 7.570E+09 | 9.156E+15 | 7.117E+07 | 7.117E+07 | 0.000E+00 | 0.000E+00 | 2.628E+02 | 2.628E+02 |
| HE-131m | TOTALS | 0.000E+00 | 0.000E+00 | - | - | - | - | - | - | - | - |
| HE-133 | INITIAL | 0.000E+00 | 0.000E+00 | 6.980E+10 | 1.890E+16 | 6.014E+08 | 6.014E+08 | 0.000E+00 | 0.000E+00 | 2.176E+02 | 2.176E+02 |
| HE-133 | TOTALS | 0.000E+00 | 0.000E+00 | - | - | - | - | - | - | - | - |
| HE-139m | INITIAL | 0.000E+00 | 0.000E+00 | 7.560E+11 | 1.005E+15 | 3.323E+08 | 3.323E+08 | 0.000E+00 | 0.000E+00 | 1.184E+02 | 1.184E+02 |
| HE-139m | TOTALS | 0.000E+00 | 0.000E+00 | - | - | - | - | - | - | - | - |
| HE-135 | INITIAL | 0.000E+00 | 0.000E+00 | 7.380E+11 | 3.465E+16 | 3.243E+09 | 3.243E+09 | 0.000E+00 | 0.000E+00 | 1.684E+02 | 1.684E+02 |
| HE-135 | TOTALS | 0.000E+00 | 0.000E+00 | - | - | - | - | - | - | - | - |
| HE-137 | INITIAL | 0.000E+00 | 0.000E+00 | 2.520E+12 | 8.357E+14 | 2.763E+08 | 2.763E+08 | 0.000E+00 | 0.000E+00 | 3.367E+02 | 3.367E+02 |
| HE-137 | TOTALS | 0.000E+00 | 0.000E+00 | - | - | - | - | - | - | - | - |
| HE-138 | INITIAL | 0.000E+00 | 0.000E+00 | 2.520E+12 | 3.081E+15 | 1.019E+09 | 1.019E+09 | 0.000E+00 | 0.000E+00 | 3.459E+02 | 3.459E+02 |
| HE-138 | TOTALS | 0.000E+00 | 0.000E+00 | - | - | - | - | - | - | - | - |
| ALL NUCLIDES | INITIAL | 0.000E+00 | 0.000E+00 | 9.212E+10 | - | - | - | - | - | - | - |
| STEP 10 | | | | | | | | | | | |

Duquesne
Light
Health Physics Department

ERS-APO-91-035

ATTACHMENT 3

Page 37 of 56



Health Physics Department

ERS-MPO-91-035

ATTACHMENT 3

P

808

20

38

of

1

10

88

10

18

四


TRAITS -- Transport of Radioactive Material in Linear Systems. v1.1
3-182. F.F. Concurrent Iodine Spike

| | COMP | SGS | VSL (ppm) | COMP - Control Room 1.730E+05 C/L f.t. |
|------------------------|-------------------|-------------------|-------------------------|---|
| INITIAL | 0.000E+00 KR-83m | 0.000E+00 KR-83m | 0.000E+00 KR-83m | 0.000E+00 KR-83m |
| | 0.000E+00 KR-85m | 0.000E+00 KR-85m | 0.000E+00 KR-85m | 0.000E+00 KR-85m |
| | 0.000E+00 KR-85 | 0.000E+00 KR-85 | 0.000E+00 KR-85 | 0.000E+00 KR-85 |
| | 0.000E+00 KR-B7 | 0.000E+00 KR-B7 | 0.000E+00 KR-B7 | 0.000E+00 KR-B7 |
| | 0.000E+00 KR-88 | 0.000E+00 KR-88 | 0.000E+00 KR-88 | 0.000E+00 KR-88 |
| | 0.000E+00 KR-89 | 0.000E+00 KR-89 | 0.000E+00 KR-89 | 0.000E+00 KR-89 |
| | 0.000E+00 KR-90 | 0.000E+00 KR-90 | 0.000E+00 KR-90 | 0.000E+00 KR-90 |
| | 0.000E+00 KE-131M | 0.000E+00 KE-131M | 0.000E+00 KE-131M | 0.000E+00 KE-131M |
| | 0.000E+00 KE-133M | 0.000E+00 KE-133M | 0.000E+00 KE-133M | 0.000E+00 KE-133M |
| | 0.000E+00 KE-133 | 0.000E+00 KE-133 | 0.000E+00 KE-133 | 0.000E+00 KE-133 |
| | 0.000E+00 KE-135M | 0.000E+00 KE-135M | 0.000E+00 KE-135M | 0.000E+00 KE-135M |
| | 0.000E+00 KE-135 | 0.000E+00 KE-135 | 0.000E+00 KE-135 | 0.000E+00 KE-135 |
| | 0.000E+00 KE-137 | 0.000E+00 KE-137 | 0.000E+00 KE-137 | 0.000E+00 KE-137 |
| | 0.000E+00 KE-138 | 0.000E+00 KE-138 | 0.000E+00 KE-138 | 0.000E+00 KE-138 |
| | 0.000E+00 I-131 | 0.000E+00 I-131 | 0.000E+00 I-131 | 0.000E+00 I-131 |
| | 0.000E+00 I-132 | 0.000E+00 I-132 | 0.000E+00 I-132 | 0.000E+00 I-132 |
| | 0.000E+00 I-133 | 0.000E+00 I-133 | 0.000E+00 I-133 | 0.000E+00 I-133 |
| | 0.000E+00 I-134 | 0.000E+00 I-134 | 0.000E+00 I-134 | 0.000E+00 I-134 |
| | 0.000E+00 I-125 | 0.000E+00 I-125 | 0.000E+00 I-125 | 0.000E+00 I-125 |
| A.C.T., PUL/T (t0 uCi) | 1.000E+00 | 1.000E+00 | 1.000E+00 | 1.000E+00 |
| PRODUCTION, uCi/s | 0.000E+00 KR-83m | 0.000E+00 KR-83m | 0.000E+00 KR-83m | 0.000E+00 KR-83m |
| | 0.000E+00 KR-85A | 0.000E+00 KR-85A | 0.000E+00 KR-85A | 0.000E+00 KR-85A |
| | 0.000E+00 KR-85 | 0.000E+00 KR-85 | 0.000E+00 KR-85 | 0.000E+00 KR-85 |
| | 0.000E+00 KR-B7 | 0.000E+00 KR-B7 | 0.000E+00 KR-B7 | 0.000E+00 KR-B7 |
| | 0.000E+00 KR-88 | 0.000E+00 KR-88 | 0.000E+00 KR-88 | 0.000E+00 KR-88 |
| | 0.000E+00 KR-89 | 0.000E+00 KR-89 | 0.000E+00 KR-89 | 0.000E+00 KR-89 |
| | 0.000E+00 KR-90 | 0.000E+00 KR-90 | 0.000E+00 KR-90 | 0.000E+00 KR-90 |
| | 0.000E+00 KE-131M | 0.000E+00 KE-131M | 0.000E+00 KE-131M | 0.000E+00 KE-131M |
| | 0.000E+00 KE-133M | 0.000E+00 KE-133M | 0.000E+00 KE-133M | 0.000E+00 KE-133M |
| | 0.000E+00 KE-133 | 0.000E+00 KE-133 | 0.000E+00 KE-133 | 0.000E+00 KE-133 |
| | 0.000E+00 KE-135M | 0.000E+00 KE-135M | 0.000E+00 KE-135M | 0.000E+00 KE-135M |
| | 0.000E+00 KE-135 | 0.000E+00 KE-135 | 0.000E+00 KE-135 | 0.000E+00 KE-135 |
| | 0.000E+00 KE-137 | 0.000E+00 KE-137 | 0.000E+00 KE-137 | 0.000E+00 KE-137 |
| | 0.000E+00 I-138 | 0.000E+00 I-138 | 0.000E+00 I-138 | 0.000E+00 I-138 |
| | 1.360E+06 I-13, | 2.520E+06 I-132 | 0.000E+00 I-132 | 0.000E+00 I-132 |
| | 3.080E+06 I-133 | 3.080E+06 I-133 | 0.000E+00 I-133 | 0.000E+00 I-133 |
| | 3.680E+06 I-134 | 3.680E+06 I-134 | 0.000E+00 I-134 | 0.000E+00 I-134 |
| | 2.810E+06 I-135 | 2.810E+06 I-135 | 0.000E+00 I-135 | 0.000E+00 I-135 |
| REMOVAL | 3.309E-07 1/sec | 2.069E-06 1/sec | 1.000E+01 CFM | 1.000E+01 CFM |
| NUC 1-14 REL FR | 0.000E+00 | 0.000E+00 | INTAKE REDUCT 0.000E+00 | INTAKE REDUCT 0.000E+00 |
| NUC 15-20 REL FR | 0.000E+00 | 0.000E+00 | INTAKE FILTER 9.360E-01 | INTAKE FILTER 9.360E-01 |

Page 39 of 56

Duquesne
Light
Health Physics Department

ERS-APO-9L-035
ATTACHMENT 3



ERS-APO-9L-035

ATTACHMENT 3


Page 40 of 56

| MULTIPLERS_{room} | | STEP | TIME | XPR | XREM | XRF | XPR | XREM | XRF | XPR | XREM | XRF |
|---------------------------|------------|------|------------|-----------|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| | | | | 1.00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 |
| 1 | 1. B00E+03 | 1 | 1. B00E+03 | 1.00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 |
| 2 | 5. 400E+03 | 2 | 5. 400E+03 | 1.00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 |
| 3 | 7. 200E+03 | 3 | 7. 200E+03 | 1.00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.00 |
| 4 | 9. 000E+03 | 4 | 9. 000E+03 | 1.00 | 1.00 | 0.000E+20 | 0.000E+00 | 0.396 | 0.000E+00 | 0.792 | 0.000E+00 | 1.00 |
| 5 | 1. 440E+04 | 5 | 1. 440E+04 | 1.00 | 1.00 | 0.000E+00 | 0.000E+00 | 0.396 | 0.000E+00 | 0.792 | 0.000E+00 | 1.00 |
| 6 | 2. 880E+04 | 6 | 2. 880E+04 | 2.00E-03 | 1.00 | 0.000E+00 | 0.000E+00 | 0.396 | 0.000E+00 | 0.792 | 0.000E+00 | 1.00 |
| 7 | 3. 060E+04 | 7 | 3. 060E+04 | 0.000E+00 | 1.00 | 0.000E+00 |
| 8 | 3. 640E+04 | 8 | 3. 640E+04 | 0.000E+00 | 1.00 | 0.000E+00 |
| 9 | 3. 456E+05 | 9 | 3. 456E+05 | 0.000E+00 | 1.00 | 0.000E+00 |
| 10 | 2. 592E+06 | 10 | 2. 592E+06 | 0.000E+00 | 1.00 | 0.000E+00 |

| MULTIPLERS_{room} | | STEP | TIME | CONTROL ROOM | | | ENVIRONMENT | | |
|---------------------------|---------------------|------|------------|--------------|-----------|-------|-------------|-------|-------|
| X/G | Breathing Occupancy | | | X/G | Breathing | M3/s | M3/s | M3/s | M3/s |
| 1. 000E+00 | 3. 470E-04 | 1 | 1. 000E+00 | 1. 590E-04 | 1. 00 | 1. 00 | 0. 000E+00 | 1. 00 | 1. 00 |
| 2 | 5. 400E+03 | 2 | 5. 400E+03 | 1. 590E-04 | 1. 00 | 1. 00 | 0. 000E+00 | 1. 00 | 1. 00 |
| 3 | 7. 200E+03 | 3 | 7. 200E+03 | 1. 590E-04 | 1. 00 | 1. 00 | 0. 000E+00 | 1. 00 | 1. 00 |
| 4 | 9. 000E+03 | 4 | 9. 000E+03 | 1. 590E-04 | 1. 00 | 1. 00 | 0. 000E+00 | 1. 00 | 1. 00 |
| 5 | 1. 440E+04 | 5 | 1. 440E+04 | 1. 590E-04 | 1. 00 | 1. 00 | 0. 000E+00 | 1. 00 | 1. 00 |
| 6 | 2. 880E+04 | 6 | 2. 880E+04 | 1. 590E-04 | 1. 00 | 1. 00 | 0. 000E+00 | 1. 00 | 1. 00 |
| 7 | 3. 060E+04 | 7 | 3. 060E+04 | 7. 880E-05 | 1. 00 | 1. 00 | 0. 000E+00 | 1. 00 | 1. 00 |
| 8 | 3. 640E+04 | 8 | 3. 640E+04 | 7. 880E-05 | 1. 00 | 1. 00 | 0. 000E+00 | 1. 00 | 1. 00 |
| 9 | 3. 456E+05 | 9 | 3. 456E+05 | 5. 960E-05 | 1. 00 | 1. 00 | 0. 000E+00 | 1. 00 | 1. 00 |
| 10 | 2. 592E+06 | 10 | 2. 592E+06 | 3. 760E-05 | 1. 00 | 1. 00 | 0. 000E+00 | 1. 00 | 1. 00 |

TRAITS — Transport of Radioactive Material in Linear Systems: v1.1
3-18% F F Concurrent Iodine Spike

| STEP | TIME | RCS | | | 3 SEC | | | AVERAGE | | | CUMULATIVE | | | STEPS | | |
|---------------|---------|-----------|-----------|-----|-----------|-----------|-----|-----------|----------|-----------|------------|-----|-----------|-----------|-------------|-----|
| | | CURRENT | INTEGRD | UCI | CURRENT | INTEGRD | UCI | RELEASED | RELEASED | UCI | CURRENT | UCI | RELEASED | UCI | CURRENT | UCI |
| I-131 | INITIAL | 0.000E+00 | 1.429E+16 | | 0.000E+00 | 3.991E+15 | | 1.904E+06 | | 0.000E+00 | 0.000E+00 | | 0.000E+00 | 0.000E+00 | A. 314E+04 | |
| I-131 | TOTALS | | | | | | | | | | | | | | | |
| I-132 | INITIAL | 0.000E+00 | 4.327E+14 | | 0.000E+00 | 1.697E+12 | | 1.145E+06 | | 0.000E+00 | 0.000E+00 | | 0.000E+00 | 0.000E+00 | B. 917E+04 | |
| I-132 | TOTALS | | | | | | | | | | | | | | | |
| I-133 | INITIAL | 0.000E+00 | 4.635E+15 | | 0.000E+00 | 1.653E+14 | | 3.808E+06 | | 0.000E+00 | 0.000E+00 | | 0.000E+00 | 0.000E+00 | C. 2760E+04 | |
| I-133 | TOTALS | | | | | | | | | | | | | | | |
| I-134 | INITIAL | 0.000E+00 | 2.414E+14 | | 0.000E+00 | 3.618E+11 | | 4.475E+05 | | 0.000E+00 | 0.000E+00 | | 0.000E+00 | 0.000E+00 | D. 626E+03 | |
| I-134 | TOTALS | | | | | | | | | | | | | | | |
| I-135 | INITIAL | 0.000E+00 | 1.376E+15 | | 0.000E+00 | 1.554E+13 | | 2.604E+05 | | 0.000E+00 | 0.000E+00 | | 0.000E+00 | 0.000E+00 | E. 141E+04 | |
| I-135 | TOTALS | | | | | | | | | | | | | | | |
| All. NUCLIDES | | 6.328E+09 | | | 8.554E+08 | | | | | | | | | | | |
| @ STEP 10 | | | | | | | | | | | | | | | | |



Duquesne
Light

Health Physics Department

ERS-APO-91-035

ATTACHMENT 3


Page 41 of 56

TRANSPORT OF Radioactive Material in Linear Systems: v1.1
J-182 F F Concurrent Iodine Spike

| ENVIRONMENT | | BETA-SUBMC | | PHOTON-SUBMC | | BETA-SUBMC | | TRANSPORT | |
|--------------|----------|------------|-----------|--------------|-----------|------------|-----------|-----------|----------|
| | | DOSE | DOSE RATE | DOSE | DOSE RATE | DOSE | DOSE RATE | DATE | TIME |
| | | mfrem | mfrem/hr | mfrem | mfrem/hr | mfrem | mfrem/hr | mm:ss | mm:ss |
| I-131 | TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 4.22E-05 | 3.68E-04 |
| I-132 | TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.07E-04 | 4.18E-04 |
| I-133 | TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.29E-04 | 1.59E-03 |
| I-134 | TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 3.11E-05 | 1.34E-04 |
| I-135 | TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 2.08E-04 | 8.90E-04 |
| ALL NUCLIDES | | | | | | | | | |
| 0.5000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.05E-06 | 5.99E-05 | 5.69E-03 |
| 1.5000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 3.90E-06 | 2.01E-05 | 2.50E-02 |
| 2.5000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 4.10E-06 | 1.23E-05 | 2.74E-02 |
| 2.5000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 7.61E-06 | 1.79E-05 | 9.56E-02 |
| 4.0000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 4.96E-05 | 4.53E-05 | 1.56E-01 |
| 8.0000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 4.11E-04 | 2.71E-04 | 4.77E-01 |
| 8.5000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 9.75E-04 | 6.08E+00 | 2.28E+00 |
| 24.0000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.96E-05 | 3.01E-05 | 3.17E-01 |
| 96.0000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.60E-05 | 1.02E-07 | 7.21E-06 |
| 720.0000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 4.79E-07 | 9.64E-14 | 3.87E-03 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 5.30E-13 | 0.00E+00 | 5.12E-12 |
| | | | | | | | 3.16E-04 | 3.41E-03 | 5.00E+00 |
| | | | | | | | | | 7.30E+00 |

| |
|---------------------------|
| Duquesne Light |
| Health Physics Department |
| ERS-MPO-91-035 |
| ATTACHMENT 3 |
| Page 42 of 56 |

TRAITS -- Transport of Radioactive Material in Linear Systems, v1
4 18% F/F 35Cs-S Initial Steam Release

| | | |
|---|--|---------------|
|  Duquesne Light Health Physics Department | ERS-APO-9L-035 ATTACHMENT 3 | Page 17 of 56 |
|---|--|---------------|

| | COMP | NOT USED IN THIS CASE | COMP | 3 SGs Init | Stm | VOLUME: | COMP | Control Room |
|-----------------------|----------|-----------------------|------------|------------|-----|--------------------|--------------------|--------------|
| INITIAL | | | | | | 1 7.20E+05 Cu. Ft. | | |
| 0.000E+00 | WR-83m | | 5.770E-05 | WR-83m | C: | | 0.000E+00 WR-B3m | |
| 0.000E+00 | WR-85m | | 2.810E-04 | WR-85m | | | 0.000E+00 WR-B5m | |
| 0.000E+00 | WR-85 | | -1.480E-03 | WR-85 | | | 0.000E+00 WR-B5 | |
| 0.000E+00 | WR-87 | | 1.610E-04 | WR-87 | | | 0.000E+00 WR-B7 | |
| 0.000E+00 | WR-88 | | 4.290E-04 | WR-88 | | | 0.000E+00 WR-B8 | |
| 0.000E+00 | WR-89 | | 1.290E-03 | WR-89 | | | 0.000E+00 WR-B9 | |
| 0.000E+00 | WR-90 | | 0.000E+00 | WR-90 | | | 0.000E+00 WR-B90 | |
| 0.000E+00 | XE-1.31M | | 1.440E-05 | XE-1.31M | | | 0.000E+00 XE-1.31M | |
| 0.000E+00 | XE-1.33M | | 4.130E-04 | XE-1.33M | | | 0.000E+00 XE-1.33M | |
| 0.000E+00 | XE-1.33 | | 3.520E-03 | XE-1.33 | | | 0.000E+00 XE-1.33 | |
| 0.000E+00 | XE-1.35M | | 1.460E-04 | XE-1.35M | | | 0.000E+00 XE-1.35M | |
| 0.000E+00 | XE-1.35 | | 4.310E-04 | XE-1.35 | | | 0.000E+00 XE-1.35 | |
| 0.000E+00 | XE-1.37 | | 2.190E-05 | XE-1.37 | | | 0.000E+00 XE-1.37 | |
| 0.000E+00 | XE-1.38 | | 9.030E-05 | XE-1.38 | | | 0.000E+00 XE-1.38 | |
| 0.000E+00 | I-1.31 | | 8.130E-03 | I-1.31 | | | 0.000E+00 I-1.31 | |
| 0.000E+00 | I-1.32 | | 2.400E-03 | I-1.32 | | | 0.000E+00 I-1.32 | |
| 0.000E+00 | I-1.33 | | 1.160E-03 | I-1.33 | | | 0.000E+00 I-1.33 | |
| 0.000E+00 | I-1.34 | | 5.360E-04 | I-1.34 | | | 0.000E+00 I-1.34 | |
| 0.000E+00 | I-1.35 | | 5.210E-03 | I-1.35 | | | 0.000E+00 I-1.35 | |
| ACT. MUL T (to uCi/s) | | | 1.000E+06 | | | | 1.000E+00 | |
| PRODUCTION, uCi/s | | | | | | | | |
| 0.000E+00 | WR-83m | | | | | 0.000E+00 WR-B3m | | |
| 0.000E+00 | WR-85m | | | | | 0.000E+00 WR-B5m | | |
| 0.000E+00 | WR-85 | | | | | 0.000E+00 WR-B5 | | |
| 0.000E+00 | WR-87 | | | | | 0.000E+00 WR-B7 | | |
| 0.000E+00 | WR-88 | | | | | 0.000E+00 WR-B8 | | |
| 0.000E+00 | WR-89 | | | | | 0.000E+00 WR-B9 | | |
| 0.000E+00 | WR-90 | | | | | 0.000E+00 WR-B90 | | |
| 0.000E+00 | XE-1.31M | | | | | 0.000E+00 XE-1.31M | | |
| 0.000E+00 | XE-1.33M | | | | | 0.000E+00 XE-1.33M | | |
| 0.000E+00 | XE-1.35M | | | | | 0.000E+00 XE-1.35M | | |
| 0.000E+00 | XE-1.37 | | | | | 0.000E+00 XE-1.37 | | |
| 0.000E+00 | XE-1.38 | | | | | 0.000E+00 XE-1.38 | | |
| 0.000E+00 | I-1.31 | | | | | 0.000E+00 I-1.31 | | |
| 0.000E+00 | I-1.32 | | | | | 0.000E+00 I-1.32 | | |
| 0.000E+00 | I-1.33 | | | | | 0.000E+00 I-1.33 | | |
| 0.000E+00 | I-1.34 | | | | | 0.000E+00 I-1.34 | | |
| 0.000E+00 | I-1.35 | | | | | 0.000E+00 I-1.35 | | |
| 0.000E+00 | I-1.36 | | | | | 1.000E+00 I-1.36 | | |
| 0.000E+00 | I/sec | | | | | | 1.283E-01 I/sec | |
| 0.000E+00 | | | | | | | 0.000E+00 | |
| 0.000E+00 | | | | | | | 0.000E+00 | |

REMOVAL
NUC 1-14 REL FR
NUC 15-20 REL FR

INTAKE REDUCT 0.000E+00
INTAKE FILTER 0.260E-01

TRAILS -- Transport of Radioactive Material in Linear Systems - v1.1
4. 18% F.F.
350s-S Initial Steam Release



ERS-APO-91-035
ATTACHMENT 3

Page 44 of 56

| MULTIPLIERS ^(a) | | NPR | | XREM | | XRF | | XRM | | XPR | | XRF | |
|----------------------------|-----------|-----------|------|-----------|------|-----------|------|-----------|------|-----------|------|-----------|------|
| STEP | TIME | 0.000E+00 | 1.00 |
| 1 | 1.000E+03 | 0.000E+00 | 1.00 |
| 2 | 5.400E+03 | 0.000E+00 | 1.00 |
| 3 | 7.200E+03 | 0.000E+00 | 1.00 |
| 4 | 9.000E+03 | 0.000E+00 | 1.00 |
| 5 | 1.440E+04 | 0.000E+00 | 1.00 |
| 6 | 2.880E+04 | 0.000E+00 | 1.00 |
| 7 | 3.060E+04 | 0.000E+00 | 1.00 |
| 8 | 8.640E+04 | 0.000E+00 | 1.00 |
| 9 | 3.456E+05 | 0.000E+00 | 1.00 |
| 10 | 2.592E+06 | 0.000E+00 | 1.00 |

| CONTROL FLOW | | | ENVIRONMENT | | |
|--------------|-----------|-----------|-------------|-----------|-----------|
| X/G | Breath | Occupancy | X/B | Breathing | |
| S/M3 | M3/s | M3/s | S/M3 | M3/s | M3/s |
| 1.000E+00 | 3.470E-04 | 1.000E+00 | 1.000E+00 | 3.470E-04 | 1.000E+00 |

| MULTIPLIERS ^(a) | | STEP | | TIME, s | | XREM | | XRF | | XRM | | XPR | |
|----------------------------|-----------|------|-----------|---------|------|------|------|-----|------|-----|------|-----|------|
| 1 | 1.000E+03 | 1 | 5.900E-04 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 |
| 2 | 5.400E+03 | 1 | 5.900E-04 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 |
| 3 | 7.200E+03 | 1 | 5.900E-04 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 |
| 4 | 9.000E+03 | 1 | 5.900E-04 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 |
| 5 | 1.440E+04 | 1 | 5.900E-04 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 |
| 6 | 2.880E+04 | 1 | 5.900E-04 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 |
| 7 | 3.060E+04 | 1 | 5.900E-04 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 |
| 8 | 8.640E+04 | 1 | 5.900E-04 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 |
| 9 | 3.456E+05 | 1 | 5.900E-04 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 |
| 10 | 2.592E+06 | 1 | 5.900E-04 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 | 1 | 0.00 |

TRAILS -- Transport of Radioactive Material in Linear Systems, v1.1

4 182 F F 350G-S Initial Stream Release

| | NOT USED IN THIS CAS | 3 5G5 Init | 5m INTEGRD | AVERAGE | RELEASE | CURRENT | RELEASED | RELEASE | DATE (DD) |
|---------|----------------------|------------|------------|-----------|-----------|-----------|-----------|-----------|-----------|
| STEP | TIME | INTEGRD | CURRENT | uC1 | uC1 | uC1 | uC1 | uC1 | uC1 |
| KR-03m | INITIAL | 0 000E+00 | 0 000E+00 | 5 770E+01 | 4 487E+02 | 5 765E+01 | 0 000E+00 | 0 000E+00 | 1 264E+01 |
| KR-03m | TOTALS | | | | | | | | |
| KR-05m | INITIAL | 0 000E+00 | 0 000E+00 | 2 810E+02 | 2 165E+03 | 2 809E+02 | 0 000E+00 | 0 000E+00 | 9 294E+01 |
| KR-05m | TOTALS | | | | | | | | |
| KR-05 | INITIAL | 0 000E+00 | 0 000E+00 | 1 480E+03 | 1 152E+04 | 1 480E+03 | 0 000E+00 | 0 000E+00 | 7 197E+02 |
| KR-05 | TOTALS | | | | | | | | |
| KR-07 | INITIAL | 0 000E+00 | 0 000E+00 | 1 610E+02 | 1 251E+03 | 1 608E+02 | 0 000E+00 | 0 000E+00 | 2 794E+01 |
| KR-07 | TOTALS | | | | | | | | |
| KR-09 | INITIAL | 0 000E+00 | 0 000E+00 | 4 290E+02 | 3 337E+03 | 4 288E+02 | 0 000E+00 | 0 000E+00 | 1 184E+02 |
| KR-09 | TOTALS | | | | | | | | |
| XE-131H | INITIAL | 0 000E+00 | 0 000E+00 | 1 350E+01 | 1 022E+02 | 1 313E+01 | 0 000E+00 | 0 000E+00 | 1 329E+01 |
| XE-131H | TOTALS | | | | | | | | |
| XE-133H | INITIAL | 0 000E+00 | 0 000E+00 | 1 460E+01 | 1 121E+02 | 1 440E+01 | 0 000E+00 | 0 000E+00 | 6 934E+00 |
| XE-133H | TOTALS | | | | | | | | |
| XE-133 | INITIAL | 0 000E+00 | 0 000E+00 | 3 520E+03 | 2 739E+04 | 3 520E+03 | 0 000E+00 | 0 000E+00 | 1 682E+03 |
| XE-133 | TOTALS | | | | | | | | |
| XE-135H | INITIAL | 0 000E+00 | 0 000E+00 | 1 460E+02 | 1 130E+03 | 1 452E+02 | 0 000E+00 | 0 000E+00 | 6 720E+00 |
| XE-135H | TOTALS | | | | | | | | |
| XE-135 | INITIAL | 0 000E+00 | 0 000E+00 | 4 310E+02 | 3 354E+03 | 4 309E+02 | 0 000E+00 | 0 000E+00 | 1 935E+02 |
| XE-135 | TOTALS | | | | | | | | |
| XE-137 | INITIAL | 0 000E+00 | 0 000E+00 | 2 190E+01 | 1 663E+02 | 2 140E+01 | 0 000E+00 | 0 000E+00 | 2 617E+01 |
| XE-137 | TOTALS | | | | | | | | |
| XE-138 | INITIAL | 0 000E+00 | 0 000E+00 | 9 030E+01 | 6 983E+02 | 8 973E+01 | 0 000E+00 | 0 000E+00 | 1 712E+02 |
| XE-138 | TOTALS | | | | | | | | |
| I-131 | INITIAL | 0 000E+00 | 0 000E+00 | 8 130E+03 | 6 327E+04 | 8 130E+03 | 0 000E+00 | 0 000E+00 | 3 914E+03 |
| I-131 | TOTALS | | | | | | | | |
| I-132 | INITIAL | 0 000E+00 | 0 000E+00 | 2 400E+03 | 1 866E+04 | 2 399E+03 | 0 000E+00 | 0 000E+00 | 5 969E+02 |
| I-132 | TOTALS | | | | | | | | |
| I-133 | INITIAL | 0 000E+00 | 0 000E+00 | 1 160E+03 | 9 027E+03 | 1 160E+03 | 0 000E+00 | 0 000E+00 | 5 149E+02 |
| I-133 | TOTALS | | | | | | | | |
| I-134 | INITIAL | 0 000E+00 | 0 000E+00 | 5 360E+02 | 4 164E+03 | 5 351E+02 | 0 000E+00 | 0 000E+00 | 7 096E+01 |
| I-134 | TOTALS | | | | | | | | |
| I-135 | INITIAL | 0 000E+00 | 0 000E+00 | 5 210E+03 | 4 054E+04 | 5 209E+03 | 0 000E+00 | 0 000E+00 | 1 920E+03 |
| I-135 | TOTALS | | | | | | | | |

Duquesne
Light
Health Physics Department

ERS-APO-9L035


ATTACHMENT 3

Page 45 of 56

TRAITS -- Transport of Radioactive Material in Linear Systems: v1.1
4 18% F F 350s-S Initial Steam Release

NOT USED IN THIS CAS
CURRENT INTEGRD
uCi/sec
0 000E+00

STEP TIME
ALL NUCLIDES
@ STEP 10



ERS-APO-9L-035
ATTACHMENT

Page 46 of 56

| STEP | TIME | ALL NUCLIDES | AVERAGE | | RELEASE | | CURRENT | | CONTINUOUS | | INTEGRD |
|------|------|--------------|-----------|-----------|---------|---------|---------|---------|------------|---------|-----------|
| | | | RELEASED | RELEASE | uCi | uCi/sec | uCi | uCi/sec | | | |
| @ | STEP | 10 | 0 000E+00 | 0 000E+00 | 0 | 000E+00 | 0 | 000E+00 | 0 | 000E+00 | 0 000E+00 |

TRAILS - Transport of Radioactive Material in Linear Systems, v11
4 18% F F 3SGS-S Initial Steam Release

| | PHOTON-SURFG DOSE mrem | BETA-SURFG DOSE mrem/hr | THYR-1D-INHAL DOSE RATE mrem mrem/hr | PHOTON-SURFG DOSE RATE mrem mrem/hr | THYR-1D-INHAL DOSE RATE mrem mrem/hr | PHOTON-SURFG DOSE RATE mrem mrem/hr | THYR-1D-INHAL DOSE RATE mrem mrem/hr |
|-------------------|------------------------------|-------------------------------|---|--|---|--|---|
| KR-83m TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| KR-85m TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| KR-85 TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| KR-87 TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| KR-88 TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| KR-89 TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| XE-131H TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| XE-133H TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| XE-133 TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| XE-135H TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| XE-135 TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| XE-137/ TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| XE-138 TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| I-131 TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| I-132 TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| I-133 TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |
| I-134 TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |


Duquesne
Light
Health Physics Department

ERS-AFO-91-035
ATTACHMENT 3

Page 47 of 56

TRANSPORT OF RADIOACTIVE MATERIAL IN LINEAR SYSTEMS. VI
A 182 FF 350-S Initial Steam Release

| ENVIRONMENT | | | | | | CONTINUATION | | | | | |
|------------------|------------------|------------------|------------------|------------------|------------|--------------|------------|------------|------------|------------|------------|
| PHOTON-SUBHC | BETA-SUBHC | THYROID-131I | PHOTON-SUBHC | BETA-SUBHC | DISP. RATE | DISP. RATE | DISP. RATE | DISP. RATE | DISP. RATE | DISP. RATE | DISP. RATE |
| DOSE mRads/hr | DOSE mRads/hr | DOSE mRads/hr | DOSE mRads/hr | DOSE mRads/hr | hr/min | min/hr | min/hr | min/hr | min/hr | min/hr | min/hr |
| 1-135 | | | | | | | | | | | |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 7.80E-05 | 3.34E-05 | 1.70E-05 | 1.70E-05 | 1.70E-05 | 1.70E-05 | 1.70E-05 |
| ALL NUCLIDES | | | | | | | | | | | |
| 0.5000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.66E-06 | 6.43E-06 | 1.06E-05 | 4.11E-05 | 3.08E-02 | 1.21E-01 | 1.21E-01 |
| 1.5000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 5.24E-06 | 4.28E-06 | 3.42E-05 | 3.84E-05 | 1.07E-01 | 9.41E-02 | 9.41E-02 |
| 2.0000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.92E-06 | 3.48E-06 | 1.30E-05 | 2.38E-05 | 4.42E-02 | 8.29E-02 | 8.29E-02 |
| 2.5000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.58E-06 | 2.87E-06 | 1.10E-05 | 2.01E-05 | 3.89E-02 | 7.30E-02 | 7.30E-02 |
| 4.0000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 3.31E-06 | 1.64E-06 | 2.39E-05 | 1.24E-05 | 9.11E-02 | 5.09E-02 | 5.09E-02 |
| 8.0000 h | 0.00E+00 | 0.00E+00 | 3.00E+00 | 0.00E+00 | 3.62E-04 | 4.75E-04 | 2.89E-05 | 3.80E-05 | 1.25E-01 | 1.83E-02 | 1.83E-02 |
| 16.0000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 6.08E-08 | 1.35E-08 | 2.10E-07 | 2.10E-07 | 2.58E-03 | 5.90E-04 | 5.90E-04 |
| 24.0000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 5.73E-10 | 5.65E-07 | 5.77E-09 | 3.08E-03 | 3.68E-05 | 3.68E-05 |
| 9.6.0000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 2.48E-09 | 1.14E-08 | 1.40E-14 | 2.07E-04 | 1.05E-10 | 1.05E-10 |
| 17.20.0000 h | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 8.28E-14 | 0.00E+00 | 5.93E-10 | 0.00E+00 | 0.00E+00 |
| TOTALS | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 | 1.74E-05 | 1.23E-04 | 4.44E-01 | 4.44E-01 | 4.44E-01 | 4.44E-01 | 4.44E-01 |



Page 48 of 56

CDFP: NOT USED IN THIS CASE

COMP: VOB UPN: Control No:

Q

COMP: VOB UPN: 1. 730E+05 Cu Ft

| INITIAL | CDFP | 3 SCs Init | Sec Liq | VOL UPN | COMP | Control No: |
|-------------------|-------------------|------------|---------|-------------------|-------------------|-------------|
| 0.000E+00 KR-B3m | 0.000E+00 KR-B3m | Ci | | 0.000E+00 KR-B3m | 0.000E+00 KR-B3m | |
| 0.000E+00 KR-B5m | 0.000E+00 KR-B5m | | | 0.000E+00 KR-B5m | 0.000E+00 KR-B5m | |
| 0.000E+00 KR-B5 | 0.000E+00 KR-B5 | | | 0.000E+00 KR-B5 | 0.000E+00 KR-B5 | |
| 0.000E+00 KR-B7 | 0.000E+00 KR-B7 | | | 0.000E+00 KR-B7 | 0.000E+00 KR-B7 | |
| 0.000E+00 KR-BB | 0.000E+00 KR-BB | | | 0.000E+00 KR-BB | 0.000E+00 KR-BB | |
| 0.000E+00 KR-B9 | 0.000E+00 KR-B9 | | | 0.000E+00 KR-B9 | 0.000E+00 KR-B9 | |
| 0.000E+00 KR-90 | 0.000E+00 KR-90 | | | 0.000E+00 KR-90 | 0.000E+00 KR-90 | |
| 0.700E+00 XE-131m | 0.700E+00 XE-131m | | | 0.000E+00 AE-131m | 0.000E+00 AE-131m | |
| 0.000E+00 XE-132m | 0.000E+00 XE-132m | | | 0.000E+00 XE-132m | 0.000E+00 XE-132m | |
| 0.000E+00 XE-133 | 0.000E+00 XE-133 | | | 0.000E+00 XE-133 | 0.000E+00 XE-133 | |
| 0.000E+00 XE-133m | 0.000E+00 XE-133m | | | 0.000E+00 XE-133m | 0.000E+00 XE-133m | |
| 0.000E+00 XE-135 | 0.000E+00 XE-135 | | | 0.000E+00 XE-135 | 0.000E+00 XE-135 | |
| 0.000E+00 XE-137 | 0.000E+00 XE-137 | | | 0.000E+00 XE-137 | 0.000E+00 XE-137 | |
| 0.000E+00 XE-138 | 0.000E+00 XE-138 | | | 0.000E+00 XE-138 | 0.000E+00 XE-138 | |
| 0.000E+00 I-131 | 0.000E+00 I-131 | | | 7.280E+00 I-131 | 0.000E+00 I-131 | |
| 0.000E+00 I-132 | 0.000E+00 I-132 | | | 2.740E+00 I-132 | 0.000E+00 I-132 | |
| 0.000E+00 I-133 | 0.000E+00 I-133 | | | 1.330E+01 I-133 | 0.000E+00 I-133 | |
| 0.000E+00 I-134 | 0.000E+00 I-134 | | | 6.120E-02 I-134 | 0.000E+00 I-134 | |
| 0.000E+00 I-135 | 0.000E+00 I-135 | | | 5.980E+00 I-135 | 0.000E+00 I-135 | |
| 1.000E+00 | 1.000E+00 | | | 1.000E+00 | 1.000E+00 | |

PRODUCTION: uCi/s:

| | | | | | | |
|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|--|
| 0.000E+00 KR-B3m | |
| 0.000E+00 KR-B5m | |
| 0.000E+00 KR-B5 | |
| 0.000E+00 KR-97 | |
| 0.000E+00 KR-BB | |
| 0.000E+00 KR-B9 | |
| 0.000E+00 KR-90 | |
| 0.000E+00 XE-131m | |
| 0.000E+00 XE-132m | |
| 0.000E+00 XE-133 | |
| 0.000E+00 XE-135m | |
| 0.000E+00 XE-135 | |
| 0.000E+00 XE-137 | |
| 0.000E+00 XE-138 | |
| 0.000E+00 I-131 | |
| 0.000E+00 I-132 | |
| 0.000E+00 I-133 | |
| 0.000E+00 I-134 | |
| 0.000E+00 I-135 | |

REMOVAL:
NUC 1-14 REL FR
NUC 15-20 REL FR

2. 069E-06 1/sec
0.000E+00
0.000E+00

INTAKE REDUCT:
0.000E+00
0.000E+00

ATTACHMENT 3
Page 49 of 56

INTAKE FILTER:
0.000E+00
0.000E+00

INTAKE CFI:
0.000E+00
0.000E+00

MULTIPLIERS>


| STEP | TIME | XPR | XREM | XRF | XPR | XREM | XRF | XPR | XREM | XRF | XPR | XREM | XRF |
|------|------------|-----------|------|-----------|-----------|------|-----------|-----------|------|-----------|-----------|-----------|-----------|
| 1 | 1.800E+03 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 50.0 | 50.0 | 0.000E+00 |
| 2 | 5.400E+03 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 70.0 | 70.0 | 0.000E+00 |
| 3 | 7.200E+03 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 70.0 | 70.0 | 1.00 |
| 4 | 9.000E+03 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 70.0 | 70.0 | 1.00 |
| 5 | 1.440E+04 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 70.0 | 70.0 | 1.00 |
| 6 | 2.880E+04 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 70.0 | 70.0 | 1.00 |
| 7 | 3.060E+04 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 1.980E+03 | 1.980E+03 | 0.000E+00 |
| 8 | 8.640E+04 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 50.0 | 50.0 | 0.000E+00 |
| 9 | 3.4560E+05 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 50.0 | 50.0 | 0.000E+00 |
| 10 | 2.5920E+06 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 0.000E+00 | 1.00 | 0.000E+00 | 50.0 | 50.0 | 0.000E+00 |

MULTIPLIERS>

| STEP | TIME | X/G | Breathing Occupancy | X/G | Breathing | X/G | Breathing | X/G | Breathing | X/G | Breathing | X/G | Breathing |
|------|------------|-----|---------------------|------|-----------|-----|-----------|-----|-----------|------|-----------|-----|-----------|
| 1 | 1.800E+03 | 1 | 3.90E-04 | 1.00 | 1.00 | 0 | 0.000E+00 | 0 | 0.000E+00 | 1.00 | 1.00 | 0 | 0.000E+00 |
| 2 | 5.400E+03 | 1 | 5.90E-04 | 1.00 | 1.00 | 0 | 0.000E+00 | 0 | 0.000E+00 | 1.00 | 1.00 | 0 | 0.000E+00 |
| 3 | 7.200E+03 | 1 | 5.90E-04 | 1.00 | 1.00 | 1 | 0.000E+00 | 0 | 0.000E+00 | 1.00 | 1.00 | 0 | 0.000E+00 |
| 4 | 9.000E+03 | 1 | 5.90E-04 | 1.00 | 1.00 | 1 | 0.000E+00 | 0 | 0.000E+00 | 1.00 | 1.00 | 0 | 0.000E+00 |
| 5 | 1.440E+04 | 1 | 5.90E-04 | 1.00 | 1.00 | 1 | 0.000E+00 | 0 | 0.000E+00 | 1.00 | 1.00 | 0 | 0.000E+00 |
| 6 | 2.880E+04 | 1 | 5.90E-04 | 1.00 | 1.00 | 1 | 0.000E+00 | 0 | 0.000E+00 | 1.00 | 1.00 | 0 | 0.000E+00 |
| 7 | 3.060E+04 | 1 | 5.90E-04 | 1.00 | 1.00 | 1 | 0.000E+00 | 0 | 0.000E+00 | 1.00 | 1.00 | 0 | 0.000E+00 |
| 8 | 8.640E+04 | 1 | 5.90E-04 | 1.00 | 1.00 | 1 | 0.000E+00 | 0 | 0.000E+00 | 1.00 | 1.00 | 0 | 0.000E+00 |
| 9 | 3.4560E+05 | 1 | 5.90E-04 | 1.00 | 1.00 | 1 | 0.000E+00 | 0 | 0.000E+00 | 1.00 | 1.00 | 0 | 0.000E+00 |
| 10 | 2.5920E+06 | 1 | 5.90E-04 | 1.00 | 1.00 | 1 | 0.000E+00 | 0 | 0.000E+00 | 1.00 | 1.00 | 0 | 0.000E+00 |

TRAITS -- Transport of Radioactive Material in Linear Systems. v1.1
 3 18% F F 350s-8 Initial Secondary Liquid Iodines

| NOT USED IN THIS CAS | | | | 3 50s Init Sec Liq | | | | AVERAGE | | | | CONTROL ROOM | | | |
|----------------------|---------|-----------|-----------|--------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|--------------|-----------|-----|-----------|
| STEP | TIME | CURRENT | INTEGRAL | CURRENT | INTEGRAL | RELEASED | RELEASE | CURRENT | CURRENT | INTEGRAL | INTEGRAL | uC1 | uC1 | uC1 | uC1 |
| | | uC1 | uC1 - sec | uC1 | uC1 - sec | uC1 | uC1 / sec | uC1 | uC1 | uC1 | uC1 | uC1 - sec | uC1 - sec | uC1 | uC1 - sec |
| i-131 | INITIAL | 0.000E+00 | 0.000E+00 | 9.280E+06 | 8.253E+12 | 3.723E+05 | | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.460E+04 | | | |
| i-131 | TOTALS | | | | | | | | | | | | | | |
| i-132 | INITIAL | 0.000E+00 | 0.000E+00 | 2.740E+06 | 3.213E+10 | 4.848E+04 | | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.876E+03 | | | |
| i-132 | TOTALS | | | | | | | | | | | | | | |
| i-133 | INITIAL | 0.000E+00 | 0.000E+00 | 1.330E+07 | 1.383E+12 | 4.824E+05 | | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 3.141E+04 | | | |
| i-133 | TOTALS | | | | | | | | | | | | | | |
| i-134 | INITIAL | 0.000E+00 | 0.000E+00 | 6.120E+04 | 2.763E+08 | 5.241E+02 | | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 2.691E+01 | | | |
| i-134 | TOTALS | | | | | | | | | | | | | | |
| i-135 | INITIAL | 0.000E+00 | 0.000E+00 | 5.950E+06 | 1.983E+11 | 1.722E+05 | | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 1.091E+04 | | | |
| i-135 | TOTALS | | | | | | | | | | | | | | |
| ALL NUCLIDES | | 0.000E+00 | | 6.703E+05 | | | | | | | | | | | |
| • STEP | 10 | | | | | | | | | | | | | | |




ERS-APO-9L-035

ATTACHMENT 3

Page 51 of 56

TRAILS -- Transport of Radioactive Material in Linear Systems: v1
S 10% F 350-S Initial Secondary Liquid Iodines





Duquesne
Light

Health Physics Department

ERS-MPD-91-035

ATTACHMENT 4

Page 53 of 56



1000 E. 44th Street, Philadelphia, PA 19125
1001 COPPER RIDGE
P.O. BOX 6612
PHILADELPHIA, PA 19161-6612
215-785-4462
FAX: 215-785-4460

ARP-91-444
October 8, 1991

Mr. Steve La Vie
Duquesne Light Company
Beaver Valley Power Station
P. O. Box 4
Shippingport, PA 15077

Subject: Control Room X/Q Values for BVPS

References:

- 1) HALLIBURTON NUS Proposal No. PS808127
- 2) Duquesne Light Company Purchase Order No. D068239
- 3) Telecon From S. La Vie to M. Septoff August 9, 1991
- 4) Letter from J. Ramsdell to M. Septoff August 15, 1991

Dear Steve:

This letter presents the X/Q values suitable for design basis accident releases from selected plant vents to the BVPS common control room intake. The methodology used is presented by Ramsdell in NUREG/CR-5055 as modified by NUREG/CP-0116, by discussions with Ramsdell in September 1991 (Reference 4) and a paper presented in Atmospheric Environment, Volume 24B, No. 3, pp 377-388, 1990. The work was performed in accordance with the description contained in Reference 3 as approved by reference 2. It is noted that all work was performed using approved project procedures in accordance with the HALLIBURTON NUS ESD Quality Assurance Manual, Revision 6.

Tables 1 and 2 presents the X/Q values for the selected plant vents for Unit 1 and Unit 2, respectively, for averaging periods of 0-8 hours, 8-24 hours, 1-4 days, and 4-30 days. The release points, distances and directions to the common control room intake, and building cross sectional areas were those provided in an analysis performed by Stone and Webster Corporation using the Murphy and Campe methodology. Duquesne Light Company provided this information to us on September 6, 1991. Five years of meteorological data for the period January 1986 through December 1990 were used. Results of the Murphy and Campe methodology are also presented in the tables for comparison. It is seen that, for the 0-8 hr averaging period reductions in X/Q values as compared to those obtained using the Murphy and Campe methodology range from a factor of 2 to over an order of magnitude.



Duquesne
Light

Health Physics Department

ERS-MPD-91-035

ATTACHMENT 4

Page 54 of 56

Mr. Steve La Vie
ARP-91-444
October 8, 1991
Page 2

A report describing the methodology and results with a comparison with the Murphy and Campe methodology suitable for presentation to the NRC will be prepared. The computer code and its documentation will be provided with the report. Further, as we discussed, a scientific paper could also be prepared suitable for presentation at a DOE/NRC Nuclear Air Cleaning Conference.


As part of HALLIBURTON NUS Quality Assurance procedures a Division Quality Assurance Review Board (DQARB) was convened to review the technical and quality aspects of the analysis. The results of the DQARB indicate that (1) the documentation for the computer code generated for the analysis should be revised to provide additional information related to code identification and its use, and (2) the need to clarify the relationship between the test cases and the hand calculations used to verify the correct operation of the code. Therefore, the results provided in the tables should be considered as preliminary until the DQARB approves the documentation, receives the clarification, and completes its review. It is expected that this will be completed early next week.

If you have any questions please call me.

Sincerely,

Michael Septoff
Project Manager

Enclosures
cc: A. Toblin
W. McIntire

Duquesne
Light

Health Physics Department

ERS-MPD-91-035


ATTACHMENT 4

Page 55 of 56

TABLE 1 DESIGN BASIS ACCIDENT X/Q VALUES (sec/m³) FOR SELECTED BVPS PLANT VENTS TO THE COMMON CONTROL ROOM INTAKE - UNIT 1

Release Point Methodology 0-8 hr 8-24 hr 1-4 day 4-30 day

| Containment Edge | Ramsdell | 4.33E-4 | 2.04E-4 | 1.46E-4 | 8.84E-5 |
|-------------------------|--------------|---------|---------|---------|---------|
| Containment Top | Murphy-Campe | 2.88E-3 | 1.90E-3 | 6.52E-4 | 1.41E-4 |
| Auxiliary Building | Ramsdell | 2.73E-4 | 1.28E-4 | 9.17E-5 | 5.57E-5 |
| Main Steamvalve | Ramsdell | 4.30E-3 | 2.01E-3 | 1.49E-3 | 9.25E-4 |
| | Murphy-Campe | 8.24E-3 | 6.01E-3 | 2.32E-3 | 6.18E-4 |
| Service Building | Ramsdell | 7.60E-4 | 3.51E-4 | 2.59E-4 | 1.58E-4 |
| | Murphy-Campe | 2.97E-3 | 1.94E-3 | 6.92E-4 | 1.54E-4 |
| Turbine Building | Ramsdell | 6.25E-4 | 3.04E-4 | 2.36E-4 | 1.57E-4 |
| | Murphy-Campe | 7.47E-3 | 5.09E-3 | 1.88E-3 | 4.93E-4 |
| Gas Waste Storage Vault | Ramsdell | 2.43E-3 | 1.22E-3 | 8.90E-4 | 6.26E-4 |
| | Murphy-Campe | 7.81E-3 | 5.55E-3 | 2.11E-3 | 7.11E-4 |
| Gas Waste Storage Vault | Ramsdell | 5.11E-4 | 2.15E-4 | 1.65E-4 | 1.14E-4 |
| | Murphy-Campe | 2.03E-2 | 1.51E-2 | 5.99E-3 | 1.32E-3 |



Health Physics Department

ERS-MPO-91-035

ATTACHMENT 4

Page 56 of 56

TABLE 2 DESIGN BASIS ACCIDENT X/Q VALUES (sec/m³) FOR SELECTED BVPS PLANT VENTS TO THE COMMON CONTROL ROOM INTAKE - UNIT 2

Release Point Methodology 0-8 hr 8-24 hr 1-4 day 4-30 day

| Containment Edge | Ramsdell | 1.88E-4 | 9.32E-5 | 7.06E-5 | 4.18E-5 |
|-------------------------|--------------|---------|---------|---------|---------|
| Containment Top | Murphy-Campe | 4.16E-3 | 2.81E-3 | 1.09E-3 | 1.58E-4 |
| Auxiliary Building | Ramsdell | 1.04E-3 | 5.15E-4 | 4.04E-4 | 2.46E-4 |
| Main Steamvalve | Murphy-Campe | 1.33E-2 | 9.30E-3 | 3.94E-3 | 1.20E-3 |
| Service Building | Ramsdell | 1.59E-4 | 7.86E-5 | 5.96E-5 | 3.76E-5 |
| Turbine Building | Murphy-Campe | 7.75E-3 | 5.63E-3 | 1.99E-3 | 3.26E-4 |
| Gas Waste Storage Vault | Ramsdell | 2.21E-4 | 1.11E-4 | 8.51E-5 | 5.17E-5 |
| | Murphy-Campe | 5.42E-3 | 3.62E-3 | 1.43E-3 | 3.31E-4 |
| | Ramsdell | 2.72E-4 | 1.43E-4 | 1.10E-4 | 6.30E-5 |
| | Murphy-Campe | 6.46E-3 | 4.90E-3 | 2.00E-3 | 5.75E-4 |
| | Ramsdell | 1.74E-3 | 9.06E-4 | 7.69E-4 | 5.55E-4 |
| | Murphy-Campe | 1.23E-1 | 1.04E-1 | 5.08E-2 | 2.00E-2 |

ATTACHMENT B

Beaver Valley Power Station, Unit No.2

Additional Information - Proposed Technical Specification Change No. 57



Information copy of the UFSAR changes
to address the radiological
consequences of a locked rotor accident

of a HEPA filter and carbon adsorber with effective iodine removal efficiency of 95 percent. These emergency supply filtration units and associated air handling equipment are designed to Seismic Category 1 and Safety Class 3 requirements.

A control room air manifold system which consists of flexible hose connections to air storage bottles is provided to ensure chlorine-free air for up to six (6) hours. The manifold system is located within the common control room and is provided with sufficient lengths of flexible hoses to reach all vital areas of the common control room.

In addition, a sufficient quantity of portable self-contained breathing apparatus and protective clothing are provided for the operators who are located in the control room. This equipment is located in the locker rooms near the control room.

The evaluation of radiation exposure to personnel in the main control room envelope examined the contribution from the four LOCA sources defined in Section 6.4.2.5. In addition, the inhalation dose from inleakage into the main control room of radionuclides in the external cloud was also examined for each of the DBAs considered in Chapter 15. Dose calculations are based on the source terms and pertinent parameters defined in Chapter 15 for each DBA, the flux-to-dose conversion factors given in Table 6.4-2 and the appropriate inhalation dose conversion factors described in TID 14844 by Di Nunno (et al 1962).

The limiting design basis accident for the main control room personnel whole body gamma and beta skin dose is the LOCA. The small line break outside containment (SLB) is the limiting DBA for the thyroid dose.

Exposure from inhalation is principally attributable to airborne radioactivity in the main control room envelope due to:

1. Intake prior to main control room isolation,
2. Inleakage during main control room isolation, or
3. Post-isolation ventilation intake.

The CIB signal isolates the control room almost immediately after a LOCA. For DBAs that do not cause a CIB signal, control room isolation is initiated by a high radiation signal from redundant Category 1 area monitors centrally located in the BVPS-2 control room except for the main steamline break (MSLB) which does not initiate a high radiation signal. For the MSLB, manual operator action by t=30 min post-accident is needed to maintain habitability.

*AND THE LOCKED Room
ACCIDENT (LRA)*

The analyses considers a conservative selection of parameters to calculate the thyroid dose. Ventilation intake prior to control room

AND THE LOCKED Room ACCIDENT

AND THE LOCKED ROOM ACCIDENT (LAH)

isolation and an assumed 10 cfm unfiltered inleakage are the main contributors to the thyroid dose. The maximum normal ventilation intake rate of 500 cfm (for both BVPS-1 and BVPS-2 intakes) prior to isolation and an minimum clean up rate of 690 cfm post-isolation are used to maximize the dose estimate. The post-isolation clean-up rate is based on BVPS-1 control room pressurization test data adjusted for the combined control room volume. The analysis also assumes coincident loss of offsite power.

For Condition IV DBAs which do not initiate a CIB signal, the accident duration is 8 hours (except for the fuel handling accident (FHA) for which releases are assumed to continue over a 30-day period). Control room doses for those DBAs that do not initiate a CIB signal (except for the FHA) are therefore based on purging the control room 8 hours after accident initiation.

The information and data required to develop the radiological consequences for the main control room are presented in the respective sections describing the design basis accident analysis.

The main control room dose presented in Table 15.0-13 has been calculated to be less than the limit specified in General Design Criterion 19 and the main control room may, therefore, be safely occupied during any condition of operation.

5.4.4.7 Toxic Gas Protection

The main control room design provides protection of the personnel in the main control room from any toxic effects from spills of chemicals stored onsite. The effects of spills of chemicals along transportation routes are evaluated in Section 2.2.3.

In the event of a toxic gas release, main control room habitability is maintained by isolating the air intake, recirculating air conditioned air, and by maintaining a positive pressure using compressed air for 1 hour, after which, the main control room will remain isolated for the duration of the accident.

Redundant, sensitive, and automatic Seismic Category I detection and isolation equipment is provided for the detection of chlorine gas.

The storage areas of toxic gases and chemicals that could produce toxic gases are shown in Table 6.4-3 and on Figure 6.4-5.

6.4.5 Inspection and Testing Requirements

The major items of equipment that maintain the habitability of the main control room are the emergency supply filtration units, their fans,

— 6-4-8a —

- Proposed -

15.0.9.2 Activities in the Fuel Pellet Clad Gap

For accident analysis, the core gap activities are based on the guidance provided in Regulatory Guides 1.25 and 1.77. The noble gas and iodine inventory in the fuel gap region is assumed to be 10 percent (30 percent for Kr-85 and 12 percent for I-131 for the fuel handling accident²) of the core inventory. The values are presented in Table 15.0-7.

AND THE LOCKED ROTOR ACCIDENT

15.0-11a

- PROPOSED -

the environment resulting from each accident are presented in the respective sections.

Accident atmospheric dispersion coefficients (X/Q) for the exclusion area boundary and low population zone were used to calculate the potential offsite doses. The 0.5 percent sector-dependent X/Q values, presented in Table 15.0-11, were determined as described in Section 2.3.4. Main control room X/Q values for the LOCA are also given in Table 15.0-11.

The atmospheric releases given in each accident section are used in conjunction with the appropriate X/Q values of Table 15.0-11 to calculate the potential offsite doses for the corresponding accidents and the potential control room dose due to a LOCA. The methodology for determining the doses is discussed in Appendix 15A. The resulting EAB and LPZ doses are presented in Table 15.0-12 for all postulated accidents. The potential dose to main control room personnel due to a LOCA is presented in Table 15.0-13.

For all cases the potential offsite doses are within the limits of 10 CFR 100, while the potential doses for the main control room due to a LOCA are within the limits of GDC 19 of Appendix A to 10 CFR 50.

15.0.13 References for Section 15.0

Bordelon F.M. et al 1974a. SATAN-VI Program: Comprehensive Space Time Dependent Analysis of Loss-of-Coolant. WCAP-8302 (Proprietary) and WCAP-8306.

Bordelon F.M. et al 1974b. LOCTA-IV Program: Loss-of-Coolant Transient Analysis. WCAP-8305.

Burnett, T.W.T. et al 1972. LOFTRAN Code Description. WCAP-7907, June 1972. (Also supplementary information in letter from T.M. Anderson, NS-TMS-1802, May 26, 1978 and NS-TMS-1824, June 16, 1978.)

Hunin C. 1972. FACTRAN, A FORTRAN IV Code Thermal Transients in a UO_2 Fuel Rod. WCAP-7908.

Risher, Jr. D.H. and Barry R.F. 1975. TWINKLE - A Multi-Dimensional Neutron Kinetics Computer Code. WCAP-7979-P-A (Proprietary) and WCAP-8028-A, (Non-Proprietary).

U.S. Nuclear Regulatory Commission (USNRC) 1972. Assumptions Used for Evaluating the Potentia's Radiological Consequence of a Fuel Handling Accident in the Fuel Handling and Storage Facility for Boiling and Pressurized Water Reactors. Safety Guide 25.

USNRC 1974. Assumption Used for Evaluating a Control Rod Ejection Accident for Pressurized Water Reactors. Regulatory Guide 1.77.

(A) *INSERT
(ATTACHED)*

-15.0-15-

- PROPOSED -

PROPOSED INSERT FOR PAGE 150-15 REFERENCE
SECTION

DURANKO, M.P. 1991. OFFSITE DOSE CONSEQUENCES
OF A LOCKED REACTOR ACCIDENT AT UNIT 2 WITH 17%
FAILED FUEL, ERS-MPO-91-022.

DURANKO, M.P. 1991. ASSESSMENT OF THE DOSES IN
THE UNIT 2 CONTROL ROOM DUE TO A LOCKED REACTOR
ACCIDENT AT UNIT 2 ASSUMING 18% FAILED
FUEL.

-PROPOSED-

TABLE 15.0-12
POTENTIAL DOSES DUE TO POSTULATED ACCIDENTS
(Rem)

| Postulated Accident | FSAR Section | Exclusion Area Boundary | | | Low Population Zone* | | |
|--|--------------|----------------------------------|--|--|--|--|--|
| | | Thyroid | Whole Body Gamma | Beta Skin | Ithyroid | Whole Body Gamma | Beta Skin |
| Main steam line break | 15.1.5 | 10.5 | 1.2×10^{-2} | 4.6×10^{-3} | 1.5 | 1.4×10^{-3} | 1×10^{-4} |
| Pre-accident Iodine spike | | 9.1 | 2.2×10^{-2} | 6.7×10^{-3} | 3.2 | 6.8×10^{-3} | 2.2×10^{-3} |
| Concurrent Iodine spike | | | | | | | |
| Loss of nonemergency ac power to the station auxiliaries | 15.2.6 | 1.5×10^{-1} | 5.2×10^{-4} | 4.1×10^{-4} | 2.1×10^{-2} | 6.5×10^{-5} | 6.8×10^{-5} |
| Locked rotor | 15.3.3 | $3.25 E+1$ | 3.41 | 2.09 | $1.44 E+1$ | $3.48 E-1$ | $2.17 E-1$ |
| | | $2.64 E-1$ | 2.8×10^{-4} | 5.2×10^{-4} | 1.7×10^{-1} | 4.8×10^{-4} | 1.7×10^{-4} |
| Rod ejection | 15.4.8 | | | | | | |
| Containment leakage | | 8.1×10^1 | 1.9×10^{-1} | 6.5×10^{-2} | 2.0 | 9.2×10^{-3} | 3.2×10^{-3} |
| Secondary side | | 2.2×10^{-1} | 5.1×10^{-1} | 3.7×10^{-1} | 1.1×10^{-2} | 2.5×10^{-2} | 1.8×10^{-2} |
| Small line break - loss-of-coolant | 15.6.2 | 1.6×10^1 | 7.0×10^{-2} | 2.4×10^{-2} | 8.2×10^{-1} | 3.4×10^{-3} | 1.2×10^{-3} |
| Steam generator tube rupture | 15.6.3 | | | | | | |
| Pre-accident Iodine spike | | 11.7 | 6.8×10^{-2} | 5.2×10^{-2} | 1.0 | 3.6×10^{-3} | 2.7×10^{-3} |
| Concurrent Iodine spike | | 6.0 | 7.3×10^{-2} | 5.2×10^{-2} | 1.0 | 4.6×10^{-3} | 3.0×10^{-3} |
| Loss-of-coolant | 15.6.5 | | | | | | |
| Containment leakage | | 2.7×10^2 | 5.3 | 2.5 | 1.3×10^1 | 2.6×10^{-1} | 1.2×10^{-1} |
| ECCS leakage | | 8.3×10^{-1} | 1.3×10^{-2} | 5.1×10^{-3} | 6.3×10^{-1} | 1.2×10^{-2} | 1.1×10^{-2} |
| Waste gas system rupture | 15.7.1 | - | 3.1×10^{-1} | 1.9×10^{-1} | | | |
| Line rupture | | - | 1.6×10^{-1} | 1.5 | | | |
| Tank rupture | | | | | | | |
| Fuel handling | 15.7.4 | 2.9×10^1 | 2.33 | 6.58 | 1.4 | 1.1×10^{-1} | 3.2×10^{-1} |

NOTE:

*For duration of accident

2. Locked Rotor with Two Loops Operating

The transient results for this case are shown on Figure 15.3-21 through 15.3-24. The results of these calculations are also summarized in Table 15.3-2. The peak RCS pressure is slightly higher than for the previous case, but is still less than that which would cause stresses to exceed the faulted condition stress limits. The cladding temperature transient is still well below the 2,700°F limit.

3. Locked Rotor with Three Loops Operating, Loss of Power to the Remaining Pumps

The transient results for this case are shown on Figures 15.3-17 through 15.3-20. The results of these calculations are summarized in Table 15.3-2b. The peak RCS pressure reached during the transient is less than that which would cause stresses to exceed the faulted condition stress limits. Also, the peak cladding surface temperature is considerably less than 2,700°F. Both the peak RCS pressure and the peak cladding surface temperature for this case are similar to the 3-loop transient with power available as discussed on the previous page.

The calculated sequence of events for the three cases analyzed is shown in Table 15.3-1. Figures 15.3-17 and 15.3-21 show that the core flow reaches a new equilibrium value by 10 seconds. With the reactor tripped, a stable plant condition will eventually be attained. Normal plant shutdown may then proceed.

Following reactor trip, Beaver Valley Power Station - Unit 2 (BVPS-2) will approach a stabilized condition at hot standby; normal plant operating procedures may then be followed to maintain a hot condition or to cool the plant to cold shutdown. The operating procedures would call for operator action to control RCS boron concentration and pressurizer level using the CVCS, and to maintain steam generator level through control of the main feedwater system or AFWS. Any action required of the operator to maintain BVPS-2 in a stabilized condition will be in a time frame in excess of ten minutes following reactor trip.

15.3.3.3 Radiological Consequences

The radiological consequences of a postulated locked rotor accident are analyzed ~~with the primary and secondary coolant concentrations assumed to be at Technical Specification limits~~. The primary to secondary system leakage rate is at the Technical Specification value of 1 gpm. ~~No gaseous activity is assumed to be released into the primary coolant since there is no fuel failure postulated~~. The primary coolant and secondary side iodine and noble gas concentrations are presented in Table 15.0-8.

ASSUMING 18% FAILED FUEL

-15.3-10-

PRIOR TO THE START OF
THE ACCIDENT

- PROPOSED -

TABLE 15.3-3
PARAMETERS USED FOR THE LOCKED
ROTOR ACCIDENT

| <u>Parameter</u> | <u>Expected</u> | <u>Technical Specification</u> |
|--|-----------------|--------------------------------|
| Power (Mwt) | 2,766 | 2,766 |
| Fraction of fuel with defects <i>(PRIOR TO ACCIDENTS)</i> | 0.0012 | .0026 |
| Primary coolant concentrations <i>(PRIOR TO ACCIDENTS)</i> | Table 11.1-2 | Table 15.0-8 |
| Secondary coolant concentrations <i>(PRIOR TO ACCIDENT)</i> | Table 11.1-6 | Table 15.0-8 |
| Primary to secondary leak rate (gpm) | 0.009 | 1.0 |
| Iodine partition factor in all steam generators prior to and during the accident | 0.01 | 0.01 |
| Duration of plant cooldown by secondary system after accident (hr) | 8 | 8 |
| Steam release from steam generators (lb) | | |
| 0-2 hr | 443,878 | 443,878 |
| 2-8 hr | 793,664 | 793,664 |
| Feedwater flow to steam generators (lb) | | |
| 0-2 hr | 527,065 | 527,065 |
| 2-8 hr | 874,470 | 874,470 |
| Steam generator fluid content/SG (lb) | | |
| Liquid | 99,300 | 99,300 |
| Steam | 8,700 | 8,700 |
| Concurrent iodine spiking Release rates into primary coolant | Table 15.0-10 | Table 15.0-10 |
| Duration (hr) | 4 | 4 |

-1 of 1-

-Proposed-

TABLE 15.3-4

LOCKED ROTOR ACCIDENT RELEASES
TO THE ENVIRONMENT

| <u>Nuclide</u> | <u>Total Releases (Ci)</u> | | |
|----------------|----------------------------|----------------------|----------------------|
| | <u>0-2 Hr</u> | <u>0-8 Hr</u> | |
| Kr-83m | $3.60E+2$ | 3.7×10^{-2} | 6.7×10^{-2} |
| Kr-85m | $1.11E+3$ | 2.3×10^{-1} | 5.9×10^{-1} |
| Kr-85 | $8.88E+1$ | 1.3 | 5.3 |
| Kr-87 | $1.54E+3$ | 8.7×10^{-2} | 1.3×10^{-1} |
| Kr-88 | $2.86E+3$ | 3.0×10^{-1} | 6.6×10^{-2} |
| Kr-89 | $1.79E+2$ | 4.8×10^{-4} | 4.8×10^{-4} |
| Xe-131m | $1.80E+1$ | 1.3×10^{-2} | 5.1×10^{-2} |
| Xe-133m | $1.57E+2$ | 3.5×10^{-1} | 1.4 |
| Xe-133 | $6.82E+3$ | 3.1 | 1.2×10^1 |
| Xe-135m | $3.31E+2$ | 7.9×10^{-2} | 1.0 |
| Xe-135 | $1.63E+3$ | 3.7×10^{-1} | 2.2 |
| Xe-137 | $2.76E+2$ | 9.2×10^{-4} | 9.2×10^{-4} |
| Xe-138 | $1.02E+3$ | 1.5×10^{-2} | 1.5×10^{-2} |
| I-131 | $2.64E+1$ | 2.2×10^{-1} | 2.8 |
| I-132 | $2.13E+1$ | 3.3×10^{-1} | 4.3 |
| I-133 | $4.89E+1$ | 3.5×10^{-1} | 5.2 |
| I-134 | $2.16E+1$ | 9.1×10^{-3} | 5.3×10^{-3} |
| I-135 | $3.89E+1$ | 2.2×10^{-1} | 3.3 |

Proposed