

DEC 11 1984

Docket No. 50-271

Vermont Yankee Nuclear Power Corporation
ATTN: Mr. Warren P. Murphy
Vice President and Manager
of Operations
RD 5, Box 169
Ferry Road
Brattleboro, Vermont 05301

Gentlemen:

Subject: Inspection No. 50-271/84-11

This refers to your letter date September 24, 1984, in response to our letter dated August 17, 1984.

Thank you for informing us of the corrective and preventive actions documented in your letter. These actions will be examined during a future inspection of your licensed program.

We have reviewed your response to the violation pertaining to the installation of the high range containment monitoring channels (NUREG-0737, Item II.F.1-3) with the Office of Nuclear Reactor Regulation, Radiological Assessment Branch, and conclude that the installed system does not meet the specifications cited in NUREG-0737. This item will not be withdrawn. Please inform this office, within 20 days of the date of this letter, of your corrective actions in accordance with the instructions contained in the Notice of Violation.

Your cooperation with us is appreciated.

Sincerely,

Original Signed

8412170135 841211
PDR ADOCK 05000271
Q PDR

Thomas T. Martin, Director
Division of Engineering and
Technical Programs

cc w/encl:

Mr. R. W. Capstick, Licensing Engineer
Mr. W. F. Conway, President and Chief Executive Officer
Mr. J. P. Pelletier, Plant Manager
Mr. Donald Hunter, Vice President
Mr. Cort Richardson, Vermont Public
Interest Research Group, Inc.
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of New Hampshire
State of Vermont

OFFICIAL RECORD COPY

RL50-271/84-11 - 0001.0.0
10/09/84

IEA
1/0

bcc w/encl:
Region I Docket Room (with concurrences)
~~Senior Operations Officer (w/o encls)~~
Section Chief, DPRP

RI:DETR
J. White/sm
10/16/84

RI:DETP
M. Shanbaky
10/16/84

RI:DETP
R. Bellamy
10/16/84

OFFICIAL RECORD COPY

RL50-271/84-11 - 0002.0.0
10/09/84