SAFEGUARDS INFORMATION



MAY 2 0 1983

SGPR r/f Case file PStarcher DKers RDiggs DKasun

EOuinn

DISTRIBUTION: NMSS r/f

MEMORANDUM FOR: Cecil O. Thomas, Chief Standardization & Special Projects Branch Division of Licensing, NRR

FROM: George W. McCorkle, Chief Power Reactor SG Licensing Branch Division of Safeguards, NMSS

Ę

SUBJECT: CHANGES TO TECHNICAL SPECIFICATIONS REGARDING THE SURVEILLANCE FREQUENCY OF DIESEL GENERATOR DAY TANK VALVES - SALEM

As a result of the Safeguards Regulatory Effectiveness Review conducted at the Salem Nuclear Generating Station during December 3 through 10. 1982, a c cern regarding the frequency of surveillance of the diesel generator day tank valves arose.

In responding to the concerns the licensee indicated that an evaluation of the valve surveillance commitments revealed that the mispositioning of the day tank valves has no greater safety implications than would the improper positioning of several other valves which have the same monthly surveillance requirements. It is our understanding that the day tank valves are at least as significant us the diesel air start valves which are provided with daily surveillance.

It is requested that NRR review the attached Safeguards Regulatory Effectiveness Review Report relative to this issue and the licensee's response to determine whether or not changes to the technical specifications for surveillance of the day tank valves are warranted.

8412170181 840430 PDR FOIA SHOLLY83-531 PDI PDR

15

George W. McCorkle, Chief Power Reactor SG Licensing Branch Division of Safeguards, NMSS

Administrative and Criminal sanctions. Attachment:

Unauthorized disclosure subject to

As stated

SAFEGUARDS INFORMATION

OFFICE SURNAME DATE cc: J. Joyner, Region I

CONTACT.

When separated from enclosure(s) , handle this document as decontrolled (insert proper clossification) ALLEDO ANTODASATION

40 74000 -	Previous con		UKMAH	Н И	
SGPR SGPR SGPR DKaşun		SGPR			
5/18/83 5/6 283		5/1/83			USAPO: 1981-31:-54