

REPORT  
ON


CRANKSHAFT TORSIONAL STRESSES

TRANSAMERICA DELAVAL MODEL DSR-48

Serial No. 74010/12

for

LONG ISLAND LIGHTING COMPANY



Roland Yang.  
April 4, 1984  
Transamerica Delaval Inc.  
Oakland, CA.

8412170299 841001  
PDR ADOCK 05000322  
G PDR

TABLE OF CONTENTS

	Introduction	Pages i & ii
Section One	Torsional Analysis	Pages i to 17
Section Two	Torsiograph Tests	" 18 to 21
Section Three	Strain Gauge Tests (FaAA)	" to
Section Four	Operating Hours Logged	" to

## I N T R O D U C T I O N

This report consists of four sections and contains calculations, test data and operating experience, which Transamerica Delaval Inc. (TDI) considers relevant material to establish the adequacy of these DSR-48 engine generator sets.

The application of these units are for emergency standby service in the LILCO Shoreham Nuclear Power Plant. These units are rated at 3500 KW and have an overload rating of 3900 KW (111.4%) allowed two hours per day of twenty four hours.

### Section One. Torsional Analysis.

A four page introduction is included here, explaining the method and nomenclature used in the torsional critical speed analysis.

The mass elastic system in the analysis reflects the piston skirt which has since been superceded. The extra reciprocating weights due to the heavier replacement piston skirt have been evaluated and the change concluded to be negligible. The effect of the 111.4% overload on torsional stress levels are shown in pages 12 to 15. Due to the close proximity of the calculated stresses to the ABS allowable stress, we elected to include Section Two..

Also included in this section are mass elastic system parameters of other DSR-48 engine generators of identical rating, to establish the similarity of these units, especially from a torsional standpoint.

### Section Two. Torsiograph Tests.

Measurements by FaAA/SWEC and TDI are presented here , along with TDI measurements on other DSR-48 engine generators of identical rating and similar mass elastic system. Here again, the intent is to establish the similiarity between the various DSR-48 engine generators. The stresses evaluated from the torsiograph measurements are still in close proximity to the ABS allowable and therefore in Section Three, we present the actual strain gage measurements, taken on the subject shaft in January, 1984.

### Section Three. Strain Gage Test.

Here the measured strains are listed along with the corresponding stresses. With the similar grade of crankshaft material, the endurance limit of the shaft is established and finally the margin of safety

determined using the Goodman diagram. A factor of safety of the replacement crankshaft is 1.48 without the benefit of shot peening. The factor of safety is 1.75 as determined by FaAA, when the effect of shot peening is taken into account and taken to increase the endurance limit by 20%.

Section Four. Operating Hours Logged.

There are seventeen engine generator sets of similar configuration and identical rating in Saudi Arabia with considerable operating hours. These similar units are running regularly and generating power today. Worthy of note are the DSR-48 units at Rafha, with 5500 hours at 3200 KW on one unit and 6200 hours at 3300 KW and 8250 hours at 3200 KW for the other two. The similarity of these units are listed in page 17. Examination of the mass elastic data (I & K) and the torsional natural frequencies (N) listed, will show that there are no essential differences between LILCO and the rest of the units. The LILCO units are undergoing performance tests at their Shoreham Nuclear Power Station, the total hours logged at loads of 3500 KW and above, are shown on page 28.

Summary.

Based on the foregoing calculations, test data and operating logs, Transamerica Delaval, Inc. considers the adequacy of these DSR-48 engine generator sets to be established for the intended service at the LILCO Shoreham Nuclear Power Station.

## INTRODUCTION

### TO

## TORSIONAL CRITICAL SPEED ANALYSIS

The engine generator system is modeled as a system of moments of inertia interconnected by torsional springs.

The standard procedure is to concentrate all the moment of inertia of each crankthrow, including rod and piston at the corresponding cylinder center position. The moment of inertia per cylinder is obtained by summing the moment of inertias of the journal, crankpin, two crankwebs, counterweights (if used), rotating part of connecting rod and the equivalent inertia of the reciprocating parts, (namely the upper end weight of the rod and the piston).

The moment of inertia, (I) is calculated by dividing the  $WK^2$  by gravitational acceleration (g).  $WK^2$  is obtained by multiplying the weight of the part by the square of the radius of gyration (K).  $WK^2$  therefore, would be in Lb. In.<sup>2</sup> or Lb.Ft.<sup>2</sup> units and inertia (I) in Lb.In.Sec.<sup>2</sup> or Lb.Ft.Sec.<sup>2</sup> units. The inertia values, thus represent the concentrated inertia of the moving parts at each crankthrow.

From our torsional vibration analysis data files, we obtained the appropriate values of inertia or stiffness to make up the model.

The procedure and notations used in this analysis are explained below.

### NATURAL FREQUENCY EVALUATION

This is done by Holzer's method. In our Holzer's tabulation, the definition of the notations are as follows:

$\omega^2$ EIGENVALUE	(Omega squared), in $10^6$ radian/second <sup>2</sup>
NO.	Mass number, counted from the free end of the engine
INERTIA	Inertia of the various masses, in lb.in.sec. <sup>2</sup>
THETA	Relative amplitude or angular position, in radians.
IOM2T	Product of INERTIA * $\omega^2$ * THETA, and is the vibratory torque due to each mass, in $10^6$ ft.lb.
SIGNAM	Summation of the vibratory torques, in $10^6$ ft.lb.
SHAFTK	Torsional stiffness of shaft, in $10^6$ ft.lb/radian.
DTHETA	Quotient of SIGNAM divided by SHAFTK. This is the relative angular displacement between masses. The unit is radians.

STRESS EVALUATION

From the Holzer Tabulation, we determine the following, which are later used in the stress calculations.

SIGMA I \* THETA \*\* 2 This is the summation of the products of INERTIA and THETA squared. The first of the two printed, is that of the engine up to and including the last crankthrow and the second, that of the whole system.

T INT and T EXT These are the maximum stresses in the shafting within the engine (INTERNAL) and outside of the engine (EXTERNAL). The stresses are evaluated for each section of shafting by this formula:

$$\text{SIGNAM} * \frac{\pi}{180} * \frac{16}{\pi D^3}$$

Only the maximums are printed out.

STRESSED DIAMETER OF EXTERNAL SHAFT

This is the diameter of the external shaft at which the maximum stress occurs.

EQUILIBRIUM AMPLITUDE

If the applied and resisting torques are applied and suddenly removed, the shaft is put into a state of free vibration and the curve of angular displacement can be analyzed into a series of normal elastic curves, each corresponding to one of the normal modes of free vibration of which the system is capable. The amplitude of any of these modes of vibration under the above conditions is referred to as the EQUILIBRIUM AMPLITUDE, since it is the amplitude which is attained without any magnification due to resonance with an external pulsating couple. It is determined by:

$$\frac{\text{Piston Area} * \text{Crank Radius} * 180}{\omega^2 * 10^6 * \sum I \theta^2}$$

This is left in the form - - - Constant 1 \* T<sub>N</sub> \*  $\sum \theta_N$

F IN The work output into the system and is determined by:  
 \* Piston Area \* Crank Radius \*  $\phi$  \* T<sub>N</sub> \*  $\sum \theta_N$   
 This is left in the form - - - Constant 2 \* T<sub>N</sub> \*  $\sum \theta_N$

FE Hysteresis damping due to friction, etc. and is determined by:

$$\frac{\pi * \omega^2 * 10^6 * \sum I \phi^2 * \phi^2}{25}$$



FD Viscous Damper damping, from this expression:  

$$\frac{W^2 \text{ Damper Ring (lb.ft.}^2) * 12 \pi^3 * \left(\frac{180}{\pi}\right)^2 * 33000 * \pi * G^2}{G * 86700000 * 30 * \omega}$$

FCR Rubber coupling damping, and is determined by:  
 Coupling Stiffness \* (.00037(D-20) (D-30)) \* DTHETA of cplg<sup>2</sup>  
 D is the durometer of the coupling rubber.

FCS Steel coupling damping, and is determined by:  
 Damping coefficient \* DTHETA of coupling<sup>2</sup>

FF Propeller damping from this expression:  

$$\frac{1 * 12 * 1.82 * 10^6 * \omega^2 * 10^6 * \text{bhp} * \text{Gear Ratio} * \text{THETA of prop}}{\text{Harmonic} * \text{RPM}^3}$$

F INT Static Stress INTERNAL, which is the product of T INT and EQUILIBRIUM AMPLITUDE. This is left in the form -----  
 Constant 3 \* T<sub>N</sub> \* Σθ<sub>N</sub>

F EXT Static Stress EXTERNAL, which is the product of T EXT and EQUILIBRIUM AMPLITUDE. This is left in the form -----  
 Constant 4 \* T<sub>N</sub> \* Σθ<sub>N</sub>

Total damping is the sum of FE + FD + FCR + FCS + FF

In the stress calculation tabulation we have the following columns, some of which are calculated from the values previously determined.

- ORDER Harmonic of the mode of vibration.
- RPM Resonant speed of the harmonic, or critical speed.
- TN T<sub>N</sub>, which is the harmonic component determined from the Fourier Analysis of a cylinder pressure diagram.
- VEC Σθ<sub>N</sub>, This is the vector summation of THETA of the crank-throws, for the engine's firing order, of the particular harmonic.
- TSTINT Static stress INTERNAL and is determined by F INT, which is:  

$$\text{Constant } 3 * T_N * \Sigma \theta_N$$
- TSTEXT Static stress EXTERNAL and is determined by F EXT, which is:  

$$\text{Constant } 4 * T_N * \Sigma \theta_N$$
- PHI φ, the front end amplitude in degrees at resonance, and is determined by:  

$$F_{IN} = \text{Total Damping}$$

TSINT

Maximum internal resonance stress in PSI, which is:

$$PHI * T INT$$

TMAXI

Maximum external resonance stresses in PSI, which is:

$$PHI * T EXT$$

When plotting the stresses versus RPM, the off resonant stresses are determined by:

$$\frac{TSINT \text{ or } TSTEXT}{\text{MAGNIFICATION FACTOR}}$$

$$\text{Where Magnification Factor} = 1 - \left( \frac{\text{RPM}}{\text{Resonant RPM}} \right)^2$$



SECTION ONE

TORSIONAL ANALYSIS

TORSIONAL AND LATERAL CRITICAL SPEED ANALYSIS

ENGINE NUMBERS 74010/12  
DELAVAL-ENTERPRISE ENGINE MODEL DSR-48  
3500 KW/4889 BHP AT 450 RPM

FOR  
STONE & WEBSTER ENGINEERING CORP.  
LONG ISLAND LIGHTING COMPANY

TRANSAMERICA DELAVAL ENGINE & COMPRESSOR DIVISION  
550 - 85th AVENUE  
OAKLAND, CALIFORNIA 94621


By: ROLAND YANG

AUGUST 22, 1983

LONG ISLAND LIGHTING COMPANY  
Delaval-Enterprise Engine Model DSR-48  
3500 KW/4889 BHP at 450 RPM

225.6 BMEP

Engine Numbers 74010/12




Mass Elastic System

Crankshaft Gear	26.52		
Water Pump Drive	63.10		
Cams & Idlers	119.70		
Shaft	9.63		
	218.95 lb.ft. <sup>2</sup>	I = 6.805 lb.ft.sec. <sup>2</sup>	
Crankthrow No.1			
As No.2 crankthrow	1541.85		
Shaft	41.81		
	1583.66 lb.ft. <sup>2</sup>	I = 49.222 lb.ft.sec. <sup>2</sup>	
Crankthrow No. 2 to 7			
Journal	43.13		
Crankpin	202.17		
Two Webs	679.81		
Reciprocating Wt.	309.99		
Rotating Weight	306.75		
	1541.85 lb.ft. <sup>2</sup>	I = 47.922 lb.ft.sec. <sup>2</sup>	
Crankthrow No.8			
As No. 2 Crankthrow	1541.85		
Shaft	71.63		
	1613.48 lb.ft. <sup>2</sup>	I = 50.149 lb.ft.sec. <sup>2</sup>	
Crankshaft Flange	255.08		
Flywheel 73 x 6½	34764.		
Generator Shaft	374.		
	35393.08 lb.ft. <sup>2</sup>	I = 1100.052 lb.ft.sec. <sup>2</sup>	
Generator Rotor	85275	lb.ft. <sup>2</sup>	I = 2650.432 lb.ft.sec. <sup>2</sup>
Total WK <sup>2</sup>	= 133335	lb.ft. <sup>2</sup>	

NOTE: The reciprocating weight used above are based on 800 lb. The replacement "AE" piston skirt is 26 lb. heavier. We have evaluated the effect of this weight difference and conclude that the change in natural frequencies and stresses is less than .5% and therefore negligible.

EQUIVALENT LENGTH  $D_e = 1''$

Front Gear to Cylinder No. 1	.0001661''	$K = 58.121 \times 10^6$ ft.lb./rad.
Between Cylinders	.0011394''	$K = 84.727 \times 10^6$ ft.lb./rad.
Cylinder No. 8 to Flywheel	.0012547''	$K = 76.941 \times 10^6$ ft.lb./rad.
Flywheel to Generator		



$$L_e = \frac{3 - .0515 \times 16.25}{20^4} + \frac{.055 \times 16}{16^4} + 9 + .03 \times 16$$

$$+ \frac{-.03 \times 16 + 13.25 - .021 \times 16.572}{18^4} + \frac{.021 \times 16.572 + 16.574}{16.572^4}$$

$$= .0000132 + .0001580 + .0001183 + .000593 = .0003488''$$

$$K = 276.773 \times 10^6 \text{ ft.lb./radian}$$

Shafting Diameters

Front gear to Cylinder No. 1	8''
Crankpin	12''
Cylinder No. 8 to Flywheel	12''
Generator Shaft	16''

Flywheel Weight	6935 lb.
Gen. Rotor Weight	17150 lb.

Torsional Natural Frequencies

First Mode	2323 vpm
Second Mode	5575 vpm
Third Mode	7000 vpm

Electrical Natural Frequency

$$N = \frac{35200}{450} \sqrt{\frac{11260 \times 60}{133335}} = 175 \text{ vpm}$$

Generator Shaft Lateral Natural Frequency

3191 vpm

MODE 1  
 OMEGA SQUARED IN (RADIAN/SECOND)\*\*2 = .25318702  
 NATURAL FREQUENCY IN V.P.M. = 2323.19

NO.	INERTIA	THETA	ICM2T	SIGMA M	SHAFT X	DTHETA
1	6.8	1.00000	.403	.403	58.1	.00693
2	49.2	.99307	2.893	3.296	84.7	.03890
3	47.9	.95417	2.706	6.002	84.7	.07084
4	47.9	.88333	2.505	8.508	84.7	.10041
5	47.9	.78291	2.221	10.728	84.7	.12662
6	47.9	.65629	1.861	12.590	84.7	.14859
7	47.9	.50770	1.440	14.030	84.7	.16559
8	47.9	.34211	.970	15.000	84.7	.17704
9	50.1	.16507	.490	15.490	76.9	.20132
10	1100.1	-.02625	-2.360	13.130	276.8	.04744
11	2650.4	-.08369	-13.129	.001		

MODE 1  
 OMEGA SQUARED .0532  
 NATURAL FREQUENCY 2323.1900  
 SIGMA I\*THETA\*\*2 2385.7810  
 SIGMA I\*THETA\*\*2 2707.4896

T INT 9561.73  
 T EXT 3419.27  
 STRESSED DIAMETER OF EXTERNAL SHAFT 16.00  
 EQUILIBRIUM AMPLITUDE .00065213052  
 W IN 7487.33  
 W INT 8.15  
 W EXT 2.91  
 W B 17744629.  
 W D 0.  
 W CD 0.  
 W CS 0.  
 W D 0.

ORDER	RCM	TN	VEC	TSTINT	TSTEXT	PHI	TMAXI	TMAXE
1.0	4646	155.86	.701	889.8	618.2	.728	7053.	2592.
1.5	2323	94.58	.146	112.7	40.5	.158	1513.	541.
1.8	1548	129.52	1.394	1471.3	526.1	1.454	13304.	4972.
2.0	1161	41.05	.376	125.7	45.0	.670	6408.	2292.
2.5	929	71.71	1.394	814.6	291.3	1.050	10036.	3589.
3.0	774	16.16	.146	19.3	6.9	.044	423.	151.
3.5	663	42.79	.701	244.3	87.4	.376	3596.	1286.
4.0	580	27.66	5.285	1191.1	425.9	2.066	19750.	7063.
4.5	516	23.76	.701	135.7	48.5	.216	2063.	738.
5.0	464	17.37	.146	20.7	7.4	.061	587.	210.
5.5	422	12.84	1.394	145.8	52.2	.433	4138.	1480.
6.0	387	5.68	.376	17.4	6.2	.052	494.	175.
6.5	357	4.49	1.394	51.0	18.2	.151	1447.	517.
7.0	321	3.69	.146	4.4	1.6	.013	125.	45.
7.5	309	3.05	.701	17.4	6.2	.052	494.	175.
8.0	290	2.52	5.285	108.4	38.8	.322	3076.	1100.
8.5	272	2.26	.701	12.9	4.6	.038	366.	131.
9.0	258	1.97	.146	2.3	.8	.007	67.	24.
9.5	244	1.53	1.394	17.3	6.2	.051	492.	176.
10.0	232	1.27	.376	3.9	1.4	.012	110.	39.
10.5	221	1.14	1.394	13.0	4.6	.038	368.	132.
11.0	211	1.02	.146	1.2	.4	.004	34.	12.
11.5	202	.89	.701	5.1	1.8	.015	144.	51.
12.0	193	.79	5.285	13.9	12.1	.100	961.	344.

MODE  
 ORIGIN SQUARED IN (RADIAN/SECOND) \*\*R = .34090021  
 NATURE OF FREQUENCY IN V.P.M. \*\*R = .070.00

NO.	INERTIA	TETA	ICENT	BIGR M	SHIFT X	DELTA
1	6.0	1.02000	2.320	2.320	20.1	.00000
2	49.0	.96000	16.110	16.430	84.7	.21750
3	47.0	.74207	12.131	32.561	84.7	.36070
4	47.0	.38107	6.238	36.799	84.7	.43433
5	47.0	-.05266	-1.057	35.942	84.7	.42421
6	47.0	-.47667	-7.787	28.155	84.7	.33230
7	47.0	-.80000	-13.216	14.939	84.7	.17632
8	47.0	-.98530	-16.036	-1.157	84.7	-.01366
9	50.1	-.97164	-16.611	-17.768	76.9	-.23093
10	1100.1	-.74070	-277.770	-195.536	276.8	-1.06780
11	2650.4	.32710	295.542	.004		

MODE  
 ORIGIN SQUARED .3409  
 NATURE OF FREQUENCY 0.070.00  
 BIGR M 2070.9856  
 SHIFT X 10006.1814  
 DELTA 2.715.43  
 ICENT 76363.62  
 BIGR M 16.00  
 SHIFT X .000032.03763  
 DELTA 7487.63  
 ICENT .68  
 BIGR M 110473321.  
 SHIFT X 0.  
 DELTA 0.  
 BIGR M 0.  
 SHIFT X 0.  
 DELTA 0.

CR	RM	TN	VEC	TSTINT	TSTEXT	PMI	TMAXI	TMAXE
1	11151	105.86	1.500	160.7	544.6	.005	5792.	10624.
2	5075	94.88	.253	16.3	55.4	.044	997.	3379.
3	3717	109.52	3.789	335.6	1137.0	.625	14418.	48851.
4	3787	41.05	.702	19.7	66.8	.201	4667.	15474.
5	2220	71.71	3.789	185.8	629.5	.488	10487.	35566.
6	1828	16.16	.253	2.8	9.5	.012	279.	945.
7	1893	42.79	1.500	44.1	149.5	.138	2953.	10006.
8	1393	27.66	1.511	22.9	77.6	.076	1726.	5849.
9	1209	53.76	1.500	24.5	83.0	.075	1694.	5739.
10	1115	17.27	.253	3.0	10.2	.023	209.	709.
11	1013	12.84	3.789	33.3	112.7	.125	2386.	8085.
12	929	11.42	.702	5.5	18.6	.015	352.	1192.
13	857	9.08	3.789	23.5	79.7	.066	1500.	5084.
14	726	7.61	.253	1.3	4.5	.004	82.	278.
15	742	6.17	1.500	6.4	21.6	.018	405.	1373.
16	696	5.60	1.211	4.1	14.9	.012	269.	911.
17	638	4.74	1.500	4.9	16.6	.013	320.	1016.
18	610	4.68	.253	.7	2.4	.002	44.	149.
19	585	3.58	3.789	6.7	22.6	.022	510.	1728.
20	357	1.87	.702	.9	3.0	.003	79.	266.
21	321	1.69	3.789	4.4	14.8	.017	382.	1292.
22	260	1.42	.253	.2	.8	.001	23.	77.
23	204	1.15	1.500	1.2	4.0	.005	118.	400.
24	204	.95	1.211	.8	2.7	.002	103.	349.



MODE 3  
 OMEGA SQUARED IN (RAD/SEC)<sup>2</sup> = .53738427  
 NATURAL FREQUENCY IN V.P.M. = 7000.26

NO.	INERTIA	THETA	IOM2T	SIGMA M	SHIFT K	DELTA
1	6.8	1.00000	3.657	3.657	08.1	.06292
2	49.2	.93708	24.787	28.444	84.7	.03571
3	47.9	.60137	15.487	43.931	84.7	.01850
4	47.9	.08288	2.134	46.065	84.7	.04369
5	47.9	-.46081	-11.867	34.148	84.7	.46081
6	47.9	-.86443	-22.261	11.936	84.7	.14288
7	47.9	-1.00531	-25.889	-13.953	84.7	-.16488
8	47.9	-.84063	-21.648	-35.681	84.7	-.46081
9	50.1	-.46044	-11.331	-46.932	76.9	-.60997
10	1100.1	.18953	112.041	65.129	276.8	.23524
11	2650.4	-.04571	-65.129	.000		

MODE 3  
 OMEGA SQUARED .5374  
 NATURAL FREQUENCY 7000.2600  
 SIGMA 1+THETA\*\*2 2375.2154  
 SIGMA 1+THETA\*\*2 2997.4770  
 T 28970.37  
 T MAX 16955.47  
 ESTABLISHED DIAMETER OF EXTERNAL SHAFT 16.00  
 BRICK AMPLITUDE .000064773254  
 H 7487.33  
 H MAX 2.46  
 H MAX 1.44  
 H MAX 162397888.  
 H D 0.  
 H D 0.  
 H D 0.  
 H D 0.

NO	RPM	TN	VEC	TSTINT	TSTEXT	SM	TMAXI	TMAXE
.5	14000	155.86	.955	365.7	214.0	.111	3223.	1887.
1.0	7000	94.58	.857	199.0	116.4	.102	2969.	1738.
1.5	4666	129.52	3.103	986.9	577.6	.358	10371.	6070.
2.0	3500	41.05	2.525	254.6	149.0	.498	14432.	8446.
2.5	2800	71.71	3.103	546.4	318.8	.258	7486.	4381.
3.0	2333	16.16	.857	34.0	19.9	.029	831.	488.
3.5	2000	42.79	.955	100.4	58.8	.057	1644.	962.
4.0	1750	27.66	1.970	133.9	78.3	.085	2468.	1445.
4.5	1555	23.76	.955	55.8	32.6	.033	943.	522.
5.0	1400	17.37	.857	36.5	21.4	.022	623.	365.
5.5	1272	12.84	3.103	97.8	57.3	.059	1717.	1005.
6.0	1166	11.42	2.525	78.8	41.4	.038	1111.	651.
6.5	1076	9.08	3.103	69.2	40.5	.037	1079.	632.
7.0	1000	7.61	.857	16.0	9.4	.008	245.	143.
7.5	933	6.17	.955	14.5	8.5	.008	226.	132.
8.0	875	5.00	1.970	24.2	14.2	.013	384.	225.
8.5	823	4.74	.955	11.1	6.5	.006	167.	98.
9.0	777	4.08	.857	8.6	5.0	.005	131.	77.
9.5	736	2.58	3.103	19.7	11.5	.013	367.	215.
10.0	700	1.87	2.525	11.6	6.8	.009	248.	145.
10.5	666	1.69	3.103	12.9	7.5	.009	275.	161.
11.0	636	1.42	.857	3.0	1.7	.002	67.	39.
11.5	608	1.15	.955	2.7	1.6	.002	66.	38.
12.0	583	.96	1.970	4.7	2.7	.004	120.	70.



The preceding pages show the analysis based on the nameplate rating of the engines. To illustrate the changes in amplitudes and stress levels when operating at 111.4% (3900 KW) or overload condition allowed for two hours per day, we supplemented the analysis with the following pages.

The changes in the amplitude and stress between the two load conditions are reflected in the "T sub n" ( $T_n$ ) values. The following is a listing of the 111.4%  $T_n$  divided by the 100%  $T_n$  for the orders or harmonics calculated. The ratios show the increase in amplitude and stress level due to the extra load at 111.4% load operation.

<u>ORDER</u>	<u>FIRST MODE</u>	<u>SECOND MODE</u>	<u>THIRD MODE</u>
.5	1.1040	1.1040	1.1040
1.0	1.0777	1.0777	1.0777
1.5	1.0963	1.0963	1.0963
2.0	.8877	.8877	.8877
2.5	1.0217	1.0217	1.0217
3.0	1.1733	1.1733	1.1733
3.5	1.0694	1.0694	1.0694
4.0	1.0600	1.0600	1.0600
4.5	1.0669	1.0669	1.0669
5.0	1.0662	1.0662	1.0662
5.5	1.0639	1.0639	1.0639
6.0	1.0370	1.0727	1.0727
6.5	1.0379	1.0727	1.0727
7.0	1.0379	1.0749	1.0749
7.5	1.0361	1.0729	1.0729
8.0	1.0357	1.0700	1.0700
8.5	1.0398	1.0738	1.0738
9.0	1.0406	1.0735	1.0735
9.5	1.0196	1.0581	1.0581
10.0	1.0157	1.0431	1.0481
10.5	1.0175	1.0473	1.0473
11.0	1.0098	1.0423	1.0423
11.5	1.0112	1.0261	1.0261
12.0	1.0000	1.0313	1.0313

From the above, the increase in amplitude or stress level due to the fourth order at 111.4% load will be about 6% higher than that at 100%. If we calculate the stress levels at 450 RPM due to the .5, 1.5, 2.5, 4.0, 4.5, 5.0, 5.5 orders and sum these by the Square Root of the Sum of the Squares, the overall amplitude at 111.4% (4154 psi) will be about 7% higher than that (3879 psi) at 100% load.



MODE 2  
 OMEGA SQUARED IN (RAD/SEC)<sup>2</sup> = .34089903  
 NATURAL FREQUENCY IN V.D.N. = 5875.51

NO.	INERTIA	THETA	TEXT	SIGMA X	SIGMA Y	TEXT
1	6.8	1.00000	6.320	6.320	84.7	.00000
2	49.2	.96000	16.110	16.430	84.7	.00700
3	47.9	.74257	12.131	30.561	84.7	.38070
4	47.9	.38187	6.238	56.799	84.7	.42400
5	47.9	-.05246	-.857	35.940	84.7	.48400
6	47.9	-.47667	-7.787	28.150	84.7	.33000
7	47.9	-.80897	-13.216	14.939	84.7	.17000
8	47.9	-.98530	-16.096	-1.157	84.7	-.01300
9	50.1	-.97164	-16.611	-17.768	76.9	-.03000
10	1100.1	-.74071	-277.771	-235.539	276.8	-1.02700
11	2650.4	.32709	235.538	.000		

MODE 2  
 OMEGA SQUARED .3409  
 NATURAL FREQUENCY 5875.5100  
 SIGMA I+THETA++2 2578.9663  
 SIGMA I+THETA++3 13306.1896  
 T INT 227.19.43  
 T EXT 78983.00  
 STABILIZER DIAMETER OF EXTERNAL SHIRT 16.00  
 BUCKLE FOR AMPLITUDE .000000:00007  
 H 17 7487.00  
 H 17 .68  
 H 17 2.00  
 H 17 110478560.  
 H 17 0.  
 H 17 0.  
 H 17 0.

ORDER	ARM	TN	VED	TSTINT	TSTEXT	P-1	TMAX1	TMAXE
.5	11151	172.07	1.508	177.4	601.2	.279	633.1	614.1
1.0	5575	101.93	.253	17.6	59.7	.046	1036.	3500.
1.5	2717	141.99	3.789	367.9	1246.5	.681	15460.	58100.
2.0	2787	36.44	.702	17.5	59.3	.198	4493.	15214.
2.5	2230	77.57	3.789	201.0	601.0	.462	10892.	36919.
3.0	1858	18.96	.253	3.3	11.1	.012	266.	903.
3.5	1593	45.76	1.508	47.2	159.9	.134	5052.	10241.
4.0	1392	29.32	1.211	24.3	82.2	.078	1771.	5999.
4.5	1239	25.35	1.508	26.1	88.6	.077	1747.	5919.
5.0	1115	18.52	.253	3.2	10.8	.009	216.	731.
5.5	1013	13.66	3.789	35.4	119.9	.108	2485.	8316.
6.0	929	10.25	.702	5.9	19.9	.016	365.	1235.
6.5	857	9.74	3.789	25.2	85.5	.068	1536.	5271.
7.0	796	8.18	.253	1.4	4.8	.004	85.	289.
7.5	743	6.62	1.508	6.8	23.1	.019	420.	1424.
8.0	696	5.35	1.211	4.4	15.9	.012	276.	943.
8.5	653	5.09	1.508	5.3	17.8	.014	312.	1058.
9.0	619	4.38	.253	.8	2.8	.002	45.	155.
9.5	586	2.73	3.789	7.1	24.9	.023	523.	1771.
10.0	557	1.96	.702	.9	3.2	.004	80.	271.
10.5	521	1.77	3.789	4.6	15.5	.017	388.	1315.
11.0	506	1.48	.253	.3	.9	.001	23.	78.
11.5	484	1.18	1.508	1.2	4.1	.005	119.	404.
12.0	464	.99	1.211	.8	2.8	.005	106.	358.



MODE 3  
 OMEGA SQUARED IN (RADIANS/SECOND)\*\*2 = .53738424  
 NATURAL FREQUENCY IN V.P.M. = 7000.25


NO.	INERTIA	THETA	TINT	SIGMA X	SIGMA Y	TINT
1	6.6	1.00000	3.657	3.657	84.7	.600000
2	49.2	.92728	24.727	24.727	84.7	.000000
3	47.9	.60127	15.487	43.931	84.7	.000000
4	47.9	.08288	2.134	45.025	84.7	.000000
5	47.9	-.46081	-11.857	34.128	84.7	.000000
6	47.9	-.86443	-22.261	11.936	84.7	.140000
7	47.9	-1.00531	-25.889	-12.953	84.7	-1.160000
8	47.9	-.84053	-21.646	-35.691	84.7	-1.400000
9	50.1	-.42044	-11.331	-46.932	76.9	-1.000000
10	1100.1	.18952	112.041	65.109	276.8	.000000
11	2650.4	-.04571	-65.109	.000		

MODE 3  
 OMEGA SQUARED .5374  
 NATURAL FREQUENCY 7000.2500  
 SIGMA 1+THETA\*\*2 2375.2154  
 SIGMA 1+THETA\*\*2 2997.4770  
 T INT 26370.37  
 T EXT 16955.47  
 STRESSED DIAMETER OF EXTERNAL SHAFT 15.00  
 EQUILIBRIUM AMPLITUDE .000054773255  
 F IN 7487.33  
 F INT 2.46  
 F EXT 1.44  
 F INT 162197.71  
 F D 0.  
 F CB 0.  
 F CB 0.  
 F CB 0.

ORDER	RXY	TN	VEC	TSTINT	TSTEXT	P-1	TINT	TSTEXT
.5	14000	172.07	.955	403.7	226.3	.120	3503.	2500.
1.0	7000	101.93	.857	214.4	125.5	.100	3064.	1800.
1.5	4666	141.99	3.103	1061.9	633.2	.354	1112.	6500.
2.0	3500	38.44	2.525	226.9	132.3	.430	1413.	8000.
2.5	2800	77.57	3.103	531.1	345.9	.371	783.8	4500.
3.0	2333	18.96	.857	39.9	22.3	.027	793.	400.
3.5	2000	45.76	.955	107.4	62.8	.059	1699.	900.
4.0	1750	29.32	1.970	141.9	82.0	.087	2531.	1400.
4.5	1555	25.05	.955	59.5	34.8	.034	972.	500.
5.0	1400	18.52	.857	39.9	22.8	.022	642.	375.
5.5	1272	12.66	3.103	104.1	60.9	.061	1766.	1000.
6.0	1166	12.25	2.525	75.9	44.4	.040	1152.	674.
6.5	1076	9.74	3.103	74.2	43.4	.039	1119.	655.
7.0	1000	8.18	.857	17.2	10.1	.009	254.	145.
7.5	933	6.62	.955	15.5	9.1	.009	224.	137.
8.0	875	5.35	1.970	25.9	15.2	.014	398.	202.
8.5	823	5.09	.955	12.0	7.0	.006	174.	102.
9.0	777	4.38	.857	9.2	5.4	.005	136.	82.
9.5	736	2.73	3.103	20.8	12.2	.013	376.	212.
10.0	700	1.95	2.525	12.2	7.1	.009	252.	146.
10.5	666	1.77	3.103	13.5	7.3	.010	279.	162.
11.0	636	1.48	.857	3.1	1.6	.002	68.	40.
11.5	608	1.18	.955	2.8	1.6	.002	65.	39.
12.0	583	.99	1.970	4.8	2.8	.004	121.	71.



The next page (p.17) is a Tabulation of Mass Elastic Data showing other DSR-48 engines of similar rating. Except for minor differences in flywheel and generator, the torsional characteristic of these units are very similar, as indicated by the similarities between the torsional natural frequencies. A listing of operating hours accymulated for several of these units are included in Section Four of this submittal.



Typical Torsional Mass Elastic System (DSR-48/Generator)

TABULATION OF MASS ELASTIC DATA OF DSR-48 ENGINES.

	LILCO 74010/ 74012	Kousheng Taiwan 75005/ 75008	Gulf States 74039/ 74042	U. of Texas 78029/ 78030	SMUD 81015/ 81016	Saudi Arabia 81015/ 81016
I <sub>1</sub>	6.805	8.250	6.805	8.560	6.805	6.805
I <sub>2</sub>	49.222	49.222	49.222	54.389	49.222	54.389
I <sub>3</sub>	47.922	47.922	47.922	53.090	47.922	53.090
I <sub>4</sub>	47.922	47.922	47.922	53.090	47.922	53.090
I <sub>5</sub>	47.922	47.922	47.922	53.090	47.922	53.090
I <sub>6</sub>	47.922	47.922	47.922	53.090	47.922	53.090
I <sub>7</sub>	47.922	47.922	47.922	53.090	47.922	53.090
I <sub>8</sub>	47.922	47.922	47.922	53.090	47.922	53.090
I <sub>9</sub>	50.149	50.841	50.149	58.257	50.149	55.316
I <sub>10</sub>	1100.520	1009.604	426.527	368.572	1280.633	1280.633
I <sub>11</sub>	2650.432	2828.371	4976.067	2756.882	2650.430	2552.371
K <sub>1</sub>	58.121	58.121	58.121	58.121	58.121	58.121
K <sub>2</sub>	84.727	84.727	84.727	84.727	84.727	84.727
K <sub>3</sub>	84.727	84.727	84.727	84.727	84.727	84.727
K <sub>4</sub>	84.727	84.727	84.727	84.727	84.727	84.727
K <sub>5</sub>	84.727	84.727	84.727	84.727	84.727	84.727
K <sub>6</sub>	84.727	84.727	84.727	84.727	84.727	84.727
K <sub>7</sub>	84.727	84.727	84.727	84.727	84.727	84.727
K <sub>8</sub>	84.727	84.727	84.727	84.727	84.727	84.727
K <sub>9</sub>	76.941	67.327	76.941	76.941	76.941	76.941
K <sub>10</sub>	276.773	326.100	309.720	229.770	254.397	252.445
N <sub>1</sub>	2323	2280	2277	2143	2317	2219
N <sub>2</sub>	5576	5988	6421	3669	5146	5125
N <sub>3</sub>	7000	7064	8792	6307	6913	6619
CTWT	-	-	-	1	-	1

Note:

- I Inertia values of mass elastic system (Lb. ft. sec.<sup>2</sup>)
- K Stiffness values of mass elastic system ( Million ft. lb. per Radian)
- CTWT Counterweight used at each crankthrow
- Saudi Arabia Installations are:
  - Dhuba 76010 to 76014
  - Oneiza 76026 to 76028
  - Wadi 78044 to 78046
  - Rafha 79002 to 79004
  - Rabigh 80001 to 80003

N Torsional Natural Frequencies of the first three modes (V.P.M.)

SECTION TWO

TORSIOGRAPH TESTS

#### TORSIOGRAPH TESTS

One of the three engine (S/N 74010/12) was torsioographed by both Failure Analysis Associates (FaAA) jointly with Stone & Webster (SWEC) as well as by Transamerica Delaval (TDI). TDI only measured overall torsional amplitudes.

On page 19 are measured results by FaAA/SWEC and those by TDI. FaAA's measurement reflects actual peak to peak amplitudes of the overall composite waveform. FaAA also provided the Square Root of the Sum of the Squares (SRSS), which would be comparable to the overall amplitudes measured by TDI using the Bell & Howell C.E.C. Vibration Meter. Also included in page 19 are test results of other DSR-48 engine generator sets with similar mass elastic system and of identical rating. It can be readily observed that the Fourth Order amplitudes measured by FaAA/SWEC on the subject crankshaft are similar to values measured by TDI on similar DSR-48 engine generators. Also the FaAA/SWEC SRSS amplitudes and TDI measured overall amplitudes are very similar. It may also be noted here that the Bell & Howell C.E.C. instrumentation used by TDI is widely used in the trade and although the measurement do not represent a theoretically correct peak to peak amplitude, it does however provide a common method in measuring the combined effects of the various harmonics. On page 20, reference is made to the approval of crankshaft drawing 03-310-05-AC, as well as the corresponding ABS forging report number and physical properties. For comparison of the actual crankshaft minimum tensile property between LILCO, Kousheng and Rafha, we have included the values for the latter two.

On page 21, allowable stress levels due to single harmonic and overall are calculated using 1982 and current 1984 ABS Rules.

TORSIONAL TEST DATA ON DSR-48 ENGINE GENERATOR SETS.

A. Torsiograph Test Results by FaAA/SWEC

	<u>3500 KW</u>		<u>3800 KW</u>	
Fourth Order	.32 <sup>o</sup>	3108 psi	.339 <sup>o</sup>	3242 psi
Overall, Pk to Pk	.693 <sup>c</sup>	6626 psi	.719 <sup>o</sup>	6875 psi
Overall, Calculated by SRSS	.424 <sup>o</sup>	4054 psi	.454 <sup>o</sup>	4341 psi

B. Torsiograph Test Results by TDI, Using Bell & Howell C.E.C. Model  
1-117-0001 Vibration Meter.

	<u>3500 KW</u>		<u>3800 KW</u>	
Overall	.425 <sup>o</sup>	4064 psi	.450 <sup>o</sup>	4302 psi

C. Torsiograph Test Results by TDI, Using Bell & Howell C.E.C. Model  
1-117-0001 Vibration Meter, on other DSR-48 Engine Generators.

<u>S/N 76014</u>	<u>3500 KW</u>		<u>3850 KW</u>	
Fourth Order	.350 <sup>o</sup>	3365 psi	.370 <sup>o</sup>	3557 psi
Overall	.420 <sup>o</sup>	4038 psi	.460 <sup>o</sup>	4423 psi
<u>S/N 74039</u>				
Fourth Order	.362 <sup>o</sup>	3385 psi	.372 <sup>o</sup>	3478 psi
Overall	.450 <sup>o</sup>	4208 psi	.480 <sup>o</sup>	4488 psi

PHYSICAL PROPERTIES OF CRANKSHAFTS

<u>ABS REPORT ON CASTINGS OR FORGINGS REPORT NO.</u>	<u>LOWER VALUE YIELD POINT - PSI</u>	<u>LOWER VALUE TENSILE STRENGTH - PSI</u>
<u>LILCO</u>		
83-ES 85280-1031	58291	100777
83-ES 85279-1031	57276	101792
83-ES 86290-365	48576	100777
<u>RAFHA, 79004</u>		
79-K078165-232	50500	93700
<u>KOUSHENG, 75006/08</u>		
	55000	93000
	54000	93500
	57000	98000

Crankshaft material specified is ABS Grade 4 which is A668 - Class E.  
Minimum yield point is 43000 psi and minimum tensile strength is 83000 psi.

The crankshafts for the DSR-48 carry a part or drawing number 03-310-05-AC,  
and has ABS approval stamped, dated 2-26-1976.



ALLOWABLE TORSIONAL STRESS CALCULATION.

Based on Para. 34.47 of 1984 ABS Rules.

$$S = \left( \frac{U + 23180}{18} \right) C_k C_d C_r$$

where U = Minimum Tensile Strength of Shaft Material 100000 PSI

C<sub>k</sub> is .55 for propeller shafts and crankshafts

C<sub>d</sub> is size factor,  $.35 + 0.487 / \sqrt[5]{12} = .6463$

C<sub>r</sub> is speed ratio factor, 1.38 for 90% to 105% rated RPM.

$$S = \left( \frac{100000 + 23180}{18} \right) (.55) (.6463) (1.38)$$

= 3357 PSI due to single order

Total Allowable Stress = 150% of 3357 = 5035 PSI

ALLOWABLE TORSIONAL STRESS CALCULATION.

Based on Table 34.3 of 1982 ABS Rules.

<u>Engine Speed</u>	<u>.3 x 450 RPM</u>	<u>.8 x 450 RPM</u>	<u>.95 to 1.0 x 450 RPM</u>	<u>1.05 x 450 RPM</u>
	= 135 RPM	= 360 RPM	427.5 to 450	472.5 RPM

Grade 2, 60000 psi	5689 psi	3556 psi	2134 psi	3556 psi
Grade 4, 100000 psi	8217 psi	5136 psi	3082 psi	5136 psi

$$\text{Stress limit multiplier} = \frac{2}{3} \left( \frac{100000 - 60000}{60000} \right) + 1 = 1.4444$$

for adjustment from 60000 psi  
to 100000 psi material.

SECTION THREE

STRAIN GAUGE TESTS

Submittal to the American Bureau of Shipping  
for the DSR-48 13-Inch by 12-Inch Replacement Crankshafts

Fatigue Analysis of the Replacement Crankshafts

The factor of safety against fatigue failure in the replacement (12-inch crank pins) crankshafts is calculated in this section. The stress levels in the replacement crankshafts are computed from strain gage test data. The endurance limit is first established for the failed crankshafts (11-inch crank pins) from strain gage test data. This endurance limit is then scaled to account for the higher ultimate tensile strength of the replacement crankshaft. The effect of shot peening the replacement crankshafts provides an additional margin against fatigue failure.

Stresses in Replacement Crankshafts

The replacement crankshaft was instrumented with strain gages in the fillet locations of crank pins 5 and 7 and tested under operational conditions at both 3500 kW (100% rated load) and 3800 kW (109% rated load), 450 RPM synchronous speed. The highest stresses were measured in crank pin 5. A dynamic model of the crankshaft confirms that this pin undergoes the greatest range of torque. Three-dimensional finite element models of a quarter crank throw show that the strain gage rosette was placed in the location of highest stress, both within the fillet and around the crank pin. The following strains were measured at 3500 kW:

<u>Strain Gage</u>	<u>Maximum</u>	<u>Minimum</u>
5-1 (compression)	-195 $\mu\epsilon$	288 $\mu\epsilon$
5-2 (bending)	695 $\mu\epsilon$	-410 $\mu\epsilon$
5-3 (tension)	737 $\mu\epsilon$	-610 $\mu\epsilon$

To account for the simultaneous effects of shear and bending, the stress state is represented by equivalent stresses using Sine's method [1]. For a biaxial stress state, the equivalent alternating stress,  $S_{qa}$ , and equivalent mean stress,  $S_{qm}$ , are given by:

$$S_{qa} = (S_{a1}^2 - S_{a1}S_{a2} + S_{a2}^2)^{1/2}$$

$$\text{and } S_{qm} = S_{m1} + S_{m2}$$

where  $S_{a1}$  and  $S_{a2}$  are the alternating components of principal stress, and  $S_{m1}$  and  $S_{m2}$  are the mean components of principal stress. From the test report [2], the equivalent alternating stress,  $S_{qa}$ , and equivalent mean stress,  $S_{qm}$ , on crank pin 5 were calculated to be:

$$S_{qa} = 24.6 \text{ ksi}$$

$$S_{qm} = 4.8 \text{ ksi}$$

Equivalent stresses,  $S_{qa}$  and  $S_{qm}$ , are those alternating and mean uniaxial stresses that can be expected to give the same life as the given multiaxial stresses.

#### Endurance Limit for Failed Crankshaft

The failed crankshaft was instrumented with strain gages in the fillet location of crank pin 5. This fillet on the failed crankshaft had previously experienced a fatigue crack during performance testing. After the test, the three-dimensional finite element models of a quarter crank throw showed that the strain gage location on the failed crankshaft was placed close to the location of maximum stress. The measured stress range is used to establish the endurance limit in this analysis as a conservative assumption, although the actual maximum stress range is revealed by the finite element model to be about 15 percent higher at a nearby location. From the test report [3], the following strains were measured at 3500 kW:

<u>Strain Gage</u>	<u>At Maximum Torque</u>	<u>At Minimum Torque</u>
5-1 (tension)	1118 $\mu\epsilon$	-707 $\mu\epsilon$
5-2 (bending)	773 $\mu\epsilon$	-459 $\mu\epsilon$
5-3 (compression)	-389 $\mu\epsilon$	266 $\mu\epsilon$

The equivalent alternating stress,  $S_{qa}$ , and equivalent mean stress,  $S_{qm}$ , were calculated to be:

$$S_{qa} = 33.7 \text{ ksi}$$

$$S_{qm} = 10.9 \text{ ksi}$$

From the test logs, it was determined that the shaft had experienced 273 hours at equal to or greater than 100% load, or about  $4 \times 10^6$  cycles. By using Miner's rule and typical slopes of S-N curves, it was determined that the endurance limit for this mean stress was 32.4 ksi. The ultimate tensile strength for these crankshafts averaged 96 ksi. A line representing this endurance limit is shown on the Goodman diagram [4] in Figure 3.1.

This line is bounded by two lines showing the endurance limit for full scale crankshafts based on other test data [5].

#### Endurance Limit for Replacement Crankshafts

The replacement crankshafts have a minimum tested ultimate tensile strength of 103 ksi. The endurance limit scales linearly with ultimate tensile strength. On this basis, the endurance limit for the replacement crankshaft is shown in Figure 3.1.

The fillet regions of the replacement crankshafts have been shot peened. The effect of shot peening may produce widely differing increases in fatigue endurance limit; however, a conservative minimal value of this increase is 20% [6]. The endurance limit for the replacement crankshafts, including the effect of shot peening, is shown in Figure 3.1.

### Factor of Safety Against Fatigue Failure

The factor of safety against fatigue failure of the replacement crankshafts is 1.48 when the effect of shot peening is not considered, and is 1.75 when the effect of shot peening is assumed to increase the endurance limit by 20%.

At 3800 kW, the strain gage test data [1] on the replacement crankshaft shows that the stress level is 4% greater than it is at 3500 kW. At 3900 kW it would be about 5% greater than it is at 3500 kW. Thus, there is an adequate safety margin against fatigue failure at the specified diesel generator set two-hour-per-24-hour period rating of 3900 kW.



## References

1. Fuchs, H.O., and Stephens, R. I., "Metal Fatigue in Engineering," Wiley, 1980.
2. Bercel, E., and Hall, J.R., "Field Test of Emergency Diesel Generator 103," Stone & Webster Engineering Corporation, March, 1984.
3. Bercel, E., and Hall, J.R., "Field Test of Emergency Diesel Generator 101," Stone & Webster Engineering Corporation, October, 1983.
4. Collins, J.A., "Failure of Materials in Mechanical Design," Wiley, 1991.
5. Nishihara, M., and Fukui, Y., "Fatigue Properties of Full Scale Forged and Cast Steel Crankshafts," Transactions of the Institute of Marine Engineering, Series B on Component Design for Highly Pressure-Charged Diesel Engines, London, January, 1976.
6. Burrell, N.K., "Controlled Shot Peening to Produce Residual Compressive Stress and Improved Fatigue Life," Proceedings of a Conference on Residual Stress for Designers and Metallurgists, American Society for Metals, April, 1980.




Figure 3-1. Goodman diagram for replacement crankshafts.

SECTION FOUR

OPERATING HOURS LOGGED

AVAILABLE LOGGED HOURS OF OPERATION OF DSR-48, RATED 3500 KW @ 450 RPM

SERIAL NUMBER	LOCATION	KILOWATT RATING @ 450 RPM	TOTAL HOURS LOGGED	DATE LOGGED	AV. LOAD REPORTED	OTHER LOADS & HOURS REPORTED
74010 )	LILCO, Shoreham	3500	( 368	4-01-84 )		3500 KW & Above 114 Hrs.
74011 )			( 430	4-01-84 )	--	3500 KW & Above 116 Hrs.
74012 )			( 345	4-01-84 )		3500 KW & Above 110 Hrs.
75005 )	KOUSHENG, TAIWAN	3600	( 246	3-15-84 )	Mostly 100%	--
75006 )			( 221	3-15-84 )		
75007 )			( 368	3-15-84 )		
75008 )			( 299	3-15-84 )		
76010 )	DHUBA, SAUDI ARABIA	3500	( 19800	3-17-84 )		
76011 )			( 23300	3-17-84 )		
76012 )			( 23800	3-17-84 )	--	--
76013 )			( 19700	3-17-84 )		
76014 )			( 23500	3-17-84 )		
76026 )	ONEIZA, SAUDI ARABIA	3515	( 16204	3-17-84 )		3000/3200 KW for 9000 Hrs.
76027 )			( 12428	3-17-84 )	--	
76028 )			( 14978	3-17-84 )		
78029 )	U. OF TEXAS	3500	( 8180	3-15-84	1100 KW	--
78030 )			( 5385	3-01-84	1100 KW	--
78044 )	WADI DAWASIR, SAUDI ARABIA	3515	( 10882	3-17-84	2200/3000 KW	--
78045 )			( 10832	3-17-84	2200/3000 KW	--
78046 )			( 11212	3-17-84	2200/3000 KW	--
79002 )	RAFI SAUDI ARABIA	3515	( 12667	3-16-84	--	3300 KW for 6200 Hrs.
79003 )			( 11655	3-16-84	--	3200 KW for 8250 Hrs.
79004 )			( 13186	3-16-84	--	3200 KW for 5500 Hrs.
80001 )	RABIGH, SAUDI ARABIA	3515	( 10196	3-16-84	2700 KW	--
80002 )			( 10245	3-16-84	2800 KW	--
80003 )			( 11602	3-16-84	2800 KW	--