



GPU Nuclear Corporation
Post Office Box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4000
Writer's Direct Dial Number

April 10, 1992
C321-92-2117

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555


Gentlemen:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Special Report No. 92-01

Enclosed is Special Report No. 92-01 which is submitted in accordance with technical specification 3.12.G.3.

If there are any questions, please call Mr. Michael Heller, Licensing Engineer, at (609) 971-4680.

Sincerely,



J.J. Barton
Vice President and Director
Oyster Creek

Enclosure

cc: NRC Region 1 Administrator
NRC Resident Inspector
Oyster Creek NRC Project Manager

9204170151 920410
PDR ADOCK 05000219
S PDR

IF22
11

Special Report 92-01

Report Date: April 10, 1992

Occurrence Date: February 27, 1992

Identification of Occurrence:

The carbon dioxide (CO₂) fire suppression system for the 4160 volt switchgear was inoperable for greater than 14 days which requires a special report per technical specification 3.12.G.3.

Description of Occurrence:

On February 26, 1992, a CO₂ system valve stem leaking CO₂ was being repaired. Removal of insulation necessary to repair the leakage revealed corroded pipe and fittings which indicated the potential for failure of these components. On February 27, 1992, it was decided to exhaust the CO₂ from the tank and make repairs. The system was declared inoperable and a continuous firewatch with backup fire suppression equipment was established in accordance with technical specification 3.12.G.2.

Corrective Action:

A thorough examination of the CO₂ system was conducted. The corrosion is attributed to moisture intrusion into the piping insulation and possibly electro-galvanic reaction. The piping insulation, which was not an NFPA or vendor requirement for the original installation, was not and will not be reinstalled to avoid future corrosion problems. Corroded components including the CO₂ tank were replaced and the system was declared operable on March 27, 1992 after successful completion of a system functional test.