

MAY 31 1992

Docket No. 50-289

Mr. T. Gary Broughton
Vice President and Director, TMI-1
GPU Nuclear Corporation
Three Mile Island Nuclear Station
P. O. Box 480
Middletown, Pennsylvania 17057-0191

Dear Mr. Broughton:

Subject: Inspection No. 50-289/92-12

This letter refers to the safety inspection conducted by Messrs. J. C. Jang and J. J. Kottan of this office on May 19-20, 1992 of activities authorized by NRC License No. DPR-50 at the Three Mile Island Nuclear Station, Unit 1, Middletown, Pennsylvania and to the discussions of our findings held by Messrs. J. C. Jang and J. J. Kottan with Mr. D. Hassler and other members of your staff at the conclusion of the inspection.

Areas examined during this inspection are important to public health and safety, and are described in the NRC Region I Inspection Report which is enclosed with this letter. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

Within the scope of this inspection, we noted that your staff improved its knowledge in the areas of effluent radiation monitoring system calibration methods. Furthermore, we noted that your staff prepared complete, detailed packages of data to resolve NRC's concerns (two unresolved items) regarding effluent radiation monitoring system calibrations. These efforts were noteworthy as described in Sections 3.0 and 4.0 of this inspection report. No safety concerns or violations of regulatory requirements were identified.

OFFICIAL RECORD COPY

9206090026 920531
PDR ADOCK 05000289
Q PDR

11
IE 06

MAY 31 1992

No reply to this letter is required. Your cooperation with us in this matter is appreciated.

Sincerely,

Original Signed By:
James H. Joyner

James H. Joyner, Chief
Facilities Radiological Safety
and Safeguards Branch
Division of Radiation Safety
and Safeguards

Enclosure: NRC Region I Inspection Report No. 50-289/92-12

cc w/encl:

R. E. Rogan, Licensing and Nuclear Safety Director
M. R. Knight, TMI-1 Licensing Engineering
M. J. Ross, Operations and Maintenance Director, TMI-1
J. A. Knubel, Licensing and Regulatory Affairs Director
E. L. Blake, Jr., Esquire
TMI-Alert (TMIA)
K. Abraham, PAO (2)
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
Commonwealth of Pennsylvania

OFFICIAL RECORD COPY

MAY 31 1992

bcc w/encl:

Region I Docket Room (with concurrences)

R. Blough, DRP

J. Joyner, DRSS





J. Rogge, DRP

L. Rossbach, SRI, Beaver Valley

D. Vito, SRI, Oyster Creek

R. Lobel, OEDO

R. Hernan, PD 1-4, NRR

DRSS:RI JANG	DRSS:RI KOTTAN	DRSS:RI BORES	DRSS:RI JOYNER
5/28/92	5/28/92	5/28/92	5/31/92
			

OFFICIAL RECORD COPY