

OPERATING STATUS

1. Reporting Period: January, 1996 Gross Hours in Reporting Period: 744
 2. Currently Authorized Power Level (Mwt): 3565 Max. Depend. Capacity (MWe-Net): 1167
Design Electrical Rating (MWe-Net): 1170
 3. Power Level to Which Restricted (If Any) (MWe-Net): N/A
 4. Reasons for Restriction (If Any): N/A
- | | This Month | Yr. to Date | Cumulative |
|---|------------------|------------------|--------------------|
| 5. Number of Hours Reactor was Critical | <u>699.6</u> | <u>699.6</u> | <u>75,316.4</u> |
| 6. Reactor Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>339.8</u> |
| 7. Hours Generator on Line | <u>699.6</u> | <u>699.6</u> | <u>74,479.3</u> |
| 8. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>0.0</u> |
| 9. Gross Thermal Energy Generated (MWh) | <u>2,481,700</u> | <u>2,481,700</u> | <u>247,823,370</u> |
| 10. Gross Electrical Energy Generated (MWh) | <u>863,196</u> | <u>863,196</u> | <u>86,122,116</u> |
| 11. Net Electrical Energy Generated (MWh) | <u>828,168</u> | <u>828,168</u> | <u>82,265,019</u> |
| 12. Reactor Service Factor | <u>94.0%</u> | <u>94.0%</u> | <u>82.5%</u> |
| 13. Reactor Availability Factor | <u>94.0%</u> | <u>94.0%</u> | <u>82.9%</u> |
| 14. Unit Service Factor | <u>94.0%</u> | <u>94.0%</u> | <u>81.6%</u> |
| 15. Unit Availability Factor | <u>94.0%</u> | <u>94.0%</u> | <u>81.6%</u> |
| 16. Unit Capacity Factor (Using MDC) | <u>95.4%</u> | <u>95.4%</u> | <u>79.3%</u> |
| 17. Unit Capacity Factor (Using Design MWe) | <u>95.1%</u> | <u>95.1%</u> | <u>77.0%</u> |
| 18. Unit Forced Outage Rate | <u>6.0%</u> | <u>6.0%</u> | <u>4.8%</u> |
19. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of each):
Refuel VIII outage began February 3, 1996.
 20. If Shut Down at End of Report Period, Estimate Date of Startup: March 31, 1996

Wolf Creek Generating Station
Monthly Operating Report
January, 1996
Page 3 of 6