



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

WISCONSIN ELECTRIC POWER COMPANY

DOCKET NO. 50-266

POINT BEACH NUCLEAR PLANT, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 168
License No. DPR-24

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Wisconsin Electric Power Company (the licensee) dated May 26, 1994, as supplemented January 5, April 25 and October 12, 1995, and February 2 and March 1, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-24 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 168, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective immediately upon issuance. The Technical Specifications are to be implemented within 45 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Allen G. Hansen, Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of issuance: March 20, 1996



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

WISCONSIN ELECTRIC POWER COMPANY

DOCKET NO. 50-301

POINT BEACH NUCLEAR PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 172
License No. DPR-27

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Wisconsin Electric Power Company (the licensee) dated May 26, 1994, as supplemented January 5, April 25 and October 12, 1995, and February 2 and March 1, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-27 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 172, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective immediately upon issuance. The Technical Specifications are to be implemented within 45 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Allen G. Hansen, Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of issuance: March 20, 1996

ATTACHMENT TO LICENSE AMENDMENT NOS. 168 AND 172
TO FACILITY OPERATING LICENSE NOS. DPR-24 AND DPR-27
DOCKET NOS. 50-266 AND 50-301

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by amendment number and contain marginal lines indicating the area of change.

REMOVE

TS 15.3.1-7

TS 15.3.1-8

TS Figure 15.3.1-1

TS Figure 15.3.1-2

INSERT

TS 15.3.1-7

TS 15.3.1-8

TS Figure 15.3.1-1

TS Figure 15.3.1-2

of the vessel is computed to be 2.5×10^{19} neutrons/cm² for 40 years of operation at 1518 Mwt and 80 percent load factor.⁽²⁾ This maximum fluence is the exposure expected at the inner reactor vessel wall. However, the neutron fluence used to predict the ΔRT_{NDT} shift is the one-quarter shell thickness neutron exposure. The relationship between fluence at the vessel ID wall and the fluence at the one-quarter and three-quarter shell thickness locations is as presented in Regulatory Guide 1.99 Revision 2, "Radiation Damage to Reactor Vessel Materials."

(Reference 6)

Once the fluence is determined, the adjusted reference temperature used in revising the heatup and cooldown curves is obtained by utilizing the method in Section 1.1 of Regulatory Guide 1.99 Revision 2 (Reference 6) for the limiting weld material of both Unit 1 and Unit 2.

The heatup and cooldown curves presented in Figure 15.3.1-1 and 15.3.1-2 were calculated based on the above information and the methods of ASME Code Section III (1974 Edition), Appendix G, "Protection Against Nonductile Failure", and are applicable up to the operational exposure indicated on the figures.

The regulations governing the pressure-temperature limits (10 CFR 50 - Appendix G and ASME Code Section III - Appendix G) do not require additional margins for instrumentation uncertainties be added to the heatup and cooldown curves. This is because the inclusion of instrumentation uncertainties, in addition to other conservatisms in the methods for calculating the pressure temperature limits, is not necessary to protect the vessel from damage.

Unit 1 - Amendment No. ~~24, 53, 98, 125, 168~~

Unit 2 - Amendment No. ~~57, 59, 102, 129, 172~~

15.3.1-7

The actual temperature shift of the vessel material will be established periodically during operation by removing and evaluating reactor vessel material irradiation surveillance specimens installed near the inside wall of the reactor vessel in the core area. Since the neutron spectra at the irradiation samples and vessel inside radius are identified by a specified lead factor, the measured temperature shift for a sample is an excellent indicator of the effects of power operation on the adjacent section of the reactor vessel. If the experimental temperature shift (at the 30 ft-lb level) does not substantiate the predicted shift, new prediction curves and heatup and cooldown curves must be developed.

The pressure-temperature limit lines shown on Figure 15.3.1-1 for reactor criticality and for inservice leak and hydrostatic testing have been provided to assure compliance with the minimum temperature requirements of Appendix G to 10 CFR 50 for reactor criticality and for inservice leak and hydrostatic testing.

The spray should not be used if the temperature difference between the pressurizer and spray fluid is greater than 320F°. This limit is imposed to maintain the thermal stresses at the pressurizer spray line nozzle below the design limit.

The temperature requirements for the steam generator correspond with the measured NDT for the shell.

The reactor vessel materials surveillance capsule removal schedules have been developed based upon the requirements of the Code of Federal Regulations, Title 10, Part 50, Appendix H, and with consideration of ASTM Standard E-185-82. When the capsule lead factors are considered, the scheduled removal dates accommodate the weld data needs of all the participants in the Babcock and Wilcox Master Integrated Reactor Vessel Surveillance Program. Additionally, the schedule will provide plate/forging material data as well as fluence data corresponding to the expiration of the current licenses and of any future license extensions.


References

- (1) FSAR, Section 4.1.5
- (2) Westinghouse Electric Corporation, WCAP-12794, Rev. 2/12795, Rev. 2
- (3) Westinghouse Electric Corporation, WCAP-8743
- (4) Westinghouse Electric Corporation, WCAP-8738
- (5) Babcock & Wilcox, BAW 1803
- (6) Regulatory Guide 1.99, Revision 2

Unit 1 - Amendment No. ~~24, 98, 125, 131, 168~~ 15.3.1-8

Unit 2 - Amendment No. ~~57, 102, 128, 129, 135, 172~~

Figure 15.3.1-1/PBNP Units 1 & 2
Heatup Limitations Applicable to
23.6 Effective Full Power Years
(Approximately January 2001)



Unit 1 - Amendment 125, 168
Unit 2 - Amendment 129, 172

Figure 15.3.1-2/PBNP Units 1 & 2
Cooldown Limitations Applicable to
23.6 Effective Full Power Years
(Approximately January 2001)

