

ENCLOSURE 1

NOTICE OF VIOLATION

Duke Power Company
McGuire Unit 1

Docket Nos. 50-369
License Nos. NPF-9

During the Nuclear Regulatory Commission (NRC) inspection conducted on April 19, 1992 through May 16, 1992, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violation is identified below:

Technical Specification 6.8.1 requires that written procedures be established, implemented, and maintained covering the applicable procedures recommended in Appendix A of Regulatory Guide 1.33, Revision 2, February, 1978, which includes the operation of safety related systems, maintaining containment integrity, and performing surveillance tests on safety-related equipment. Licensee's Procedure OP/1/A/6250/03A, Enclosure 4.1, Establishing BW (Wet Layup Recirculation) Step 1.3, Requires that the condensate booster pumps be off for putting a steam generator in wet lay-up condition.

Contrary to the above, on May 6, 1992, a licensed operator failed to adhere to procedure OP/1/A/6250/03A, for putting a steam generator in wet layup condition, in that a condensate booster pump was left running. This resulted in the actuation on an engineered safety feature actuation, main steam isolation on high pressure negative rate change.

This is a Severity Level IV (Supplement I) violation and applies to Unit 1 only.

Pursuant to the provisions of 10 CFR 2.201, Duke Power Company is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555 with a copy to the Regional Administrator, Region II, and if applicable, a copy to the NRC Resident Inspector, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order may be issued to show cause why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Atlanta, Georgia
this 29 day of May 1992

9206230097 920529
PDR ADDCK 05000369
G PDR