

June 16, 1992

Docket No. 50-285

Mr. W. Gary Gates  
Division Manager - Nuclear Operations  
Omaha Public Power District  
444 South 16th Street Mall  
Mail Stop 8E/EP4  
Omaha, Nebraska 68102-2247

Dear Mr. Gates:

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 - AMENDMENT NO. 146 TO FACILITY  
OPERATING LICENSE NO. DPR-40 (TAC NO. M80911)

The Commission has issued the enclosed Amendment No. 146 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. This amendment consists of changes to the Technical Specifications (TS) in response to your application dated June 28, 1991, as supplemented November 27, 1991, and April 23, 1992.

The amendment revises the TS to increase the maximum allowable setpoint drift for the main steam safety valve (MSSV) setpoints from  $\pm 1\%$  to  $+3\%/-2\%$  and to specify lift settings for all MSSVs and for the two pressurizer safety valves.

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

Original signed by:

Steven D. Bloom, Acting Project Manager  
Project Directorate IV-1  
Division of Reactor Projects - III/IV/V  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 146 to DPR-40
2. Safety Evaluation

cc w/enclosures:

See next page

DISTRIBUTION:

Docket File

B. Roger	NRC/Local PDR	PD4-1 Reading
S. Little	M. Virgilio	J. Larkins
D. Hagan(MS3206)	ACRS(10) (MSP315)	OGC(MS15B18)
C. Grimes(MS11E22)	G. Hill(4)	Wanda Jones(MS7103)
OPA(MS2G5)	PD4-1 Plant File	S. Bloom
	OC/LFMB(MS4503)	P. Harrell,RIV

OFC	LA:PD4-1	PM:PD4-1	OGC	D:PD4-1
NAME	SLittle	SBloom	JPW	JLarkins
DATE	6/8/92	6/9/92	6/9/92	6/16/92

OFFICIAL RECORD COPY Document Name: FC780911.amd

9206250245 920616  
PDR ADOCK 05000285  
P PDR

NRC FILE CENTER COPY

LED  
111



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

June 16, 1992

Docket No. 50-285

Mr. W. Gary Gates  
Division Manager - Nuclear Operations  
Omaha Public Power District  
444 South 16th Street Mall  
Mail Stop 8E/EP4  
Omaha, Nebraska 68102-2247

Dear Mr. Gates:

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 - AMENDMENT NO. 146 TO FACILITY  
OPERATING LICENSE NO. DPR-40 (TAC NO. M80911)

The Commission has issued the enclosed Amendment No. 146 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. This amendment consists of changes to the Technical Specifications (TS) in response to your application dated June 28, 1991, as supplemented November 27, 1991, and April 23, 1992.

The amendment revises the TS to increase the maximum allowable setpoint drift for the main steam safety valve (MSSV) setpoints from  $\pm 1\%$  to  $+3\%/-2\%$  and to specify lift settings for all MSSVs and for the two pressurizer safety valves.

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

A handwritten signature in dark ink, appearing to read "Steven D. Bloom", is written over a horizontal line.

Steven D. Bloom, Acting Project Manager  
Project Directorate IV-1  
Division of Reactor Projects - III/IV/V  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 146 to DPR-40
2. Safety Evaluation

cc w/enclosures:  
See next page

Mr. W. Gary Gates  
Omaha Public Power District

Fort Calhoun Station, Unit No. 1

cc:

Harry H. Voigt, Esq.  
LeBoeuf, Lamb, Leiby & MacRae  
1875 Connecticut Avenue, NW  
Washington, D.C. 20009-5728

Mr. Jack Jensen, Chairman  
Washington County Board  
of Supervisors  
Blair, Nebraska 68008

Mr. Raymond P. Mullikin, Resident Inspector  
U.S. Nuclear Regulatory Commission  
Post Office Box 309  
Fort Calhoun, Nebraska 68023

Mr. Charles B. Brinkman, Manager  
Washington Nuclear Operations  
Combustion Engineering, Inc.  
12300 Twinbrook Parkway, Suite 330  
Rockville, MD 20852

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Harold Borchert, Director  
Division of Radiological Health  
Nebraska Department of Health  
301 Centennial Mall, South  
Post Office Box 95007  
Lincoln, Nebraska 68509

Mr. T. L. Patterson, Manager  
Fort Calhoun Station  
Post Office Box 399  
Fort Calhoun, Nebraska 68023