

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61242-9740
Tel 309-654-2241



ESK-96-036

March 25, 1996

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Subject: Quad Cities Nuclear Power Station Units 1 and 2
Complete Version of Technical Specification Upgrade Program (TSUP) and List
of Deferred Surveillance Requirements
NRC Docket Nos. 50-254 and 50-265

References: (a) J. S. Perry letter to U. S. NRC, dated March 1, 1996 (ComEd supplement to
TSUP Cleanup)
(b) P. L. Piet letter to U. S. NRC, dated November 14, 1995 (ComEd submittal for
TSUP Cleanup)
(c) J. L. Schrage letter to U. S. NRC, dated September 20, 1995 (ComEd submittal
for TSUP Section 6.0 for Quad Cities)

The purpose of this letter is to provide a complete version of the TSUP pages that reflect the current configuration of Quad Cities Station and to specify surveillance requirements that will not be current upon implementation of the TSUP project. The attached listing reflects all previously approved sections for the TSUP project and includes any additional changes identified in the referenced letters.

Each previous change to the TSUP pages, up to and including the referenced submittals, has received both on-site and off-site review, in accordance with station procedures. In addition, Quad Cities has performed additional, supplemental reviews of the TSUP pages to determine their adequacy and accuracy. Therefore, to the best of my knowledge and belief, the information contained therein is true and correct. Such information has been reviewed in accordance with Company practice and I believe it to be reliable.

ComEd also requests that implementation of the surveillances listed in Attachment B be delayed until the next refuel outage for each unit. These surveillances are new for Quad Cities Station and require the reactor to be in a shutdown condition to perform.


9603290101 960325
PDR ADOCK 05000254
P PDR

ADD 1

March 25, 1996

ComEd requests that the NRC staff review and approve the attached TSUP pages as well as approve the deferral of the performance of surveillances specified herein by April 21, 1996 in order to ensure that an orderly implementation of the project can be completed. If there are any further questions, please contact the Quad Cities Regulatory Assurance Supervisor, N. J. Chrissotimos.

Sincerely,


E. S. Kraft, Jr.
Site Vice President
Quad Cities Station

Attachments: A - List of Deferred Surveillance Requirements
B - Technical Specification Upgrade Program Pages - Complete Listing

cc: H. J. Miller, Regional Administrator - RIII
R. M. Pulsifer, Project Manager - NRR
C. G. Miller, Senior Resident Inspector - Quad Cities
Office of Nuclear Facility Safety - IDNS
R. J. Singer, MidAmerican Energy Company (without attachment)
D. C. Tubbs, MidAmerican Energy Company (without attachment)

ATTACHMENT A

Technical Specification Upgrade Program Quad Cities Nuclear Power Station

List of Deferred Surveillance Requirements (SR)

- SR 4.2.A.2: Logic System Functional Tests (LSFT), for isolation Actuation Instrumentation, Table 4.2.A-1, Item 4 a, Reactor Water Cleanup (RWCU) isolation on Standby Liquid Control (SBLC) initiation.
- SR 4.2.A.2: LSFTs, for Isolation Actuation Instrumentation, Table 4.2.A-1, Items 2.a, 2.b, 2.c and 2.d, Secondary Containment isolation.
- SR 4.2.C.2: LSFT for Anticipated Transient Without Scram (ATWS) - Recirculation Pump Trip (RPT).
- SR 4.6.F.1.b: LSFT for Main Steam Line (MSL) relief valves actuation high reactor pressure.

ATTACHMENT B

Technical Specification Upgrade Program Pages - Complete Listing
Quad Cities Nuclear Power Station