



COMBUSTION ENGINEERING OWNERS GROUP

**CENPD-279
SUPPLEMENT 7**

**ANNUAL REPORT ON ABB CE ECCS
PERFORMANCE EVALUATION MODELS**

FINAL REPORT

CEOG TASK 923

prepared for the
C-E OWNERS GROUP

February 1996

© Copyright 1996 Combustion Engineering, Inc. All rights reserved
ABB Combustion Engineering Nuclear Operations

9603290121 960326
PDR ADOCK 05000317
P PDR



ABSTRACT

This report describes changes and errors in the ABB Combustion Engineering evaluation models for ECCS analysis in 1995 per the requirements of 10CFR50.46. For this reporting period, one error in the input processing for the COMPERC-II refill/reflood code for large break LOCA analysis was found and corrected. No other changes were made to the ABB CE evaluation models for the large break, small break or post-LOCA long term cooling calculations.

Correction of the error in COMPERC-II had no effect on the cladding temperature (PCT) for large break LOCA. The sum of the absolute magnitudes of the PCT changes for large break LOCA from all reports to date continues to be less than 1 °F. No change occurred in the PCT for small break LOCA or post-LOCA long term cooling. Per the criteria of 10CFR50.46, no action beyond this annual report is required.

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
1.0	<u>INTRODUCTION</u>	1
2.0	<u>ABB CE CODES USED FOR ECCS EVALUATION</u>	3
3.0	<u>EVALUATION MODEL CHANGES AND ERROR CORRECTIONS</u>	4
3.1	COMPERC-II for Large Break LOCA	4
3.1.1	Code Description	
3.1.2	Error in COMPERC-II	
3.1.3	Correction of COMPERC-II Code Error	
3.1.4	Impact of COMPERC-II Error on PCT	
4.0	<u>CONCLUSIONS</u>	6
5.0	<u>REFERENCES</u>	7