

ATTACHMENT 2

PEACH BOTTOM ATOMIC POWER STATION  
UNITS 2 AND 3

Docket Nos. 50-277  
50-278

License Nos. DPR-44  
DPR-56

TECHNICAL SPECIFICATION CHANGES

List of Attached Pages

<u>Unit 2</u>	<u>Unit 3</u>
132	132

LIMITING CONDITIONS FOR OPERATIONSURVEILLANCE REQUIREMENTS3.5.F Minimum Low Pressure Cooling  
and Diesel Generator  
Availability

1. During any period when one diesel generator is inoperable, continued reactor operation is permissible only during the succeeding seven days unless such diesel generator is sooner made operable provided that the remaining diesel generators and the low pressure core and containment cooling systems which are powered by the remaining diesel generators are operable. If this requirement cannot be met, an orderly shutdown shall be initiated and the reactor shall be placed in the Cold Shutdown Condition within 24 hours.
2. Any combination of inoperable components in the core and containment cooling systems shall not defeat the capability of the remaining operable components to fulfill the cooling functions.
3. When irradiated fuel is in the reactor vessel and the reactor is in the Cold Shutdown Condition, both core spray systems, the LPCI and containment cooling systems may be inoperable, provided no work is being done which has the potential for draining the reactor vessel.
4. During a refueling outage, fuel and LPRM removal and replacement may be performed provided at least one of the following conditions below is satisfied:

4.5.F Minimum Low Pressure  
Cooling and Diesel  
Generator Availability

1. If a diesel generator becomes inoperable for any reason other than preplanned preventative maintenance or testing, the operable diesel generators shall be demonstrated to be operable immediately and daily thereafter.

LIMITING CONDITIONS FOR OPERATION3.5.F Minimum Low Pressure Cooling  
and Diesel Generator  
Availability

1. During any period when one diesel generator is inoperable, continued reactor operation is permissible only during the succeeding seven days unless such diesel generator is sooner made operable provided that the remaining diesel generators and the low pressure core and containment cooling systems which are powered by the remaining diesel generators are operable. If this requirement cannot be met, an orderly shutdown shall be initiated and the reactor shall be placed in the Cold Shutdown Condition within 24 hours.
2. Any combination of inoperable components in the core and containment cooling systems shall not defeat the capability of the remaining operable components to fulfill the cooling functions.
3. When irradiated fuel is in the reactor vessel and the reactor is in the Cold Shutdown Condition, both core spray systems, the LPCI and containment cooling systems may be inoperable, provided no work is being done which has the potential for draining the reactor vessel.
4. During a refueling outage, fuel and LPRM removal and replacement may be performed provided at least one of the following conditions below is satisfied:

SURVEILLANCE REQUIREMENTS4.5.F Minimum Low Pressure  
Cooling and Diesel  
Generator Availability

1. If a diesel generator becomes inoperable for any reason other than preplanned preventative maintenance or testing, the operable diesel generators shall be demonstrated to be operable immediately and daily thereafter.