

ENCLOSURE 1

NOTICE OF VIOLATION

Duke Power Company
McGuire Nuclear Station

Docket No. 50-369
License No. NPF-17

The following violation was identified during an inspection conducted on July 20 - August 20, 1984. The Severity Level was assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

Technical Specification 3.3.3.10 requires that the loose part detection system be operable in Modes 1 and 2. Further, if one or more channels are inoperable for more than thirty days, a report outlining the cause of the malfunction and plans for restoring the channel(s) is to be prepared and submitted within the next ten days.

Contrary to the above, on July 27, 1984, the inspector has noted that the licensee failed to prepare and submit a special report within the required time frame when one of the four channels of the Unit 1 loose part detection system was declared inoperable on June 12, 1984 and remained in that state until the finding was made.

This is a Severity Level V violation (Supplement I).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: SEP 27 1984