LICENSEE: CLEVELAND ELECTRIC ILLUMINATING COMPANY

FACILITY: PERRY NUCLEAR POWER PLANT, UNIT 1

SUBJECT: SUMMARY OF MEETING HELD ON FEBRUARY 15, 1996

TO DISCUSS THE DRYWELL SHIELD DOORS

On February 15, 1996, NRC staff members met at Rockville, Maryland, with employees of Cleveland Electric Illuminating Company (CEI) to discuss the drywell shield doors at the Perry Nuclear Power Plant. A list of attendees is included as Attachment 1.

The licensee made a presentation concerning the drywell shield doors based on the handout included as Attachment 2. They determined that open drywell shield doors during power ascension is an unreviewed safety question, and therefore, they would submit a license amendment for NRC approval of the issue. The NRC staff commented that the licensee should fully review the original design specifications and should use minimal ASME Code allowables for material property values instead of certified test results. Also, the NRC staff asked how much safety margin was there, if you just considered the 2 inch tie rods supporting the doors. The licensee stated that they would consider the comments and question in the development of their license amendment submittal.

Original signed by:

Jon B. Hopkins, Sr. Project Manager Project Directorate III-3 Division of Reactor Projects III/IV Office of Nuclear Reactor Regulation

Docket No. 50-440

Attachments: As stated

cc w/atts: See next page

DISTRIBUTION: See attached page

DOCUMENT NAME: G:\PERRY\M94294.MTS

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	LA: PD3-3	E	PM: PD3-3	E
NAME	DFoster-Curseen		JHopkins:sw /	
DATE	03/27/96	de	03/27/96 4	

OFFICIAL RECORD COPY

010093

NRC FILE CENTER COPY

9604010406 960327 PDR ADOCK 05000440 P PDR Perry Nuclear Power Plant Centerior Service Company

cc:

Mr. James D. Kloosterman Regulatory Affairs Manager Cleveland Electric Illuminating Co. Perry Nuclear Plant P.O. Box 97, E-210 Perry, Ohio 44081

Jay E. Silberg, Esq. Shaw, Pittman, Potts & Trowbridge 2300 N Street, N.W. Washington, D.C. 20037

Ms. Mary E. O'Reilly Centerior Energy Corporation 300 Madison Avenue Toledo, Ohio 43652

Resident Inspector's Office U.S. Nuclear Regulatory Commission Parmly at Center Road Perry, Ohio 44081

Regional Administrator U.S. NRC, Region III 801 Warrenville Road Lisle, Illinois 60532-4531

Lake County Prosecutor
Lake County Administration Bldg.
105 Main Street
Painesville, Ohio 44077

Ms. Sue Hiatt OCRE Interim Representative 8275 Munson Memtor, Ohio 44060

Terry J. Lodge, Esq. 618 N. Michigan Street, Suite 105 Toledo, Ohio 43624

Ashtabula County Prosecutor 25 West Jefferson Street Jefferson, Ohio 44047

State of Ohio Public Utilities Commission East Broad Street Columbus, Ohio 43266-0573

James R. Williams, Chief of Staff Ohio Emergency Management Agency 2825 West Granville Road Worthington, Ohio 43085 Unit Nos. 1 and 2

Mr. Richard D. Brandt, Plant Manager Cleveland Electric Illuminating Co. Perry Nuclear Power Plant P.O. Box 97, SB306 Perry, Ohio 44081

Mr. James W. Harris, Director Division of Power Generation Ohio Dept. of Industrial Relations P.O. Box 825 Columbus, Ohio 43216

The Honorable Lawrence Logan Mayor, Village of Perry 4203 Harper Street Perry, Ohio 44081

The Honorable Robert V. Orosz Mayor, Village of North Perry North Perry Village Hall 4778 Lockwood Road North Perry Village, Ohio 44081

Attorney General
Department of Attorney General
30 East Broad Street
Columbus, Ohio 43216

Radiological Health Program Ohio Department of Health P. O. Box 118 Columbus, Ohio 43266-0118

Ohio Environmental Protection Agency DERR--Compliance Unit ATTN: Mr. Zack A. Clayton P.O. Box 1049 Columbus, Ohio 43266-0149


Mr. Thomas Haas, Chairman Perry Township Board of Trustees 3750 Center Rd., Box 65 Perry, Ohio 44081

Mr. Donald C. Shelton
Acting Vice President
Nuclear - Perry
Centerior Service Company
P.O. Box 97, A200
Perry, Ohio 44081

ATTENDEES

February 15, 1996


NAME	ORGANIZATION	
J. Hopkins	NRC	
B. Ferrell	CEI	
J. Kloosterman	CEI	
G. Bagchi	NRC	
C. Tan	NRC	
S. Lee	NRC	
G. Marcus	NRC	
J. Powers	CEI	
S. Meyer	CEI	
C. Angstadt	CEI	
T. Adams	CEI/Stevenson & Associates	



DRYWELL AIRLOCK SHIELD DOORS

James J. Powers III
Design Engineering Manager

February 15, 1996



INTRODUCTION

- Shield Door Function is Radiation Shielding Only; i.e., ALARA
- Drywell Access Required During Power Ascension
 - MSIV Yoke Guide Adjustments
 - System Boundary Inspections for Leakage
- Shield Doors are Steel Plate Structure Filled With Concrete
 - Suspended from a Monorail System
 - Slide Apart Similar to Closet Doors




INTRODUCTION

- Shield Door Suspension Not Evaluated for Dynamic Loads When Open
- Need to Evaluate Supported System Operability and Whether Doors are Adequately Restrained
- Evaluation Performed for Interim Acceptability
- Open Shield Doors During Power Ascension Determined to be a USQ
- 10CFR50.59c Submittal of a USAR Change Under 10CFR50.90



CHRONOLOGY

- Dynamic Load Design Issue Identified at Restart from RFO4
 - Condition Report CR 94-1149 Written
- Condition Report Interim Acceptability Analysis Completed April 1995
 - Guidance from GL 91-18 Applied
 - Interim Acceptability Demonstrated
- Initial Design Analysis for Doors in Open Position Completed in November 1995
- Support Structure Reanalyzed in January 1996
 - Interim Acceptability Reconfirmed Using Guidance of GL 91-18
 - Acceptance Criteria Established for Long Term



CURRENT ANALYSIS

- Shield Door Support System Analyzed Using ANSYS Finite Element Model
- Several Members and Connections Stressed Beyond Design Basis
 Allowables for Design Basis Load Combinations
- Functional Acceptance Criteria Developed
 - Monorail Suspension System
 - Platform Steel




- Monorail Suspension Structure Functional Evaluation:
 - Structural Integrity (Door Restraint) of Primary Concern
 - Load Combinations Involving SRV Were Combined By SRSS
 - Allowable Stress for Load Combinations Involving OBE Raised From $0.6F_{\gamma}$ to F_{γ}
 - Pool Swell Loads Not Concurrent With SSE
 - Limited Structural Energy Absorption Considered by Use of Inelastic Response Spectra
 - Only 90% of Plastic Section Modulus Applied
 - Maximum Principal Strain Limited to 20% Ultimate Strain
- Acceptance Criteria Met



- Platform Functional Evaluation:
 - Continued Support of SSCs of Primary Concern
 - Design Basis Load Combinations Applied
 - Allowable Stress Increased From 0.6F_Y to F_Y
 - Operating Load Case: D + SRV₁ + OBE
- Acceptance Criteria Met



- Conservatisms Supporting Functionality:
 - Conservative Design Basis Hydrodynamic Spectra Used
 - Analyses Conducted as Equivalent Static Linear Elastic; No Non-Linear Time History Applied
 - No Components Which Would Exhibit a Brittle Failure Mode
 - Isolated Application of Maximum Strain Criteria




SCHEDULE FOR RESOLUTION

- NRC Approval Required Prior to Power Ascension Mode 2
- 10CFR50.90 Submittal Planned February 21, 1996
- Mode 2 Currently Scheduled for March 25, 1996




CONCLUSIONS

- Guidance of Generic Letter 91-18 Used for Interim Acceptability
- Shield Doors in the Open Position Beyond RFO5 Considered Acceptable Based On:
 - a) Limited Strain Deformation of Support System During Postulated Design Basis Dynamic Loads,
 - b) Functionality of Shield Door Support System Maintained,
 - Concrete Shelf and Platform Support Steel Beneath Shield Doors Limit Vertical Movement of Doors.



DRYWELL AIRLOCK SHIELD DOORS



DISTRIBUTION FOR MEETING SUMMARY DATED: March 27, 1996 Docket File PUBLIC PDIII-3 r/f OGC ACRS

E-MAIL
W. Russell/F. Miraglia (WTR/FJM)

R. Zimmerman (RPZ)

J. Roe (JWR) E. Adensam (EGA1)

G. Marcus (GHM)

D. Foster-Curseen (DJF3)

E. Jordan (ELJ1) G. Bagchi (GXB1)

C. Tan (CPT)

S. Lee (SSL)

M. Satorius (MAS)

B. McCabe (BCM)

W. Axelson, RIII (WLA)