

ENCLOSURE 1

NOTICE OF VIOLATION

Mississippi Power and Light Company  
Grand Gulf

Docket No. 50-416  
License No. NPF-13

The following violation was identified during an inspection conducted on August 27 - September 14, 1984. The Severity Level was assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

Technical Specifications 6.8.1 requires written instructions be established, implemented and maintained.

Contrary to the above, the requirements of Technical Section Instruction 09-S-02-402, Rev. 1, "Individual Control Rod Scram to Reduce Flange Leakage", were not met in that on September 12, 1984, a proper hydraulic control unit valve lineup was not made.

This is a Severity Level IV violation (Supplement I).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date:     OCT 17 1984