PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-III-84-109 Date 12/14/84 DMB This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the staff on this date. Commonwealth Edison Company Facility: Licensee Emergency Classification: LaSalle, Unit 2 Notification of an Unusual Event Marseilles, IL 61341 Alert Docket No. 50-374 Site Area Emergency General Emergency X Not Applicable SHUTDOWN GREATER THAN 48 HOURS Subject: On December 14, 1984 at 1:33 p.m. (CST), Unit 2 scrammed from 97% power due to a turbine trip on high vibration. The licensee's investigation of the high vibration turbine trip is continuing. The licensee plans on doing various maintenance items prior to restarting the the unit, which is expected to take five days. The State of Illinois will be notified. This information is current as of 3:15 p.m. (CST) on December 14, 1984.

CONTACT:

FTS388-5696

MNBB 426

EDO

PA

MPA

ELD

FTS 388-5656

DISTRIBUTION:

H. St. 434 Chairman Palladino Comm. Roberts Comm. Asselstine

Comm. Bernthal Comm. Zech SECY

ACRS CA

PDR

SP

NRR

Air Rights 4.3/

Phillips 2/5

E/W 4.54 IE

OIA AEOD

INPO 7,37 NSAC 7:30 NMSS RES

> MAIL: ADM: DMB

DOT: Trans Only

Willste 435

Applicable Resident Site 4,46

Regions I 4,40, II 443, IV 7,20, V 7,25 Licensee (Corporate Office) 4,47

Rev. 07/06/84 0