



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ARKANSAS POWER & LIGHT COMPANY

DOCKET NO. 50-313

ARKANSAS NUCLEAR ONE, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 90
License No. DPR-51

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Arkansas Power and Light Company (the licensee) dated October 9, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.c.(2) of Facility Operating License No. DPR-51 is hereby amended to read as follows:


8501020121 841220
PDR ADOCK 05000313
P PDR

Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 90, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 20, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 90

FACILITY OPERATING LICENSE NO. DPR-51

DOCKET NO. 50-313

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains vertical lines indicating the area of change.

Remove

40

Insert

40

3.4 STEAM AND POWER CONVERSION SYSTEM

Applicability

Applies to the turbine cycle components for removal of reactor decay heat.

Objective

To specify minimum conditions of the turbine cycle equipment necessary to assure the capability to remove decay heat from the reactor core.

Specifications

3.4.1 The reactor shall not be heated, above 280°F unless the following conditions are met:

1. Capability to remove a decay load of 5% full reactor power by at least one of the following means:
 - a. A condensate pump and a main feedwater (MFW) pump, using turbine by-pass valve.
 - b. A condensate pump and the auxiliary feedwater (AFW) pump using turbine by-pass valve.
- **2. Fourteen of the steam system safety valves are operable.
3. A minimum of 16.3 ft. (107,000 gallons) of water is available in the condensate storage tank.
4. Both emergency feedwater (EFW) pumps and both EFW block valves are capable of automatic actuation, or a dedicated operator is available for their operation.*
5. Both main steam block valves and both main feedwater isolation valves are operable.
6. The emergency feedwater valves associated with Specification 3.4.1.4 shall be operable.

3.4.2 The Steam Line Break Instrumentation and Control System (SLBIC) shall be operable when main steam pressure exceeds 700 psig and shall be set to actuate at 600 ± 25 psig.

* One train of EFW may be removed from the control-grade automatic actuation mode for purposes of surveillance testing of the automatic actuation circuitry for a period not to exceed one (1) hour per test without invoking the reporting requirements of Specification 6.12.3.

** Except that during hydrotests, with the reactor subcritical, fourteen of the steam system safety valves may be gagged and two (one on each header), may be reset for the duration of the test, to allow the required pressure for the test to be attained.