





Steven K. Sewell Senior Director, Engineering & Regulatory Affairs

Ref

Luminant P.O. Box 1002 6322 North FM 56 Glen Rose, TX 76043 • 254.897.6113

10 CFR 50.55a

CP-202000269 TXX-20030

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555-0001

04/10/2020

SUBJECT: COMANCHE PEAK NUCLEAR POWER PLANT (CPNPP)

DOCKET NO. 50-446

SUPPLEMENT TO INSERVICE INSPECTION (ISI) PROGRAM RELIEF REQUEST

Reference 1. Letter TXX-20026 from Steven K. Sewell to the NRC "Inservice Inspection (ISI) and Inservice Test (IST) Program Relief Requests" dated April 7, 2020 (ML20099D059)

2. April 9, 2020 phone call between NRC and Jack Hicks, CPNPP Manager, Regulatory Affairs

Dear Sir or Madam:

Vistra Operations Company LLC ("Vistra OpCo") provides the following clarifying information to supplement the Inservice Inspection (ISI) Program Relief Request Number 2A3-2 submitted with Reference 1:

- Section 1 of the ISI Relief Request describes the ASME Code components affected as "Comanche Peak Unit 2 ASME Class 1, 2, and 3 components and component supports." The affected components and supports are itemized in Table 1 of the request.
- The hardships associated with conducting the visual examinations (VT-3) listed in Table 1 of the ISI Relief Request are related to the availability of VT-3 qualified technicians. ASME Section XI, IWA-2300 provides specific qualification requirements per ASME Section XI and ANSI/ASNT CP-189 for ISI examiners. CPNPP has a limited number of site nondestructive examination (NDE) personnel capable of performing VT-3 examinations. CPNPP has relied on contracted personnel to perform ISI Program VT-3 examinations since initial commercial operation commenced. The contracted personnel are very proficient and accustomed to performing ISI VT-3 examinations. The site personnel qualified to perform VT-3 examinations are quality control (QC) inspectors. The availability of the QC inspectors is extremely limited due to their support of many other critical outage activities.
- Any reference to a Snubber examination in Table 1 includes only that portion of the component support not excluded from Section XI examination as defined by ASME Section XI Figure IWF-1300-1(f).

6555 SIERRA DRIVE IRVING, TEXAS 75039 0214-812-4600 VISTRAENERGY.COM

This communication contains no new commitments.

Should you have any questions, please contact James Barnette at (254) 897-5866 or james.barnette@luminant.com.

Sincerely,

Steven K. Sewell

c - Scott Morris, Region IV [Scott.Morris@nrc.gov]
Dennis Galvin, NRR [Dennis.Galvin@nrc.gov]
John Ellegood, Senior Resident Inspector, CPNPP [John.Ellegood@nrc.gov]
Neil Day, Resident Inspector, CPNPP [Neil.Day@nrc.gov]