

UNITED STATES NUCLEAR REGULATORY COMMISSIONPUBLIC SERVICE COMPANY OF NEW HAMPSHIREDOCKET NO. 50-433NOTICE OF WITHDRAWAL OF APPLICATION FORAMENDMENT TO FACILITY OPERATING LICENSE

The United States Nuclear Regulatory Commission (the Commission) has granted the request of Public Service Company of New Hampshire (the licensee) to withdraw its March 23, 1992 application for proposed amendment to Facility Operating License No. NPF-86 for the Seabrook Station, located in Seabrook Township, Rockingham County, New Hampshire.

The proposed amendment would have revised Technical Specification Surveillance Requirement 4.6.1.2.a to maintain the 40 plus or minus 10 month testing interval for Type A Containment Integrated Leak Rate Tests, but eliminate the requirement to perform three Type A tests in each 10 year service period. The requested amendment also proposed to decouple every third Type A Containment Integrated Leak Rate Test in a 10 year service period from the 10 year plant inservice inspection shutdown.

However, by letter dated June 1, 1992, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated March 23, 1992, and the licensee's letter, dated June 1, 1992, which withdrew the application for license amendment. The above documents are available for public inspection at the Commission's Public Document Room,