



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

COMMONWEALTH EDISON COMPANY

DOCKET NO. 50-237

DRESDEN NUCLEAR POWER STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 115
License No. DPR-19


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Commonwealth Edison Company (the licensee) dated October 14, 1991, as supplemented February 6, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-19 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 115, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Richard J. Barrett, Director
Project Directorate III-2
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 29, 1992

ATTACHMENT TO LICENSE AMENDMENT NO. 115

FACILITY OPERATING LICENSE NO. DPR-19

DOCKET NO. 50-237

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the attached pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE

1/2.1-5
B 1/2.1-15
3/4.1-5
3/4.1-7
3/4.1-10
B 3/4.1-16
B 3/4.1-20

INSERT

1/2.1-5
B 1/2.1-15
3/4.1-5
3/4.1-7
3/4.1-10
B 3/4.1-16
B 3/4.1-20

1.1 SAFETY LIMIT (Cont'd.)

2.1 LIMITING SAFETY SYSTEM SETTING
(Cont'd.)

- E. Turbine stop valve scram shall be less than or equal to 10% valve closure from full open.
- F. Generator Load Rejection Scram which initiates from actuation of the fast acting solenoid valve pressure switches shall be greater than or equal to 460 psig EHC fluid pressure.
- G. Main Steamline Isolation Valve Closure Scram shall be less than or equal to 10% valve closure from full open.
- H. Main Steamline Pressure initiation of main steamline isolation valve closure shall be greater than or equal to 850 psig.
- I. Turbine Control Valve Fast Closure Scram on loss of control oil pressure shall be set at greater than or equal to 900 psig.

2.1 LIMITING SAFETY SYSTEM SETTING BASES (Cont'd.)

The design of the ECCS components to meet the above criteria was dependent on three previously set parameters: the maximum break size, the low water level scram setpoint and the ECCS initiation setpoint. To lower the setpoint for initiation of the ECCS could lead to a loss of effective core cooling. To raise the ECCS initiation setpoint would be in a safe direction, but it would reduce the margin established to prevent actuation of the ECCS during normal operation or during normally expected transients.

- E. Turbine Stop Valve Scram - The turbine stop valve closure scram trip anticipates the pressure, neutron flux and heat flux increase that could result from rapid closure of the turbine stop valves. With a scram trip setting of 10 percent of valve closure from full open, the resultant increase in surface heat flux is limited such that MCPR remains above the MCPR fuel cladding integrity safety limit, even during the worst case transient that assumes the turbine bypass is closed.
- F. Generator Load Rejection Scram - The generator load rejection scram is provided to anticipate the rapid increase in pressure and neutron flux resulting from fast closure of the turbine control valves due to a load rejection and subsequent failure of the bypass; i.e., it prevents MCPR from becoming less than the MCPR fuel cladding integrity safety limit for this transient. For the load rejection without bypass transient from 100% power, the peak heat flux (and therefore LHGR) increases on the order of 15% which provides wide margin to the value corresponding to fuel center-line melting and 1% cladding strain.
- The trip setpoint of greater than or equal to 460 psig EHC fluid pressure was developed to ensure that the pressure switch is actuated prior to closure of the turbine control valves (at approximately 400 psig EHC fluid pressure) yet assure that the system is not actuated unnecessarily due to EHC system pressure transients which may cause EHC system pressure to momentarily decrease.
- G. Reactor Coolant Low Pressure Initiates Main Steam Isolation Valve Closure - The low pressure isolation at 850 psig was provided to give protection against fast reactor depressurization and the resulting rapid cooldown of the vessel. Advantage was taken of the scram feature which occurs when the main steam line isolation valves are closed to provide for reactor shutdown so that operation at pressures lower than those specified in the thermal hydraulic safety limit does not occur, although operation at a pressure lower than 850 psig would not necessarily constitute an unsafe condition.
- H. Main Steam Line Isolation Valve Closure Scram - The low pressure isolation of the main steam lines at 850 psig was provided to give protection against rapid reactor depressurization and the resulting rapid cooldown of the vessel. Advantage was taken of the scram feature which occurs when the main steam line isolation valves are closed, to provide for reactor shutdown so that high power operation at low reactor pressure does not occur, thus providing protection for the fuel cladding integrity safety limit. Operation of the

TABLE 3.1.1

REACTOR PROTECTION SYSTEM (SCRAM) INSTRUMENTATION REQUIREMENTS

Minimum Number Operable Inst. Channel (1) System	Trip Function	Trip Level Setting	Modes in Which Function Must be Operable			Action*
			Refuel (6)	Startup/Hot Standby	Run	
	Mode Switch in Shutdown		X	X	X	A
1	Manual Scram		X	X	X	A
	IRM					
3	High Flux	(LT/E) 120/125 of Full Scale	X	X	N/A	A
3	Inoperative		X	X	N/A	A
	APRM					
2	High Flux	Specification 2.1.A.1	X	X(8)	X	A or B
2	Inoperative**		X	X(8)	X	A or B
2	High Flux (15% Scram)	Specification 2.1.A.2	X	X	N/A	A
2	High Reactor Pressure	(LT/E) 1060 psig	X(10)	X	X	A
2	High Drywell Pressure	(LT/E) 2 psig	X(7), X(9)	X(7), (9)	X(9)	A
2	Reactor Low Water Level	(GT/E) 1 inch***	X	X	X	A
2 (Per Bank)	High Water Level in Scram Discharge Volume (Thermal and dP Switch)	(LT/E) 40 inches above bottom of the Instrument Volume	X(2)	X	X	A or D
2	Turbine Condenser Low Vacuum	(GT/E) 23 in. Hg Vacuum	X(3)	X(3)	X	A or C
2	Main Steam Line High Radiation	(LT/E) 3 X Normal Full Power Background	X	X	X(11)	A or C
4(5)	Main Steam Line Isolation Valve Closure	(LT/E) 10% Valve Closure	X(3)	X(3)	X	A or C
2	Generator Load Rejection, turbine control valve trip system oil pressure low	(GT/E) 460 psig****	X(4)	X(4)	X(4)	A or C
2	Turbine Stop Valve Closure	(LT/E) 10% Valve Closure	X(4)	X(4)	X(4)	A or C
2	Turbine Control - Loss of Control Oil Pressure	(GT/E) 900 psig	X(4)	X(4)	X(4)	A or C

Notes: (LT/E) = Less than or equal to.
(GT/E) = Greater than or equal to.
(Notes continue on next two pages)

NOTES: (For Table 3.1.1 Cont'd)

Required changes in Main Steam Line Radiation Monitor trip setting will be made within 24 hrs except during controlled power descensions at which time the setpoint change will be made prior to going below 20% power. If due to a recirculation pump trip or other unanticipated power reduction event the reactor is below 20% power without the setpoint change, control rod motion will be suspended until the necessary trip setpoint adjustment is made.

- * If the first column cannot be met for one of the trip systems, that trip system shall be tripped.

If the first column cannot be met for both trip systems, the appropriate actions listed below shall be taken:

- a. Initiate insertion of operable rods and complete insertion of all operable rods within 4 hours.
- b. Reduce power level to IRM range and place mode switch in the Startup/Hot Standby position within 8 hours.
- c. Reduce turbine load and close main steam line isolation valves within 5 hours.
- d. In the refuel mode, when any control rod is withdrawn, suspend all operations involving core alterations and insert all insertable control rods within one hour.

- ** An APRM will be considered inoperable if there are less than 2 LPRM inputs per level or there are less than 50% of the normal complement of LPRM's to an APRM.

- *** 1 inch on the water level instrumentation is greater than or equal to 504" above vessel zero (see Bases 3.2).

- **** Trip is indicative of turbine control valve fast closure (due to low EHC fluid pressure) as a result of fast acting solenoid valve actuation.

TABLE 4.1.2
 SCRAM INSTRUMENTATION CALIBRATIONS
 MINIMUM CALIBRATION FREQUENCIES FOR REACTOR PROTECTION INSTRUMENT CHANNELS

<u>Instrument Channel</u>	<u>Group (1)</u>	<u>Calibration Test</u>	<u>Minimum Frequency (2)</u>
* High Flux IRM	C	Comparison to APRM after Heat Balance	Every Shutdown (4)
High Flux APRM Output Signal	B	Heat Balance	Once Every 7 Days
Flow Bias	B	Standard Pressure and Voltage Source	Refueling Outage
High Reactor Pressure	A	Standard Pressure Source	Every 3 Months
High Drywell Pressure	A	Standard Pressure Source	Every 3 Months
Reactor Low Water Level	B	Water Level	(5)
Turbine Condenser Low Vacuum	A	Standard Vacuum Source	Every 3 Months
Main Steam Line High Radiation	B	Standard Current Source (3)	Every 3 Months
Turbine Control - Loss of Control Oil Pressure	A	Pressure Source	Every 3 Months
High Water Level in Scram Discharge Volume (dp only)	A	Water Level	Once per Refueling Outage
Generator Load Rejection	A	Pressure Source	Once per Refueling Outage

NOTES: (For Table 4.1.2)

1. A description of the three groups is included in the bases of this Specification.
2. Calibration tests are not required when the systems are not required to be operable or are tripped. If tests are missed, they shall be performed prior to returning the systems to an operable status.
3. The current source provides an instrument channel alignment. Calibration using a radiation source shall be made during each refueling outage.
- *4. If reactor startups occur more frequently than once per week, the functional test need not be performed; i.e., the maximum functional test frequency shall be once per week.
5. Trip units are calibrated monthly concurrently with functional testing (staggered one channel out of 4 every week). Transmitters are calibrated once per operating cycle.

4.1 SURVEILLANCE REQUIREMENT BASES (Cont'd.)

of the sensor failure rate and the test interval. A three-month test interval was planned for group (A) sensors. This is in keeping with good operating practice, and satisfies the design goal for the logic configuration utilized in the Reactor Protection System.

To satisfy the long-term objective of maintaining an adequate level of safety throughout the plant lifetime, a minimum goal of 0.9999 at the 95% confidence level is proposed. With the (1 out of 2) X (2) logic, this requires that each sensor have an availability of 0.993 at the 95% confidence level. This level of availability may be maintained by adjusting the test interval as a function of the observed failure history (See Reference 6). To facilitate the implementation of this technique, Figure 4.1.1 is provided to indicate an appropriate trend in test interval. The procedure is as follows:

1. Like sensors are pooled into one group for the purpose of data acquisition.
2. The factor M is the exposure hours and is equal to the number of sensors in a group, n, times the elapsed time T ($M = nT$).
3. The simulated number of unsafe failures is plotted as an ordinate against M as an abscissa on Figure 4.1.1.
4. After a trend is established, the appropriate monthly test interval to satisfy the goal will be the test interval to the left of the plotted points.
5. A test interval of one month will be used initially until a trend is established.

The turbine control valve fast acting solenoid valve pressure switches directly measure the trip oil pressure that causes the turbine control valves to close in a rapid manner. The reactor scram setpoint was developed in accordance with NEDC-31336, "General Electric Instrument Setpoint Methodology" dated October 1986. As part of the calculation, a specific calibration period is utilized to achieve a nominal trip point and an allowable setpoint (Technical Specification value). The nominal setpoint is procedurally controlled. Based on the calculation input, the calibration period is defined to be every Refueling Outage.

Group (B) devices utilize an analog sensor followed by an amplifier and a bi-stable trip circuit. The sensor and amplifier are active components and a failure is almost always accompanied by an alarm and an indication of the source of trouble. In the event of failure, repair or substitution can start immediately. An "as-is" failure is one that "sticks"

Reference 6:
Reliability of Engineered Safety Features as a Function of Testing Frequency, I.M. Jacobs, Nuclear Safety, Vol. 9, No. 4, July-Aug. 1968, pp. 310-312.

4.1 SURVEILLANCE REQUIREMENT BASES (Cont'd.)

A comparison of Tables 4.1.1 and 4.1.2 indicates that six instrument channels have not been included in the latter Table. These are: Mode Switch in Shutdown, Manual Scram, High Water Level in Scram Discharge Volume dP and Thermal Switches, Main Steam Line Isolation Valve Closure, and Turbine Stop Valve Closure. All of the devices or sensors associated with these scram functions are simple on-off switches and, hence, calibration is not applicable; i.e., the switch is either on or off. Further, these switches are mounted solidly to the device and have a very low probability of moving; e.g., the switches in the scram discharge volume tank. Based on the above, no calibration is required for these six instrument channels.

- B. The FDLRC shall be checked once per day to determine if the APRM gains or scram requires adjustment. This may normally be done by checking the LPRM readings, TIP traces, or process computer calculations.

Only a small number of control rods are moved daily and thus the peaking factors are not expected to change significantly and thus a daily check of the FDLRC is adequate.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

COMMONWEALTH EDISON COMPANY

DOCKET NO. 50-249

DRESDEN NUCLEAR POWER STATION, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 112
License No. DPR-25


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Commonwealth Edison Company (the licensee) dated October 14, 1991, as supplemented February 6, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 3.B. of Facility Operating License No. DPR-25 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 112, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Richard J. Barrett, Director
Project Directorate 111-2
Division of Reactor Projects - 111/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 29, 1992

ATTACHMENT TO LICENSE AMENDMENT NO. 112

FACILITY OPERATING LICENSE NO. DPR-25

DOCKET NO. 50-249

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the attached pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE

1/2.1-5
B 1/2.1-15
3/4.1-5
3/4.1-7
3/4.1-10
B 3/4.1-16
B 3/4.1-20

INSERT

1/2.1-5
B 1/2 1-15
3/4.1-5
3/4.1-7
3/4.1-10
B 3/4.1-16
B 3/4.1-20

1.1 SAFETY LIMIT (Cont'd.)

2.1 LIMITING SAFETY SYSTEM SETTING
(Cont'd.)

- E. Turbine stop valve scram shall be less than or equal to 10% valve closure from full open.
- F. Generator Load Rejection Scram which initiates from actuation of the fast acting solenoid valve pressure switches shall be greater than or equal to 460 psig CHC fluid pressure.
- G. Main Steamline Isolation Valve Closure Scram shall be less than or equal to 10% valve closure from full open.
- H. Main Steamline Pressure initiation of main steamline isolation valve closure shall be greater than or equal to 850 psig.
- I. Turbine Control Valve Fast Closure Scram on loss of control oil pressure shall be set at greater than or equal to 900 psig.

2.1 LIMITING SAFETY SYSTEM SETTING BASES (Cont'd.)

The design of the ECCS components to meet the above criteria was dependent on three previously set parameters: the maximum break size, the low water level scram setpoint and the ECCS initiation setpoint. To lower the setpoint for initiation of the ECCS could lead to a loss of effective core cooling. To raise the ECCS initiation setpoint would be in a safe direction, but it would reduce the margin established to prevent actuation of the ECCS during normal operation or during normally expected transients.

- E. Turbine Stop Valve Scram - The turbine stop valve closure scram trip anticipates the pressure, neutron flux and heat flux increase that could result from rapid closure of the turbine stop valves. With a scram trip setting of 10 percent of valve closure from full open, the resultant increase in surface heat flux is limited such that MCPR remains above the MCPR fuel cladding integrity safety limit, even during the worst case transient that assumes the turbine bypass is closed.
- F. Generator Load Rejection Scram - The generator load rejection scram is provided to anticipate the rapid increase in pressure and neutron flux resulting from fast closure of the turbine control valves due to a load rejection and subsequent failure of the bypass; i.e., it prevents MCPR from becoming less than the MCPR fuel cladding integrity safety limit for this transient. For the load rejection without bypass transient from 100% power, the peak heat flux (and therefore LHGR) increases on the order of 15% which provides wide margin to the value corresponding to fuel centerline melting and 1% cladding strain.

The trip setpoint of greater than or equal to 460 psig EHC fluid pressure was developed to ensure that the pressure switch is actuated prior to closure of the turbine control valves (at approximately 400 psig EHC fluid pressure) yet assure that the system is not actuated unnecessarily due to EHC system pressure transients which may cause EHC system pressure to momentarily decrease.

- G. Reactor Coolant Low Pressure Initiates Main Steam Isolation Valve Closure - The low pressure isolation at 850 psig was provided to give protection against fast reactor depressurization and the resulting rapid cooldown of the vessel. Advantage was taken of the scram feature which occurs when the main steam line isolation valves are closed to provide for reactor shutdown so that operation at pressures lower than those specified in the thermal hydraulic safety limit does not occur, although operation at a pressure lower than 850 psig would not necessarily constitute an unsafe condition.
- H. Main Steam Line Isolation Valve Closure Scram - The low pressure isolation of the main steam lines at 850 psig was provided to give protection against rapid reactor depressurization and the resulting rapid cooldown of the vessel. Advantage was taken of the scram feature which occurs when the main steam line isolation valves are closed, to provide for reactor shutdown so that high power operation at low reactor pressure does not occur, thus providing protection for the fuel cladding integrity safety limit. Operation of the

TABLE 3.1.1
 REACTOR PROTECTION SYSTEM (SCRAM) INSTRUMENTATION REQUIREMENTS

Minimum Number Operable Inst. Channels per Trip (1) System	Trip Function	Trip Level Setting	Modes in Which Function Must be Operable			Action*
			Refuel (6)	Startup/Hot		
				Standby	Run	
1	Mode Switch in Shutdown		X	X	X	A
1	Manual Scram		X	X	X	A
	IRP					
3	High Flux	(LT/E) 120/125 of Full Scale	X	X	N/A	A
3	Inoperative		X	X	N/A	A
	APRM					
2	High Flux	Specification 2.1.A.1	X	X(8)	X	A or B
2	Inoperative**		X	X(8)	X	A or B
2	High Flux (15% Scram)	Specification 2.1.A.2	X	X	N/A	A
2	High Reactor Pressure	(LT/E) 1060 psig	X(10)	X	X	A
2	High Drywell Pressure	(LT/E) 2 psig	X(7), X(9)	X(7),(9)	X(9)	A
2	Reactor Low Water Level	(GT/E) 1 inch***	X	X	X	A
2 (Per Bank)	High Water Level in Scram Discharge Volume (Float and dp Switch)	(LT/E) 37.25 inches above bottom of the Instrument Volume	X(2)	X	X	A or D
2	Turbine Condenser Low Vacuum	(GT/E) 23 in. Hg Vacuum	X(3)	X(3)	X	A or C
2	Main Steam Line High Radiation	(LT/E) 3 X Normal Full Power Background	X	X	X	A or C
4(5)	Main Steam Line Isolation Valve Closure	(LT/E) 10% Valve Closure	X(3)	X(3)	X	A or C
2	Generator Load Rejection, turbine control valve trip system oil pressure low	(GT/E) 460 psig****	X(4)	X(4)	X(4)	A or C
2	Turbine Stop Valve Closure	(LT/E) 10% Valve Closure	X(4)	X(4)	X(4)	A or C
2	Turbine Control - Loss of Control Oil Pressure	(GT/E) 900 psig	X(4)	X(4)	X(4)	A or C

Notes: (LT/E) = Less than or equal to.
 (GT/E) = Greater than or equal to.
 (Notes continue on next two pages)

NOTES: (For Table 3.1.1 Cont'd)

* If the first column cannot be met for one of the trip systems, that trip system shall be tripped.

If the first column cannot be met for both trip systems, the appropriate actions listed below shall be taken:

- a. Initiate insertion of operable rods and complete insertion of all operable rods within 4 hours.
- b. Reduce power level to IRM range and place mode switch in the Startup/Hot Standby position within 8 hours.
- c. Reduce turbine load and close main steam line isolation valves within 5 hours.
- d. In the refuel mode, when any control rod is withdrawn, suspend all operations involving core alterations and insert all insertable control rods within one hour.

** An APRM will be considered inoperable if there are less than 2 LPRM inputs per level or there are less than 50% of the normal complement of LPRM's to an APRM.

*** 1 inch on the water level instrumentation is greater than or equal to 504" above vessel zero (see Bases 3.2).

**** Trip is indicative of turbine control valve fast closure (due to low EHC fluid pressure) as a result of fast acting solenoid valve actuation.

TABLE 4.1.2
 SCRAM INSTRUMENTATION CALIBRATIONS
 MINIMUM CALIBRATION FREQUENCIES FOR REACTOR PROTECTION INSTRUMENT CHANNELS

<u>Instrument Channel</u>	<u>Group (1)</u>	<u>Calibration Test</u>	<u>Minimum Frequency (2)</u>
* High Flux IRM	C	Comparison to APRM after Heat Balance	Every Shutdown (4)
High Flux APRM Output Signal	B	Heat Balance	Once Every 7 Days
Flow Bias	B	Standard Pressure and Voltage Source	Refueling Outage
High Reactor Pressure	A	Standard Pressure Source	Every 3 Months
High Drywell Pressure	A	Standard Pressure Source	Every 3 Months
Reactor Low Water Level	B	Water Level	(5)
Turbine Condenser Low Vacuum	A	Standard Vacuum Source	Every 3 Months
Main Steam Line High Radiation	B	Standard Current Source (3)	Every 3 Months
Turbine Control - Loss of Control Oil Pressure	A	Pressure Source	Every 3 Months
High Water Level in Steam Discharge volume (dp only)	A	Water Level	Once per Refueling Outage
Generator Load Rejection	A	Pressure Source	Once per Refueling Outage

NOTES: (For Table 4.1.2)

1. A description of the three groups is included in the bases of this Specification.
2. Calibration tests are not required when the systems are not required to be operable or are tripped. If tests are missed, they shall be performed prior to returning the systems to an operable status.
3. The current source provides an instrument channel alignment. Calibration using a radiation source shall be made during each refueling outage.
- *4. If reactor startups occur more frequently than once per week, the functional test need not be performed; i.e., the maximum functional test frequency shall be once per week.
5. Trip units are calibrated monthly concurrently with functional testing (staggered one channel out of 4 every week). Transmitters are calibrated once per operating cycle.

4.1 SURVEILLANCE REQUIREMENT BASES (Cont'd.)

of the sensor failure rate and the test interval. A three-month test interval was planned for group (A) sensors. This is in keeping with good operating practice, and satisfies the design goal for the logic configuration utilized in the Reactor Protection System.

To satisfy the long-term objective of maintaining an adequate level of safety throughout the plant lifetime, a minimum goal of 0.9999 at the 95% confidence level is proposed. With the (1 out of 2) X (2) logic, this requires that each sensor have an availability of 0.993 at the 95% confidence level. This level of availability may be maintained by adjusting the test interval as a function of the observed failure history (See Reference 6). To facilitate the implementation of this technique, Figure 4.1.1 is provided to indicate an appropriate trend in test interval. The procedure is as follows:

1. Like sensors are pooled into one group for the purpose of data acquisition.
2. The factor M is the exposure hours and is equal to the number of sensors in a group, n, times the elapsed time T ($M = nT$).
3. The accumulated number of unsafe failures is plotted as an ordinate against M as an abscissa on Figure 4.1.1.
4. After a trend is established, the appropriate monthly test interval to satisfy the goal will be the test interval to the left of the plotted points.
5. A test interval of one month will be used initially until a trend is established.

The turbine control valve fast acting solenoid valve pressure switches directly measure the trip oil pressure that causes the turbine control valves to close in a rapid manner. The reactor scram setpoint was developed in accordance with NEDC-31336, "General Electric Instrument Setpoint Methodology" dated October 1986. As part of the calculation, a specific calibration period is utilized to achieve a nominal trip point and an allowable setpoint (Technical Specification value). The nominal setpoint is procedurally controlled. Based on the calculation input, the calibration period is defined to be every Refueling Outage.

Group (B) devices utilize an analog sensor followed by an amplifier and a bi-stable trip circuit. The sensor and amplifier are active components and a failure is almost always accompanied by an alarm and an indication of the source of trouble. In the event of failure, repair or substitution can start immediately. An "as-is" failure is one that "sticks"

Reference 6:
Reliability of Engineered Safety Features as a Function of Testing Frequency,
I. M. Jacobs, Nuclear Safety, Vol. 9, No. 4, July-Aug. 1968, pp. 310-312.

4.1 SURVEILLANCE REQUIREMENT BASES (Cont'd.)

A comparison of Tables 4.1.1 and 4.1.2 indicates that six instrument channels have not been included in the latter Table. These are: Mode Switch in Shutdown, Manual Scram, High Water Level in Scram Discharge Volume Float Switches, Main Steam Line Isolation Valve Closure, and Turbine Stop Valve Closure. All of the devices or sensors associated with these scram functions are simple on-off switches and, hence, calibration is not applicable; i.e., the switch is either on or off. Further, these switches are mounted solidly to the device and have a very low probability of moving; e.g., the switches in the scram discharge volume tank. Based on the above, no calibration is required for these six instrument channels.

- B. The FDLRC shall be checked once per day to determine if the APRM gains or scram requires adjustment. This may normally be done by checking in the LPRM readings, TIP traces, or process computer calculations.

Only a small number of control rods are moved daily and thus the peaking factors are not expected to change significantly and thus a daily check of the FDLRC is adequate.