

From: David J. Vito (03V)
To: JFR John Rogge
Date: Monday, March 27, 1995 10:03 AM
Subject: RI-95-A-0026, OC Security Allegation

John,

I finally got a chance to look at the content of the acknowledgement letter sent to the allegor by JFR and I've had a chance to talk to him on Friday 3/24/95. I read through the documentation again to see if there appeared to be any DCI issues. I couldn't find anything that implied that he felt that his termination was due to his raising any safety issues to DC management or to the NRC, only that he was providing a "list" of all the problems he saw with the OC security program. You can go ahead and start processing the referral to the licensee now. Thanks.

CC: BCS, DFC, JFD

G/31

Talked to G. Smith on
3/27/95.

He does not see a kid
of anything he sees webster

G/32

ALLEGATION DISPOSITION RECORD

Rev. 2 10/5/94

Site: Oyster Creek Section Chief (AOC): Rogge
Allegation No: RS-95-A-0044 Date Received: 3/9/95
Acknowledged: n/a Receipt Report to SAC: 3/9/95
CONFIDENTIALITY GRANTED: Yes ☒ No ☐ OI Informed: yes

IS THERE A HARASSMENT/DISCRIMINATION ISSUE:

(If yes, complete H&ID section on reverse)

DOES THE ALLEGATION INVOLVE POTENTIAL WRONGDOING:

DOES THE ALLEGATION HAVE POLITICAL IMPLICATIONS:

DOES THE ALLEGATION REQUIRE RESOURCES TO RESOLVE

WHICH CAN NOT BE OBTAINED BY THE AOC:

Yes ☐ No ☒
Yes ☐ No ☒
Yes ☐ No ☒
Yes ☐ No ☒

If yes to any of the above, the allegation needs to go to an Allegation Panel.
Otherwise, document disposition actions below.

ALLEGATION PANEL (AP) DECISIONS

Date: 3/22/95 Previous APs on issue: Yes / ☒ No ☐
Chair - hanning w/h Branch Chief - —
Section Chief (AOC) - Briggs (acting) SAC - Vito
(Others) - G. Smith OI Rep. - —

DISPOSITION ACTIONS: (State specific action required for closure (including special concurrences), responsible person, ECD and expected closure documentation)

1) Resident to inspect

Responsible Person: DNP/Rogge/Briggs ECD: 4/21/95

Closure Documentation: — Completed: —

2) Closure w/ memo to file

Responsible Person: SAC ECD: 4/30/95

Closure Documentation: — Completed: —

3) —

Responsible Person: — ECD: —

Closure Documentation: — Completed: —

4) —

Responsible Person: — ECD: —

Closure Documentation: — Completed: 6/33

Safety Significance Assessment: low

Allegation Receipt Report
(Use also for staff suspected wrongdoing)

Page 1 of

Date/Time

Received: 3/2/95; 10:30 AM
3/15/95; 1:00 PM

Allegation No. REDAK RE-95-A-0058
(leave blank)

Employee Receiving Allegation or suspecting wrongdoing
(first two initials and last name): S. M. Pindale

Name of

Alleger: *

Home Address: *

Home Phone: *

City/State/Zip: *

Alleger's

Alleger's Position/Title: * Paint Mechanic

Facility: Oyster Creek

Docket No. or Materials License No.:

Was alleger informed of NRC identity protection policy?

Yes ☒ No ☒

If a licensee employee or contractor,
did they raise the issue to their management?

Yes ☒ No ☐

Was confidentiality requested?

Yes ☐ No ☒

Was confidentiality initially granted?

Yes ☐ No ☒

Individual Granting Confidentiality:

Criteria for determining whether the issue is an allegation:

Is it a declaration, statement, or assertion of impropriety or inadequacy? Yes / No

Is the impropriety or inadequacy associated with NRC regulated activities? Yes / No

Is the validity of the issue unknown? Yes / No

If No to any of the above questions, the issue is not an allegation and should be handled by other appropriate methods (e.g. as a request for information or an OSHA referral).

Allegation Summary or staff suspected wrongdoing (brief description of concern(s)):

Various issues were discussed related to work planning effectiveness, work union issues, delaying the individual from contacting the NRC, Oyster Creek management's dedication to doing permanent repair work vs. patchwork, and concerns relative to him being "singled-out" by OC supervision because he is outspoken regarding his concerns (including his willingness to talk to the NRC).

Number of Concerns: Several

Type of Regulated Activity

(a) ☒ Reactor
(b) ☐ Vendor
(c) ☐ Materials

(d) ☐ Safeguards
(e) ☐ Other:

(Specify)

Functional Area(s):

☐ (a) Operations
☐ (b) Construction
☐ (c) Safeguards
☐ (d) Transportation

☐ (e) Emergency Preparedness
☐ (f) Onsite Health and Safety
☐ (g) Offsite Health and Safety
☐ (h) Other:

* These sections are not completed for instances of potential wrongdoing identified by NRC staff.

Distribution: SAC OI

G/34

Detailed Description of Allegation or staff suspected wrongdoing:

On 3/8/95, the alleged _____ telephoned the NRC Resident office and said that he had several concerns, however, his foreman would not allow him to talk to the NRC. I told him I would get back to him shortly. Immediately after our discussion, his foreman (Freeman), and other maintenance supervision telephoned the NRC office to inform me that earlier in the day _____ had been very disruptive in a pre-job briefing. They said he expressed several outbursts over his concern regarding the use of station helpers in erecting scaffolding. They told me that _____ was counseled for his disruptive action, and that he would probably be over to see me soon. It appeared that maintenance supervision delayed his visiting the NRC so that they can meet and contact the resident before the alleged arrived.

_____ came to the Resident office around 10:30 a.m., and expressed several concerns related to work effectiveness and job pre-planning. He also stated that his foreman initially said that he could not approach the NRC with his concerns. The foreman (Bill Freeman) subsequently (about 10 minutes later) informed the alleged that it was O.K. to go to the NRC office, after he (Freeman) discussed _____ actions with higher maintenance supervision.

On 3/7/95, the alleged was told to attend a pre-job briefing at 8:30 AM on 3/8/95. He was also told to arrive early to review the associated RWP. However, the alleged determined that the RWP and an associated job order were not completed. At the meeting, he observed that only mechanics were expected to perform the job. He thought that two station helpers would assist two mechanics, and therefore reduce radiation dose to mechanics. He then protested to the work assignment, and the lack of sufficient information to do an effective pre-job planning.

Two Radcon workers walked-in and asked "What's the problem." The pre-job meeting was then apparently postponed by Radcon due to lack of progress. However, Freeman told the maintenance workers to stay so they could continue to pre-plan. _____ protested because there was no RWP or work order, and _____ was planning from only a hand written sketch (job was to erect scaffolding).

_____ went on to explain his frustration with Oyster Creek's mentality to do only patchwork to repair problems. He said workers are not allowed to do things right, and that many parts are no longer maintained in the storeroom due to major financial cuts. He characterized the above as a detriment to safe operation of the plant. I asked him if he had any examples of problems related to nuclear safety or those that could possibly adversely impact safe operation of the facility. He had none. However, he described one occasion when he and other workers were told to remove asbestos insulation although they were not qualified for asbestos removal. In that case, the work assignment was ultimately redirected, and qualified personnel performed the work.

_____ also expressed concern that he was being singled out by his supervision because he is "an outspoken critic" of how business is conducted at Oyster Creek. He said that after the 3/8/95 incident, Freeman gave him a "brow-beating" concerning his "disruptive outbursts." _____ asked Freeman for union representation prior to his "brow-beating," however, it was denied because Freeman said it was not disciplinary action.

_____ also expressed concern regarding time he had taken off from work (about 2 weeks) as a result of some personal activities. He said he had requested time off without pay, however, they charged him with vacation pay. He requested correction, but it was not corrected. _____ said although he showed a letter requiring his time away from the site to his acting foreman, supervision apparently denied seeing the letter and approving the time off. _____ expressed concern that he was not being treated fairly, and that he is being singled out because he is outspoken and talks to the NRC.

At the end of our interview, I explained to _____ that I would process his concerns, and explained that some of his concerns fell outside NRC's purview, and that the NRC would get back to him.

One final note: On the afternoon of 3/8/95, the Maintenance Director (Jim Hildebrand) and the Radcon Manager (Roger Shaw) came into the NRC Resident office to 1) question whether I could discuss any results of my discussion with [redacted] and 2) whether I had any further maintenance or radcon questions for them. I informed them that [redacted] and I discussed the events of the morning (as they knew of), that I could not tell them any further information, and that I had no further questions at that point.

Update from R. Summers:

On the afternoon of 3/15/95, the alleged again telephoned the NRC Resident Office with the following additional information regarding apparent harassment and intimidation because of having raised the concerns about conducting the pre-job brief without a work package including a RWP, as follows:

1. He was taken to a disciplinary meeting regarding unapproved absence. This was for the aforementioned leave to appear in court. His acting supervisor had been given a letter from the individual's lawyer regarding the leave and individual claims that he received verbal abuse. However, now individual was informed that management never approved or acknowledges receipt of individual's request for LWOP. Therefore, he was charged annual leave for the absent period and penalized 2 days pay for discipline.
2. He has been assigned duties by himself while working nights, which is done to separate him from rest of workers.

The individual provided non-specific concerns regarding: drug use by O.C. managers and medical department personnel; use of craft urine samples (that are clean) to substitute for the samples from known managers who use drugs.

I then explained to the individual the NRC identity protection policy, especially in light of the individual's new claim regarding H & I. The individual explained that he had already brought this matter to management's attention and therefore he was not concerned that NRC ~~might~~ release his identity.

Title

General Hydrostatic Test, Initial Service Leak Test, and Pneumatic Test Procedure
(ANSI B31.1)

Revision No.
4

EXHIBIT 1
DATA SHEET

4.4

Job Order No: 60617
Pressure Test Type: ☐ Hydro ☐ Pneumatic ☒ Initial Service
System/Component Name: V-16-0103

Boundaries: WELD Connections n-o Seat Leakage

Spec. No.: _____ Spec Test Pressure: _____

6.1.1/6.2.1/6.3.1

Prerequisites met/Precautions Limitations understood: William Green, 3-11-95
Job Supervisor Date

6.1.3.1/6.2.2.1

Pressure Gauge Serial No.: _____ Date Calibrated: _____
Observed Pressure Gauge Reading: _____
Pressure Gauge Calibration Correction: _____
Actual Corrected Pressure: _____

6.1.5.1/6.2.5.1/6.3.3.1

Leakage observed: ☐ Yes ☒ No
Leakage description: _____

Testor: William Green, 3-13-95
Signature Date

QA/QC: _____
Signature Date

ANI: _____
Signature NA Date

6.1.7.1/6.2.6.1

Test set-up removed: _____
Job Supervisor Date
Verified By _____ Date

6.1.8/6.2.8

Tests Results: SAT

7.1

Pressure Gauge check ☐ Sat ☒ Unsat

Comments: NA G/35

DM 3-9-95

P.E. 125-1 File No. 072-95
REV. 0
Page 1 of 11

FORM 125-1

ENGINEERING EVALUATIONS

Prepared By: C.A. SchillingPSETA/Group No. NADate Prepared: MARCH 2, 1995System ID No.(s) 215

Check As Applicable:

B/A No. NA

- * Alternate Replacement per 124.2 X
- * Configuration or Facility Change per EMP-002
- * Engineering Direction/Evaluation per EMP-002

Work Request No. 766616Job Order No. 60617Deviation RPT No. 95-109Description: V-16-0103 REPLACEMENT

The system/component related to this activity is classified as:

NSR RR OTHER X

Lonergan relief valve model FSS-1 is no longer made. An acceptable replacement is Lonergan series L14B 1" x 1" st.st relief valve. The old valve had socket weld connections vs. threaded connections for the new valve. B31.1 does not allow the use of threaded fittings for water service above 100psi and 220°F. Although the design conditions for line specifications DR-13 and DR-15 are 150psi and 250°F the threaded connections are permitted for the following reasons:

1. Normal operating conditions are 110psig and 120°F or less.
2. The system is instrumented to not exceed the operating conditions.
3. This is a 'thermal' relief valve. Its purpose is to protect the Demineralizer in the event that the Demineralizer is full and isolated and the water expands.
4. The inlet threaded connection will be seal welded.

A threaded coupling may be used to adapt the threaded inlet of the valve to socket weld. One end of the coupling is to be bored to a diameter of 1.330" +/- .005" and a depth of .5" to .65". The coupling is to be treaded onto the inlet of the valve and the threads seal welded. CAUTION: Minimize the heat buildup in the valve during seal welding.

Prepared by: C.A. Schilling
SignatureDate: 3-6-95

Independent Review Required: X YES NO Init. CAS
(Required for NSR Evaluations and NSR/RR Alternate Replacements)

Independent Reviewer: [Signature]
SignatureDate: [Signature]

(Must be RTR for Alternate Replacements)

Reviewed and Accepted By: [Signature] 3/6/95

125-1 CONTINUATION SHEET

The outlet of the valve does not have to be seal welded because it goes to a hub drain.

A Fire Hazard Input and Status Form is not required because no combustibles are being added and there are no changes or interfaces with any fire protection feature or system.

An EQ Input and Status Form is not required because there are no EQ requirements for this component.

When the installation is complete submit an FCN to revise the GMS2 component data base with the new valve nameplate data.

Title
Control of Engineering Directed Alternate Replacements

Revision No.
8

Eng. Evaluation # 072-93
Page 3 of 11

ATTACHMENT 124.2-1

ALTERNATE REPLACEMENT EVALUATION

1) Does this activity meet the definition of an "Alternate Replacement" X
Describe the "Alternate Replacement" and why it is required. Relief Valve
V-16-0103 is obsolete and needs to be replaced. Therefore
a new valve must be specified.

2) Safety Determination/Evaluation attached.

3) Detailed evaluation of alternate replacement attached. (125-1 Form)

4) Technical Evaluation of Replacement Item. (124.2-2, 124.2-3)

CS
Initial

CS
Initial

CS
Initial/ NA

5) Do Engineering Configuration Concerns of EMP-014 apply?

YES NO

Concurrence
Obtained
(If Yes)

Masonry Block Walls

___ ☒

Electrical Loads

___ ☒

Piping and Pipe Supports

___ ☒

Raceway Loads

___ ☒

Environmental Qualification of Electrical Components

___ ☒

Fire Hazards Analysis Report

___ ☒

Containment Electrical Penetrations

___ ☒

Control of Concrete Rebar Cutting

___ ☒

Plant Computer Configuration

___ ☒

Human Factors

___ ☒

RF Interference and Electrical Noise

___ ☒

Appendix R Commitment

___ ☒

Tech Functions concurrences obtained for each item marked "YES"

___ ☒

___ ☒

NA
Init / NA

Title
Control of Engineering Directed Alternate ReplacementsRevision No.
8Eng. Evaluation # 012-95
Page 4 of 11ATTACHMENT 124.2-1ALTERNATE REPLACEMENT EVALUATION
(Continued)

- 6) FCN required ✓ YES NO
~~FCN #~~ issued or implementor directed by 125-1 Form
to issue upon installation.
- 7) Procedure Changes Required (attach list if required). CAS
Init/NA
- 8) Preventive Maintenance Update Required (attach PM Requests). NA
Init/NA
- 9) Vendor Manuals Update Required (attach request). NA
Init/NA
- 10) Spare Parts Required (attach list). NA
Init/NA
- 11) NPRDS Data Base Update NA
Init/NA
- 12) Form 124.2-2 issued. Copy attached ✓ Issue later CAS
Initial
- 13) Cross Disciplinary Review Required. NA
Init/NA
- 14) References WR/JO # 60617 PETA/Item No. NA

Title

Control of Engineering Directed Alternate Replacements

 Revision No.
8

 Eng. Evaluation : 072-95
Page 5 of 11

ATTACHMENT 124.2-2

REPLACEMENT ITEM TECHNICAL EVALUATION FORM

1. Item Identification

Tag No.: V-16-103

Manufacturer

Model/Part #

Description

 Original Lenegon
FSS-1
1" St. St. Relief Valve

 Replacement Lenegon
L148-EX-M60150
1" St. St. Relief Valve

2. Function/Location

"Thermal" Relief Valve on the Cleanup Demineralizer inlet.

 3. Functional Classification: Other

(NSR, RR or "Other")

 Basis: ☒ QCL

☐ QA Screen/DKPS

☐ Other (Attach documentation)

4. Functional Mode:

Basis: _____ (Active or Passive)

5. Credible Failure Mode(s)/Failure Effects (NSR - only)

Set point drift

6. Critical Characteristics for Design/Acceptance

materials of construction, inlet/outlet size, inlet to outlet direction

7. Equivalency Evaluation

(See attached Equivalency Evaluation Table)

See Attached

Control of Engineering Directed Alternate Replacements

ATTACHMENT 124.2-3

Comparison Codes:

- I = Identical to original design requirements
E = Exceeds original design requirements
R = Design difference reconciled in Remarks section
(For NSR or RR Replacements with NSR interfaces, ensure differences are reconciled with design basis documents)

Remarks: R1 Field Fit-up to compensate

* SEE 125.1 FOR RECONCILIATION OF THROUGH WORK SHEET W/WD

Design Basis Reconciliation (NSR/NSR Interface Replacements)

Title
Control of Engineering Directed Alternate Replacements

Revision No.
8

ATTACHMENT 124.2-4

CONFIGURATION CHANGE NOTIFICATION

Eng. Evaluation No. 072-9

Rev. 0

Page 7 of 11

Description:

Status: ☐ Installed WR/JO # _____
☒ Evaluation Complete to be installed by WR/JO # 60617
☐ Evaluation Complete outage required to install WR/JO # _____

Turnover: Operations requested to perform Procedure 124 Turnover

☐ Yes ☒ No

Operations Contact: B. Shumaker

	Yes	Complete	No
Procedure changes required	_____	_____	✓
Procedure cross-disciplinary review required	_____	_____	✓
Preventive Maintenance update required	_____	_____	✓
Vendor Manuals update required	✓	_____	✓
FCN required	✓	_____	✓
Spare Parts required	_____	_____	_____
Labels per Procedure 109 required *	_____	_____	✓
NPRDS Data Base update	_____	_____	✓

CDL
3-6-95


* (Note: If yes and not complete, attach list and status)

Distribution

Manager Operations Support
 Vendor Document Control Manager
 Director Engineering & Design
 Supervisor Procurement Engineering
 System Engineer
 Manager Maintenance Assessment
 Manager Plant Training Oyster Creek
 Quality Control Manager

From:

Originator: CA Schilling ext. 4907
 Supervisor: PCW 4895
 Manager: DM 4081



OYSTER CREEK NUCLEAR GENERATING
STATION PROCEDURE

Number
124.2

Title

Control of Engineering Directed Alternate Replacements

Revision No.
8

ATTACHMENT 124.2-5

Eng. Evaluation 072-95
Rev. 0

MATERIAL REQUIREMENTS

Page 8 of 11[illegible]

Procurement Engineer Review: Signature

Date 3/1/61

(3095P/14)

E5-1

Safety/Environmental Determination and 50.59 Review
(EP-016)

Unit <u>Oyster Creek</u>	Page 9 of <u>11</u>
Document/Activity Title <u>V-16-0103 Replacement</u>	SE Rev. No.
Document No. (if applicable) <u>072-95</u>	SE No.
Type of Activity (modification, procedure, test, experiment, or document): <u>Alternate Replacement</u>	Doc. Rev. No. <u>0</u>

1. Does this document involve any potential non-nuclear environmental concern? ☐ Yes ☒ No

To answer this question, complete the Environmental Determination (ED) form. Any YES answer on the ED form requires an Environmental Impact Assessment by Environmental Controls, per 1000-ADM-4500.03. If in doubt, consult Environmental Controls or Environmental Licensing for assistance. If all answers are NO, further environmental review is not required. In any event, continue with Question 2, below.

2. Is this activity/document listed Section I or II of the matrices in Corporate Procedure 1000-ADM-1291.01? ☒ Yes ☐ No

If the answer to question 1 is NO, stop here. This procedure is not applicable and no documentation is required. (If this activity/document is listed in Section IV of 1000-ADM-1291 review on a case-by-case basis to determine applicability.) If the answer is YES, proceed to question 3.

3. Is this a new activity/document or a substantive revision to an activity/document? ☒ Yes ☐ No

If the answer to question 3 is NO, stop here and complete the approval section below. This procedure is not applicable and no documentation is required. If the answer is YES, proceed to answer all remaining questions. These answers become the Safety/Environmental Determination and 50.59 Review.

4. Does this activity/document have the potential to adversely affect nuclear safety or safe plant operations? ☐ Yes ☒ No

5. Does this activity/document require revision of the system/component description in the FSAR or otherwise require revision of the Technical Specifications or any other part of the SAR? ☐ Yes ☒ No

6. Does the activity/document require revision of any procedural or operating description in the FSAR or otherwise require revision of the Technical Specifications or any other part of the SAR? ☐ Yes ☒ No

7. Are tests or experiments conducted which are not described in the FSAR, the Technical Specifications or any part of the SAR? ☐ Yes ☒ No

IF ANY OF THE ANSWERS TO QUESTIONS 4, 5, 6, OR 7 ARE YES, PREPARE A WRITTEN SAFETY EVALUATION FORM.

If the answers to 4, 5, 6, and 7 are NO, this precludes the occurrence of an Unreviewed Safety Question or Technical Specifications change. Provide a written statement in the space provided below (use back of sheet if necessary) to support the determination, and list the documents you checked.

NO, because: See Attached

Documents checked: FSAR 5.4.8, TS 3.3.E

8. Are the design criteria as outlined in TMI-1 SDD-T1-000 Div. I or OC-SDD-000 Div. I Plant Level Criteria affected by, or do they affect the activity/document? ☐ Yes ☒ No

If YES, indicate how resolved: _____

Engineer/Originator <u>[Signature]</u>	APPROVALS (print name and sign)	Date <u>3-3-95</u>
Supervisor <u>[Signature]</u>		Date <u>[Signature]</u>
Responsible Technical Reviewer <u>[Signature]</u>		Date <u>[Signature]</u>
Other Reviewer(s)		Date

ENVIRONMENTAL DETERMINATION

Page 10 of 11

Division/Unit

Oyster Creek

Document No.
Eng. Evaluation
072-95

Revision No.

0

Document Title

V-16-103 Replacement

1. Will Document implementation result in an increased potential to release hazardous chemicals (gas, liquid, solid or semi-solid) to the environment? ☐ Yes ☒ No
2. Will Document implementation compromise existing capability to control, treat, or monitor releases to the environment? ☐ Yes ☒ No
3. Will Document implementation cause a physical or chemical change in the characteristics of facility discharges, effluents, or withdrawals? ☐ Yes ☒ No
4. Will Document implementation result in the permanent or temporary storage (for use, disposal, or transfer) of any hazardous or other regulated waste, or hazardous chemical(s), outside of established handling facilities or procedures where the margin of control or containment will increase the potential of a release to the environment? ☐ Yes ☒ No
5. Will the implementation of the Document result in an increase in the amount or a change in the type of hazardous waste(s) typically generated, and/or previously evaluated for the type of activity? ☐ Yes ☒ No
6. Does Document implementation result in land disturbance (e.g., excavation work, grading), or modification or alteration of storm water drainage systems that would change site storm water runoff or increase sediment loading of storm water runoff? ☐ Yes ☒ No
7. Will Document implementation result in a physical alteration to a wastewater treatment facility or other facility system(s) or component regulated by environmental permits (e.g., discharge to groundwater permit, discharge to surface water permit, etc.)? ☐ Yes ☒ No

SIGNATURES

Preparer

CD Schilling

Date

3/3/95

Cognizant Supervisor/Manager, or Designee

Date

Environmental Technical Reviewer

Date

Other Reviewer(s)

Date



Determination/Evaluation Continuation

4. This activity will restore the Cleanup System integrity. A leaking relief valve is being replaced with a relief valve of the same setpoint and size.
5. This valve is not described in detail in any licensing basis document. A 1" x 1" stainless steel relief valve is being replaced by a 1" x 1" stainless steel relief valve with the same setpoint.
6. This is a passive valve. It does not require operator action at any time.
7. This is not a test or experiment.

RWP 950096

DATE 3/9/95

TIME 0830

RCFO: S. L. LAFLEY
(print) initials

[Signature]

Initials

RWP / ALARA REVIEW REQUIREMENTS: Confirm that the involved Radiological Controls Technicians (RCTs) have read or reviewed the RWP and ALARA review (if any).

[Signature]

RADIOLOGICAL CONDITIONS: Review the Dose-Rates, Contamination Levels and Airborne Radioactivity levels in each of the work areas identified above. Maximum Dose Rates, Low Dose Waiting Areas, Dose stratification (Non-uniform dose rates), and other identified Radiological Parameter are to be reviewed.

[Signature]

CHANGES TO RADIOLOGICAL CONDITIONS: Explain the anticipated changes (if any) to the Radiological conditions in each of the work areas caused by this task or other tasks working in the area.

[Signature]

ENGINEERING CONTROLS: Review the Engineering Controls, in-place or planned, (HEPA Exhaust system(s), HEPA Vacuum cleaning, containments, catches, drains, shielding, etc.).

[Signature]

RWP DOSIMETRY REQUIREMENTS: Identify any SPECIAL dosimetry requirements specified on the RWP and confirm that all personnel understand their individual dosimetry requirements.

[Signature]

REQUIRED AVAILABLE EXPOSURE: Identify the required available exposure from the RWP. The GRCS/RCT will confirm that all personnel understand the required available exposure limit and that they are aware of the approximate dose they expect to receive.

[Signature]

RWP PROTECTIVE CLOTHING REQUIREMENTS: Identify any SPECIAL protective clothing requirements specified on the RWP and confirm that all personnel understand their specific Protective Clothing Requirements.

[Signature]

COVERAGE / MONITORING: Review the monitoring requirements specified on the RWP and identify surveys and other Radiological Controls actions specified in the Coverage Plan. Confirm that the workers and the Covering RCTs understand the Monitoring requirements and specific survey actions.

[Signature]

RWP RESPIRATORY PROTECTION REQUIREMENTS: Confirm that all personnel understand their specific Respiratory Protection Requirements and Breathing Zone Air Sampling requirements (if any). Confirm that workers understand that MPC (DAC) hours may be accrued during this task and that they are aware of the approximate number expected.

[Signature]

Remind crew/workers to use "self check"

RCFO All questions have been resolved with the following noted exceptions:

SELF CHECK DISCUSSED
[]-NONE (Sign) [Signature]

G/36

RWP 950096DATE 3/8/85TIME: 0845Job Supervisor: Steve Consi
(or designee) (print)SC
initialsInitials

RWP / ALARA REVIEW REQUIREMENTS: Confirm that all workers have read/reviewed the RWP and ALARA review (if any).

SC

SCOPE: Describe the scope of work to be performed which is to be covered by this briefing. NOTE: The entire scope of work need not be briefed if a series of incremental briefings (shiftly, daily, etc.) are to be done.

SC

WORK AREAS: Identify all the work areas inside the RCA. All laydown areas or temporary work areas are to be identified. The location(s) where material is to exit the RCA is to be identified (MAC, Bldg-3, Gate 20, etc.).

SC

INTERFERENCE / COORDINATION: Identify any other tasks known to be working in the same area(s) and the possible impact that these other jobs may have on this task.

SC

SYSTEM STATUS: Identify the status of the systems involved in the task(s). (tagged-out and drained, in-service, not-drained, energized, pressurized, etc.).

SC

SYSTEM OPENING / OPEN SYSTEM WORK: Identify all system opening evolutions or locations (components) where open system work is to be done. If any draining of fluid systems is to be done, identify where and how the drainage is to be routed.

SC

WORK PROCESS: Identify the work processes to be done (welding, burning, grinding, hand-tools, power tools, test equipment, lapping, hydrolazing, etc.).

SC

WORKER POSITIONS: Individual workers will identify their expected work positions (standing, kneeling, etc), and all locations where the workers expect to go.

SC

SAFETY: Confirm that there are no unanswered Industrial Safety Concerns (heat stress, fall protection, asbestos, temporary use of power cords, confined space etc).

SC

Job Supervisor: All questions have been resolved with the following noted exceptions:

G/37SC
[]-NONE (Sign)

WELDING PACKAGE INFORMATION REQUEST

PAGE 1 OF 3

JOB ORDER#: 60617EA#: 316400PLANNER: J. Sletten EXT: 4112 DATE: 3/8/95DATE REQUIRED: 3/9/95 DATE RECEIVED BY WELDING: 3/9/95DESCRIPTION OF WORK: Install New Relief Valve V-16 0103DATE RETURNED: 3/8/95 1. _____ 2. _____

DATE RETURNED FOR CORRECTIONS: 1. _____ 2. _____

REASON FOR RETURN: 1. _____
2. _____

DATE RETURNED TO WELDING: 1. _____ 2. _____

MATERIAL INFORMATION

PIPING

ITEM NO.	SIZE	SCH.	SPEC/GRADE	NEW/EXIST
1.	1" SS	40	A312 316SS	X
2.	1" SS	40	A106 GR. B	X
3.	1" SS	40	A106 GR. B	X
4.	1" SS	40	A312/A316 TP304/TP316	X
5.				
6.				
7.				
8.				

PIPE FITTINGS/VALVES

	TYPE	SCH/RATE	SPEC/GRADE	NEW/EXIST
9.	ELBOW 45° CS	3000#	A105	X
10.	Coupling 1" SS	3000#	A182 F316	X
11.	Coupling 1" THRD	3000#	A182 F316	X
12.				
13.	Valve Relief 1" 150#		A351-CF8M	X
14.				
15.				
16.				

STRUCTURAL/OTHER

	TYPE	SCH/RATE	SPEC/GRADE	NEW/EXIST
17.				
18.				
19.				
20.				
21.				
22.				
23.				
24.				

G/38

ENGINEERING INFORMATIONSYSTEM NAME: Cleanup SystemSYSTEM NO.: 215LINE SPEC: ND ND 3M PTCm WRC
DR-13 & DR-15 3-9-95SAFETY CLASS: MSR ☐ RR ☐ OTHER ☒ASME SECTION XI: YES ☐ NO ☒CLASS: IWB ☐ IWC ☐ IWD ☐ N/A ☒REPAIR PROGRAM: YES ☐ NO ☒CONSTRUCTION CODE: B31.1 YEAR: 1955INSPECTION CRITERIAINSPECTION CODE: B31.1 YEAR: 1989NDE REQUIRED: VT ☒ MT ☐ PT ☐ RT ☐ UT ☐LEAK TEST ☒ HYDRO TEST ☐ OTHER ☐Non-Isolatable from relief valveAWI/AWII REQUIRED: YES ☐ NO ☒STRUCTURAL MATERIAL TRACEABILITY: CMTR ☐ C OF C ☐ N/A ☒PIPING MATERIAL TRACEABILITY: spec & grade

OTHER MATERIAL TRACEABILITY: _____

ATTACHMENTS: MNCR ☐ FCR ☐ FCN ☐ OTHER ☐

ENGINEER/DATE


Ch. Shilling 3/3/95
ENGINEERING APPROVAL/DATENOTES: Ref Plant Engineering 125.1 # 072-95PRE-APPROVED ENGINEERING USED FOR THIS WPIC ☐

PLANNER/DATE

WPIR SKETCH

JO#: 60017

WELD MAP#: 3A-215-NM-C12



Title
Conduct of Radiological Engineering

Revision No.
7

FORM 6630-ADM-4010.02-1

Page 1 of ____

RADIOLOGICAL REVIEW REQUEST FORM

I

Title Activity Description		Document No.		RER
R&B 75' CLEAN-UP VALVE AISLE REPLACE V-16-103		JA# 60617 312400		95010B
REVIEW REQUEST DATA		ARN REVIEW REVISIONS		EXPOSURE MANAGEMENT
Requestor's Name	R. HEFFNER/CLAFFEY	Rev.	Date	ETN
Homebase Code	2110			RFD16VM
Telephone Number	4496 / 4712			ESTIMATED EXPOSURE
Review Need Date	3-8-95			(person-Rem) 1205140
RAD CON RECEIVING DATA		REVIEW DATA USED		ACTUAL EXPOSURE (person-Rem)
Date	3-8-95			EXPIRATION DATE
Time				12-31-95
Review Basis	DOSE ESTIMATE			
ACCEPTED BY:	Robert A. Heffner	Maximum Exposed Individual (Per RWP Entry) 400 mRem		

DOSE ESTIMATE ONLY

II

RWP TIME STUDY		DESCRIPTION OF RWP AREAS			
		1	2	3	4
NC	Job Classification	75' VALVE AISLE	75' OUTSIDE		
A	MECH SCAFFOLDING INSTALL/REM	16.25	8		
B	STABER/MECH SHIELDING	1.0			
C	STABER/MECH CLEAN-UP	0.25			
D	MECH WELDING	2.5			
E	FIRE WATCH	2.5			
F	RAD CON	2			
G					
H					
Max. Time Per Individual Entry		16.25	8		

Review Performed By

Concurred By (if applicable)

Robert A. Heffner 13-8-95
(Rad-Eng) ROBERT A HEFFNER Date

J. DERBY 3/8/95
Date

G/39

JO# 00060617 CYCLE 15
PRI 1 MLSTN NA

OFFICIAL
GPU NUCLEAR
JOB ORDER

WORK TYPE CM
REVISION 00

WR# 766616 STATUS AUTH



REV DATE 03/07/95
TIME SHT# 2400-CR812

WORK REQUESTING INFO

Comp V-16-0103 VALVE REACTOR BLDG 75 FT 3 IN L
Comp Desc RWCU SYSTEM DEMINERALIZER INLET SAFETY RELIEF VALVE SYS 215

Work Desc THE RELIEF VALVE IS LEAKING-BY. PLEASE INVESTIGATE
AND REPAIR.

(DVR 95-109)

Cause of Failure & Symptoms

REFERENCE USE

AW PROC. 2-000 - ADM - 1213.00

ETN=RFD16VM/PLANNER PLEASE CONTACT RAD-ENG R.HEFFNER X-400 HANKS JDERB
Y-950228

Failure Codes
Detect

Symptom

WORK INITIATION APPROVALS

Title	Signature	Date	Route#
Originator	JEFF DOSTAL	02/27/95	MP06
OPERATIONS MANAGEMENT	COLANGELO, M.	02/28/95	
WORK AUTHORIZATION APRV	COLANGELO, M.	02/28/95	
MAINTENANCE JOB PLANNER	CLEFFEY, J.	03/07/95	
AREA SUPERINTENDENT	<i>[Signature]</i>	3-9-95/10:40 AM	
J/G COORDINATOR	<i>[Signature]</i>	3/9/95	
GSS TO START WORK	<i>[Signature]</i>	3/11/95	

Attachment #

IO #

Page

of

Ops Comments:

WORK COMPLETE APPROVALS

Title	Signature	Date/Time
J/G COORDINATOR	<i>[Signature]</i>	3-14-95 1012
QA AFTER JOB COMPLETE	<i>[Signature]</i>	
GSS AFTER JOB COMPLETE	<i>[Signature]</i>	3-14-95 1025
AREA SUPERINTENDENT	<i>[Signature]</i>	4/10/95 0845
MAINTENANCE ASSESSMENT		
DOCUMENT CONTROL		

G/40

JO# 00060617 CYCLE 15
PRI 1 MLSTN NA
WR# 766616 STATUS AUTH

GPU NUCLEAR
JOB ORDER

WORK TYPE CM
REVISION 00
REV DATE 03/07/95
TIME SHT# 2400-CR812

PLANNING INFO

Comp V-16-0103
Comp Desc RWCU SYSTEM DEMINERALIZER INLET SAFETY RELIEF VALVE SYS 215

Work Desc THE RELIEF VALVE IS LEAKING-BY. PLEASE INVESTIGATE
AND REPAIR.
(DVR 95-109)

NSR N RR N OTHER Y OQA PLAN Y ISI N CLEAN CLASS B NPRD COMP N
PLANT MODE 0 ENV QUAL N IST N SAFETY CLASS

Special Comments
REACTIVITY ITEM

Weld/Bond Docs Req'd? Y Switch/Tag/Drain Req'd? Y Work Cntr ASME
Grind/Burn Permits Req'd? Y Temp Variation Req'd? N Craft MECH
Auth Nuclear Inspec Req'd? N Deficiency Tag Issued? P Est Mnhrs 0032
Insurance Insp Prgrm Req'd? N Fire Barrier Breached? N Crew Size 04
Resp Technical Rev Req'd? A Ind Safety Rev Req'd? N EM# 072-95
ALARA Review Req'd? Y Confined Space Req'd? N EER#
Radiation Wrk Permit Req'd? Y Non-Rad Protect Req'd? N DOC#
Leak Ctmt Installed? N Scaffolding Req'd? Y QDR#
Insulation Removal Req'd? N Post Maint Test Req'd? Y MNCR#
ARN 95010B ETN RFD16VM Plt Engineer Prj Eng
Est Milirem 1600 BA 312400 WO 2400-50187 WA 240050187
QV Required N
QV H/W Issued
QV Notif Name Notif Date / /
Procedures ---Tech Manual--- ---Drawings---

COMPONENT BASE LINE INFORMATION

TF Verify Y
Comp Code VALVE
Comp Type PRESSURE RELIEF
PWR Source N/A
Pri Src Doc MPR2400-SMM-3218.04
QA/QC Rqmt QA/QC REQUIRED
QA/QC Bas COMP RELIABILITY
Func Class PLANT SUPPORT
Mfr Name LONERGAN, JE COMPANY
Mfr Code L265
Comp Size 1.0X1.0
Reference N/A
Documents & Drawings MFG-LG B-2402
FLO-GE 148F444 SH1
ECI-N/A
Seismic Func NO SEISMIC FUNCTION
Func Mode AUTOMATIC OPERATION
Classific OTHER
Model# FSS-1
Serial# N/A
Matls IDN 000000000

OFFICIAL

JOB# 00060617

JOB ORDER WORK PERFORMED

TIME SHT#

2400-CR812

Problem Condition Found Relief VALVE PASSING

Corrective Action/Special Tools, Rigging etc.

STAGED AND BUILT SCAFFOLD

MADE FIELD MEASUREMENTS

CUT AND BENCH WELDED VALVE AND ASSOCIATED PIPING

CUT OUT OLD VALVE

INSTALLED NEW VALVE ASSEMBLY AND MADE 2 FIELD WELDS.

INSPECTED AND ACCEPTED WELDS

PULLED TAGS 0410

SUBMITTED FCN

① Scaffolding and Portable Shielding will be Remove under ASME-MM-004703 to allow for time review and closure of the welding Documents.

Post Maintenance Test SMJ

Responsible Supv Work Center ID? ASME Run Hour Meter Reading? NA

Environmental Qual Restored? YES (N/A) Shift Completed? DAY (MID) NIGHT

NPRD Failure Report Required? (YES) N/A Results Code 01

Component Failed? (YES) NO Leak Containment Removed? YES (N/A)

Employee ID# 02861 09009 C227 9470 B351 0016

or Contract Badge# 4609 A492 B3976

===== OFFICIAL =====

JO# 00060617

JOB ORDER MACHINERY HISTORY

TIME SHT#
2400-CR812

Cause of Failure (Root Cause) Description ACE

===== CAUSE OF FAILURE DESCRIPTION CODES =====

Lubrication Problem- AE	Aging/Cyclic Fatigue - <u>BD</u>	Insulation Breakdown- AR
Weld Related - AF	Dirty - BE	Setpoint Drift - AL
Mech Damage/Binding- BB	Previous Repr/Install- AM	Out of Calibration - BH
Mech Adjustment Out- BC	Incorrect Procedure - AN	Short/Grounded - AE
Normal/Abnorml Wear- AD	Incorrect Action - BJ	Open Circuit - AT
Abnormal Stress - AG	Loose Part/Connection- AV	Contacts Burn/Pitted- AU
Foreign Material - AB	Material/Part Defect - AZ	Circuit Defective - AW
Blocked/Obstruction- BF	Wrong Part - AA	Burned/Burned Out - AX
Corrosion - BG	Other - <u>XX</u>	Electrical Overload - AY
Particulate Contam - AC		

** CHOOSE ONLY THE **

BEST THREE CODES

===== CORRECTIVE ACTION CODES =====

Recalibrate/Adjust - AA	** CHOOSE ONLY **	Repair Component/Part-AG
Temporary Measures - AC	ONE CODE	Replace Component - <u>AK</u>
Modify/Substitute - AE		Replace Parts - AH

===== ENGINEERING SUPPORT INFO =====

** Please Record if not Available with Job Order Issuance **

Comp Data Base Update Req'd? YES N/A

New Model# _____ New Serial# _____

New Mfr _____

Eng Mod# 072-95

Eng Eval Report# 125
0712-95

Memo# _____

MNCR#s _____ QDR#s _____

RWP# 950096

STD# 95-0204

OCNGS RADIOLOGICAL SURVEY

No. REC-95-1064

Date 3-1-95

Time 1030

Location CLEAN UP VALVE ASIL: & CONTROL AREA

RWP 950001

Reason Inspect V-16-103, V-2-715

Rx Power - 100 %

SMEARABLE CONTAMINATION

LOCATION	B/C	CPM	DPM	MRAD/HR	AREA	INSTRUMENTATION D.
1 Floor		200 K	CPM	4.1	100 c	INST R02A
2 Floor		140 K	DPM	4.1		S/N 4124 BCF
3 Floor		4 M	RAD	4.1		CDD 4-19-95
4 V-2-715		80 K	DPM	4.1		INST
5 V-16-103		40 K		32		S/N BCF
6 O/A Piping		60 K		32		CDD
7 Light Fixture		415		4.1		
8 O/A Piping		80 K	DPM	4.1	100 c	
9						CONTAMINATION SURV
10						INST RM-14
11						S/N 4131
12						CDD 5-8-95
13						EFF 10% BKG 60
14						INST location 1000
15						S/N 22143
16						CDD 8-8-95
17						CF 32 BKG 60
18						AIR SAMPLE DATA
19						FC #
20						NOTES

Surveyor: (print name)

Signature

Date 3-1-95

Reviewer: (print name)

Signature

Date 3-1-95

① Contact Dose Rates are Circled

② Smear Locations are Boxed

All Dose Rates are General Area Readings in mr/hr Unless Otherwise Noted

☑ No BETA Detected Unless Otherwise Noted

☐ No BETA Readings Taken

Remarks: V-2-715 Has hole to basement leak, located 3' 10" in overhead

V-16-103 located 16' in overhead

1-10' 1-6' Steamback located in Room

Overhead Piping very dirty, highly radioactive

ALS # 1316-95 - 2.95-9 AB

N5268 105-1

G/41

Copy

ALLEGATION DISPOSITION RECORD

Rev. 2 10/5/94

Site: Oyster Creek Section Chief (AOC): Rogge
 Allegation No.: RI-95-A-0026 Date Received: 2/6/95
 Acknowledged: NRE will acknowledge Receipt Report to SAC: 2/6/95
 CONFIDENTIALITY GRANTED: Yes ☒ No ☐ OI Informed: yes
 IS THERE A HARASSMENT/DISCRIMINATION ISSUE: Yes ☐ No ☐
 (If yes, complete H&ID section on reverse)
 DOES THE ALLEGATION INVOLVE POTENTIAL WRONGDOING: Yes ☐ No ☐
 DOES THE ALLEGATION HAVE POLITICAL IMPLICATIONS: Yes ☐ No ☒
 DOES THE ALLEGATION REQUIRE RESOURCES TO RESOLVE WHICH CAN NOT BE OBTAINED BY THE AOC: Yes ☐ No ☐

If yes to any of the above, the allegation needs to go to an Allegation Panel. Otherwise, document disposition actions below.

ALLEGATION PANEL (AP) DECISIONS

Date: 2/8/95 Previous APs on issue: Yes / ☒ No ☐
 Chair - Cooper Branch Chief - Dun
 Section Chief (AOC) - Rogge SAC - Vito
 (Others) - G. Smith OI Rep. - Letts

DISPOSITION ACTIONS: (State specific action required for closure (including special concurrences), responsible person, ECD and expected closure documentation)

- 1) SAC will review the NRE acknowledgement letter to determine whether any additional info may need to be provided to allegor (e.g. notifying him of referral to licensee, or providing BCL info if necessary)
 Responsible Person: SAC ECD: TBD

Closure Documentation: _____ Completed: _____

- 2) Refer issues to licensee

Responsible Person: DRP/Rogge ECD: 2/28/95
 Closure Documentation: _____ Completed: _____

- 3) DRSS to review licensee response - then repanel issue

Responsible Person: DRSS/Smith ECD: TBD
 Closure Documentation: _____ Completed: _____

- 4) No specific indication of wrongdoing at this time (per B. Letts)

Responsible Person: _____ ECD: 6/4/95
 Closure Documentation: _____ Completed: _____

Safety Significance Assessment: low - individual issues of low significance - if subsequent assessment of issues collectively raises additional concerns, will reassess significance at that time