



PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
P.O. BOX 87
PERRY, OHIO 44081

Michael D. Lyster
VICE PRESIDENT - NUCLEAR

July 1, 1992
PY-CEI/NRR-1518 L

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Perry Nuclear Power Plant
Docket No. 50-440
Correction to 10CFR21 Notification

Gentlemen:

By correspondence dated June 19, 1992 (PY-CEI/NRR-1516L), Perry Nuclear Power Plant submitted a 10CFR21 notification to report defects in Main Steam Isolation Valve (MSIV) poppets supplied by Atwood and Morrill Company, Incorporated (A&M). On June 24, 1992, it was noted that the Corrective Action section of the referenced notification contained an error. In the second paragraph of the Corrective Actions, the letter states that poppets with serial numbers (S/Ns) 3, 7, 8, 9, 10, and 11 were installed in the plant. This sentence should indicate that after being repaired at A&M as described, poppet S/N 4 was installed in the plant rather than S/N 3. Poppet S/N 3 is being retained as a spare.

Should you require additional information regarding this subject, please contact Mr. Kevin Donovan, Licensing and Compliance Section Manager at (216) 259-3737, extension 5606.

Sincerely,

Michael D. Lyster

MDL:RWG:ss

cc: NRC Project Manager
NRC Sr. Resident Inspector
NRC Region III Administrator

660117
9207070221 920701
PDR ADOCK 05000440
S PDR

Operating Companies
Cleveland Electric Illuminating
Toledo Edison

IE19
110