

DATE: 06/26/92  
TIME: 13:58:47

UNION ELECTRIC COMPANY  
DOCUMENT CONTROL SYSTEM  
DOCUMENT TRANSMITTAL

PAGE: 1  
ARDC8811

TRANSMITTAL NUMBER: 224352  
TO CONTROL NUMBER: 338  
TITLE: OTHER  
DEPT: NUCLEAR REGULATORY COMM.  
LOCATION: WASHINGTON, DC  
TRANSMITTAL DATE: 920626

RETURN ACKNOWLEDGED TRANSMITTAL AND  
SUPERSEDED DOCUMENTS (IF APPLICABLE) TO:  
ADMINISTRATION RECORDS  
UNION ELECTRIC COMPANY  
CALLAWAY PLANT  
P.O. BOX 620  
FULTON, MO 65251

TRAN	DOC			RET		ALT	ALT		
CODE	TYPE	DOCUMENT	NUMBER	REV	REV	MED	COPY	MED	COPY
-----				----	----	----	----	----	-----
R		DRAW J-26060A		001	000	C	1		

ACKNOWLEDGED BY:

DATE:

060177

9207080242 920626  
PDR ADDCK 05000483  
F PDR

A045  
11

DOCUMENT CONTROL  
JUN 20 1992  
330  
ION PAGES)

[illegible]

NRC EMERGENCY RESPONSE DATA SYSTEM  
DATA POINT LIBRARY  
J-26060A Rev. 1

REV.  
0  
1

AFFECTED PAGES

NEW DOCUMENT

Page 2 & 9 change SEN0701 units from PCM to %

# CRITICAL SAFETY FUNCTION PARAMETERS

PARAMETER	PARAMETER DESCRIPTION	UNITS	COMPUTER POINT
REACTIVITY CONTROL			
NI POWER RNG	Nuclear Instruments, Power Range	%	SPDS0059
NI INTER RNG	Nuclear Instruments, Intermediate Range	AMPS	SPDS0060
NI SOURC RNG	Nuclear Instruments, Source Range	CPS	SPDS0041
NL	Post Accident Wide Range	%	SEN0701
NL	Post Accident Source Range	CPS	SEN0702
CORE COOLING			
REAC VES LEV	Reactor Vessel Water Level	%	REU0523
TEMP CORE EX	Highest Temperature at the Core Exit	DEGF	REU0090
SUB MARGIN	Saturation Temperature-Highest CET	DEGF	SPDS0006
CORE FLOW	Total Reactor Coolant Flow	%	REU0487
STEAM GENERATORS			
SG LEVEL 1/A	Steam Generator 1 (or A) Water Level	%	REL0404A
SG LEVEL 2/B	Steam Generator 2 (or B) Water Level	%	REL0424A
SG LEVEL 3/C	Steam Generator 3 (or C) Water Level	%	REL0444A
SG LEVEL 4/D	Steam Generator 4 (or D) Water Level	%	REL0464A
SG PRESS 1/A	Steam Generator 1 (or A) Pressure	PSIG	SPDS0022
SG PRESS 2/B	Steam Generator 2 (or B) Pressure	PSIG	SPDS0023
SG PRESS 3/C	Steam Generator 3 (or C) Pressure	PSIG	SPDS0024
SG PRESS 4/D	Steam Generator 4 (or D) Pressure	PSIG	SPDS0025
MN FD FL 1/A	Stm Gen 1 (or A) Main Feedwater Flow	KLB/HR	SPDS0026
MN FD FL 2/B	Stm Gen 2 (or B) Main Feedwater Flow	KLB/HR	SPDS0027
MN FD FL 3/C	Stm Gen 3 (or C) Main Feedwater Flow	KLB/HR	SPDS0028
MN FD FL 4/D	Stm Gen 4 (or D) Main Feedwater Flow	KLB/HR	SPDS0029
AX FD FL 1/A	Stm Gen 1 (or A) Auxiliary FW Flow	KLB/HR	SPDS0054
AX FD FL 2/B	Stm Gen 2 (or B) Auxiliary FW Flow	KLB/HR	SPDS0055
AX FD FL 3/C	Stm Gen 3 (or C) Auxiliary FW Flow	KLB/HR	SPDS0056
AX FD FL 4/D	Stm Gen 4 (or D) Auxiliary FW Flow	KLB/HR	SPDS0057
HL TEMP 1/A	Stm Gen 1 (or A) Inlet Temperature	DEGF	SPDS0030
HL TEMP 2/B	Stm Gen 2 (or B) Inlet Temperature	DEGF	SPDS0031
HL TEMP 3/C	Stm Gen 3 (or C) Inlet Temperature	DEGF	SPDS0032
HL TEMP 4/D	Stm Gen 4 (or D) Inlet Temperature	DEGF	SPDS0033
CL TEMP 1/A	Stm Gen 1 (or A) Outlet Temperature	DEGF	SPDS0034
CL TEMP 2/B	Stm Gen 2 (or B) Outlet Temperature	DEGF	SPDS0035
CL TEMP 3/C	Stm Gen 3 (or C) Outlet Temperature	DEGF	SPDS0036
CL TEMP 4/D	Stm Gen 4 (or D) Outlet Temperature	DEGF	SPDS0037

DATA POINT LIBRARY REFERENCE FILE

Date:	06/25/92
Reactor Unit:	CW1
Data Feeder:	N/A
NRC ERDS Parameter:	NL
Point ID:	SEN0701
Plant Spec Point Desc:	POST ACCIDENT WIDE RANGE
Generic/Cond Desc:	POST ACCIDENT WIDE RANGE
Analog/Digital:	A
Engr Units/Dig States:	%
Engr Units Conversion:	N/A
Minimum Instr Range:	1.000E-08
Maximum Instr Range:	2.000E+02
Zero Point Reference:	N/A
Reference Point Notes:	N/A
PROC or SENS:	P
Number of Sensors:	2
How Processed:	AVERAGE
Sensor Locations:	REACTOR CAVITY
Alarm/Trip Set Points:	N/A
NI Detector Power Supply	
Cut-off Power Level:	N/A
NI Detector Power Supply	
Turn-on Power Level:	N/A
Instrument Failure Mode:	LOW
Temperature Compensation	
For DP Transmitters:	N/A
Level Reference Leg:	N/A
Unique System Desc:	MAY FAIL HIGH.