



MPR Associates, Inc.  
320 King Street  
Alexandria, VA 2314

### CALCULATION TITLE PAGE

Client *FLORIDA POWER CORPORATION*

Page 1 of 41

Project *REVIEW OF CALCULATION OF ALLOWABLE  
MAKEUP TANK PRESSURE VS. LEVEL*

Task No.  
*102-075*

Title *HEAD LOSS IN BWT TO MAKEUP PUMP FLOW*

Calculation No.  
*102075DHH02*

Preparer/Date	Checker/Date	Reviewer/Date	Rev. No.
<i>Alkhasani 1-2-96</i>	<i>R-E Wolf 1/4/96</i>	<i>S. Sethu 1/5/96</i>	<i>0</i>



MPR Associates, Inc.  
320 King Street  
Alexandria, VA 22314

### RECORD OF REVISIONS

Calculation No. <i>10E07SDH402</i>	Prepared By <i>Altman</i>	Checked By <i>RAW</i>	Page <i>2</i>
---------------------------------------	------------------------------	--------------------------	---------------

Revision	Description
<i>0</i>	<i>Original Issue, January 5, 1996.</i>

Calculation No. 102075DH402	Prepared By <i>W. Harrison</i>	Checked By <i>AAW</i>	Page 3
--------------------------------	-----------------------------------	--------------------------	--------

## HEAD LOSS IN BWST TO MAKEUP PUMP FLOW

### 1. PURPOSE

The purpose of this calculation is to estimate the loss in total head for the flow from the BWST to the point of tie-in with the line to the makeup tank. The general arrangement of the system is shown schematically in the sketch on page 5. The head losses are calculated for Case 2F of the revised Florida Power calculation M94-005 Rev 2 (Ref 1.) In that case:

Flow from BWST to 14x14x6 reducing tee = 4291 gpm

Flow from tee to makeup pump IC suction = 600 gpm

The water temperature of the BWST flow is 100°F.

### 2. SUMMARY OF RESULTS

For the specified conditions, the calculated loss in total head from the BWST to the makeup tank tie-in is:

$$\text{Total head loss} = 11.87044 \text{ (of water at } 100^\circ\text{F)}$$

$$\text{Head loss in 14in pipe and through the 14x14x6 tee to the 6in pipe} = 4.06084$$

$$\text{Head loss in 6in pipe from outlet of tee to tie in point} = 7.80964$$

Calculation No. 102075DHH02	Prepared By <i>Al Hassan</i>	Checked By <i>BAW</i>	Page 4
--------------------------------	---------------------------------	--------------------------	--------

### 3. SUMMARY OF METHODOLOGY

The specific length of pipe and the number and type of fittings were based on the drawings listed as Reference 9.

The losses due to fluid friction in the piping and the losses in the components (elbows, valves, tees, etc.) are calculated from the sources identified. The calculation is divided into the following sections:


- Determination of fluid friction factor (Section 4)
- Determination of component loss coefficients (Sect. 5)
- Piping lengths and components (Sect. 6)

The detailed numerical summary is provided in the spreadsheet table of Appendix A



Calculation No. 10207514402	Prepared By <i>Al Harrison</i>	Checked By <i>CAW</i>	Page 5
--------------------------------	-----------------------------------	--------------------------	--------

SCHMATIC OF SYSTEM.



Calculation No.

102075DH402

Prepared By

M. Harrison

Checked By

ASW

Page 6

#### 4. FRICTION FACTOR

The friction factor for the friction loss in the pipe will be based on the Darcy-Weisbach (Fanning) formula

$$h_f = f \frac{L}{D} \frac{V^2}{2g} \quad \text{for head loss}$$

or, it expressed in pressure loss (lb/ft<sup>2</sup>)

$$\Delta p_f = f \frac{\rho}{g} \frac{L}{D} \frac{V^2}{2}$$

where,

$f$  is the friction factor (dimensionless)

$\rho$  is the weight density (lb/ft<sup>3</sup>)

$g$  is the gravitational constant (32.174 ft/sec<sup>2</sup>)

$L$  is the length of the run (ft)

$D$  is the pipe inside diameter (ft)

$V$  is the average velocity in the pipe (ft/sec)

The friction factor,  $f$ , will be determined from the Colebrook equation\*:

$$\frac{1}{\sqrt{f}} = -0.86 \ln \left( \frac{\epsilon/D}{3.7} + \frac{2.51}{N_R \sqrt{f}} \right)$$

where,  $N_R$  is Reynold's No.,  $\frac{VD}{\nu}$   $\nu$  = kinematic viscosity  
ft<sup>2</sup>/sec

\* See, for example, any standard Fluid Mechanics reference such as References 2-5, for example, Ref. 4 page 179, eqn 4-84



Calculation No. 10207SDHH02	Prepared By <i>W. J. ...</i>	Checked By TAW	Page 7
--------------------------------	---------------------------------	-------------------	--------

$\epsilon$  is the absolute roughness, ft.

For commercial, new steel pipe  $\epsilon$  is usually taken as 0.00015 ft (References 3 and 4)

The friction coefficient is evaluated using Mathcad to solve the implicit relation for  $f$ . See the following page

**DETERMINATION OF FRICTION FACTORS**

The dynamic viscosity of water at 100F and approximately atmospheric pressure:

$$\mu = 142.0 \cdot 10^{-7} \cdot \text{lb} \cdot \frac{\text{sec}}{\text{ft}^2} \quad \text{Ref. 8: ASME Steam Tables (1967), Table 10, page 280 10-20 psia, 100F}$$

The density of water at 100F and approximately atmospheric pressure:

$$\rho = \frac{1 \text{ lb}}{0.01613 \text{ ft}^3} \quad \text{Ref. 8: ASME Steam Tables (1967), Table 3, page 131, 15 psia, 100F}$$

The kinematic viscosity is then:

$$v = \frac{\mu}{\rho} \quad v = 7.369 \cdot 10^{-6} \cdot \frac{\text{ft}^2}{\text{sec}}$$

The absolute roughness will be assumed to be that for commercial steel pipe. Since the piping is stainless steel, there should be little change in service. The value is the one normally identified with the Moody curve (see Streeter 2nd ed., Reference 4, page 183, for example)

$$e = 0.00015 \text{ ft}$$

The friction factor, f, is determined from the Colebrook equation (see Reference 4, Streeter, 2nd ed. page 179).

$$\frac{1}{\sqrt{f}} = -0.86 \cdot \ln \left( \frac{e}{D \cdot 3.7} + \frac{2.51}{\text{Nr} \cdot \sqrt{f}} \right)$$

where, D is the pipe diameter, ft  
 Nr is Reynolds Number

14-inch nominal pipe:

$$D := 1.1042 \text{ ft} \quad Q := 4291 \cdot \frac{\text{gal}}{\text{min}} \quad V := \frac{Q}{\pi \cdot \frac{D^2}{4}} \quad V = 9.984 \cdot \frac{\text{ft}}{\text{sec}} \quad \text{Nr} := \frac{D \cdot V}{v} \quad \text{Nr} = 1.496 \cdot 10^6$$

$$\text{Guess value } g := 0.01 \quad f := \text{root} \left( -0.86 \cdot \ln \left( \frac{e}{D \cdot 3.7} + \frac{2.51}{\text{Nr} \cdot \sqrt{g}} \right) - \frac{1}{\sqrt{g}}, g \right) \quad f = 0.01384$$

6-inch nominal pipe

$$D := 0.5054 \text{ ft} \quad Q := 600 \cdot \frac{\text{gal}}{\text{min}} \quad V := \frac{Q}{\pi \cdot \frac{D^2}{4}} \quad V = 6.664 \cdot \frac{\text{ft}}{\text{sec}} \quad \text{Nr} := \frac{D \cdot V}{v} \quad \text{Nr} = 4.57 \cdot 10^5$$

$$\text{Guess value } g := 0.01 \quad f := \text{root} \left( -0.86 \cdot \ln \left( \frac{e}{D \cdot 3.7} + \frac{2.51}{\text{Nr} \cdot \sqrt{g}} \right) - \frac{1}{\sqrt{g}}, g \right) \quad f = 0.01667$$

Calculation No.

102075DHH02

Prepared By

*[Signature]*

Checked By

RAW

Page 9

## 5. COMPONENT LOSS COEFFICIENTS

This section develops the specific head loss coefficients for the components in the system exclusive of the straight pipe. Note that these coefficients incorporate the friction losses as part of the total loss; consequently, it is not necessary to include the length of the flow path in the friction loss determination.

In general, the simple methods outlined in such widely used references as Crane (Reference 2) are used for common components such as elbows, fully open gate valves, and sudden contractions. For the flow through tees, the more complicated methods of Miller (Reference 3) are used. The check valve flow resistance is based on test results as reported by EPRI in Reference 6.

Calculation No.

102075DHH02

Prepared By

*Al H. ...*

Checked By

RAW

Page 10

a. *BUST* Exit


The exit will be assumed to be a flush, sharp edged entrance, and a value of  $K = 0.5$  will be used (See Reference 2, p A-29).

A rounding of the entrance could reduce this somewhat; however, the tank drawings show a vortex suppression structure, but do not define its configuration. The full loss for a sharp entrance is assumed to account for this uncertainty.

Calculation No.

102075DHH02

Prepared By



Checked By

RAN

Page 11

## b. ELBOWS.

 90° Flanged or butt welded (not threaded)  $r/d = 1.5$ 

Crane (Ref 2, page A-29)

 90°  $K = 14 f_T$  where  $f_T$  is given in the table on pA-26

 Note that both 14 and 6 elbows have  $r/d = 1.5$ , but

$$14\text{-in } f_T = .013 \quad \text{so } K = 14 \times .013 = \underline{0.182}$$

$$6\text{-in } f_T = .015 \quad K = 14 \times .015 = \underline{0.210}$$

$$45^\circ \quad K = (n-1)(0.25\pi f_T \frac{r}{d} + 0.5K) + K$$

 where  $n = \text{number of } 90^\circ \text{ bends} = \frac{1}{2}$ 
 $r/d = 1.5$  and  $K = 14 f_T$ 

$$K = (\frac{1}{2} - 1)(0.25\pi f_T 1.5 + 0.5 \cdot 14 f_T) + 14 f_T$$

$$K = -\frac{1}{2}(1.1781 f_T + 7 f_T) + 14 f_T = 9.91 f_T$$

$$14\text{-in } K = 9.91 \times .013 = \underline{0.129}$$

$$6\text{-in } K = 9.91 \times .015 = \underline{0.149}$$


Two other reference sources were also consulted for elbow losses. Those results are presented on subsequent pages. Both the methods of Ito (Reference 10) and Miller (Reference 3) result in loss coefficients generally lower than the above values. Because of the widespread use of the Crane-based values and because they are somewhat conservative compared to other methods they will be used in the calculations.



Calculation No.

102075DH402

Prepared By



Checked By

RAW

Page 12

Ito (Reference 10) presents a correlation for the total pressure loss in a smooth bend,  $k_t$ , as  $(\text{for } N_R (r/r_c)^2 > 91$ .

$$k_t = 0.00241 \alpha \theta (N_R)^{-0.17} \left(\frac{R}{r}\right)^{0.84} \quad \text{where}$$

$\alpha$  = a constant that depends on  $\theta$  and  $R/r$ .

$\theta$  = bend angle, in degrees.

$N_R$  = Reynolds number

$R$  = radius of curvature of the bend.

$r$  = inside radius of the pipe.

For long radius elbows  $R = 1.5 \cdot 2r$  or  $R/r = 3.0$

for  $\theta = 90^\circ$   $\alpha = 0.95 + 17.2 (R/r)^{-1.96}$

for  $\theta = 45^\circ$   $\alpha = 1 + 14.2 (R/r)^{-1.47}$

Ito defines the total loss coefficient as follows

$$k_t = \frac{L_{ht}}{\frac{V^2}{2g}} \quad \text{where } L_{ht} = \text{total head loss}$$

Ito's expression is evaluated for the Crystal River 14 and 6 inch pipe on page 14 using Mathcad. be compared to the Crane (Ref. 2).

14-in	$90^\circ$	Ito	$K = 0.143$	} $K_{ratio} = \frac{0.143}{0.182} = 0.79$
		Crane	$K = 0.182$	
	$45^\circ$	Ito	$K = 0.093$	} $K_{ratio} = \frac{0.093}{0.129} = 0.72$
		Crane	$K = 0.129$	

So for the 14-in pipe Ito's correlation gives lower  $k_t$  by 20-25 percent



Calculation No.

102075DHH02

Prepared By

*H. Harrison*

Checked By

*RAW*

Page 13

Similarly for 6-inch pipe

90°	Ito $K = 0.175$	} Ratio = 0.83
	Crowe $K = 0.210$	
45°	Ito $K = 0.114$	} Ratio = 0.77
	Crowe $K = 0.149$	

So for 6-inch pipe Ito's correlation gives lower  $k$  by about 20 percent.

EVALUATION OF ITO'S EXPRESSION FOR ELBOW HEAD LOSS

This is an evaluation of the following expression from Reference 10:

$$k_t(\alpha, \theta, N_R, R_r) := 0.00241 \cdot \alpha \cdot \theta \cdot N_R^{-0.17} \cdot (R_r)^{0.84}$$

For all elbows the radius ratio is:  $R_r := 3.0$  (This is a R/D of 1.5 for long radius elbows.)

For 14 inch nominal pipe

$$N_R := 1.496 \cdot 10^6$$

90 Degree bend:  $\theta := 90$

$$\alpha := 0.95 + 17.2 \cdot R_r^{-1.96}$$

$$k_t(\alpha, \theta, N_R, R_r) = 0.143$$

45 Degree bend  $\theta := 45$

$$\alpha := 1 + 14.2 \cdot R_r^{-1.47}$$

$$k_t(\alpha, \theta, N_R, R_r) = 0.093$$

For 6 inch nominal pipe

$$N_R := 4.57 \cdot 10^5$$

90 Degree bend:  $\theta := 90$

$$\alpha := 0.95 + 17.2 \cdot R_r^{-1.96}$$

$$k_t(\alpha, \theta, N_R, R_r) = 0.175$$

45 Degree bend  $\theta := 45$

$$\alpha := 1 + 14.2 \cdot R_r^{-1.47}$$

$$k_t(\alpha, \theta, N_R, R_r) = 0.114$$

Calculation No. 102075DHH02	Prepared By <i>Harrison</i>	Checked By <i>RSW</i>	Page 15
--------------------------------	--------------------------------	--------------------------	---------

Miller (Reference 3, p80) in Fig. 5.41 provides a bend loss coefficient as a function of  $r/d$  and the bend angle for a Reynolds number of  $10^6$ .




Fig. 5.41. Bend performance chart — circular cross-section ( $Re = 10^6$ )


For those conditions:  $K_{90} = 0.183$   $K_{45} = 0.088$

These values are lower than obtained by the Crow (Ref. 2) method for all 6-inch elbows and 45° 14-in elbows. The values for 14-in 90° elbows are essentially the same.

Calculation No. 102075DHH02	Prepared By <i>[Signature]</i>	Checked By <i>RSW</i>	Page 16
--------------------------------	-----------------------------------	--------------------------	---------

c. Tees  
14x14x6 Reducing Tee (T1) (branch flow)

Miller (Reference 3, Ch. 13) provides a method to get the pressure change across a tee, with flow out a reduced size branch. The arrangement is as shown in the sketch at right.  $\bar{u}$ s are the mean velocities in the branches.



p 304, Miller defines a loss coefficient,  $K_{z1}$ , as follows

$$\text{where total } H = z + \frac{p}{\rho g} + \frac{u^2}{2g} \text{ and } h = z + \frac{p}{\rho g}$$

$$K_{z1} = \frac{\left( \frac{\bar{u}_3^2}{2g} + h_3 \right) - \left( \frac{\bar{u}_1^2}{2g} + h_1 \right)}{\frac{\bar{u}_2^2}{2g}}$$

$K_{z1}$  is given for various values of area and flow ratio in Fig 13.21.4, Ref 3 (Miller indicates (p 304) that for  $Re > 2 \times 10^5$  no correction to  $K_{z1}$  is needed.  $Re$  is both 14 and 6 inch runs are  $> 2 \times 10^5$  so no correction is needed.)

Area Ratio:

$$D_3 \quad 14 \text{ in pipe} = 14.00 - 2 \times 0.375 = 13.250 \text{ in} = 1.1042 \text{ ft}$$

$$D_1 = 6 \text{ in pipe} = 6.625 - 2 \times 0.280 = 6.065 \text{ in} = 0.50542 \text{ ft}$$

$$A_r = \left( \frac{0.50542}{1.1042} \right)^2 = (0.45774)^2 = 0.20952$$

Flow Ratio:

$$Q_1 = 600 \text{ gpm} \quad Q_2 = 4291 \text{ gpm}$$

$$\frac{Q_1}{Q_2} = \frac{600}{4291} = 0.1398$$

Calculation No. 102075DHH02	Prepared By <i>Alt Harrison</i>	Checked By <i>RLW</i>	Page 17
--------------------------------	------------------------------------	--------------------------	---------

Using these values  
 from Fig 13.21 of Reference 3 (see the following page)

$$K_{31} = 1.2$$

From the definition of  $K_{31}$ , we can get the head loss,  $h_3 - h_1$ ,

$$K_{31} \frac{\bar{u}_3^2}{2g} = \frac{\bar{u}_3^2}{2g} + h_3 - \frac{\bar{u}_1^2}{2g} - h_1$$

$$h_3 - h_1 = K_{31} \frac{\bar{u}_3^2}{2g} - \left( \frac{\bar{u}_3^2}{2g} - \frac{\bar{u}_1^2}{2g} \right)$$

The total head at 1 and 3

$$H_1 = z_1 + \frac{p_1}{\rho g} + \frac{u_1^2}{2g} \quad H_3 = z_3 + \frac{p_3}{\rho g} + \frac{u_3^2}{2g}$$

$$\text{or} \quad H_1 = h_1 + \frac{u_1^2}{2g} \quad H_3 = h_3 + \frac{u_3^2}{2g}$$

so the total head at 1 [note that this would not be the measured value, but only the apparent value after recovery, ~30D]

$$H_3 - H_1 = h_3 + \frac{u_3^2}{2g} - h_1 - \frac{u_1^2}{2g} = (h_3 - h_1) + \left( \frac{u_3^2}{2g} - \frac{u_1^2}{2g} \right)$$

$$H_3 - H_1 = K_{31} \frac{u_3^2}{2g} - \left( \frac{u_3^2}{2g} - \frac{u_1^2}{2g} \right) + \left( \frac{u_3^2}{2g} - \frac{u_1^2}{2g} \right)$$

$$\text{So, } H_3 - H_1 = K_{31} \frac{u_3^2}{2g} = 1.2 \frac{(9.984)^2}{2 \cdot 32.2} = \underline{\underline{1.8574 \text{ ft}}}$$

Calculation No. <i>102075DHH02</i>	Prepared By <i>Al Hassan</i>	Checked By <i>RSJ</i>	Page <i>18</i>
---------------------------------------	---------------------------------	--------------------------	----------------

*CURVE OF  $K_{31}$  VALUES FROM REFERENCE 3.*




Fig. 13.21'. Dividing flow: branch angle 90°, loss coefficient  $K_{31}$

Calculation No. 102075DHH02	Prepared By <i>Al Johnson</i>	Checked By <i>RAW</i>	Page 19
--------------------------------	----------------------------------	--------------------------	---------

14x14x10 Reducing Tee (T1a)

Flow in the run branch only (all 14in)

Using Miller (Ref 3, Fig 13.23) see following page.

$$\frac{Q_1}{Q_2} = 0 \text{ (no flow in branch)}$$



$$K_{32} \equiv \frac{\left( \frac{u_3^2}{2g} + h_3 \right) - \left( \frac{u_2^2}{2g} + h_2 \right)}{\frac{u_2^2}{2g}}$$

Fig. 13.23 shows  $K_{32} = 0.04$

since  $u_3 = u_2$  (no branch flow)

$$K_{32} = \frac{h_3 - h_2}{\frac{u_2^2}{2g}}, \quad h_3 - h_2 = K_{32} \frac{u_2^2}{2g}$$

Compare to the friction loss alone,  $L = 1.8333 \text{ ft}$ ,  $D = 1.1042 \text{ ft}$

$$f \frac{L}{D} = 0.01384 \times \frac{1.8333}{1.1042} = 0.023$$

The friction loss alone is somewhat less, so use  $K = 0.04$

(Ref 2)

Note, the value in Crane of 20 would give  $20 \times 0.01384 = 0.277$  however that is for a pipe thread fitting, not one with a smooth interior. It is not appropriate for this case.



Calculation No.  
102075DHH02

Prepared By  
*H. H. ...*

Checked By  
*RAW*

Page 20

FROM MILLER, Reference 3, page 319




Fig. 13.23. Dividing flow: branch angles of 45-90°, loss coefficient  $K_{32}$



Calculation No. 102675D4402	Prepared By <i>W. Harrison</i>	Checked By <i>LAW</i>	Page 21
--------------------------------	-----------------------------------	--------------------------	---------

6x6x6 Tee (T2)

Flow in run and out branch, no through run flow.


Using the method in  
Miller (Ref 3)

p304 + Fig. 13.21 see page 18

$$A_r = 1.0$$

$$Q_r = 1.0$$

$$K_{31} = 1.13$$



$$K_{31} = \frac{\left(\frac{U_3^2}{2g} + h_{f3}\right) - \left(\frac{U_1^2}{2g} + h_{f1}\right)}{U_3^2/2g}$$

$$U_3 = U_1$$

$$K_{31} \frac{U_3^2}{2g} = h_{f3} - h_{f1}$$

$$h_{f3} - h_{f1} = \underline{1.13} \frac{U_3^2}{2g}$$

Calculation No.

102075D4402

Prepared By

*[Signature]*

Checked By

RAW

Page 22

6x6x6 Tee (T3)

Flow in run branch only.

As for the 14x14x10 tee, the Fig 13.23 in Miller (Ref. 3) gives a K of 0.04

The friction loss in the run as a pipe would be:

$$L = 0.9367 \text{ ft} \quad D = 0.50542 \text{ ft} \quad f = 0.01667$$

so

$$f \frac{L}{D} = 0.01667 \times \frac{0.9367}{0.50542} = 0.0309$$

so only a small form loss, as would be expected.

so use

$$K = \underline{0.04}$$

6x6x4 Reducing Tee (T4)

Flow is through the run. In this case the form losses would not be fully realized until after the component; however, half of the 6x6x6 tee loss will be used.

$$K = \underline{0.02}$$

Calculation No.

10C075DHH02

Prepared By

*H. Harrison*

Checked By

*RAW*

Page 23

## d. GATE VALVES

6 inch - (MUV-58, MUV-62, MUV-63)

These gate valves will be completely open. The drawing for MUV-58 does not show any reduction of area through the valve.

Crane (Ref. 2, p A-27) recommends  $K = 8f_T$  where  $f_T$  comes from a table on p A-26, and for 6 in nominal pipe is .015, so  $K = .015 \times 8$

or  $K = \underline{0.12}$

Calculation No.

102075DH402

Prepared By

*H. Harrison*

Checked By

*L.A.W.*

Page 24

## e. CHECK VALVE

6 inch MUV (Crane 6 in 300 lb class, swing check)

Crane (Ref 2, p A-27) gives a  $K$  value of 50 ft  
for the condition where the disk is fully lifted.

For this case, as for the gate valve,  $f_T$  will be taken  
from the table on p A-26, i.e.  $f_T = .015$  so

$$K = 50 \times .015 = 0.75$$

This value is correct only if the valve is fully open.

In EPRI NP-5479 (Ref. 6) actual test data are cited  
for a 6-600 lb Crane valve that show it was not fully  
open until the velocity, with cold water, reached 11 ft/sec.  
Consequently, MUV-60 at only 6.7 ft/sec  
will not be fully open. In that case the  $K$  value for  
the fully open valve will be too low, since the partially  
open disk will extend into the flow stream.

Calculation No.

102075DHH 02

Prepared By

M. Harrison

Checked By

-PAW

Page 25

Some test data are available in Reference 6 EPR1 NP-5479, Appendix D, on the cold water pressure drop through a conventional 6 in swing check valve at various disk angles.

The valve was a Pacific 6" - 300 lb valve. The valve in Crystal River is a Crane 6" - 300 lb valve. Although the valves are not identical, their behavior should be similar.

Reference 6 shows that the Pacific valve was fully open when the disk had swung to 70° and that this fully open condition was effectively reached in the 10-14 ft/sec velocity range. This corresponds to the data cited in Fig 3-4 which shows that a Crane 6" - 600 valve was fully lifted at about the same velocity, ~11 ft/sec. At that point (10-11 ft/sec) the pressure drop across the valve (for 68°F water) was 0.5 psi. At the same velocity, the pressure drop for the 6" - 300 Pacific valve reported in NP-5479 was essentially the same - 0.5 psi.

It will be assumed that the Crane 6" - 300 swing check valve behaves the same as the Pacific 6" - 300 swing check reported in Appendix D of NP-5479. The EPR1 report gives for the Pacific valve:

- A curve (Fig D-7) of disk angle as a function of flow velocity.
- A curve (Fig D-17) of flow coefficient as a function of disk angle.

(See the following pages.)

At the reference velocity of 6.7 ft/sec in the bin piping the disk angle from Figure D-7 would be 60°.

Calculation No.

102075DHH02

Prepared By

*W. Harrison*

Checked By


*BAW*

Page 56

FROM EPRI NP-5479, Reference 6

### DISK POSITION vs FLOW RATE

Baseline Test, 20d



BASELINE TEST RESULTS FOR 6" SWING CHECK VALVE

FIGURE D-7

Calculation No.

103075DHH02

Prepared By

*H. Harrison*

Checked By


*PAW*

Page 27

FROM EPRI NP-5479 Reference 6.

VALVE FLOW COEFFICIENT vs. STOP ANGLE

6 Inch Swing Check Test Valve



C<sub>v</sub> TEST RESULTS FOR 6" SWING CHECK VALVE

FIGURE D-17



Calculation No.

102075DHH02

Prepared By

*M. Harrison*

Checked By

*RAW*

Page 28

The  $C_v$  for that disk orifice from Fig D-17 is 1150  $\frac{\text{gpm}}{\sqrt{\text{psi}}}$

$C_v$  and  $K$  are related by the following expression  
(Crane, Ref. 2, p 3-4)

$$K = \frac{891 d^4}{(C_v)^2} \quad \text{where } d \text{ is pipe ID in inches}$$

$$d = 6.065 \text{ in}$$

$$K = \frac{891 (6.065)^4}{1150^2} = 0.9116$$

This is slightly higher than the 0.75 value obtained using Crane (Ref. 2) which recommended 50ft.

so use  $K = \underline{0.912}$



Calculation No. 102075DHH02	Prepared By <i>W. Harrison</i>	Checked By <i>RAW</i>	Page 29
--------------------------------	-----------------------------------	--------------------------	---------

6. PIPING LENGTHS AND COMPONENT IDENTIFICATION


This section tabulates the components and length of straight pipe from the BWST outlet to tie-in to the makeup tank.

Ref. drawing PI-305-816 sk 5 of 5

- BWST Nozzle -

- P1 - BWST-to-elbow

$$L = 7' 7\frac{1}{8}" - 21" = 7.594 - 1.750 = \underline{5.844 \text{ A.}} \quad \checkmark$$



- E1 - 90 elbow

- P2a - 90 elbow to tee run

$$L = 7' 6" - 21" - \frac{1.833}{2} = 7.500 - 1.750 - 0.917 = \underline{4.833 \text{ A.}} \quad \checkmark$$


- T1a - Tee Run 14x14x10 Rad. Tee

- P2b - tee to elbow

$$L = 26.6875 - 2' 8\frac{1}{4}" - \frac{22"}{2} - \frac{21 \tan 22.5^\circ}{12}$$

$$L = 26.6875 - 2.6875 - 0.9167 = 7.249$$

$$L = \underline{22.3584}$$




- E2 - elbow 45°

- P3 - angled tee-elbow to elbow

$$\frac{E}{21} = \tan 22.5^\circ$$

$$E = 21 \tan 22.5^\circ = 8.698 \text{ in}$$

$$E = 0.725 \text{ A.}$$



$$L = 3' 9\frac{5}{8}" - 2E = 3.802 - 2 \times 0.725 = \underline{2.352 \text{ A.}} \quad \checkmark$$

Note: Piping and component item numbers are arbitrary assignments, where shown on the drawings they are related to section identification numbers on the drawings, i.e., (46) etc.

Calculation No.

Prepared By

Checked By

Page 30


102075DHH 02

*Harrison*

*RAW*

Not clear whether there is a short run of pipe between the elbow and the tee.

See previous page  
 $E = 0.725 \text{ ft}$




If  $1' 7 \frac{3}{4}'' - E \approx 11''$  there is no pipe

$$1.646 - 0.725 = 0.921 \text{ ft} \quad 11'' = 0.917 \text{ ft} \text{ - (no pipe)}$$

- T1 - 14x14x6 Red Tee
- P4 - (Tee to 90° elbow)

$$L = 5' 0 \frac{5}{8}'' - 9'' - 0.781 \text{ ft}$$



$$L = 5.0521 - 0.750 - 0.781$$

$$L = \underline{3.521 \text{ ft}}$$

- E4 - 90° elbow
- P5 - Vert. run elbow-elbow


The drawing is not clear on the position of the horizontal pipe. So use elevations.

There is a value of  $18' 8 \frac{1}{4}''$  on the drawing; however, the bottom of the dimension arrow is not distinct, but

$$18' 8 \frac{1}{4}'' = 18.688 \text{ ft} \text{ - so result checks use } 18.688 \text{ ft}$$

So

$$L = 18.688 - 2 \times \frac{9}{12} = \underline{17.188 \text{ ft}} \checkmark$$



- E5 90° elbow
- E5a 45° elbow

Calculation No.

102075DHH02

Prepared By

H. Harrison


Checked By

R. W.

Page 31

- P6 - elbow to elbow

Drawing is not clear, there appear to be two dimensions; however, it is not evident whether they are to the match point of the 45° elbow or the weld to the straight pipe.



$$\text{if } 9'' \sin 45^\circ + 9'' \cos 45^\circ = 12.75 \text{ in then dimension is to weld}$$

$$= 12.728 \text{ in} - \text{so dimension is to weld}$$

$$L = 4'4'' - 9'' = \underline{\underline{3.583 \text{ ft}}}$$

- E6 - 90°-elbow

- P7 - elbow-elbow

$$L = 9.0 - 2 \times 9/12 = \underline{\underline{7.500 \text{ ft}}}$$

- E7 - 90°-elbow

- MUV-58 - 6" Gate valve (44-47)

- P47-48 - between valves.  $L = \underline{\underline{0.5729 \text{ ft}}}$  from drawing.

- MUV-60 6" check valve (48-49)

- T2 - 6-tee - (out branch)

Reference

 drawing P1-303-816  
 sh 50, 5


 drawing P1-303-86  
 sh 2 & 2

Calculation No. 102075DHH02	Prepared By <i>[Signature]</i>	Checked By RAW	Page 32
--------------------------------	-----------------------------------	-------------------	---------

- PT2-129 - tee to 90 elbow  
 $L = 8' - \text{tee br} - \text{elbow}$  (for Tee br. see p 37)  
 $L = 8.0 - 0.469 - 0.750 = \underline{6.781 A}$

- E129-131 - 90° elbow

- P131-133 - elbow-elbow




$$e_6 = 9 \tan 22.5^\circ = 3.728 \text{ in}$$

$$L = 7.8813 + 0.9575 - \frac{3.728}{12} - \frac{9}{12} = \underline{7.778 A. \checkmark}$$

0.311      0.750

- E133-135 - 45° elbow

- P135-139 - elbow to elbow



$$- 11.4167 + 3.4271 A$$

$$L = 11.4167 + 3.4271 - 0.75 - \frac{3.728}{12} = \underline{13.783 A. \checkmark \checkmark}$$

- E139-141 - 90° elbow

- P141-142 - elbow to elbow

$$L = 2.000 - 2 \times 0.750 = \underline{0.500 A. \checkmark}$$

- E142-144 - 90° elbow

- P144-151 - elbow to elbow

$$L = 2.500 + 11.000 + 10.000 + 10.500 - 2 \times 0.75 = \underline{32.50 A}$$

- E151-153 - 90° elbow

Calculation No.

Prepared By

Checked By


Page 33

102075DHH02

*[Handwritten Signature]*


RAW

- P156-153 - elbow 90 to elbow 45



$$L = 4.833 - 0.311 - 0.750 = \underline{3.772 \text{ ft}}$$

- E156-158 - 45° elbow
- P160-158 - elbow-elbow



$$L = 7.0710 - 0.750 - 0.311 = \underline{6.010 \text{ ft}}$$

- E160-162 - 90° elbow
- E162-164 - 90° elbow

$$P177-164 - L = 6.000 + 7.250 + 7.250 + 7.250 + 7.250 + 16.250 + 1.0 - 2 \times 0.750$$

$$L = 52.20 - 1.50 = \underline{50.750 \text{ ft}}$$

- E177-179 - 90° elbow
- P179-182 elbow to elbow

$$L = 4.500 + 4.25 - 2 \times 0.750 = 8.75 - 1.50 = \underline{7.25 \text{ ft}}$$

- E182-184 - 90° elbow
- P184-73 - elbow to tee, (as-built dimensions used)

$$L = 5.3333 + 0.7917 + 0.8750 - 0.750 - \frac{0.938}{2}$$

$$L = \underline{5.781 \text{ ft}}$$

(For the dimensions see p. 37)

- T3 - 6x6x6 Tee-run  
(no pipe between tee and valve)

- MUV-62 6" Gate Valve
  - P206-207 - valve to valve
- $$L = \underline{0.9167 \text{ ft}} \text{ (as-built)}$$

- MUV-63 6" Gate Valve
  - P210-T4 MUV-63 to T
- $$L = 5.5000 + 5.5417 - \frac{0.938}{2} = \underline{10.573 \text{ ft}}$$
- T4 - 6x6x4 tee.

DRAWING P1-303-861 542 of 2

DRAWING

DRAWING P1-305-858 542 of 2

Calculation No. 102075DHH 02	Prepared By <i>[Signature]</i>	Checked By <i>RAW</i>	Page 34
---------------------------------	-----------------------------------	--------------------------	---------

Piping from Makeup Tank to Tie-in Point

This information used to establish volume of piping.

Reference drawing PI-305-860 Sht of 2

- PTK-4 - makeup tank to elbow

$$L = 14.50 - 0.500 = \underline{14.00 \text{ ft}}$$

- ELBOW-90°

- P6-12 - elbow to elbow

$$L = 1.500 + 1.000 + 3.250 - 2 \times 0.500 = \underline{4.750 \text{ ft}}$$

- ELBOW-90°

- TEE 4x4x3 - Run

(For Tee dimensions see p 37.)

- P29-27 tee to valve

$$L = 1.3333 + 2.5729 - 0.688/2 = \underline{3.562 \text{ ft}}$$

- MUV-65 - 4" check valve. L = 1.1667 ft.


- P34-32 check valve to 45° elbow

$$L = 3.000 + 0.6458 - 0.207 = \underline{3.439 \text{ ft}}$$

- ELBOW-45°

- P36-37 elbow to elbow

$$L = 1.000 - 2 \times 0.207 = 0.586 \text{ ft}$$



- E 37-39 - 45° elbow

- PV64-39 elbow to valve

$$L = 0.4167 + 1.1042 - 0.207 = \underline{1.314 \text{ ft}}$$

- MUV-64 valve. L = 2 x 0.6667 ft

- P56-44 valve to elbow

$$L = 4.1667 + .3333 + 9.7500 + .8333 + 9.6667 + 4.250 + 2.0 + 4.5833 + 7.500 - 0.6667 - 0.5$$

$$L = \underline{41.917 \text{ ft}}$$

- ELBOW 90°

- P58-65 elbow to elbow

$$L = .8229 + 9.500 + 10.000 + 2.000 - 2 \times 0.5$$

$$L = \underline{21.323 \text{ ft}}$$

- ELBOW 90°

Calculation No.

102075DHH

Prepared By

*W. W. W.*

Checked By

RAW

Page 35

- P 67-69 elbow to elbow (use as-built)

$$L = 2.3333 - 2 \times 0.5 = \underline{1.333 \text{ ft}}$$

- ELBOW 90°

- PT4-71 elbow to tee

$$L = \frac{(106 - 104.5)}{1.5} - 0.500 - 0.427$$

↙ (For tee dimension see p 37)

$$L = \underline{0.573 \text{ ft}}$$

- TEE 6x6x4 - Branch




Calculation No. 102075DHH02	Prepared By <i>M. H. ...</i>	Checked By <i>R. ...</i>	Page 36
--------------------------------	---------------------------------	-----------------------------	---------


STANDARD TEE DIMENSIONS Ref: ASME B16.9 (1993) (Ref. 7)

These dimensions are used to establish the lengths of straight pipe.

- T10. 14x14x10 Reducing Tee (Std) Ref. 9  
 14 in Sch 30 14 OD - 0.375 in wall Ref. 9  
 10.75 OD - 0.365 in wall Ref. 9




- T1 14x14x6 Reducing Tee (Std)  
 6 in - 6.625 OD x 0.280 wall Ref. 9






Calculation No. 102075DHH02	Prepared By <i>Alston</i>	Checked By <i>RAW</i>	Page 37
--------------------------------	------------------------------	--------------------------	---------


T2 6x6x6 Ref. 9  
T3 6in. 6.625 x 0.280 wall Ref. 9



T4 6x6x4 Ref. 9  
4in 4.5000 x 0.237 wall = 4.056 ID Ref. 9



T5 4x4x3 Ref. 9  
3in = 3.500 OD x 0.216 wall = 3.068 ID



Calculation No.

102075DHH02

Prepared By

*Nickerson*

Checked By

*RDW*

Page 38

## 7. REFERENCES

1. Florida Power Corporation, "Allowable MUT-1 Indicated Overpressure vs. Indicated Level," Calc. A194-0053, Rev. 2 with identified revisions for PR95-0532 and CP-150 OCRM0-95-NJP-18
2. Crane Company, Flow of Fluids through Valves, Fittings, and Pipes, Technical Paper 410, Crane Company, New York, (1988)
3. D.S. Miller, Internal Flow Systems Design and Performance Prediction, Second Edition, Gulf Publishing, Houston (Air Science Company, Corning, N.Y.) (1990).
4. V. L. Streeter, Fluid Mechanics, Second Edition, McGraw-Hill, New York, (1958)
5. I.E. Idelchik, Handbook of Hydraulic Resistance, Second Edition, Hemisphere, Washington (1986) Translated and Edited by G.R. Malyavskaya, Martynenko, and Fried.
6. Electric Power Research Institute, "Application Guidelines for Check Valves in Nuclear Power Plants," EPRI NP-5479, January 1988.
7. American Society of Mechanical Engineers, "Factory-Made Wrought Steel Buttwelding Fittings," ASME B16.9-1993, ASME, New York 1993.
8. American Society of Mechanical Engineers, "ASME Steam Tables," ASME, New York 1967.

Calculation No.

102075DHH 02

Prepared By

*M. Harrison*

Checked By

*RAW*

Page 39

## REFERENCES (Cont'd)

9. Florida Power Corporation, Crystal River Plant, Unit No. 3  
DRAWINGS

PI-305-816, sh. 5 of 5, Rev. 0 - Seismic Diagram, D.H.  
System, "Decay Heat Removal from Decay Heat Pump  
3-B to Pen #345."

PI-305-861, sh 2 of 2, Rev. 0 - Seismic Diagram, M.U.  
System, "From Borated Water Storage Tank to  
Makeup Pump Suctions."

PI-305-858, sh 2 of 2, Rev. 0 - Seismic Diagram, M.U.  
System, "From MUV-69 to Make-up Pump  
Suctions 3A-3B-3C"

10. H. Ito, "Pressure Losses in Smooth Pipe Bends," Transactions  
of the ASME, Series D, Journal of Basic Engineering,  
March 1960, pages 131-143.

Calculation No.

102075DHH02

Prepared By

M. Harrison

Checked By

FAW

Page 40

## APPENDIX A

This appendix consists of a printout of the spreadsheet used to perform the quantitative calculations of head loss. The majority of the values are input from other calculations. The spreadsheet performs the following simple calculation:

$$\Delta H = \left( f \frac{L}{D} + K \right) \frac{V^2}{2g}$$

and then sums the values.

The "items" are identified in Section 6.

The loss factors are obtained from Section 5

The friction factors are obtained in Section 4

Item	Nom. Size	Description	Ref Drwg	Straight Pipe Length Ft	Elevation Ft	Comp Flow Length Ft	Flow Diameter Ft	Pipe L/D	Comp. Total Loss Coef	Friction Factor	Velocity ft/sec	Velocity Head ft	Combined Head Loss Coeff K	Head Loss ft
NBWST	14	outlet nozzle			120.5	0	1.1042	0	0.5	0.01384	9.984	1.548	0.5	0.7739
P1	14	pipe	-816	5.844	120.5		1.1042	5.292519		0.01384	9.984	1.548	0.073248	0.1134
E1	14	90 elbow	-816		120.5-vert	2.7489	1.1042	0	0.182	0.01384	9.984	1.548	0.182	0.2817
P2a	14	pipe	-816	4.833	vertical		1.1042	4.376924		0.01384	9.984	1.548	0.060577	0.0638
T1a	14-10-14	run tee	-816		vertical	1.8333	1.1042	0	0.04	0.01384	9.984	1.548	0.04	0.0619
P2b	14	pipe	-816	22.3584	vertical		1.1042	20.24851		0.01384	9.984	1.548	0.280239	0.4338
E2	14	45 elbow	-816		vert-45el	1.3744	1.1042	0	0.129	0.01384	9.984	1.548	0.129	0.1997
P3	14	pipe	-816	2.352	45 angle		1.1042	2.130049		0.01384	9.984	1.548	0.02948	0.0456
E3	14	45 elbow	-816		45el-86.3	1.3744	1.1042	0	0.129	0.01384	9.984	1.548	0.129	0.1997
T1	14-6-14	red br tee	-816		86.313		1.1042	0	1.2	0.01368	9.984	1.548	1.2	1.8574
Sum				35.3874				32.048	2.18				2.623544	4.0608
P4	6	pipe	-816	3.521	86.313		0.5054	6.966759		0.01667	6.664	0.690	0.116136	0.0801
E4	6	90 elbow	-816		86.313-ve	1.1781	0.5054	0	0.21	0.01667	6.664	0.690	0.21	0.1448
P5	6	pipe	-816	17.188	vertical		0.5054	34.00871		0.01667	6.664	0.690	0.566925	0.3909
E5	6	90 elbow	-816		vert-105	1.1781	0.5054	0	0.21	0.01667	6.664	0.690	0.21	0.1448
E5a	6	45 elbow	-816		105	0.58905	0.5054	0	0.149	0.01667	6.664	0.690	0.149	0.1027
P6	6	pipe	-816	3.583	105		0.5054	7.089434		0.01667	6.664	0.690	0.118181	0.0815
E6	6	90 elbow	-816		105-vert	1.1781	0.5054	0	0.21	0.01667	6.664	0.690	0.21	0.1448
P7	6	pipe	-816	7.5	vertical		0.5054	14.83973		0.01667	6.664	0.690	0.247378	0.1706
E7	6	90 elbow	-816		vert-96	1.1781	0.5054	0	0.21	0.01667	6.664	0.690	0.21	0.1448
MUV-58	6	gate vlv	-861		96	1.323	0.5054	0	0.12	0.01667	6.664	0.690	0.12	0.0827
P47-48	6	pipe	-861	0.5729	96		0.5054	1.133558		0.01667	6.664	0.690	0.018896	0.0130
MUV-60	6	check vlv	-861		96	0	0.5054	0	0.912	0.01667	6.664	0.690	0.912	0.6289
T2	6-6-6	br tee	-861		96		0.5054	0	1.13	0.01667	6.664	0.690	1.13	0.7792
P129-T2	6	pipe	-861	6.781	vertical		0.5054	13.4171		0.01667	6.664	0.690	0.223663	0.1542
E129-131	6	90 elbow	-861		vert-104	1.1781	0.5054	0	0.21	0.01667	6.664	0.690	0.21	0.1448
P131-133	6	pipe	-861	7.778	104		0.5054	15.38979		0.01667	6.664	0.690	0.256548	0.1769
E133-135	6	45 elbow	-861		104	0.58905	0.5054	0	0.149	0.01667	6.664	0.690	0.149	0.1027
P135-139	6	pipe	-861	13.783	104		0.5054	27.27147		0.01667	6.664	0.690	0.454615	0.3135
E139-141	6	90 elbow	-861		104-vert	1.1781	0.5054	0	0.21	0.01667	6.664	0.690	-0.21	0.1448
P141-142	6	pipe	-861	0.5	vertical		0.5054	0.989315		0.01667	6.664	0.690	0.016492	0.0114
E142-144	6	90 elbow	-861		vert-106	1.1781	0.5054	0	0.21	0.01667	6.664	0.690	0.21	0.1448
P144-151	6	pipe	-861	32.5	106		0.5054	64.3055		0.01667	6.664	0.690	1.071973	0.7392
E151-153	6	90 elbow	-861		106	1.1781	0.5054	0	0.21	0.01667	6.664	0.690	0.21	0.1448
P156-153	6	pipe	-861	3.772	106		0.5054	7.463395		0.01667	6.664	0.690	0.124415	0.0858
E156-158	6	45 elbow	-861		106	0.58905	0.5054	0	0.149	0.01667	6.664	0.690	0.149	0.1027
P160-158	6	pipe	-861	6.01	106		0.5054	11.89157		0.01667	6.664	0.690	0.198232	0.1367
E160-162	6	90 elbow	-861		106-vert	1.1781	0.5054	0	0.21	0.01667	6.664	0.690	0.21	0.1448
E162-164	6	90 elbow	-858		vert-104.5	1.1781	0.5054	0	0.21	0.01667	6.664	0.690	0.21	0.1448
P177-164	6	pipe	-858	50.75	104.5		0.5054	100.4155		0.01667	6.664	0.690	1.673927	1.1543
E177-179	6	90 elbow	-858		104.5	1.1781	0.5054	0	0.21	0.01667	6.664	0.690	0.21	0.1448
P179-182	6	pipe	-858	7.25	104.5		0.5054	14.34507		0.01667	6.664	0.690	0.239132	0.1649
E182-184	6	90 elbow	-858		104.5	1.1781	0.5054	0	0.21	0.01667	6.664	0.690	0.21	0.1448
P184-T3	6	pipe	-858	5.781	104.5		0.5054	11.43846		0.01667	6.664	0.690	0.190679	0.1315
Sum				167.2699				330.9654	5.129				10.64619	7.3414
T3	6	run tee	-858		104.5	0.9367	0.5054	0	0.04	0.01667	6.664	0.690	0.04	0.0276
MUV-62	6	gate vlv	-858		104.5	1.1666	0.5054	0	0.12	0.01667	6.664	0.690	0.12	0.0827
P206-207	6	pipe	-858	0.9167	104.5		0.5054	1.813811		0.01667	6.664	0.690	0.030236	0.0209
MUV-63	6	gate vlv	-858		104.5	1.1666	0.5054	0	0.12	0.01667	6.664	0.690	0.12	0.0827
P210-T4	6	pipe	-858	10.573	104.5		0.5054	20.92006		0.01667	6.664	0.690	0.348737	0.2405
T4	6-4-6	half run tee	-858		104.5		0.5054	0	0.02	0.01667	6.664	0.690	0.02	0.0138
Sum				11.4897				22.73387	0.3				0.678974	0.4682
Sum all														11.8704

Prepared by: W. Harrison  
 Checked by: RAW