



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

July 8, 1992

Docket Nos. 50-338  
and 50-339

LICENSEE: Virginia Electric and Power Company (VEPCO)  
FACILITY: North Anna Power Station, Unit Nos. 1&2 (NA-1&2)  
SUBJECT: MEETING SUMMARY OF JUNE 24, 1992

On June 24, 1992, J. Hegner of VEPCO met with L. Engle of NRR to discuss the current and top 9 NA-1&2 licensing actions. The actions discussed were:

1. TS 218 - Revise Settlement Monitoring. The proposed amendments would significantly reduce the number of survey points requiring periodic survey.
2. TS 227 - Residual Heat Removal Autoclosure Interlock Removal. The proposed amendments would reduce the potential for inadvertent loss of decay heat removal.
3. TS 116/103 - Intermediate Range Reactor Trip. The proposed amendments would increase the intermediate range reactor trip from 25% to 35% of rated power.
4. TS 223 - Allow Use of Stainless Steel Zircaloy Filler Rods. The proposed amendments would allow the use of solid stainless steel or solid Zircaloy-4 filler rods in place of fuel rods that are known to be failed.
5. TS 233 - Update Main Steamline Break Analysis. The proposed change would revise the rupture of a main steam pipe analysis by eliminating the low-low pressurizer safety injection initiating function.
6. TS 262 - Heatup and Cooldown Curves. The proposed amendments would revise the pressure/temperature operating limits during heatup and cooldown as well as the low temperature overpressure protection system setpoints.
7. TS 273 - Service Water - 3.0.4 Applicability. The amendments would allow mode changes when the component cooling heat exchangers service water flows are throttled.
8. TS 275 - Reactor Trip and ESFAS Instrumentation. The proposed amendments would permit staggered testing of the reactor trip system instrumentation and would permit up to 20 hours to test certain emergency safeguards feature actuation system instrumentation.

9207090291 920708  
PDR ADDCK 05000338  
P PDR

DF01  
110  
NRC FILE CENTER COPY

July 8, 1992

9. TS 265 - Technical Specification 3.0.5 (Generic Letter 87-09). The proposed amendments would revise the time frames in TS 3.0.5 for conducting a shutdown in a controlled and orderly manner to be consistent with the time frames in TS 3.0.3.

A discussion followed regarding the forthcoming submittal on service water buried piping reburishment which will require an exemption. The submittal date has slipped from mid-July to early August 1992. Also, the licensee's completed 10 CFR 50.59 for the NA-1 steam generator replacement project commencing in January 1993 has slipped from early July to early August 1992.

(Original Signed By)

Leon B. Engle, Project Manager  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION

Docket File

NRC & Local PDRs

PDII-2 RF

T. Murley/F. Miraglia

J. Partlow

S. Varga

G. Lainas

L. Engle

H. Berkow

D. Miller

E. Jordan, MNBB, 3701

M. Sinkule, RII

OGC

ACRS (10)

LA:PDII-2

DML:ter

7/8/92

PM:PDII-2

LEngle:kdj

7/8/92

D:PDII-2

HBerkow

7/8/92

Document Name NA.MIS

Virginia Electric & Power Company

cc:

Mr. William C. Porter, Jr.  
County Administrator  
Louisa County  
P.O. Box 160  
Louisa, Virginia 23093

Michael W. Maupin, Esq.  
Hunton and Williams  
P.O. Box 1535  
Richmond, Virginia 23212

Dr. W. T. Lough  
Virginia State Corporation Commission  
Division of Energy Regulation  
P.O. Box 1197  
Richmond, Virginia 23209

Old Dominion Electric Cooperative  
4201 Dominion Blvd.  
Glen Allen, Virginia 23060

Mr. E. Wayne Harrell  
Vice President - Nuclear Services  
Virginia Electric and Power Co.  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

Office of the Attorney General  
Supreme Court Building  
101 North 8th Street  
Richmond, Virginia 23219

Senior Resident Inspector  
North Anna Power Station  
U.S. Nuclear Regulatory Commission  
Route 2, Box 78  
Mineral, Virginia 23117

North Anna Power Station  
Units 1 and 2

C.M.G. Duttery, M.D., M.P.H.  
State Health Commissioner  
Office of the Commissioner  
Virginia Department of Health  
P.O. Box 2448  
Richmond, Virginia 23218

Regional Administrator, RII  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, N.W., Suite 2900  
Atlanta, Georgia 30303

Mr. G. E. Kane, Manager  
North Anna Power Station  
P.O. Box 402  
Mineral, Virginia 23117

Mr. J. P. O'Hanlon  
Vice President - Nuclear Operations  
Virginia Electric and Power Company  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

Mr. Martin Bowling  
Manager - Nuclear Licensing  
Virginia Electric and Power Co.  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

Mr. W. L. Stewart  
Senior Vice President - Nuclear  
Virginia Electric and Power Co.  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060