

DUKE POWER COMPANY
P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

January 2, 1985

TELEPHONE
(704) 373-4531

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Ms. E. G. Adensam, Chief
Licensing Branch No. 4

Re: Catawba Nuclear Station
Docket Nos. 50-413 and 50-414


Dear Mr. Denton:

By letter dated December 17, 1984, Duke Power Company requested that the NRC Staff review and approve certain proposed changes to the post-fuel-loading initial test program as required by License Condition 3 of Facility Operating License NPF-31. Revised FSAR pages for the Reactor Coolant System Flow Test, Reactor Coolant System Flow Coastdown Test and the Pressurizer Functional Test were submitted along with the justification for the changes. As a result of further review of these items, the specific changes to Chapter 14 have been revised, but the thrust of the proposed changes has not been changed. The revised, marked up FSAR pages are attached.

As a supplement to the above referenced letter, each significant change has been evaluated in accordance with 10 CFR 50.59 and the Nuclear Safety Evaluation Check List along with appropriate supporting documentation is attached. Based on these evaluations, none of the proposed changes were deemed to involve an unreviewed safety question.

In order to support initial criticality, it is requested that approval of these changes be provided by January 4, 1985.

Very truly yours,



Hal B. Tucker

ROS:slb

cc: Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

B021 Limited
11 Dec

8501070211 850102
PDR ADDCK 05000413 PDR
P

Mr. Harold R. Denton, Director
January 2, 1985
Page Two

cc: NRC Resident Inspector
Catawba Nuclear Station

Mr. Robert Guild, Esq.
P. O. Box 12097
Charleston, South Carolina 29412

Palmetto Alliance
2135½ Devine Street
Columbia, South Carolina 29205

Mr. Jesse L. Riley
Carolina Environmental Study Group
854 Henley Place
Charlotte, North Carolina 28207

Customer Reference No(s).

Westinghouse Reference No(s).
(Change Control or RFQ As Applicable)

WESTINGHOUSE
NUCLEAR SAFETY EVALUATION CHECK LIST

- 1) NUCLEAR PLANT(S) Catawba Unit 1
- 2) CHECK LIST APPLICABLE TO: Measured RCS Flow Rate During Precritical Startup Tests
(Subject of Change)
- 3) The written safety evaluation of the revised procedure, design change or modification required by 10CFR50.59 has been prepared to the extent required and is attached. If a safety evaluation is not required or is incomplete for any reason, explain on Page 2
- Parts A and B of this Safety Evaluation Check List are to be completed only on the basis of the safety evaluation performed.
- CHECK LIST - PART A
- (3.1) Yes No X A change to the plant as described in the FSAR?
- (3.2) Yes No X A change to procedures as described in the FSAR?
- (3.3) Yes No X A test or experiment not described in the FSAR?
- (3.4) Yes No X A change to the plant technical specifications (Appendix A to the Operating License)?
- 4) CHECK LIST - PART B (Justification for Part B answers must be included on Page 2.)
- (4.1) Yes No X Will the probability of an accident previously evaluated in the FSAR be increased?
- (4.2) Yes No X Will the consequences of an accident previously evaluated in the FSAR be increased?
- (4.3) Yes No X May the possibility of an accident which is different than any already evaluated in the FSAR be created?
- (4.4) Yes No X Will the probability of a malfunction of equipment important to safety previously evaluated in the FSAR be increased?
- (4.5) Yes No X Will the consequences of a malfunction of equipment important to safety previously evaluated in the FSAR be increased?
- (4.6) Yes No X May the possibility of a malfunction of equipment important to safety different than any already evaluated in the FSAR be created?
- (4.7) Yes No X Will the margin of safety as defined in the bases to any technical specification be reduced?

If the answers to any of the above questions are unknown, indicate under 5) REMARKS and explain below.

If the answer to any of the above questions in 4) cannot be answered in the negative based on written safety evaluation, the change cannot be approved without an application for license amendment submitted to NRC pursuant to 10CFR50.90.

5) REMARKS:

The following summarizes the justification upon the written safety evaluation,⁽¹⁾ for answers given in Part B of the Safety Evaluation Check List:

See attached.

(1) Reference to document(s) containing written safety evaluation: _____

FOR FSAR UPDATE

Section: _____ Page(s): _____ Table(s): _____ Figure(s): _____

Reason for/Description of Change:

Prepared by (Nuclear Safety): R.W. Orosz Date: 12-31-81
Coordinated with Engineer(s): J.E. Tierney Date: 12-31-81
Coordinating Group Manager(s): L.W. Johnson Date: 12-31-81
Nuclear Safety Group Manager: C.L.P. Gleason Date: 12-31-81

ATTACHMENT TO NUCLEAR SAFETY EVALUATION CHECKLIST
Measured RCS Flow Rate During Precritical Startup Tests

During pre-operational testing at Catawba, RCS flow rate was measured using the loop elbow tap flow meters. In at least one of the four loops the indicated flow rate was found to exceed Catawba's Mechanical Design Flow (MDF) rate of 105,000 gpm/loop. The acceptance criteria as defined in Table 14.2.12-2 (page 9) require a flow measurement greater than the Technical Specification value and less than MDF.

The loop elbow tap flow meters are not intended for, nor are they capable of, accurate, absolute measurement of RCS flow rate. They can be used for periodic verification of RCS flow after they have been calibrated with precision RCS flow calorimetric measurement. However, a precision flow calorimetric measurement requires MSSS power of 90-100%.

Therefore, at present there is no need to revise Catawba's MDF. Final verification that the acceptance criteria are met should be done based on a precision flow calorimetric measurement. Based on the existing data, no safety concern exists at this time.

Table 14.2.12-2 (Page 9)

REACTOR COOLANT SYSTEM FLOW TEST

Abstract

Purpose

To verify predicted Reactor Coolant System flow rates at normal no-load operating temperature and pressure. To align the Reactor Coolant System flow instruments.

Prerequisites

The reactor is in the hot ~~shutdown~~^{standby} condition with all rod cluster control assemblies at their fully inserted position. All four reactor coolant pumps are operating.

Test Method

The output voltage of each NC loop differential pressure transmitter is measured using a digital voltmeter. The output voltages are averaged and converted to equivalent differential pressure which is then converted to flow using a vendor supplied, plant specific graph. The loop flows are summed to give the total system flow. The flow transmitters are adjusted for 100 percent flow at normal operating conditions and zero output at zero flow.

Acceptance Criteria

Reactor coolant system flow is greater than the value specified in the Technical Specifications and less than the mechanical design flow as stated in Chapter 5 or evaluated and found acceptable by the NSSS vendor.

Following adjustment, the flow transmitters yield 100 percent flow signal at normal operating conditions and zero output at zero flow conditions, within the tolerances specified by the vendor.

Customer Reference No(s).

Westinghouse Reference No(s).
(Change Control or RFQ as Applicable)

WESTINGHOUSE
NUCLEAR SAFETY EVALUATION CHECK LIST

Page 1 of 3

1) NUCLEAR PLANT(S) Catawba Unit 1 (DCP)

2) CHECK LIST APPLICABLE TO: Flow Coastdown Test
(Subject of Change)

3) The written safety evaluation of the revised procedure, design change or modification required by 10CFR50.59 has been prepared to the extent required and is attached. If a safety evaluation is not required or is incomplete for any reason, explain on Page 3.

Parts A and B of this Safety Evaluation Check List are to be completed only on the basis of the safety evaluation performed.

CHECK LIST - PART A

(3.1) Yes No ✓ A change to the plant as described in the FSAR?

(3.2) Yes No ✓ A change to procedures as described in the FSAR?

(3.3) Yes No ✓ A test or experiment not described in the FSAR?

(3.4) Yes No ✓ A change to the plant technical specifications
(Appendix A to the Operating License)?

4) CHECK LIST - PART B (Justification for Part B answers must be included on Page 3.)

(4.1) Yes No ✓ Will the probability of an accident previously evaluated in the FSAR be increased?

(4.2) Yes No ✓ Will the consequences of an accident previously evaluated in the FSAR be increased?

(4.3) Yes No ✓ May the possibility of an accident which is different than any already evaluated in the FSAR be created?

Customer Reference No(s).

Westinghouse Reference No(s).
(Change Control or RFQ as Applicable)

WESTINGHOUSE
NUCLEAR SAFETY EVALUATION CHECK LIST

Page 2 of 3

- (4.4) Yes No ✓ Will the probability of a malfunction of equipment important to safety previously evaluated in the FSAR be increased?
- (4.5) Yes No ✓ Will the consequences of a malfunction of equipment important to safety previously evaluated in the FSAR be increased?
- (4.6) Yes No ✓ May the possibility of a malfunction of equipment important to safety different than any already evaluated in the FSAR be created?
- (4.7) Yes No ✓ Will the margin of safety as defined in the bases to any technical specification be reduced?

If the answers to any of the above questions are unknown, indicate under 5) REMARKS and explain on Page 3.

If the answer to any of the above questions in 4) cannot be answered in the negative, based on written safety evaluation, the change cannot be approved without an application for license amendment submitted to NRC pursuant to 10CFR50.90.

5) REMARKS:

6) APPROVAL LADDER (Signatures):

- (6.1) Prepared by (Nuclear Safety): Glenn Heberle Date: 12/3/84
- (6.2) Coordinated with (Engineer(s)): _____ Date: _____
- (6.3) Coordinating Group Manager(s): LLP/HBrown Date: 12/3/84
- (6.4) Nuclear Safety Group Manager: _____ Date: _____

Customer Reference No(s).

Westinghouse Reference No(s).
(Change Control or RFQ as Applicable)

WESTINGHOUSE
NUCLEAR SAFETY EVALUATION CHECK LIST

Page 3 of 3

The following summarizes the justification, based upon the written safety evaluation⁽¹⁾ for answers given in Part B of the Safety Evaluation Check List:

Catawba Unit 1 failed the flow coastdown test on Nov 29, 1984. In other words, the measured coastdown is more severe (faster) than that calculated in the FSAR complete loss of flow analysis. Thus, the analysis is non-conservative.

To verify that safety criteria are met, the loss of flow analysis was reanalyzed with the measured coastdown data input. Results show that the DNB design basis is met.

(1) Reference to document(s) containing written safety evaluation: CN-TA-84-209,

NS-RAT-PTA-84-153

PREPARED BY: Glenn Heberle DATE: 12/3/84

CATAWBA UNIT 1 SAFETY ANALYSIS FOR MEASURED RCS FLOW COASTDOWN

INTRODUCTION

A partial or complete loss of forced reactor coolant flow may result from mechanical or electrical failures in a reactor coolant pump or if there is a loss of electrical supplies to the reactor coolant pumps. If the reactor is at power at the time of the accident, DNB and fuel damage could occur due to the reduced flow and increased reactor coolant temperature. These accidents are analyzed in the FSAR (Sections 15.3.1 and 15.3.2) to show that the DNB design basis is met. The flow on which the analysis is based is calculated by the computer code LOFTRAN.

As part of the start-up testing program, a loss of flow is initiated for the purpose of verifying that the safety analysis is conservative. One of the acceptance criteria of SU.2.1.8, "Reactor Coolant Flow Coastdown," is that the measured coastdown be greater than or equal to the FSAR calculated coastdown. By so doing, it is verified that the DNB design basis would be met should a loss of flow occur.

TEST RESULTS

The test results showed that the measured flow coastdown for the partial and complete loss of flow was less than the coastdown calculated in FSAR analyses. Since this is not conservative, an analysis or evaluation of the limiting loss of flow transients based on the measured coastdown must be performed in order to assure that the design basis will be met.

METHOD OF ANALYSIS

A. Partial Loss of Flow

The flow as a function of time for a partial loss of flow is higher than for a completed loss of flow. The minimum DNBR is also higher, as can be seen by comparing the results of the FSAR analyses. Since the partial loss of flow is conservatively bounded by the complete loss of flow, it is sufficient to show acceptable results for the complete loss of flow to demonstrate that the partial loss of flow is acceptable. Therefore, the analysis is only done for the complete loss of flow.

B. Complete Loss of Flow

The method of analysis for the complete loss of flow event is the same as described in Section 15.3.2.2 except that the flow coastdown as measured during the test is used instead of using flow calculated by LOFTRAN. Table 1 lists the flow coastdown used.

RESULTS

Figure 1 shows the DNBR vs. time for the measured coastdown analysis. The calculated sequence of events is shown in Table 2. The analysis performed demonstrates that the DNBR does not decrease below the design limit for the complete loss of reactor coolant flow. Therefore, all safety criteria are met, and the measured flow coastdown is acceptable.

TABLE 1

MEASURED COASTDOWN FOR COMPLETE LOSS OF FLOW

NOMINAL FLOW = 98400 gpm per loop

<u>TIME (sec)</u>	<u>CORE FLOW (fraction)</u>
0.	1.0000
0.65	0.9284
1.65	0.8556
2.65	0.7933
3.65	0.7376
4.65	0.6900
5.65	0.6436
6.65	0.6080
7.65	0.5732
8.65	0.5395
9.65	0.5134

TABLE 2

TIME SEQUENCE OF EVENTS

<u>EVENT</u>	<u>TIME (sec)</u>
Coastdown Begins	0.0
Rods Begin to Drop	1.5
Minimum DNBR Occurs	3.6

FIGURE 1




Table 14.2.12-2 (Page 10)

REACTOR COOLANT SYSTEM FLOW COASTDOWN TEST
Abstract

Purpose

To measure the rate at which reactor coolant flow rate decreases, subsequent to reactor coolant pump trips, from various flow configurations. To measure various delay times associated with assumptions made in the analysis of the loss of flow accident.

Prerequisites

The reactor is in the hot standby condition with all rod cluster control assemblies at their fully inserted position, all four reactor coolant pumps are operating. The Reactor Coolant System Flow Test has been completed with instrumentation calibrated accordingly.

Test Method

Flow coastdown will be measured for the single loop loss of flow by tripping one of four reactor coolant pumps and monitoring flow using the elbow tap differential pressure cells. Delay times for several protective functions are measured using a strip chart recorder.

Flow coastdown will also be measured for a complete loss of flow. All four pumps will be tripped simultaneously using the Reactor Coolant Pump Electrical Monitoring System. Flow will be measured using the same method as the partial loss of flow case.

Acceptance Criteria

the 4 of 4 coastdown transient is
The core flow decrease for ~~each transient is, in each case,~~ slower than that assumed in Figure 15.3.2-1. Time delays from actuation to low flow trip, undervoltage trip and underfrequency trip actuation are less than or equal to those assumed in Chapter 15.

CNS

The following signals provide the necessary protection against a complete loss of flow accident:

1. Reactor coolant pump power supply undervoltage or underfrequency.
2. Low reactor coolant loop flow.

The reactor trip on reactor coolant pump undervoltage is provided to protect against conditions which can cause a loss of voltage to all reactor coolant pumps, i.e., station blackout. This function is blocked below approximately 10 percent power (Permissive 7).

The reactor trip on reactor coolant pump underfrequency is provided to trip the reactor for an underfrequency condition, resulting from frequency disturbances on the power grid. Reference 3 provides analyses of grid frequency disturbances and the resulting Nuclear Steam Supply System protection requirements which are generally applicable to the Catawba units.

The reactor trip on low primary coolant loop flow is provided to protect against loss of flow conditions which affect only one reactor coolant loop. This function is generated by two out of three low flow signals per reactor coolant loop. Above Permissive 8, low flow in any loop will actuate a reactor trip. Between approximately 10 percent power (Permissive 7) and the power level corresponding to Permissive 8, low flow in any two loops will actuate a reactor trip.

15.3.2.2 Analysis of Effects and Consequences

Two cases have been analyzed:

1. Loss of four pumps with four loops in operation.
2. Loss of three pumps with three loops in operation.

This transient is analyzed by three digital computer codes. First, the LOFTRAN Code (Reference 1) is used to calculate the loop and core flow during the transient, the time of reactor trip based on the calculated flows, the nuclear power transient, and the primary system pressure and temperature transients. The FACTRAN Code (Reference 2) is then used to calculate the heat flux transient based on the nuclear power and flow from LOFTRAN. Finally, the THINC Code (see section 4.4) is used to calculate the DNBR during the transient based on the heat flux from FACTRAN and flow from LOFTRAN. The "R" grid spacer factor is applied to the W-3 correlation. The DNBR transients presented represent the minimum of the typical or thimble cell.

The method of analysis and the assumptions made regarding initial operating conditions and reactivity coefficients are identical to those discussed in Section 15.3.1, except that following the loss of power supply to all pumps at power, a reactor trip is actuated by either reactor coolant pump power supply undervoltage or underfrequency.

For both cases, LOFTRAN is used to calculate

For Case 1, the loop and core flows are used in the LOFTRAN Code (Reference 1) based on the measured flow coastdown data taken during the Unit 1 startup test. For Case 2

TABLE 15.3.1-1 (Page 2)

Time Sequence of Events for Incidents
Which Result in a Decrease in Reactor Coolant
System Flow

<u>Accident</u>	<u>Event</u>	<u>Time (sec.)</u>	
		<u>Four Loop operation</u>	<u>Three Loop operation</u>
	Reactor coolant pump under-voltage trip point reached	0.	0.
	Rods begin to drop	1.5	1.5
	Minimum DNBK occurs	3.8 ⁶	3.7
Reactor Coolant Pump Shaft Seizure (Locked Rotor)			
	Rotor on one locks	0.	0.
	Low flow trip point reached	0.03	0.05
	Rods begin to drop	1.03	1.05
	Maximum RCS pressure occurs	4.0	4.8
	Maximum clad temperature occurs	3.7	4.1




FIGURE 15.3.2-1
Reactor Vessel Flow
Transient for Four Loops
in operation, Four Pumps
coasting down.




FIGURE 15.3.2-2
Nuclear Power and
Pressurizer Pressure
Transients for Four Loops
in operation, Four Pumps
coasting down.




FIGURE 15.3.2-3
Average and Hot Channels
Heat Flux Transients
for Four Loops in operation,
Four Pumps coasting down.




FIGURE 15.3.2-4
DMBR Transient for
Four Loops in operation,
Four Pumps coasting down.

DUKE POWER COMPANY
NUCLEAR SAFETY EVALUATION CHECK LIST

(1) STATION: CATAWBA UNIT 1 ✓ 2 ✓ 3

(2) CHECK LIST APPLICABLE TO: PRESSURIZER FUNCTIONAL TEST

(3) SAFETY EVALUATION PART A

The item to which this evaluation is applicable represents:

Yes ✓ No A change to the station or procedures as described in the FSAR; or a test or experiment not described in the FSAR?

If the answer to the above is "Yes", attach a detailed description of the item being evaluated and an identification of the affected section(s) of the FSAR.

(4) SAFETY EVALUATION PART B

Yes No ✓ Will this item require a change to the station Technical Specifications?

If the answer to the above is "Yes", identify the specification(s) affected and/or attach the applicable page(s) with the change(s) indicated

(5) SAFETY EVALUATION PART C

As a result of the item to which this evaluation is applicable:

Yes No ✓ Will the probability of an accident previously evaluated in the FSAR be increased?

Yes No ✓ Will the consequences of an accident previously evaluated in the FSAR be increased?

Yes No ✓ May the possibility of an accident which is different than any already evaluated in the FSAR be created?

Yes No ✓ Will the probability of a malfunction of equipment important to safety previously evaluated in the FSAR be increased?

Yes No ✓ Will the consequences of a malfunction of equipment important to safety previously evaluated in the FSAR be increased?

Yes No ✓ May the possibility of malfunction of equipment important to safety different than any already evaluated in the FSAR be created?

Yes No ✓ Will the margin of safety as defined in the bases to any Technical Specification be reduced?

If the answer to any of the preceding is "yes", an unreviewed safety question is involved. Justify the conclusion that an unreviewed safety question is or is not involved. Attach additional pages as necessary.

(6) PREPARED BY: R.D.Sharpe DATE: 12/31/84

(7) REVIEWED BY: RC Gamberg DATE: 12/31/84
(8) Page 1 of _____

DISCUSSION

- (3) During the performance of the Pressurizer Functional Test (FSAR Table 14.2.12-2, Page 37) it was determined that the opening times of the PORV's failed to meet the stated acceptance criteria.

An analysis (CNC 1223.03-00-0005) was performed to show the acceptability of slower PORV response times. Based on this analysis the PORV response time will be changed to <3 seconds (<4 seconds for Unit 1 Cycle 1). The revised FSAR page is attached.

- (5) No credit is taken for the rapid opening of the PORV's in the FSAR Chapter 15 accident analyses, however these valves do provide low temperature overpressure protection. The analysis performed in CNC 1223.03-00-0005 demonstrated the relative insensitivity of Reactor Coolant System pressure to slower PORV response times for LTOP operation. Therefore the PORV response time of <3 seconds (<4 seconds for Unit 1, Cycle 1) are acceptable.

Table 14.2.12-2 (Page 37)

PRESSURIZER FUNCTIONAL TEST
Abstract

Purpose

To establish the continuous spray flow rate, determine the effectiveness of the pressurizer normal control spray and of the pressurizer heaters, and verify the response time of the pressurizer power operated relief valves.

Prerequisites

The Reactor Coolant System is at hot standby temperature and pressure. The Reactor Coolant System is lined up for normal operation in accordance with applicable operating procedures. All reactor coolant pumps are operating. Each bank of pressurizer heaters is operable.

Test Method

While maintaining pressurizer level constant, spray bypass valves are adjusted until a minimum flow is achieved which maintains less than a 125°F temperature difference between the spray line and the pressurizer steam space.

To determine pressurizer heater and spray capability, the main pressurizer spray valves are closed. All pressurizer heaters are then energized and the time to reach a 2300 psig system pressure is measured and recorded. Full spray is initiated through each spray valve individually and in parallel. Pressure versus time is recorded for each transient. The transient is terminated at a Reactor Coolant System pressure of 2000 psig by shutting the spray valves.

With the Unit at normal operating no load temperature and pressure, each PORV shall be cycled for response time testing. The 2185 psig interlock closes the valve and original conditions are re-established.

This test is performed following initial fuel loading due to the need to establish the effectiveness of actual spray flow with core pressure drop acting as the driving head. This test is a prerequisite test for initial criticality.

Acceptance Criteria

For setting of continuous spray flow, the flow through each bypass valve is established such that the temperature difference between the spray line and the pressurizer steam space is less than 125°F.

For pressurizer PORV response times, each PORV response time is $\leq \frac{3}{8}$ seconds (≤ 4 seconds for Unit 1, Cycle 1).

For spray and heater response tests, the response to induced transients is within limits specified in vendor guidelines.

CERTIFICATION OF ENGINEERING CALCULATION

STATION AND UNIT NUMBER _____ Catawba Units 1 & 2

TITLE OF CALCULATION Pressurizer Power Operated Relief Valve Setpoint Verification
for Low Temperature Overpressure Protection

CALCULATION NUMBER _____ CNC-1223.03-00-0005

ORIGINALLY CONSISTING OF PAGES _____ 1 THROUGH 29

CONTAINED IN VOLUME NO(S). 1

ATTACHMENTS 1 THROUGH 15 CONTAINED IN VOLUME NO(S) 1

TOTAL VOLUMES _____ ORIGINAL

MICROFICHE ATTACHMENTS:

DO NOT REMOVE FROM FILE

M1 ID# N/A # OF SHEETS N/A M4 ID# N/A # OF SHEETS N/A

M2 ID# - N/A # OF SHEETS N/A M3 ID# N/A # OF SHEETS N/A

M3 ID# — N/A # OF SHEETS — N/A M5 ID# — N/A # OF SHEETS —

THESE ENGINEERING CALCULATIONS COVER QA CONDITION 1 ITEMS. IN ACCORDANCE WITH ESTABLISHED PROCEDURES, THE QUALITY HAS BEEN ASSURED AND I CERTIFY THAT THE ABOVE CALCULATION HAS BEEN ORIGINATED, CHECKED OR APPROVED AS NOTED BELOW:

ORIGINATED BY Clay E Hedrick DATE 11/21/84

CHECKED BY RC Hemberg DATE 11/27/84

APPROVED BY C. L. Sainsbury DATE 11/27/84

ISSUED TO GENERAL SERVICES DIVISION *P.S.mcm* DATE 12/18/84

ISSUED TO GENERAL SERVICES DIVISION O.S. McManus DATE 12/18/84

RECEIVED BY GENERAL SERVICES DIVISION H. Hunter DATE 12-18-81

REVISION/ADDENDA LOG:

Dev./Station Catawba

Unit 1 & 2 File No. CNC 1223.03-00-0005

Subject _____

By G.H. Hollick Date 10/26/84Sheet No. 1 of 29 Problem No. _____

Checked By _____

Date _____

1.0 STATEMENT OF PROBLEM

The Low Temperature Overpressure Protection (LTOP) System utilizes two pressurizer power operated relief valves (PORV's). These PORV's have a reduced pressure setpoint when LTOP is enabled. This calculation verifies the acceptability of a 400 psig setpoint and investigates the effects of slower PORV opening time and marginally higher setpoint, typical of instrumentation and calibration inaccuracies.

2.0 RELATION TO NUCLEAR SAFETY

TECHNICAL SPECIFICATIONS 3/4.4.9.1 and 3/4.4.9.3 establish the maximum setpoint for the LTOP PORV's as 450 psig and provide the limiting Reactor Coolant (NC) system pressure as a function of temperature. These limitations are intended to be consistent with the ASME Boiler and Pressure Vessel Code, Section III, Appendix G to prevent non-ductile failure. A combination of automatic actions (ie. LTOP actuation) and administrative controls (eg. limits on heatup and cooldown rates) are employed to assure the plant is operated safely within the above requirements.

3.0 DESIGN METHOD

References A and B present the results of pressure transient analyses which were specifically developed to permit selection of a PORV setpoint based on plant specific parameters. The procedures of Reference A are used for mass input transients. The procedures for heat input transients are developed in both Reference A and Reference B. The latter methodology is most applicable. For both mass and heat input transients, peak pressures are determined for a range of PORV response times. The

Dev./Station Catawba

Unit 1 F2 File No. CNC 1223.03 -00-0005

Subject _____

By G.E.Hedrick Date 10/26/84Sheet No. 2 of 29 Problem No. _____

Checked By _____

Date _____

3.0 mass and heat input transients are then reconsidered to examine the effect of even slower valve response and slightly higher pressure setpoints. This requires some modification and extension of the methodology developed in References A and B. It is presented as part of the calculation.

4.0 CODES AND STANDARDS

ASME Boiler and Pressure Vessel Code, Section III, Appendix G
Catawba Technical Specifications 3/4.4.9.1 and 3/4.4.9.3

5.0 DESIGN CRITERIA

A conclusion section of the Calculations, Section 9 of this calculation, compares the results of the pressure transients to the Technical Specification limits to verify acceptability of the design setpoints, etc.

6.0 PSAR and FSAR CRITERIA

None applicable.

7.0 ASSUMPTIONS AND BASES

A. The assumptions given in References A and B are adopted herein for calculations which use the procedures of those references.

B. The reference case normalized UA at 100°F presented on Figure 15, Reference B, is assumed to be 0.129. This is consistent with Reference A and the balance of Reference B.

Dev./Station CatawbaUnit 1 & 2 File No. CNC 1223.03-00-0005

Subject _____

By J.E. Adcock Date 10/26/84Sheet No. 3 of 29 Problem No. _____

Checked By _____ Date _____

7.0

- c. The Reactor Coolant (NC) System volume will be taken as 12,000 ft³ and the Steam Generator (SG) heat transfer area will be taken as 48,000 ft². These values very closely approximate the actual values and the results of calculations are insensitive to any deviation.

Dev./Station Catawba

Unit 1/2 File No. CNC 1223.03-00-0005

Subject _____

By GEHedrick Date 10/26/84

Sheet No. 4 of 29 Problem No. _____

Checked By _____

Date _____

8.0 REFERENCES

- A. "Pressure Mitigating Systems Transient Analysis Results", prepared by Westinghouse Electric Corp. for the Westinghouse Owners Group on Reactor Coolant System Depressurization, July 1977.
- B. "Supplement to the 1977 Report, Pressure Mitigating Systems Transient Analysis Results", prepared by Westinghouse Electric Corp. for the Westinghouse Owners Group on Reactor Coolant System Depressurization, September 1977
- C. Actual Flow Conditions Performance Test report for CCI Pressurizer PORVs for Catawba Nuclear Station, January 13, 1981, CNM 1205.10 - 0168.
- D. Safety Injection Pump Instruction Book, CNM 1201.05-75, for Catawba Unit 1.
- E. Safety Injection Pump Instruction Book, CNM 2201.05-20, for Catawba Unit 2.
- F. Letter, DUKE-5149, CATAWBA-2329, from R.S. Howard, Manager, Duke Power Project, Westinghouse to S.K. Blackley, Duke Power Co., June 13, 1980.
- G. Letter, CATAWBA-3311, from F.J. Twogood, Manager, Duke Power Projects, Westinghouse to S.K. Blackley, Duke Power Co., September 2, 1983.
- H. Catawba FSAR, Figures Q440.8-1 and Q440.8-2
- I. Catawba Unit 1 Databook, OP/1A/6700/01, Figures 1.5 and 1.6.
- J. Catawba Technical Specifications, Figures 3.4-2 and 3.4-3.

Dev./Station CATAWBA

Unit 1 F2 File No. CNC 1223.03-00-0005

Subject _____

By GEHedrick Date 10/26/89

Sheet No. 5 of 29 Problem No. _____

Checked By _____ Date _____

9.0 CALCULATIONS

A. MASS INPUT TRANSIENT

The procedure of Reference A, Section 4.2.1 applies directly. The mass input rate is conservatively based on the runout flowrate of a Safety Injection (NI) pump at 60°F fluid temperature. The mass input rate is

$$(650 \text{ gpm}) \left(\frac{500.26 \text{ lb/hr}}{\text{gpm}} \right) \left(\frac{\text{hr}}{3600 \text{ sec}} \right) = 90.3 \frac{\text{lb}}{\text{sec}} \quad (\text{Ref. D})$$

Procedural steps are as follows:

- 1) Select a PORV setpoint, S $S = 400 \text{ psig}$
- 2) Find ΔP_{REF} from Figure 4.2.1 (Attachment 1) $\Delta P_{\text{REF}} = 124 \text{ psi}$
- 3) Find F_V from Figure 4.2.2 (Attachment 2) $F_V = 0.56$
- 4) Find F_Z from Figure 4.2.3 (Attachment 3)
 - for a relief valve opening time of 2 sec. ${}^2 F_Z = 0.733$
 - for a relief valve opening time of 3 sec. ${}^3 F_Z = 1.0$
- 5) Find F_S from Figure 4.2.4 (Attachment 4) $F_S = 1.27$
- 6) Calculate the setpoint overshoot, ΔP , as the product of preceding factors.
 - $\Delta P = \Delta P_{\text{REF}} F_V F_Z F_S$ ${}^2 \Delta P = 64.6 \text{ psi}$
 - ${}^3 \Delta P = 88.2 \text{ psi}$
- 7) Calculate the maximum transient pressure, P_{MAX}
 - ${}^2 P_{\text{MAX}} = 464.6 \text{ psig}$
 - ${}^3 P_{\text{MAX}} = 488.2 \text{ psig}$

Dev./Station Catawba

Unit 1/2 File No. CMC 1223.03-00-0005

Subject _____

By GE Hedrick Date 10/26/84

Sheet No. 6 of 29 Problem No. _____

Checked By _____

Date _____

B. HEAT IN/OUT TRANSIENT

For the same relief valve setpoint ($S = 400 \text{ psig}$), Reference B Figures 14, 15, 20 and 21 apply. An adjustment is made to account for actual steam generator heat transfer area as compared to the reference case. The setpoint overshoot can then be found graphically as a function of three parameters. These three parameters and the values considered are:

V , NC System volume, ft^3 6,000, 13,000

T , Initial NC System temperature, $^{\circ}\text{F}$ 100, 250

Z , PORV opening time, sec. 1.5, 3.0

Linear interpolation may then be applied to obtain pressure overshoot and maximum transient pressure values for specific Catawba plant parameters.

Procedural steps are as follows:

- 1) Find the reference UA values for each value of V and T from the Figures 14, 15, 20 and 21. These are in Attachments 5 to 8.

100°F 250°F

UA_{6K}	0.083	0.139
-----------	-------	-------

UA_{13K}	0.129	0.222
------------	-------	-------

- 2) Calculate the adjustment factor for S/G heat transfer area, f .

$$f = \frac{48,000 \text{ ft}^2}{58,000 \text{ ft}^2} = 0.83$$

Dev./Station CatawbaUnit 1/2 File No. CNC 1223.03-00-0005

Subject _____

By G.E. Hedrick Date 10/26/84Sheet No. 7 of 29 Problem No. _____

Checked By _____

Date _____

- 3) Calculate adjusted UA values, UA' , for each value of V and T, from $UA' = (f)(UA)$. These adjusted UA lines are plotted on the attachments.

<u>100°F</u>	<u>250°F</u>
--------------	--------------

UA'_{6K}	0.069	0.116
UA'_{13K}	0.107	0.185

- 4) The pressure overshoots for each value of V, T and Z for the adjusted UA lines are read from the figures.

<u>100°F</u>	<u>250°F</u>
--------------	--------------

$\Delta P'_{6K}$	14 psi	50 psi
$\Delta P'_{13K}$	11 psi	36 psi
$\Delta P'_{6K}$	28 psi	100 psi
$\Delta P'_{13K}$	19 psi	78 psi

- 5) These data are placed in tabular form and pressure overshoot is calculated by linear interpolation for specific Catawba plant parameters.

$$S = 400 \text{ psig}$$

PRESSURE OVERSHOOT, psi ($\Delta P'$)

Z, sec.	1.5		2.0		3.0	
T, °F	100	250	100	250	100	250
V, ft ³						
6,000	14	50	18.7	66.7	28	100
12,000	11.4	38.0	14.4	52.4	20.3	81.1
13,000	11	36	13.7	50	19	78

Dev./Station Catawba

Unit/F'2 File No. CNC 1223.03-00-0005

Subject _____

By G. Hedrick Date 10/26/84Sheet No. 8 of 29 Problem No. _____

Checked By _____ Date _____

6) Calculate the maximum transient pressure, P_{MAX} , from

$$P_{MAX} = 5 + z \Delta P_{12K}$$

100°F250°F1.5 P_{MAX}

414.4 psig

438.0 psig

2.0 P_{MAX}

414.4 psig

452.4 psig

3.0 P_{MAX}

420.3 psig

481.1 psig

Dev./Station

Catawba

Unit 1 & 2 File No. CNC 1223.03 -00-0005

Subject

By GEHedrick Date 10/26/84

Sheet No. 9 of 29

Problem No.

Checked By

Date

C. MASS INPUT TRANSIENT, ADDITIONAL CONSIDERATIONS

In order to investigate the pressure overshoot that would result from a PORV opening time, Z , of greater than 3.0 seconds and/or an opening pressure setpoint, S , of greater than 400 psig, it is necessary to reconsider the methodology of Reference A. For this calculation, Z and S may range up to 4.0 seconds and 425 psig, respectively.

The F_Z factor is not applicable beyond 3.0 seconds, nor is extrapolation acceptable. The F_Z factor was developed as part of the interpolating mass input equation and is based on Figure 4.3.8, Reference A (Attachment 9). Due to the shape of the curves, linearization resulted in additional conservatism for Z less than 3.0 seconds. For times greater than 3.0 seconds, no additional conservatism is required beyond simply passing a line from the origin through the final data point. Thus, the predicted pressure overshoot will always exceed the actual pressure overshoot for $Z > 3$ seconds. The only other adjustment is for the mass input rate, which makes the results Catawba specific.

The pressure overshoot for $Z = 3.0$ seconds was previously determined in Section 9.0. A. 6) as

$${}^3\Delta P = 88.2 \text{ psi}$$

Linear interpolation from attachment 9 predicts

$${}^3\Delta P = 98 + \frac{(192 - 98)(13,000 - 12,000)}{(13,000 - 6,000)}$$

$$= 111.4 \text{ psi}$$

The difference is due to the assumed mass input rate. Thus,

Dev./Station

Catawba

Unit 1F2 File No. CWC 1223.03-00-0005

Subject

By St. Hedditch Date 10/26/84

Sheet No. 10 of 29

Problem No.

Checked By

Date

a mass input rate adjustment factor is

$$\frac{88.2}{111.4} = 0.79$$

A new curve may now be determined for Catawba specific parameters at $S = 425 \text{ psig}$. For $V = 13000 \text{ ft}^3$, $Z = 3 \text{ sec.}$, the pressure overshoot is

$$\Delta P = 74 + \frac{(98-74)(600-425)}{(600-400)}$$

$$= 95 \text{ psi}$$

for $V = 6000 \text{ ft}^3$, $Z = 3 \text{ sec}$, the pressure overshoot is

$$\Delta P = 155 + \frac{(192-155)(600-425)}{(600-400)}$$

$$= 187.4 \text{ psi}$$

For $V = 12000 \text{ ft}^3$, $Z = 3 \text{ sec}$, the pressure overshoot is

$$\Delta P = 95 + \frac{(187.4-95)(13000-12000)}{(13000-6000)}$$

$$= 108.2$$

And finally, considering the mass input rate adjustment

$$\Delta P = (0.79)(108.2)$$

$$= 85.5 \text{ psi}$$

Thus, the peak pressure is $425 + 85.5 = 510.5 \text{ psig}$. This is shown on Attachment 9.

Dev./Station Catawba

Subject _____

Unit 1'2 File No. CNC 1223.03-00-0005

By GEHedrick Date 10/26/84

Sheet No. 11 of 29 Problem No. _____

Checked By _____

Date _____

The pressure overshoots for either $S = 400 \text{ psig}$ or $S = 425 \text{ psig}$ is simply extrapolated to $Z = 4$ seconds = Z .

$$\Delta P(S=400, Z=4) = 88.2 \left(\frac{4}{3}\right) = 117.6 \text{ psi}$$

$$\therefore P_{\max}(S=400, Z=4) = 517.6 \text{ psig}$$

$$\Delta P(S=425, Z=4) = 85.5 \left(\frac{4}{3}\right) = 114.0 \text{ psi}$$

$$\therefore P_{\max}(S=425, Z=4) = 539.0 \text{ psig}$$

D. HEAT INPUT TRANSIENT, ADDITIONAL CONSIDERATIONS

In order to extend the opening time to $Z = 4$ seconds and setpoint $S = 425 \text{ psig}$ for these transients the same methodology previously used in Section 9.0 B. will be used and linearly extrapolated. In this case Figures 16, 17, 22 and 23 of Reference B apply and are included as Attachments 10 to 13. These figures apply for $S = 500 \text{ psig}$ and the first three steps of Section 9.0 B continue to apply. Then,

- 1) The pressure overshoots for each value of V , T and Z for the adjusted UA lines are read from the figures

100°F	250°F
-------	-------

$^{1.5} \Delta P'_{6K}$	14 psi
$^{1.5} \Delta P'_{13K}$	68 psi

$^{1.5} \Delta P'_{6K}$	9 psi
$^{1.5} \Delta P'_{13K}$	57 psi

$^{3.0} \Delta P'_{6K}$	25 psi
$^{3.0} \Delta P'_{13K}$	130 psi

$^{3.0} \Delta P'_{6K}$	23 psi
$^{3.0} \Delta P'_{13K}$	98 psi

Dev./Station Catawba

Unit 1 F2 File No. CNC 1223.03-00-0005

Subject _____

By GE Hadlock Date 10/26/84Sheet No. 12 of 29 Problem No. _____

Checked By _____

Date _____

- 3) These data are placed in tabular form and pressure overshoot is calculated by linear interpolation for specific Catawba parameters.

$$S = 500 \text{ psig}$$

PRESSURE OVERSHOT, psai (${}^z \Delta P'$)

$Z, \text{sec.}$	1.5		3.0	
$T, {}^\circ\text{F}$	100	250	100	250
V, ft^3				
6000	14	68	25	130
12000	9.7	58.6	23.3	102.6
13000	9	57	23	98

- 3) The pressure overshoots for $S = 400$ psig and $S = 500$ psig are placed in tabular form and linear interpolation is used to determine the overshoot for $S = 425$ psig. This can then be linearly extrapolated to obtain overshoot at $Z = 4$ sec. (The tables are stated in terms of P_{\max} which is $P_{\max} = S + {}^z \Delta P'$.)

$$V = 12000 \text{ ft}^3$$

PRESSURE MAXIMUM, PSIG

Z, sec	1.5		3.0		4.0	
$T, {}^\circ\text{F}$	100	250	100	250	100	250
S, psig						
500	509.7	558.6	523.3	602.6	—	—
425	436.0	468.2	446.0	511.5	452.7	540.4
400	411.4	438.0	420.3	481.1	426.2	509.8

Dev./Station Catawba

Unit 1/2 File No. CNC 1223.03-00-0005

Subject _____

By E. H. Hedges Date 10/26/84Sheet No. 13 of 29 Problem No. _____

Checked By _____

Date _____

E. CONCLUSIONS

The bounding conditions for the mass and heat input cases may be summarized as follows.

MASS INPUT PEAK PRESSURES, CATAWBA SPECIFIC

Z, sec.	3.0	4.0
S, psig.		
400	488.2	517.6
425	510.5	539.0

HEAT INPUT PEAK PRESSURES, CATAWBA SPECIFIC

Z, sec.	3.0		4.0		
	T, °F	100	250	100	250
S, psig					
400	420.3	481.1	426.2	509.8	
425	446.0	511.5	452.7	540.4	

The highest of these values for a Z = 3.0 second PORV response never becomes limiting for the Technical Specifications heatup curve. The cooldown curves may limit pressure to lower values only at lower temperatures and significant cooldown rates. For example, with a 50 °F/hr cooldown rate the temperature would have to be less than approximately 120 °F. It is difficult or impossible to establish such high cooldown rates at such low temperatures, so the setpoint is fully acceptable with Z = 3.0 seconds.

Dev./Station Catawba

Unit 1st File No. CNC 1223.03-00-0005

Subject _____

By GEHedrick Date 10/26/84

Sheet No. 14 of 29 Problem No. _____

Checked By _____

Date _____

For $Z = 4.0$ seconds, the situation is only slightly worse. At temperatures below approximately 135°F , the pressure limits of the heatup curve may become more limiting than the peak pressure. Again, it is not likely that heatup or cooldown rates would be approaching 50°F/hr in this low temperature region. In addition, $Z = 4$ seconds is not anticipated, but serves rather to indicate the trend in the event that the PORVs respond marginally slower than $Z = 3.0$ seconds. The significance of these results is primarily to demonstrate the relative insensitivity of the system to the concurrent conditions of slower PORV response times and higher PORV setpoints. Considering the extremely conservative methodology utilized, this further substantiates the acceptability of the design.

MC 1223.03-00


FIGURE 4.2.1

Mass Input

ΔP_{REF} - Reference Overshoot


ATTACHMENT 1

Attachment 1 Sheet 1 of 1
Station Columbia Unit 1 & 2
Calc. File No. CNC 1223.03-00-0005
By M E Hodnick Date 10/26/84
Calculation Sheet No. 15 of 29



X, Mass Input Rate - lb/sec

FIGURE 4.2.2



MU 1CCJ-UJ-UU


Mass Input

F_Z - Relief Valve
Opening Time Factor

FIGURE 4.2.3

ATTACHMENT 3


Attachment 3 Sheet 1 of 1
Station Catawba Unit 1 & 2
Calc. File No. CNC 1223.03-00 0005
By GE Hartung Date 10/26/89
Calculation Sheet No. 17 at 29



Mass InputF_S - Relief Valve Setpoint Factor

ATTACHMENT 4

Attachment 4 1 of 1
 Station Catalytic Unit 1A2
 Calc. File No. CNC 1223.03-00-0005
 By G.E. Heddick Date 10/26/84
 Calculation Sheet No. 18 of 29



S, Relief Valve Setpoint - psig


MC 1223-03-00

Figure 14

EFFECT OF STEAM GENERATOR UA ON
PRESSURE OVERRHOOT

ATTACHMENT 5


3 SEC. RELIEF VALVE OPENING TIME



EFFECT OF STEAM GENERATOR UA ON
PRESSURE OVERSHOOT

Figure 15

ATTACHMENT 6



NC 1223.03-001

Figure 20

EFFECT OF STEAM GENERATOR UA ON
PRESSURE OVERTHROU

ATTACHMENT 7




Figure 21

EFFECT OF STEAM GENERATOR UA ON
PRESSURE OVERSHOOT

0.30

ATTACHMENT 8

NORMALIZED UA

0.10

INITIAL RCS TEMPERATURE = 1000°F

REF.

2500F

UA

Attachment 8 Sheet 1 of 1

Station Castawtua Unit 1 & 2

Calc. File No. CNC 1223.03-00-0005

By J.C. Aedrich to 10/26/84

Calculation Sheet No. 22 of 29

1.5 SEC. RELIEF VALVE OPENING TIME

- RCS PUMP STARTUP IN 1 LOOP
- RCS VOLUME = 13000 CU. FT.
- INITIAL PRESSURE = 300 PSIG
- RCS/SG AT = 50°F
- RELIEF VALVE SETPOINT = 400 PSIG
- SG HEAT TRANSFER AREA = 58,000FT²

0

11


36

100

200

P_{MAX} - P_{SETPOINT}, PSI

FIGURE 4.3.8



EFFECT OF STEAM GENERATOR UA ON
PRESSURE OVERSHOOT

0.30

Attachment 10 Sheet 1 of 1
 Station Catawba Unit 1 & 2
 Calc. File No. CNC 1223-03-00-0005
 By SE Hedrick Date 10/26/84
 Calculation Sheet No. 24 of 29

ATTACHMENT 10

0.20

NORMALIZED UA

0.10

INITIAL RCS TEMPERATURE = 100°F

REF.

140°F

180°F

UA

250°F

0

25

100

130

200

$P_{MAX} - P_{SETPOINT}$, PSI

Figure 17

EFFECT OF STEAM GENERATOR UA ON
PRESSURE OVERSHOOT

ATTACHMENT 11




Figure 22

EFFECT OF STEAM GENERATOR UA ON
PRESSURE OVERSHOOT

ATTACHMENT 12




Figure 23

EFFECT OF STEAM GENERATOR UA ON
PRESSURE OVERSHOOT

ATTACHMENT 13

0.30

0.20

0.10

NORMALIZED UA

INITIAL RCS TEMPERATURE = 1000°F

REF.
UA

2500°F

1.5 SEC. RELIEF VALVE OPENING TIME

- RCS PUMP STARTUP IN 1 LOOP
- RCS VOLUME = 13000 CU. FT.
- INITIAL PRESSURE = 300 PSIG
- RCS/SG ΔT = 50°F
- RELIEF VALVE SETPOINT = 500 PSIG
- SG HEAT TRANSFER AREA = 58,000FT²

0

9

57

100

200

P_{MAX} - P_{SETPOINT}, PSI


Attachment 13 Sheet 1 of 1
Station CNC 1223.03 Unit 1 of 2
Calc. File No. CNC 1223.03-00-0005
By GE Hedrick Date 10/26/89
Calculation Sheet No. 27 of 29

Attachment 14 Sheet 1 of 1
 Station Catawba Unit 1&2
 Calc. File No. CNC 1223.03-00-0005
 By G.E.Hedrick Date 10/26/84
 Calculation Sheet No. 28 of 29

OP/1/A/6700/01
 UNIT ONE DATA BOOK
 FIGURE 1.5
 NC SYSTEM HEATUP LIMITS

Source CNM 1201.01-105, FSAR Q440
 CNM 1200.00-30, 3/23/84 Letter
 to JWH from GBS/Rx Safety
 Prepared By Samuel W. Bellamy
 Approved By J.W.B.
 Effective Date 7/4/84

Page 1 of 2



Attachment 15 Sheet 1 of 1
 Station Catawba Unit 1 & 2
 Calc. File No. CNC 1223.03-00-0005
 By GE Hedrick Date 10/26/84
 Calculation Sheet No. 29 of 29

OP/1/A/6700/01
 UNIT ONE DATA BOOK
 FIGURE 1.6
 NC SYSTEM COOLDOWN LIMITS

Source CNM 1201.01-105, FSAR Q440.

CNM 1201.00-30, 3/23/84 Letter


to JWH from GBS/Rx Safety

Prepared By Samuel W. Bellamy

Approved By J.W.B.

Effective Date 7/4/84

Page 1 of 2



MC 1223-03-00

PRESSURE MITIGATING SYSTEMS
TRANSIENT ANALYSIS RESULTS

Prepared by
WESTINGHOUSE ELECTRIC CORPORATION
for
THE WESTINGHOUSE OWNERS GROUP
ON REACTOR COOLANT SYSTEM
OVERPRESSURIZATION

JULY 1977

~~8110210196~~

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
	Abstract	iv
1	Introduction	1-1
	1.1 Purpose of Study	1-1
	1.2 Review of Past Events	1-2
	1.3 Selection of Parameters for Study	1-4
	1.4 Summary of Parameters	1-8
2	Calculation Method	2-1
	2.1 LOFTRAN Program and Special Modeling	2-1
	2.2 Reference Relief Valve Model	2-5
	2.3 Mass Input Model	2-13
	2.4 Heat Input Model	2-19
3	Typical Results	3-1
	3.1 Mass Input Mitigated by Relief Valve	3-1
	3.2 Heat Input Mitigated by Relief Valve	3-9
4	Instructional Guide for Setpoint/Overshoot Determination	4-1
	4.1 Introduction	4-1
	4.2 Algorithms Used for Setpoint/Overshoot Determination	4-3
	4.2.1 Setpoint Determination for Mass Input Transient	4-3

<u>Section</u>	<u>Title</u>	<u>Page</u>
	4.2.2 Setpoint Overshoot Determination for Heat Input Transient	4-11
4.3	Development of Interpolating Mass Input Equation	4-23
	4.3.1 Analytical Basis	4-24
	4.3.2 Development of Application Factors	4-25
5	Conservatisms in Study	5-1
	5.1 Relief Valve Stroke Time	5-1
	5.2 Effect of Metal Expansion	5-4
	5.3 Effect of Reactor Coolant and Injection Water Temperatures - Mass Input Cases	5-8
	5.4 Effect of Steam Generator Mass and Overall Heat Transfer Coefficient - Heat Input Cases	5-9
	5.5 Effect of Reactor Coolant Pump Startup Time - Heat Input Cases	5-13
6	Other Considerations	6-1
	6.1 Effect of Pressurizer Water Temperature	6-1
	6.2 Effect of Backpressure on Relief Valve	6-4
	6.3 Capacity of Multiple Relief Valves	6-6
	6.4 Relief Valve Cycling	6-11
	6.5 Relief Valve Capacity Change with Flashing	6-17

Appendix A

Summary Table	A-1
Mass Input Results	A-2
Heat Input Results	A-6

MC 1223·03-00

<u>Section</u>	<u>Title</u>	<u>Page</u>
Appendix B		
Figures		B-1
Mass Input		B-2
Heat Input		B-39
Appendix C		
Table 1 - Incidents of Pressure Transients Beyond Tech. Spec. Limits		C-1

ABSTRACT

The results of pressure transient analyses for the reactor coolant system of a pressurized water reactor during low-temperature, water solid operation are presented for particular cases of either mass or heat input to the system. The analyses were performed using conservative bounding input parameters plus parameter sensitivity studies to provide for results applicable to plant specific parameters. For the cases presented, the use of a nominal, two-inch air-operated relief valve, such as the pressurizer power operated relief valve, is shown to mitigate the pressure transient without the need for immediate operator intervention. A procedure is presented for selection of the relief valve setpoint to avoid violation of the 10CFR50 Appendix G pressure limitation for the reactor vessel.

SECTION 1
INTRODUCTION

1.1 PURPOSE OF STUDY

During the past few years (1972 to 1976) a number of events have occurred at operating PWR plants in which the reactor coolant pressure exceeded the allowable limit for the particular temperature as prescribed by the requirements of 10CFR50 Appendix G, during low-temperature, low-pressure, water solid modes of operation. These overpressure events were caused by either equipment malfunction, incorrect operator action or a combination of the two. In the vast majority of the events, the unscheduled pressure transient was recognized by the operator and terminated by manual action.

The purpose of this study was to evaluate the performance of a pressure mitigating system using pressurizer power operated relief valves for the causative events and plant parameters which bound the plants under consideration. The study included an evaluation of the overpressure events which have occurred and a review of the existing design features and operating practices to select for the analysis that group of causative events and pertinent plant parameters which encompass the operating plants within the W Owners Group.

1.2 REVIEW OF PAST EVENTS

Using the published records of Abnormal Occurrence Reports and information provided to the industry by the NRC in June 1976 (see Appendix C) an evaluation was made of the type of events which had occurred, their causative factors and the plant conditions at the time of the event. This review led to the general conclusion that 24 of the 29 reported events could be divided into the two major categories of either mass input or heat input to an isolated constant volume of reactor coolant. The other 5 events were either of unknown origin (3) or were caused by operators following inadequate procedures while controlling the reactor coolant pressure.

The review demonstrated that of the 18 events caused by mass input to the reactor coolant system, by far the greatest number (14) involved a mismatch between the charging and letdown flows. In all but one of the events, the mismatch was caused by a loss of letdown flow while the charging system remained in operation with a relatively low rate of mass input.

The remaining 4 mass input events were the result of an abnormal actuation of portions of the safety injection system. In the one event involving pumps, a single safety injection pump was started by an operator and flow inadvertently entered the reactor coolant system. In the other 3 events, the accumulator isolation valves were deliberately opened by the operator or inadvertently opened by a spurious signal from the engineered safety features actuation circuits. (Of course, pressurization caused by the accumulators is self limiting due to the relatively low gas pressure maintained in the accumulator.)

For the majority of the mass input caused pressure transients, the abnormal condition was recognized by the operator and terminated by operator action. However, the limit of the magnitude of the pressure transient in most cases was a direct result of the speed of the operator in recognizing the situation and taking remedial action.

Among the few (6) events attributed to the heat input case, five of the events reported were those in which a temperature asymmetry was allowed to develop in the reactor coolant system, generally due to insufficient mixing. Then, when a reactor coolant pump was started, the cooler volumes of reactor coolant would circulate around the system and be heated by warmer sections of the system, particularly the steam generators. These heat input events are self limiting in that the temperatures eventually equalize and past experience has indicated that the magnitude of the pressure transient is not great. One event was the result of removing heat from the coolant such that the temperature was allowed to decrease to a temperature too low for the coolant pressure being controlled at the time.

1.3 SELECTION OF PARAMETERS FOR STUDY

1.3.1 Relief Valve

The pressurizer power operated relief valves were selected as the logical mechanism for mitigating reactor coolant pressure transients because the hardware already exists on the operating plants. The valves are typically 2 inch nominal body size globe valves each located in a 3 inch line. Their normal function is to relieve reactor coolant pressure at operating plant conditions so the extension of the function to provide relief at a lower pressure is a natural utilization of the function. Since the power relief valve is controlled by an instrumentation system using electrical signals, the implementation of the function to a lower pressure range can be easily accomplished by electrical circuitry independent of the existing logic circuits which need not be affected. The reference relief valve model described in Section 2.2 was developed based on the general characteristics of a typical power operated relief valve.

1.3.2 Reactor Coolant Volume

The operating plants in the owners group to which this study is directed consist of 2, 3 and 4 loop plants with various designs of reactor vessels, steam generators and pressurizers such that reactor coolant volume enclosed varies widely. To bound all of the plants, the study considered the use of two extreme volumes; 6000 and 13,000 cu.ft. in all of the cases evaluated for both mass input and heat input.

1.3.3 Reactor Coolant Pressure

For the mass input cases, two initial reactor coolant pressures were considered but it was found that for the particular cases studied, the pressure transient was well defined at the time the relief valve setpoint was reached and there was a negligible effect on the relief valve performance due to the difference in starting pressure. Therefore for conservatism, the majority of the mass input cases were started from a coolant pressure of 50 psig to assure that the mass input mechanism was always at full performance before the mitigating relief valve came into operation.

The heat input cases which involved the operation of a reactor coolant pump were restricted to a minimum initial pressure of 300 psig because of a pump shaft seal requirement. Again for conservatism, this minimum pressure was used in all the analyses to assure that the pressure transient was allowed to become well established before the mitigating relief valve was brought into operation.

1.3.4 Reactor Coolant Temperature

The initial reactor coolant temperature selected for use in the analyses was based on a review of the credible operating conditions which might be experienced in a plant when in a low-temperature, low-pressure water solid condition. For all of the mass input cases, the reactor coolant was considered to be at a cold shutdown temperature of 100°F (see Section 5.3 for additional discussion of this parameter) and the pressurizer filled solid with water at 100°F (see Section 6.1 for additional discussion).

The heat input cases were studied with various values of initial reactor coolant temperature from 100°F to 250°F, the maximum range of temperature which might be expected for operation in a water solid condition. Over this range, as was expected, the heat input transients became more severe with the higher temperatures but the allowable coolant pressure, according to the 10CFR50 Appendix G rules, also increases.

1.3.5 Mass Input Mechanisms

The review of past experience indicated that the case of a loss of letdown while charging flow continued was the most likely cause of a pressure transient. Among the operating plants, there are charging system designs which consist of positive displacement pumps, centrifugal type pumps and combinations of the two. The lowest normal flow rate occurs in those plants with small positive displacement pumps where a representative flow rate is about 40 gpm.

The maximum normal charging flow rate occurs in those plants with centrifugal type pumps where a representative flow rate is about 120 gpm. The design mass input cases due to loss of letdown flow were therefore considered to be between 40 and 120 gpm.

Although there has been only one occurrence of inadvertent mass injection due to the operation of a safety injection pump, and these pumps are normally made inoperative during low-temperature low-pressure plant operation, the potential does exist for this type of mass input transient. Therefore, the analyses was extended to include the performance of the mitigating system for the case of a single safety injection pump being placed in operation (see Section 2.3).

The safety injection accumulators were not considered as a credible mass input mechanism for this study because there are multiple administrative controls to ensure isolation including de-energizing valve control circuits during plant shutdown operations.

1.3.6 Heat Input Mechanisms

The pressure transient events selected for study involved the cases where a temperature asymmetry was formed in the reactor coolant system in which the steam generators were at a higher temperature than the remainder of the system. The magnitude of the temperature difference between the steam generators and the reactor coolant system is dependent on the previous plant operations which allowed the asymmetry to develop. For the purpose of this study to bound the possible events, temperature differences between the steam generators and the reactor coolant system up to 100°F were evaluated. However, it is considered realistic to assume a maximum temperature difference of 50°F as the design case because much higher differences are difficult to develop and are easily recognized by the operator as abnormal conditions requiring special attention.

1.4 SUMMARY OF PARAMETERS

1.4.1 General

The plants represented by the W Owners Group comprise a group of 2, 3 and 4 loop pressurized water reactor plants, each with one steam generator and one reactor coolant pump per loop. Typical total reactor coolant system volumes for the plants under consideration range between about 6000 cu.ft. and 13,000 cu.ft., and these two volumes were therefore used for this study.

1.4.2 Reference Relief Valve

The relief valve selected for use in the study as described in Section 2.2 exhibits the following general characteristics:

1. Opening time; 3 seconds
2. Closing time; 5 or 20 seconds
3. Flow capacity; $C_v = 50 \text{ gpm} / \sqrt{\text{psf}}$ per valve
4. Set pressures, various; 400, 500 and 600 psig

1.4.3 Mass Input Cases

The following two representative mass input cases as described in Section 2.3 were considered:

1. Charging flow with letdown isolated; 40 and 120 gpm
2. Inadvertent operation of one safety injection pump; 870 gpm at 500 psig

The following parameters were considered for the mass input cases:

MC 1223·03-00

1. Temperature of reactor coolant; 100°F
2. Temperature of injected water; 100°F
3. Initial pressure of coolant; 50 or 450 psig

1.4.4 Heat Input Cases

The temperature asymmetry conditions selected for study as heat input cases are discussed in Section 2.4. The following are the cases considered for both a 6000 and 13,000 cu.ft. plant size:

RCS/SG ΔT

Steam Generator Temp.	100	140	180	250
150	50	---	---	---
190	---	50	---	---
200	100	---	20	---
230	---	---	50	---
240	---	100	---	---
250	---	---	---	---
280	---	---	100	---
300	---	---	---	50

SECTION 2
CALCULATION METHOD

2.1 LOFTRAN PROGRAM AND SPECIAL MODELING

The one loop version of the LOFTRAN[†] program was utilized to perform the mass input analyses and the four loop version was utilized for the heat input analyses. No changes to either version of the program were necessary for the studies. However, some input modeling, input additions and initialization changes were required as described in the following paragraphs.

2.1.1 Mass Input Analysis

No special features of LOFTRAN were required for the mass input cases. However, some input adjustments were made to ensure that the mass input model was representative of the conditions specified for analysis.

One such adjustment was made to ensure that an isothermal condition was maintained. Since LOFTRAN was not programmed to be initialized at zero power, a very small, constant power level was maintained and nominal, full reactor coolant flow was maintained. This initialization condition does not alter the resultant pressure increase for actual mass input cases where the reactor coolant pumps may not be running.

To minimize the pressure defect associated with the compressibility of a saturated (hot) water solid pressurizer (a representation required by LOFTRAN to maintain the specified reactor coolant pressure), the pressurizer water volume was reduced to 100 ft³. The

[†] - WCAP-7907

volume difference between a nominal pressurizer and the 100 ft³ was incorporated into the total system volume but at an initial temperature of 100°F.

2.1.2 Heat Input Analysis

Except for the decay heat (loss of RHRS) and pressurizer heater input cases, more extensive adjustments were necessary for modeling the heat input cases.

The heat input cases analyzed involved the startup of a pump in one loop with the plant in a cold shutdown condition and with temperature asymmetries in the reactor coolant loops. Two possible asymmetries were assumed. One was the RCS/SG case, in which the steam generators, primary and secondary, were at a higher temperature than the remainder of the reactor coolant. The second considered that the water in the loop seal piping from the steam generator outlet to the pump suction was at a lower temperature than the remainder of the coolant and steam generators. In both cases the temperature of the reactor coolant in the tubes was at a temperature equal to the saturated condition of the secondary water mass.

The multiloop version of the LOFTRAN program was used to obtain the capabilities for a reactor coolant pump startup in one loop and for the reverse flow simulation in the inactive loops. To circumvent a flow initialization problem, the LOFTRAN loop out of service option was used with a very small input power (LOFTRAN does not permit zero power initialization) to establish a very low

natural circulation flowrate following the pump coastdown. After initialization for the natural circulation flow conditions, the code was returned to the normal program sequence to initiate the remainder of the heat input transient.

Before the heat input transient was initiated, however, it was necessary to input the required temperature profile.

For the case of the RCS/SG temperature asymmetry, the coolant temperature was made uniform everywhere except in the steam generator tubes. The steam generator secondary temperature and the coolant temperature in the steam generator tubes were input as equal but different than the reactor coolant temperature.

For the case of the loop seal temperature asymmetry, the temperature of the coolant volume in the loop seal was input different from the temperature throughout the remainder of the reactor coolant system (including the steam generator tubes) as well as the steam generator secondary temperature.

Also in the loop seal case, steam generator outlet plenum volume was set to a very small value to minimize mixing in the reverse flow loops before the cold slug from the loop seal entered the steam generator tubes. *REVERSE flow, inactive loops*

After temperature initialization, the input parameters of core heat flux, steam flux and feed flow were stepped from their respective initial (natural circulation mode) conditions to zero during the first time step. Reactor coolant pump startup is initiated at $t = 0$ seconds using the default homologous data associated with the 93A pump model.

As in the mass input case, the pressurizer volume was minimized (set equal to 100 ft³) and the difference in pressurizer volume (actual - 100 ft³) was added to the inactive volume of the reactor coolant.

2.2 REFERENCE RELIEF VALVE MODEL

The relief valve model selected as the reference for use in the transient analyses describes a nominal two inch air-operated open-close valve with a linear plug characteristic. The capacity of the valve is based on a standard geometry globe-type valve with a flow coefficient C_v equal to 50, where the flow coefficient is defined as the flow of water at 60°F, in gallons per minute, at a pressure drop of one pound per square inch across the valve while the valve is in the full open position. (i.e., $C_v = Q / \sqrt{\Delta p}$)

Since the reference relief valve is considered to discharge into the pressurizer relief tank, there will be a backpressure at the valve discharge depending on the conditions in the relief tank at the time of valve actuation. The gas blanket pressure in the relief tank normally will not exceed 10 psig but the pressure can increase, due to repeated relief valve discharges, to a maximum of 100 psig at which time a rupture disk on the tank will open to prevent a further increase in pressure.

The flow capacity of the reference relief valve versus upstream pressure (reactor coolant pressure) is shown for various values of backpressure on Figure 2.2.1. All of the short-term transient analyses (one relief valve cycle) presented in this study were based on the flow capacity of the reference relief valve subjected to a constant backpressure of 10 psig. (See Section 6.2 for additional discussion.)

The reference relief valve was considered to have a linear flow characteristic; that is, the flow through the valve at a constant differential pressure is directly proportional to the lift of the stem. This selection is consistent with the type of valve used as the pressurizer power-operated relief valve in the operating nuclear plants. However, the effect of using a non-linear valve type (see Figure 2.2.2) was also investigated to see if the performance of the system would be improved by changing to a special

plug-seat design. The opening and closing time characteristics of the non-linear valve were taken as the same as the reference linear valve.

The opening and closing characteristics of the reference relief valve used in the transient analyses were based on a particular but typical type of operator used to drive the valve stem. The reference operator was taken as an air diaphragm type with a stroke of 3/4 inch, a diaphragm area of 220 sq.in. and a compressed spring to hold the valve closed. The air pressure range required to stroke the valve was taken as 11 to 64 psig; that is, the valve stem starts to move with 11 psig pressure on the diaphragm and reaches the full stroke of 3/4 inch under a pressure of 64 psig.

When the relief valve is signalled to open, air is admitted into the piping to the valve and into the diaphragm chamber. The air continues to flow into this volume for a period of time, depending on the controlling restriction in the line, and increases the pressure until the unit pressure on the diaphragm reaches 11 psig. At this pressure, the force on the diaphragm equals the spring force holding the valve closed and a further increase in air pressure will cause the valve stem to begin to move and open the valve. For the reference valve model, this initial time delay, before the valve starts to move, is about 20% of the total time for the valve to act and is shown on Figure 2.2.3.

After the valve starts to move, the air flow into the diaphragm chamber continues to both increase the pressure to overcome the spring force and to fill the additional volume made available as the stem moves. When the valve reaches the full open position the air pressure in the diaphragm chamber is 64 psig, but since the supply pressure could be as high as 100 psig the air continues to flow into the diaphragm chamber after the valve movement has stopped until the chamber pressure equals the supply pressure. Figure 2.2.3 describes the valve stem movement (stroke) versus normalized time for the reference valve supplied from a normal 100 psig air system.

The valve is considered to be held open by the excess air pressure in the diaphragm chamber until receipt of a signal to close. Until the excess air has vented down from 100 psig to 64 psig, the valve stem will not move. This time delay of about 16% of the total time for the valve to act is shown on Figure 2.2.4. As the air pressure decreases below 64 psig, the stem begins to move under the action of the compressed spring and air flows out of the diaphragm chamber to both decrease the pressure and to remove a volume of air necessary to allow the diaphragm to move. At an air pressure of 11 psig, the valve will be in the full closed position but air will continue to vent from the diaphragm chamber until the pressure is equalized with the atmosphere. Figure 2.2.4 describes the valve stem movement (stroke) versus normalized time for the reference valve.

In the analyses presented in this study, the relief valve characteristics used to mitigate the pressure transients are described by the use of the three Figures 2.2.1, 2.2.3 and 2.2.4. For instance, if a reactor coolant pressure of 500 psig is reached during an increasing pressure transient at a time equal to 1/2 the valve stroke time, then the flow rate of water at 100°F through the valve at that instant is:

$$1107 \text{ gpm } (\text{Figure 2.2.1}) * \sqrt{\frac{62.4}{62.1}} * 0.395 \text{ (Figure 2.2.3)} = 438.3 \text{ gpm or} \\ 60.5 \text{ lb/sec}$$

The total time for the reference relief valve to act in the opening direction was taken as 3.0 seconds which is about 1 second longer than a typical power operated relief valve in an operating plant. This total time includes a 0.6 second time delay (20% of total time) from the receipt of the signal until the relief valve starts to open. The time in the transient when the valve open signal was received was varied, to simulate different values of the valve setpoint between 400 and 600 psig, to obtain the effect of the setpoint on peak transient pressure.

After the reference relief valve has opened and turned the pressure transient from an increasing to a decreasing transient, the relief valve is assumed to receive a close signal when the pressure has decreased to a value 20 psi below the original setpoint. This value of the reset pressure was used in all of the analyses in which a full valve cycle was evaluated. Upon receipt of the signal to close at the time in the transient when the pressure was 20 psi below the valve setpoint pressure, the valve was closed using the characteristic shown by Figure 2.2.4 where the total time was taken as either 5 or 20 seconds.

In the transients which did not result in full opening of the reference relief valve (e.g., letdown isolation with continued charging pump operation) the stroke position in effect at the time the reset pressure was reached was the initial position used for the start of valve closure. If other than fully open, the time delay in Figure 2.2.4, associated with depressurization of the diaphragm chamber from 100 psi to 64 psi, is not in effect. Further, the total closing time is accordingly reduced in relation to the stroke position at reset pressure.

FIGURE 2.2.1




FIGURE 2.2.2




FIGURE 2.2.3

REFERENCE RELIEF VALVE
OPENING CHARACTERISTIC

MC 1223-03-00





FIGURE 2.2.4

REFERENCE RELIEF VALVE
CLOSING CHARACTERISTIC

46 1320

K-E 10 X 10 TO 1/2 INCH 7 X 10 INCHES
KEUFFEL & ESSER CO. MADE IN U.S.A.



2.3 MASS INPUT MODEL

The two credible means of adding excess mass to the reactor coolant system while the plant is in a relatively cold (100°F) solid-water mode of operation are by creation of a mismatch between the charging and letdown flows or by inadvertently placing a safety injection pump in service. The most likely event as evidenced by the experience of the operating plants is the charging/letdown mismatch case. However, the inadvertent start of a safety injection pump has the potential for greater rates of mass input and hence more rapidly increasing coolant pressure transients. Therefore, the inadvertent start of a safety injection pump with the plant in a cold shutdown condition was selected as the limiting case.

Two particular cases of a mismatch between charging and letdown flows were evaluated; one considering the use of a positive displacement pump and the second a large centrifugal type pump. For both of these cases, the transient was initiated from the steady state condition of equal charging and letdown flows by terminating the letdown flow in a ramp fashion, as would occur if a valve in the letdown line was inadvertently closed. For the positive displacement pump case, the charging flow was considered to remain constant as the backpressure increased, while for the centrifugal pump case, the flow was considered to decrease with increasing backpressure as the flow was passed through a piping system with a constant resistance (Figure 2.3.1).

The flow from the positive displacement pump was taken as 40 gpm, a relatively typical low charging flow rate for a plant shutdown condition, while for the centrifugal pump case the charging flow was taken as 120 gpm, a relatively high value for normal charging service.

In the operating nuclear plants, there are various designs of safety injection systems and several types of pumps in use. A survey of the various systems and pumps resulted in the selection of four typical system delivery characteristics and these are shown on Figure 2.3.2. Each of the characteristics shown on Figure 2.3.2 represents the maximum expected flows into the reactor coolant system against various backpressures for the case of a single, new, non-degraded pump delivering through all the available injection flow paths.


From an inspection of Figure 2.3.2, it is evident that the system represented by Curve C is the worst case in that the system delivery into the reactor coolant system is the greatest of all the systems shown over the reactor coolant pressure range of 400 to 600 psig, the range of most interest for the transient analyses. Therefore, the system delivery described by Curve C was used in the study and is referred to as the reference safety injection pump startup case.

From test data on typical safety injection pumps, it was determined that the motors under full voltage will bring the pumps to full speed in a little over 2 seconds. Therefore, in the study, the reference SI pump was considered to reach full speed in 2 seconds. The flow from the pump does not begin immediately because the pump first must be brought up to a speed sufficient to develop a discharge head greater than the backpressure to which it is attempting to deliver. This delayed flow initiation is shown graphically on Figure 2.3.3 for two values of reactor coolant backpressure. This figure shows the flow rate into the reactor coolant system increases from zero to its equilibrium value in less than one second for the particular case of a 450 psig reactor coolant back-pressure.

Although the startup characteristics shown by Figure 2.3.3 were used in the analyses of the pressure transients for the reference SI pump start cases, it was determined that the volume of water injected during these short pump startup periods is relatively insignificant in the analyses. Only for a specific case where the initial coolant pressure is very near the relief valve setpoint will the startup transient of the pump affect the pressure transient. For such a case, the relief valve would start to open as the pump came up to speed and the pressure transient would be mitigated earlier and more effectively.

In all mass input cases, reference SI pump startup and charging flow from either the positive displacement or centrifugal pumps, the temperature of the injected water was taken equal to the reactor coolant so that the resultant pressure transient is due to the addition of mass only and is not affected by the mixing of the injection water into the reactor coolant. (See Section 5.3 for additional discussion.)

FIGURE 2.3.1



TYPICAL SAFETY INJECTION SYSTEM
DELIVERY CHARACTERISTICS
(SINGLE PUMP)

VITAL NOTES





FIGURE 2.3.3



2.4 HEAT INPUT MODEL

The investigation of the reported events of reactor coolant pressure transients and of current plant operating practices led to the conclusion that four credible heat addition mechanisms should be studied: pressurizer heaters, core decay heat and two types of reactor coolant loop temperature asymmetry.

For the pressurizer heater case the reactor coolant system is considered to be water solid and completely isolated so that any heat input to the water in the pressurizer results in an attempt to expand the system with a consequent increase in system pressure. The reference case considered the operation of 1800 KW of heaters, the design value for a large 4 loop plant, in a relatively small pressurizer of 1000 cu.ft. volume.[†] This large heat input to a small liquid volume results in a conservatively high rate of change of pressure but is not significant compared with other heat input cases studied as shown by Figure 2.4.1.

The case of heat input from core decay heat was investigated considering the decay heat from an 1882 Mwt design core added to a small system volume of 6000 cu.ft. 12 hours after plant shutdown from an extended high power run. This is a conservatively large relative value of heat addition, but the magnitude of the unrelieved transient pressure response still is not significant compared to other cases of heat input studied as shown by Figure 2.4.1.

The first of the two types of temperature asymmetry considered in the study occurs when the reactor coolant is at a relatively uniform warm temperature with little or no natural circulation and the cold reactor coolant pump seal injection water continues to enter the system. The cooler injection water will settle as a pool in the loop seal below the

[†] Typically there is 1 KW of pressurizer heaters for each 1 cu.ft. of pressurizer volume.

pump inlet formed by the piping from the steam generator outlet and the pump inlet (see Figure 2.4.2). The volume of cold water which can be trapped in the loop seal is determined by the piping layout and the typical volume used in the study was 140 cu.ft. in each loop. To fill this volume with cold water would require 3 to 4 hours of normal seal injection with the plant in a stagnant condition; i.e., no reactor coolant flow.

The coolant pressure transient is initiated upon starting one reactor coolant pump. As the pump comes up to speed, the coolant flow rate slowly increases in the active loop and the pool of cold water will be drawn up into the pump and discharged out to the cold leg piping and reactor vessel where it mixes with the warmer coolant. Simultaneously the cold pool of water in the inactive loop(s) will flow backward through the steam generator(s) at a flow rate significantly less than in the active loop. As each of the cold pools of water flow through their steam generators, their temperatures will be increased by the heat transferred from the secondary side, and since the coolant cannot expand in the isolated reactor coolant system volume, the coolant pressure will increase. The coolant pressure will continue to increase until the temperatures of the reactor coolant and steam generator water are equalized (see Figure 2.4.1) or the excess coolant volume due to the added heat is relieved through a relief valve.

The second type of temperature asymmetry occurs when the reactor coolant has been cooled down without sufficient circulation, for instance by use of the residual heat removal loop not augmented by the flow from a reactor coolant pump, and the steam generators remain at an average temperature higher than that of the reactor coolant. For this case, the steam generator shell, tubes, secondary water at the no-load level and reactor coolant enclosed in the tubes are assumed to be at a uniform

MC 1223-03-00

temperature (see Figure 2.4.3). When the pressure transient is initiated by starting one reactor coolant pump, the reactor coolant flow rate increases, washing the warm water out of the tubes and replacing it with relatively cold water from the loops. The rate of flow in the active loop is significantly higher than that in the inactive loops which are subjected to reverse flow, but in all steam generators heat is transferred to the cooler reactor coolant causing an increase in pressure. The transient pressure increase will continue until the reactor coolant and steam generator water temperatures are equalized (see Figure 2.4.1) or the excess coolant is relieved through a relief valve.

For the cases with each type of temperature asymmetry, the reference steam generators were considered to have 58,000 sq.ft. of heat transfer area and a secondary water volume of 3580 cu.ft.; both parameters being significantly greater than those for any of the operating plants, so that the rate of heat transfer and total stored heat available for transfer were conservative in this study.

Heat transfer across the steam generator tubes was assumed to be controlled by free convection on the secondary side. The heat transfer coefficient associated with this mechanism was determined from the McAdams[†] correlation for turbulent boundary layers on a vertical surface, or:

$$h_{sec} = 0.13 K \left[\frac{\rho g \beta}{\mu^2} * p_r \right]^{1/3} \left[\Delta T_{wall} \right]^{1/3}$$

[†] McAdams, W. H., "Heat Transmission", 3rd Edition, McGraw-Hill, New York, 1954

where:

h_{sec}	= secondary film coefficient of heat transfer, BTU/hr ft ² °F
ρ	= density of secondary water at film temperature, lbm/ft ³
μ	= viscosity of secondary water at film temperature, lbm/ft hr
ΔT_{wall}	= secondary to primary temperature difference, °F
g	= acceleration of gravity, ft/hr ²
β	= temperature coefficient of volume expansion, (°F) ⁻¹
k	= conductivity of secondary water, BTU/hr ft °F
P_r	= Prandtl Number evaluated at secondary film temperature

The reactor coolant pump characteristics used in the heat input studies were those representative of a controlled leakage sealed pump with a flow rate of about 95,000 gpm at normal plant conditions and a startup time of about 10 seconds.

From an inspection of Figure 2.4.1, it is evident that the heat input cases from pressurizer heaters and decay heat are not as significant as those for the cases with a loop temperature asymmetry. Therefore, these less significant cases were not studied further. Similarly, the loop seal asymmetry case is seen to give a relatively small pressure transient compared to the potential excursion possible from the RCS/SG temperature asymmetry cases and was not considered further in the study of heat input transients.

FIGURE 2.4.1




FIGURE 2.4.2

LOOP SEAL VOLUME





FIGURE 2.4.3

SG SECONDARY NO-LOAD WATER LEVEL

MC 1223·03-00



SECTION 3
TYPICAL RESULTS

3.1 MASS INPUT MITIGATED BY RELIEF VALVE

Based on the probability of occurrence and past experience, the most likely mass input case is considered to be the charging/letdown flow mismatch case in which the letdown is terminated within 2 seconds, presumably by a valve closure. Selecting an initial reactor coolant system pressure of 50 psig, the pressure response to the letdown isolation will be as described by Figure 3.1.1 for a small plant with a reactor coolant volume of 6000 cu.ft. As would be expected, the pressure increases more rapidly for the case of the larger mass input from the centrifugal pump (about 16 lb/sec) than for the input from the positive displacement pump (about 6 lb/sec). For these particular examples, the reference relief valve was given a signal to open when the pressure rose above 615 psia, but since the reference valve operator has a time delay of 0.6 seconds, the pressure continued to rise until the valve started to open. Very soon after the valve started to open, the pressure was found to stop increasing and to begin to decrease as the capacity of the valve exceeded the relatively constant mass input rate. The valve continued to move open until the reactor coolant pressure had decreased 20 psi below the valve setpoint of 615 psia. At this reset pressure the valve was signalled to close but the pressure continued to decrease as the valve began its closing cycle. Eventually the valve capacity decreased to less than the continuing mass input and the reactor coolant pressure stopped decreasing and again began to increase toward the relief valve setpoint. It is interesting to note that for the relatively low values of mass input in these examples, the relief valve did not stroke to the full open position since the valve capacity

far exceeded that required to relieve the mass input. The valve floated on the motive air in the diaphragm chamber during the opening cycle and did not reach the full open position before the air was vented from the operator. However, due to the closing characteristics of the relief valve, the valve did close completely during each cycle.

The reactor coolant pressure will repeat the cycle through the relief valve setpoint pressure and reset pressure as shown on Figure 3.1.1 until the mass input is terminated. The figure clearly shows the pressure transient is quickly mitigated by the reference relief valve for the entire range of charging flow rates and that the peak pressure reached (less than 625 psia) is less than 10 psi above the valve setpoint.


The effect of a much larger mass input flow rate on the pressure response and relief valve performance is demonstrated by Figure 3.1.2 which shows the pressure response for the case of an abnormal operation of the reference safety injection pump. For this example of a very high mass input (113 lb/sec) into a 6000 cu.ft. volume plant, the pressure rose rapidly to the setpoint of the relief valve. Due to the inherent time delay of the valve operator, the pressure continued to rise about 74 psi above the setpoint before the valve started to open. After the valve had started to open, it very quickly provided sufficient capacity to mitigate the pressure transient, but due to the rapid rate of change of system pressure during the early period of the valve stroke, the pressure rose to a peak of 770 psia before it began to decrease. The pressure overshoot above the valve 615 psia setpoint was 155 psi for this particular example of an extreme mass input into a small coolant volume.

For the example SI pump startup case shown on Figure 3.1.2, the relief valve did reach the full open position during its cycle and, therefore, when it received the close signal, there was a short time delay for the motive air to vent from the operator before the valve started to move. This time delay plus the finite time for the valve to stroke resulted in a pressure decrease before the valve capacity became less than the mass input rate. When the capacity of the valve became less than the input flow rate, the reactor coolant pressure again began to increase toward the valve setpoint. The valve will continue to cycle open and closed with an 8-1/2 second cycle time while following the coolant pressure response until the mass input is terminated.

There is a direct relationship between the rate of change of reactor coolant pressure and the rate of mass input into a given system volume as indicated by Figure 3.1.2 and Figure 3.1.3, and, conversely, there is also an inverse relationship between the rate of pressure change and the size of the volume into which a given mass rate is injected. This relationship of the system volume is shown for the particular case of the reference SI pump mass input into two different system volumes of 6000 and 13,000 cu.ft. on Figure 3.1.4.

The pressure overshoot above the 615 psia setpoint for the reference SI pump mass input case was shown to be about 155 psi on Figure 3.1.2, which gave a peak pressure of 770 psia. To reduce the peak pressure, the relief valve setpoint can be set at a lower value so that the valve begins to relieve at a lower pressure. However, the capacity of the valve is less and the mass input from the SI pump is greater at the lower pressure so the valve is not as effective in mitigating the pressure transient. These two effects of reduced capacity and higher mass input result in the pressure overshoot being increased from 155 to 192 psi as the setpoint is reduced from 600 to 400 psig for a net gain of 163 psi in the peak pressure reached. This effect is shown on Figure 3.1.5.

FIGURE 3.1.1




46 1510

K-E 10 X 10 TO THE CENTIMETER 10 X 25 C.M.
KUEFFEL & ESSER CO. MADE IN U.S.A.

MC 1223-03-00


FIGURE 3.1.2



46 1510

K+E 10 X 10 TO THE CENTIMETER 10 X 25 CM
KRUPP & ESSER CO. MADE IN U.S.A.

FIGURE 3.1.3




46 1320

K+E 10 X 10 TO 1/4 INCH 7 X 10 INCHES
KEUFFEL & ESSER CO. MADE IN U.S.A.

MC 1223-03-00

FIGURE 3.1.4




461510

K-E 10 X 10 TO THE CENTIMETER 10 X 35 CM.
KEUPFER & ESSER CO. NEW YORK

461510

K+E 10 X 10 TO THE CENTIMETER 10 X 25 CM.
KELFEL & ECKER CO. MILWAUKEE



3.2 HEAT INPUT MITIGATED BY RELIEF VALVE

As shown in Section 2.4, the heat input cases which have the potential for severe pressure transients are those in which the steam generators exhibit a higher temperature than the remainder of the reactor coolant system. The magnitude of the difference in temperature is dependent on the means by which the temperature asymmetry was achieved, but a typical difference is considered to be about 50°F because higher differentials are more difficult to achieve and are more easily recognized by the operator.

The transient pressure response for a typical heat input case in which the initial reactor coolant temperature was 180°F and the temperature differential to the steam generators was 50°F (secondary temperature 230°F; steam pressure 21 psia) is shown on Figure 3.2.1. For this transient in a 6000 cu.ft. plant (2 loop), one of the two reactor coolant pumps was started to circulate the reactor coolant through the warmer steam generators. As the coolant flow began, the warm water (230°F) in the tubes of the steam generator in the active loop was forced out and into the reactor coolant pump where it was pumped into and mixed with the 180°F reactor coolant. In the inactive loop(s), the warmer water from the tubes of the steam generator was forced out in a reverse direction due to the backflow in the inactive loop, and also mixed with the cooler reactor coolant. This initial mixing of the warm water with the larger volume of cooler water caused an initial shrinkage effect and tended to decrease the initial coolant pressure.

Simultaneously, the cooler reactor coolant which entered the steam generator began to be heated as it moved through the tube bundle. As heat was added to the coolant due to heat transfer from the secondary water in the steam generator, the coolant attempted to expand and caused a resultant pressure increase. The net effect of the expansion due to the heat transferred to the coolant and the shrinkage effect due to the mixing of the warm water into the cooler coolant was a relatively constant coolant pressure in the initial few seconds of the transient as seen on Figure 3.2.1. Then, as the flow rate increased and the heat transfer mechanism became predominant, the coolant pressure increased rapidly.

The reactor coolant pressure continued to increase until the pressure reached 500 psig, the setpoint of the relief valve. The relief valve was given a signal to open when the pressure reached 515 psia (at 9.2 seconds) but due to the inherent time delay of 0.6 seconds, the pressure continued to increase until about 9.8 seconds into the transient, at which time the relief valve began to open and the pressure began to be mitigated. Very soon afterwards, the valve had opened sufficiently to provide a capacity in excess of the expansion rate of the coolant and the coolant pressure decreased rapidly after reaching an overshoot of 100 psi above the setpoint.

For comparison, a transient pressure response for the particular case in which the temperature differential was only 20°F is also shown on Figure 3.2.1. With the lesser temperature difference, the transient is much slower and the resultant setpoint overshoot is only 15 psi, versus the overshoot of 100 psi for the 50°F ΔT case.

Figure 3.2.2 is presented to show the relationship between the setpoint overshoot and the temperature difference between the steam generators and the reactor coolant for three initial RCS temperatures; 100°F, 140°F and 180°F. For a given initial reactor coolant temperature (e.g., 180°F) the overshoot is seen to increase with increasing ΔT , where the ΔT as high as 100°F has been plotted to show the effect. It can also be seen from Figure 3.2.2 that at low values of ΔT , e.g., less than 70°F, no setpoint overshoot would be expected because the pressure would only rise from the initial value of 300 psig to some pressure less than 500 psig and the relief valve would not be actuated.

As already evidenced in Figure 3.2.2, the initial temperature of the reactor coolant also has a significant effect on the magnitude of the resultant pressure transient for the heat input cases. Figure 3.2.3 indicates the effect of the initial temperature on the setpoint overshoot for a 50°F differential temperature. By way of illustration, Figure 3.2.3 gives a pressure overshoot of 113 psi at a temperature of 200°F, whereas the overshoot is only 30 psi for an initial temperature of 100°F.

The heat input transients due to temperature asymmetry in the reactor coolant system are unique in that they are self limiting; i.e., when the temperatures are brought to equilibrium by the reactor coolant flow, the transient is ended. The use of a relief valve to mitigate the pressure transient will result in a valve cycling effect when the valve capacity is greater than the expansion rate of the coolant as it is heated, but the valve will only be required to cycle a few times until the temperatures in the system are brought to equilibrium and coolant expansion ceases. The first cycle will result in the largest setpoint overshoot. Subsequent valve cycles will result in diminishing overshoots as the coolant expansion rate diminishes until eventually the valve will close and remain closed.

Figure 3.2.4 describes the first complete cycle for the reference relief valve as it mitigates a heat input transient with an initial severe temperature difference of 100°F. For this particular case, the valve is signalled to open at a pressure of 615 psia and the resultant setpoint overshoot is 145 psi. Then, as the pressure is caused to decrease by the valve action, the valve is signalled to close at 595 psia (20 psi below setpoint) and the valve closes over a period of 5 seconds. The figure indicates the valve will close completely and the pressure will again begin to rise toward the setpoint. The open/close cycles will be repeated but subsequent cycles are expected to become of longer duration and of lesser magnitude, as the temperatures in the system approach equilibrium, until the valve will no longer be required to lift.

461510



K+E 10 X 10 TO THE CENTIMETER 18 X 25 CM.
KRUPPEL & EISNER CO. NEW YORK

FIGURE 3.2.2



MC. 1223.03-00

FIGURE 3.2.3

461510



K+E 10 X 10 TO THE CENTIMETER 19 X 25 CM
KEUPPEL & ECKER CO. HANAU W.G.D.

FIGURE 3.2.4



SECTION 4
INSTRUCTIONAL GUIDE FOR
SETPOINT/OVERSHOOT DETERMINATION

4.1 INTRODUCTION

Determination of relief valve setpoint for a specific plant requires knowledge of the expected overshoot which could occur under all possible mass input and heat input additions for that plant.

Many mass input and heat input possibilities were considered in LOFTRAN analyses which were performed to generate values of setpoint overshoot. The analyses were performed for operating plant parameters selected to bracket or bound those of the plants in the W Owners Group on RCS Overpressurization. The bounding envelope of mass input and heat input generic results are not generally applicable to any specific plant. To determine a specific relief valve setpoint, a means of interpolating the setpoint overshoot from the generic envelope has been made available and algorithms have been developed to facilitate such interpolation.

The heat input algorithm involves the use of a procedure to interpolate the setpoint overshoot for plants exhibiting a reactor coolant (RCS) volume and steam generator design different from those defined by the generic setpoint overshoot envelope. This procedure is presented in Section 4.2.2, together with an example of its application for a specific RCS volume and steam generator design.

The mass input algorithm involves the use of a procedure for the determination of a relief valve setpoint, which includes interpolation of setpoint overshoot for plants with RCS volume, relief valve setpoint, relief valve opening time and mass input rate different from, but included within, the envelope of generic setpoint overshoot results. Interpolation is expedited through the use of an equation, developed for this purpose. This equation is based on the adjustment of reference (generic envelope) setpoint overshoot results by linear application factors, with one factor determined for each of the input parameters; RCS volume, relief valve setpoint, relief valve opening time, and mass input rate for the specific plant under consideration. The equation and application factor development is presented in Section 4.2.1.

<u>Step</u>	<u>Procedure</u>	<u>Example Application</u>
1	Select relief valve setpoint operating range	Setpoint = 500 psig
2	For limiting mass input rate, obtain ΔP_{REF} from Figure 4.2.1	$\Delta P_{REF} = 82 \text{ psi}$ for mass input rate (x) = 60 lb/sec
3	For total RCS volume, obtain F_V factor from Figure 4.2.2	$F_V = 0.71$ for total RCS volume (V) = 10,000 cu.ft.
4	For the relief valve opening time (total, including delay), obtain F_Z factor from Figure 4.2.3	$F_Z = 0.733$ for relief valve opening time $Z = 2.0$ seconds
5	For the relief valve setpoint selected, obtain F_S factor from Figure 4.2.4	$F_S = 1.14$ for relief valve setpoint = 500 psig
6	Calculate the product of factors ΔP_{REF} , F_V , F_S , and F_Z determined in Steps 2 through 5 (application of Equation 1). This is the setpoint overshoot, ΔP .	ΔP (10,000 cu.ft., 500 psig, 2 seconds, 60 lb/sec) = 49 psit

+ Conservative - LOFTRAN analysis for these conditions gives an overshoot equal to 25 psi.

MC 1223-03-00

FIGURE 4.2.1





FIGURE 4.2.2




46 1320

K-E 10 X 10 TO 24 INCH 7 X 10 INCHES
KEURER & SONS CO. MADE IN U.S.A.

MC 1225-U5-UU

FIGURE 4.2.3


Mass Input
 F_Z - Relief Valve
Opening Time Factor



46 1320

K+E 10 X 10 TO 1/2 INCH 7 X 10 INCHES
KELPFEL & ECKER CO. MADE IN U.S.A.

FIGURE 4.2.4




46 1320

K+E 10 X 10 TO 1/2 INCH 7 X 10 INCHES
KELPFEL & ECKER CO. MADE IN U.S.A.

<u>Step</u>	<u>Procedure</u>	<u>Example Application</u>
7	Add ΔP (Step 6) to the relief valve setpoint (Step 1) to obtain maximum transient pressure, P_{MAX} . If $P_{MAX} <$ Appendix G limitation, selected relief valve setpoint is acceptable. If $P_{MAX} >$ Appendix G limitation, go to Step 8.	$P_{MAX} = 515 \text{ psia}$ (relief valve setpoint) plus 49 psi, or 564 psia. From Figure 4.2.5 at RCS temperature = 100°F, Appendix G pressure limit = 540 psig + 15, or 555 psia. Thus, $P_{MAX} >$ Appendix G limitation.
8	If $P_{MAX} >$ Appendix G limitation, selected relief valve setpoint is too high. Reduce setpoint and repeat Steps 5 through 7 until an acceptable setpoint is determined.	Reducing setpoint by 10 psi (564 psia - 555 psia) to 490 psig and repeating Steps 2 through 6 results in $\Delta P = 49.4$ psi and $P_{MAX} = 505 \text{ psia} + 49.4 = 554.4 \text{ psia}$. Since 554.5 psia < Appendix G limit, 490 psig is an acceptable setpoint.

FIGURE 4.2.5



4.2.2 Setpoint Overshoot Determination for Heat Input Transient


- Correlations of RCS setpoint pressure overshoot variation with RCS volume, steam generator overall UA and initial RCS temperature are presented in Figures 4.2.6, 4.2.7 and 4.2.8 for the following conditions:

Initial RCS Pressure = 300 psig
RCS/SG ΔT = 50°F
Relief Valve Setpoint = 500 psig
SG Heat Transfer Area = 58,000 ft²
 $6,000 \text{ ft}^3 \leq \text{RCS Volume} \leq 13,000 \text{ ft}^3$

FIGURE 4.2.6

EFFECT OF RCS VOLUME
ON PRESSURE OVERSHOOT

- RCS PUMP STARTUP IN 1 LOOP
- INITIAL PRESSURE = 300 PSIG
- RCS/SG ΔT = 50°F
- RELIEF VALVE SETPOINT = 500 PSIG



EFFECT OF STEAM GENERATOR UA ON
PRESSURE OVERSHOOT





FIGURE 4.2.8

EFFECT OF STEAM GENERATOR UA ON
PRESSURE OVERSHOOT

46 1320

K-E 10 X 10 TO 4 INCH 7 X 10 INCHES
KELVET & ESSER CO. MADE IN U.S.A.

- To determine the setpoint overshoot for a smaller steam generator heat transfer area and for an intermediate RCS volume, the following interpolation procedure is used. This procedure utilizes Figures 4.2.6, 4.2.7 and 4.2.8 directly without the introduction of linearization factors and associated conservatisms as for the mass input case.

The use of the procedure is described for the following example heat input parameters and the results of the sequential application of each step in the procedure to these parameters will be noted.

PARAMETERS FOR HEAT INPUT EXAMPLE

SG Heat Transfer Area	=	29,000 ft ²
RCS Volume	=	10,000 cu.ft.
Initial RCS Temperature	=	180°F
RCS/SG ΔT	=	50°F
Relief Valve Setpoint	=	500 psig

Applying the heat input procedure:

<u>Step</u>	<u>Procedure</u>	<u>Example Application</u>
1	For both the 6000 ft ³ and 13,000 ft ³ RCS volumes, obtain reference setpoint overshoots ΔP_{6K} and ΔP_{13K} from Figure 4.2.9 for the initial RCS temperature, T_{RCS} .	For $T_{RCS} = 180^\circ F$, $\Delta P_{6K} = 98 \text{ psi}$ and $\Delta P_{13K} = 68 \text{ psi}$ for RCS volumes of 6 _K and 13 _K , respectively.
2	Using both Figures 4.2.10 and 4.2.11, determine the reference normalized UA (UA_{6K} and UA_{13K}) for both RCS volumes using ΔP_{6K} and ΔP_{13K} determined in Step 1 and for the isotherm, T_{RCS} .	For $T_{RCS} = 180^\circ F$ and $\Delta P = 98 \text{ psi}$, $UA_{6K} = 0.115$ (Figure 4.2.10). For $T_{RCS} = 180^\circ F$ and $\Delta P_{13K} = 68 \text{ psi}$, $UA_{13K} = 0.184$ (Figure 4.2.11).
3	Determine what fraction, f , of 58,000 ft ² constitutes the actual steam generator heat transfer area.	$29,000 \text{ ft}^2 / 58,000 \text{ ft}^2 = 0.5$
4	Multiply both UA_{6K} and UA_{13K} (from Step 2) by f (from Step 3) to obtain new normalized UA'_{6K} and UA'_{13K} values.	$UA'_{6K} = 0.115 * 0.5 = 0.0575$ and $UA'_{13K} = 0.184 * 0.5 = 0.092$

[†] Setpoint Overshoot, $\Delta P = P_{MAX} - P_{SETPOINT}$

EFFECT OF RCS VOLUME
ON PRESSURE OVERSHOOT

- RCS PUMP STARTUP IN 1 LOOP
- INITIAL PRESSURE = 300 PSIG
- RCS/SG ΔT = 50°F
- RELIEF VALVE SETPOINT = 500 PSIG

FIGURE 4.2.9

MC 1223-03-00






FIGURE 4.2.10



MC 1223-03-00

FIGURE 4.2.11

EFFECT OF STEAM GENERATOR UA ON
PRESSURE OVERSHOOT



<u>Step</u>	<u>Procedure</u>	<u>Example Application</u>
5	For the same isotherm, T_{RCS} , and for UA'_{6K} and UA'_{13K} , obtain new setpoint overshoots $\Delta P'_{6K}$ and $\Delta P'_{13K}$ for the 6000 ft ³ and 13,000 ft ³ volumes.	From Figure 4.2.12, for $T_{RCS} = 180^{\circ}\text{F}$ and $UA'_{6K} = 0.0575$, $\Delta P'_{6K} = \underline{44 \text{ psi}}$. From Figure 4.2.13, for $T_{RCS} = 180^{\circ}\text{F}$ and $UA'_{13K} = 0.052$, $\Delta P'_{13K} = \underline{35 \text{ psi}}$
6	For the actual volume, V_{RCS} , linearly interpolate the set-point overshoot, $\Delta P'_{VRCS}$, for the new steam generator UA from the relationship:	For $V_{RCS} = 10,000 \text{ cu.ft.}$, $\Delta P'_{6K} = 44 \text{ psi}$ and $\Delta P'_{13K} = 35 \text{ psi}$,

$$\Delta P'_{VRCS} =$$

$$\Delta P'_{10K} =$$

$$\Delta P'_{6K} - \frac{V_{RCS} - 6000}{7000} (\Delta P'_{6K} - \Delta P'_{13K})$$

$$44 - \frac{10,000 - 6000}{7000} (44 - 35)$$

$$= \underline{39 \text{ psi}}$$

This P'_{VRCS} is the overshoot corresponding to the actual steam generator heat transfer area and RCS volume.





FIGURE 4.2.13



4.3 DEVELOPMENT OF INTERPOLATING MASS INPUT EQUATION

The following, simplified equation is utilized for determining mass input setpoint overshoot for a specific set of plant input parameters from the generic data.

$$\Delta P(V, S, Z, x) = \Delta P_{REF}(x) * F_V * F_S * F_Z \quad (1)$$

where:

- $\Delta P(V, S, Z, x)$ = setpoint overshoot, psi
 V = total RCS volume, cu.ft.
 S = relief valve setpoint, psig
 Z = relief valve opening time, seconds
 x = mass input rate, lb/seconds
 $\Delta P_{REF}(x)$ = reference overshoot at mass input rate x , psi
 F_V = RCS volume factor
 F_S = relief valve setpoint factor
 F_Z = relief valve opening time factor

Equation (1) involves obtaining a product of a reference overshoot ΔP_{REF} , and three application factors which account for variation in the ΔP_{REF} from reference values of RCS volume, relief valve setpoint and relief valve opening time. Linearizations involved in the development of Equation (1) will necessarily introduce some degree of conservatism in the pressure overshoot and in the determination of relief valve setpoint.

4.3.1 Analytical Basis

Development of Equation (1), and, more specifically, the development of the three application factors is based on an elementary, linear, algebraic equation involving one dependent and one independent variable, or

$$f(x) = ax + b \quad (2)$$

If this linear function is defined to pass through the origin of the coordinate system, and if $f(x)$ takes on the constant value c for a specific, reference value of $x = x_r$, then

$$\begin{aligned} f(x_r) &= c \\ b &= 0 \\ a &= c/x_r \end{aligned}$$

and Equation (2) becomes

$$f(x) = \left(\frac{c}{x_r}\right)x \quad (3)$$

Now consider two linear functions of x , $f_1(x)$ and $f_2(x)$, both passing through the origin of the coordinate system, with

$$f_1(x_r) = c_1 \quad (4)$$

$$f_2(x_r) = c_2 \quad (5)$$

These functions may be written as

$$f_1(x) = \left(\frac{c_1}{x_r}\right) x \quad (6)$$

and

$$f_2(x) = \left(\frac{c_2}{x_r}\right) x \quad (7)$$

Both functions f_1 and f_2 are graphically depicted in Figure 4.3.1. In solving Equations (6) and (7) simultaneously, the equation for one linear equation may be obtained in terms of the second equation by multiplying the second equation by the ratio of $c(x_r)$ values for the two functions, or

$$f_2(x) = f_1(x) * \frac{c_2}{c_1} \quad (8)$$

This analytic technique for the determination of one linear function from a known second linear function through the use of a multiplication factor is extended to the development of interpolative factors for the generic mass input study.

4.3.2 Development of Application Factors

1. F_V - RCS Volume Factor

Consider the setpoint overshoot-mass input rate correlation shown in Figure 4.3.2 for $V_{RCS} = 6000$ (6K) ft^3 and relief valve setpoint = 600 psig. If this curve is linearized from the point (ΔP , mass rate) = (155 psi, 113 lb/sec) through the origin (0 psi, 0 lb/sec), the resultant linear function as shown in Figure 4.3.3 exhibits the same characteristics as the linear analytic function $f_1(x)$ described earlier, namely




FIGURE 4.3.1



EFFECT OF MASS INPUT RATE
ON PRESSURE OVERSHOOTRCS VOLUME = 6000 CU.FT.
600 PSIG RELIEF VALVE OPENING SETPOINT

FIGURE 4.3.3



46 1320

K-E 10 X 10 TO .25 INCH 7 X 10 INCHES
KELVINER & ESSER CO. MADE IN U.S.A.

$$f_1(x) = \Delta P_{6K/600}(x) = \left(\frac{c_1}{x_r}\right) x \quad (9)$$

where:

$$\begin{aligned} \Delta P_{6K/600}(x) &= \text{linearized reference setpoint overshoot, psi} \\ x &= \text{mass input rate, lb/sec} \\ x_r &= \text{reference mass input rate, lb/sec} \\ c_1 &= \Delta P_{6K/600}(x_r), \text{ psi} \end{aligned}$$

For the reference conditions of 6000 ft³ RCS volume and 600 psig relief valve setpoint, Equation (9) may be written

$$\Delta P_{6K/600}(x) = \left(\frac{155 \text{ psi}}{113 \text{ lb/sec}}\right) x = \Delta P_{\text{REF}}(x) \quad (10)$$

Further, assume that the setpoint overshoot for the same 600 psig setpoint but for a 13,000 ft³ RCS volume, or $\Delta P_{13K/600}$, may also be represented by a second linear function (Figure 4.3.4), namely,

$$f_2(x) = \Delta P_{13K/600}(x) = \left(\frac{c_2}{x_r}\right) x \quad (11)$$

where:


$$\begin{aligned} \Delta P_{13K/600} &= \text{linearized setpoint overshoot for the second linear function, psi} \\ c_2 &= \Delta P_{13K/600}(x_r), \text{ psi} \end{aligned}$$

For V = 13,000 ft³ (and S = 600 psig), Equation (11) may be written:

$$\Delta P_{13K/600}(x) = \left(\frac{75 \text{ psi}}{113 \text{ lb/sec}}\right) x \quad (12)$$

MASS INPUT
Linearized Setpoint Overshoot
RCS Volume Variation

7 J 4.3.4
FIGURE 4.3.4



where:

$$c_2 = \Delta P_{13K/600} \text{ (113 lb/sec)} = 75 \text{ psi}$$

From Equation (8), Equations (10) and (12) may be combined to give the setpoint overshoot for a $13,000 \text{ ft}^3$ RCS volume in terms of an overshoot determined for the reference 6000 ft^3 volume, and a ratio of overshoots (c_2/c_1) determined at the reference mass input rate, or $x_r = 113 \text{ lb/sec}$. This relationship, for which setpoint remains unchanged at 600 psig, may be written

$$\begin{aligned}\Delta P_{13K/600}(x) &= \Delta P_{6K/600}(x) * \frac{c_2}{c_1} \\ &= \Delta P_{\text{REF}}(x) * \frac{75}{155} \\ &= 0.484 \Delta P_{\text{REF}}(x)\end{aligned}\quad (13)$$

For RCS volumes intermediate to 6000 ft^3 and $13,000 \text{ ft}^3$, values of c_2 will vary between


$$75 \text{ psi} \leq c_2 \leq 155 \text{ psi}$$

and the c_2/c_1 ratio will vary between

$$0.484 \leq c_2/c_1 \leq 1.00$$

If the c_2/c_1 ratio is set equal to F_V , the RCS volume application factor, its variation with RCS volume would be as shown in Figure 4.3.5, and the setpoint overshoot at 600 psig relief valve setpoint for any $6000 \text{ ft}^3 \leq V \leq 13,000 \text{ ft}^3$ would be obtained from the relationship

FIGURE 4.3.5



MC 1223.03-00

$$\Delta P_{V/600}(x) = \Delta P_{REF}(x) * F_V \quad (14)$$

where:

$\Delta P_{V/600}(x)$ = setpoint overshoot at mass input rate x for RCS volume V and $S = 600$ psig, psi


$\Delta P_{REF}(x)$ = reference setpoint overshoot at x (6K/600)

F_V = RCS volume factor

2. F_S - Relief Valve Setpoint Factor

Just as the $\Delta P_{6K/600}(x)$ and $\Delta P_{13K/600}(x)$ functions were linearized in Figure 4.3.4 for a change in RCS volume from $6K \text{ ft}^3$ to $13K \text{ ft}^3$, linear correlations for setpoint variations from 600 psig to 400 psig can be drawn as shown in Figure 4.3.6. Further, just as Equation (8) was utilized to relate one linear function to another for RCS volume variation from $6K \text{ ft}^3$ to $13K \text{ ft}^3$, it may also be applied to the situation where setpoint is varied. In this case, to obtain the setpoint overshoot ΔP at 400 psig for a 6000 ft^3 plant knowing ΔP at 600 psig, Equation (8) is utilized to obtain

$$\begin{aligned}\Delta P_{6K/400}(x) &= \Delta P_{REF}(x) * \frac{c_2 S}{c_1} \\ &= \Delta P_{6K/600}(x) * \left(\frac{192}{155}\right) \\ &= 1.25 \Delta P_{6K/600}(x)\end{aligned} \quad (15)$$



For a RCS volume of 13K ft³, this relationship (for a set-point change from 600 psig to 400 psig) would be

$$\begin{aligned}\Delta P_{13K/400}(x) &= \Delta P_{13K/600}(x) * \left(\frac{95}{75}\right) \\ &= 1.27 \Delta P_{13K/600}(x)\end{aligned}\quad (16)$$

To ensure a conservative determination of setpoint overshoot for a setpoint variation at any RCS volume, the maximum coefficient (1.27) in Equations (15) and (16) is utilized in the development of the application factor for the generalized correlation for setpoint variation. In this correlation, for any relief valve setpoint between 400 psig and 600 psig, the setpoint overshoot for RCS volume V from Equation (15) is given by

$$\Delta P_{V/S}(x) = \Delta P_{V/600}(x) * F_S \quad (17)$$


where:

F_S = relief valve setpoint factor as defined in Figure 4.3.7

S = relief valve setpoint 400 psig $\leq S \leq$ 600 psig

Incorporating the volume variation effect from Equation (14), Equation (17) becomes

$$\begin{aligned}\Delta P_{V/S}(x) &= \Delta P_{V/600}(x) * F_S \\ &= \Delta P_{REF}(x) * F_V * F_S\end{aligned}\quad (18)$$



To this point in the development, the effects of relief valve setpoint and RCS volume variations on setpoint overshoot have been accounted for in Equation (18). The effect of relief valve opening time remains to be considered.


3. F_Z - Relief Valve Opening Time Factor


Figure 4.3.8 describes the variation in setpoint overshoot ΔP with relief valve opening time, which includes a time delay (for air accumulation prior to valve stem motion) equal to 20% of the total opening time. Correlations are presented for 400 psig and 600 psig relief valve setpoints at RCS volumes equal to 6000 ft^3 and $13,000 \text{ ft}^3$.

To facilitate the determination of setpoint overshoot with variation in valve opening time, each correlation in Figure 4.3.8 was linearized by drawing a line, tangent to each curve at the reference condition (relief valve opening time = 3 seconds), and intersecting the abscissa at a point to the left of the origin.

Figure 4.3.9 illustrates this procedure for the reference case (600 psig setpoint, 6000 ft^3 RCS volume). If the new origin defined by the linear approximation is designated as O' , and the displacement of the origin as $\Delta Z'$, then the coordinate system for the linear functions will have a new abscissa, Z , defined in terms of the original abscissa Z' (where: $0 \text{ seconds} \leq Z' \leq 3 \text{ seconds}$) and the displacement $\Delta Z'$, or

$$Z = Z' + \Delta Z' \quad (19)$$





For any relief valve opening time, Z' , therefore, the setpoint overshoot ΔP may be obtained from the linear relationship

$$\Delta P_{V/S} (x, Z') = \left(\frac{Z' + \Delta Z'}{3 + \Delta Z'} \right) * \Delta P_{V/S} (x) \quad (20)$$

$$= F_Z * \Delta P_{V/S} (x) \quad (21)$$

The F_Z factor was optimized from a linearization of all the correlations in Figure 4.3.9. It was determined that both setpoint parametrics for 6000 ft³ RCS volume produced the largest abscissa displacement ($\Delta Z' = 0.75$ seconds). This displacement maximizes the F_Z factor to ensure a conservative setpoint overshoot. A plot of the F_Z factor with valve opening time, Z' , is shown in Figure 4.3.10. It should be noted that conservatism in overshoot determination increases as the relief valve opening time is reduced from the 3 second reference value.

By way of illustration of the use of the F_Z factor, consider a relief valve opening time of 2.0 seconds. The reference setpoint overshoot ΔP_{REF} ($= \Delta P_{6K/600}$) would be determined as follows. From Figure 4.3.10, for $Z' = 2.0$ seconds,


$$F_Z = 0.73$$

from Equation (21).

WC 1223-03-00 4-3-10

Mass Input
 F_Z - Relief Valve
Opening Time Factor

FIGURE 4.3.10



$$\Delta P_{6K/600} (x, Z' = 2.0) = 0.73 * \Delta P_{REF} (x)$$

$$= 0.73 * 155 \text{ psi}$$

$$= 113 \text{ psi}$$

This compares almost exactly with the setpoint overshoot given in Figure 4.3.8. For smaller valve opening times, use of Equation (21) will give progressively more conservative values of overshoot.

Incorporating the effect of relief valve opening time as given by Equation (21) into the expression (Equation 18) which reflects the effect of relief valve setpoint and RCS volume interpolation, the following expression is derived:

$$\Delta P_{V/S} (x, Z') = \Delta P_{V/S} (x) * F_Z$$

$$= \Delta P_{REF} (x) * F_V * F_S * F_Z$$

or

$$\Delta P (V, S, Z, x) = \Delta P_{REF} (x) * F_V * F_S * F_Z$$

which is the simplified interpolating equation (Equation 1) used in the algorithm for setpoint determination for the mass input transient.

SECTION 5 CONSERVATISMS IN STUDY

The analyses presented in this report were conducted such that certain parameters provided a degree of conservatism in the peak pressure reached during a transient. By selecting more realistic values of the parameters, the peak pressure would be reduced. This section describes the use of five particular items, each of which resulted in a conservatively high calculated value of the peak transient pressure.

5.1 RELIEF VALVE STROKE TIME


The reference relief valve selected for use in this study was considered to have a total opening time of 3.0 seconds from the instant the signal to open is received until the valve reaches the full open position. Many of the pressurizer power operated relief valves have been found by experience to act in less than 3 seconds.

To evaluate the effect of a decrease in the stroke time, a calculation was made for the particular case of mass input from the reference SI pump into a small 6000 cu.ft. volume system, for two values of valve stroke time. The first time was the reference stroke time of 2.4 seconds (that is, no delay time to fill the air system) in which the overshoot above the setpoint was found to be 80 psi. When the stroke time was reduced from 2.4 to 1.5 seconds, the overshoot was reduced to about 62 psi. Extrapolating the data to a value of zero overshoot, corresponding to a valve that opens instantaneously, the relationship shown on Figure 5.1 is obtained. This figure indicates the sensitivity of the setpoint overshoot to the time to stroke the valve and the advantage provided by the faster valves.

The effect of the stroke time on pressure overshoot for two valves is also shown on Figure 5.1.

EFFECT OF RELIEF VALVE
OPENING TIME ON RCS
PRESSURE OVERSHOOT

- LINEAR RELIEF VALVE
- NO TIME DELAY
- RELIEF VALVE SETPOINT = 600 PSIG
- INITIAL RCS PRESSURE = 50 PSIG
- RCS VOLUME = 6000 CU.FT.



5.2 EFFECT OF METAL EXPANSION

The coolant pressure transients for all cases presented in this study were computed assuming that the coolant was enclosed by a rigid, non-yielding boundary and that the pressure change was a direct result of the inability of the coolant to expand into a larger volume. In reality, the pressure boundary is elastic, and for each increase in coolant pressure, there is a finite increase in system volume which will tend to mitigate the coolant pressure response.

To evaluate the significance of the pressure boundary elasticity effect, an estimate was made of the unit change in system volume for a particular change in internal system pressure. Only the simple geometric shapes of cylinders and hemispheres were utilized in the delta volume calculation and the other portions of the pressure boundary; reactor vessel upper head and nozzle course, pump casing, steam generator inlet and outlet plenums and miscellaneous connecting piping were assumed to be inelastic.

Table 5.2 summarizes the results of the calculation to determine the change in volume, for a coolant pressure change of 1000 psi, of each major portion of the reactor coolant system. The first two columns indicate the total coolant volume enclosed in the elastic section under consideration and the second two columns indicate the change in volume (cu.ft.) of each of the sections under a 1000 psi internal pressure. The last two columns are listed to show which sections contribute the greatest percentage of the total volume change.


Table 5.2 indicates that for a volume typical of a 2 loop plant, the total volume will increase about 3 cu.ft. for a 1000 psi pressure change. To evaluate the effect of this increased volume, the mass input case with the reference SI pump was recomputed by considering that a portion of the mass input supplied by the pump is used to fill and pressurize the additional volume made available by the metal expansion. For the particular case evaluated, i.e., the reference SI pump and 6000 cu.ft. volume plant, it was determined that only about 83% of the pump flow was effective in increasing the coolant pressure and the remaining flow would be used to fill and pressurize the expansion volume.

Figure 5.2 describes the reduction in the peak pressure reached in the cycle when the pressure boundary expansion is taken into consideration. The figure shows the pressure overshoot above the setpoint calculated for the inelastic case is at least 35% higher than the realistic pressure overshoot for the actual elastic system. A similar significant degree of conservatism is inherent in all analyses presented in this study.

The pressure boundary would also change dimensions if the temperature of the metal were changed during the transients. For the mass input cases, the system was assumed to be isothermal at 100°F so for these cases there would be no dimensional change. However, in the heat input cases the reactor coolant did increase in temperature due to the heat transferred from the steam generators but at such a rapid rate that the massive metal parts of the reactor coolant system could not be changed in temperature during the short term transients considered. Therefore, the temperature effect on metal expansion was not included in this study.

TABLE 5.2
RCS VOLUME
SUMMARY

	Total, ft ³		$\Delta V/1000 \text{ psi}$		$\%$	
	<u>4 Loop</u>	<u>2 Loop</u>	<u>4 Loop</u>	<u>2 Loop</u>	<u>4 Loop</u>	<u>2 Loop</u>
REACTOR VESSEL (lower shell and head)	3775	2089	2.37	1.32	42.0	43.9
PRESSURIZER	1800	1000	1.34	0.73	23.8	24.2
STEAM GENERATOR (tubes only)	3065	1532	1.44	0.72	25.6	23.9
PIPING (equivalent 29" ID)	1225	612	0.48	0.24	8.5	8.0
	Σ		5.63	3.01		



5.3 EFFECT OF REACTOR COOLANT AND INJECTION WATER TEMPERATURES - MASS INPUT CASES

All of the mass input transients evaluated considered the reactor coolant to be isothermal at a temperature of 100°F (except the pressurizer, see Section 6.1) during the period of injection. At this low temperature, the bulk modulus of the water is at its maximum value (least compressible), which results in the greatest unit pressure change for any given unit volume change and hence the most severe transient. If the injection water temperature is equal to the coolant temperature and the uniform temperature of the coolant is about 210°F at the time of the mass injection, the bulk modulus would be about 8% lower and consequently the unit pressure change for a given volume addition would be 8% less. At higher coolant temperatures the compressibility increases markedly, and, hence, the mass input transients become less severe as the temperature is increased.

A second effect of a higher initial coolant temperature which also was not included in the mass input cases is a shrinkage effect, which occurs when cold injection water mixes with the warmer reactor coolant. The effect of mixing a volume of cold water with a volume of hot water is a net shrinkage of the total fluid volume, and if the mixture is compressed in a fixed volume, the result will be a reduction in the compression pressure. No credit was taken in any of the mass input analyses for this shrinkage effect.

5.4 EFFECT OF STEAM GENERATOR MASS AND OVERALL HEAT TRANSFER COEFFICIENT - HEAT INPUT CASES

Two parameters which directly influence the transfer of heat from the hotter steam generator secondary to the colder reactor coolant are the heat source provided by the water mass contained in the steam generator secondary side, and the rate of heat transfer across the steam generator tubes as determined by the overall heat transfer coefficient.

The quantity of heat available for heat transfer to the reactor coolant is dependent on the mass of water in the steam generator secondary and its temperature. In the LOFTRAN program, the entire steam generator secondary water mass is considered to be active in the heat transfer process. Since it is unlikely that free convection circulation will occur between the steam generator secondary mass in the tube bundle and the warmer mass above it or with the water in the downcomer region, the use of the steam generator secondary tube bundle mass alone would constitute a reasonable representation of the heat source in LOFTRAN. In all of the heat input analyses, however, the entire steam generator secondary water mass of 215,000 lb. was input for the heat input study. This large mass provided a degree of conservatism in the setpoint overshoot data obtained.

The free convective secondary side heat transfer coefficient, h_{sec} , can be shown to control the primary to secondary heat transfer. Depending on the magnitude of the reactor coolant flow rate (which determines the primary side heat transfer coefficient, h_{pri}) at any time following the pump startup, the heat transfer resistance due to h_{sec} can constitute up to 90 percent of the total resistance. For this reason, the overall heat transfer coefficient, U , used in the heat input LOFTRAN model was

assumed to be equal to h_{sec} . This assumption also provides conservatism in the heat input analyses since it ignores the added resistance to heat transfer of the primary side film and the tube wall.


An assessment was made of the effect of the steam generator mass and overall heat transfer coefficient conservatisms on the calculated set-point overshoot. The conservative and more realistic (less-conservative) LOFTRAN heat input models used for the assessment utilized the following assumptions in their input development.

Parameter	LOFTRAN Model	
	Conservative	Realistic
Steam Generator Secondary Water Mass, lb	Entire mass corresponding to no-load steam generator water level	Mass corresponding to tube bundle coverage only
U, Overall Heat Transfer Coefficient, BTU/hr ft ² °F	Equal to h_{sec} only	Includes h_{pri} , h_{sec} and tube wall conductivity

Results obtained with these two models are shown in Figure 5.4 in the form of setpoint overshoot versus time after the relief valve starts to open. These results demonstrate that removal of the secondary water mass and heat transfer conservatisms used in the heat input analysis could result in a reduction in setpoint overshoot of as much as 48% (335 psi to 175 psi) for the particular case of a pump startup in one loop of a two loop, 6000 ft³ plant with a RCS/SG temperature difference equal to 100°F and initial RCS temperature equal to 180°F.

It should be noted that this dramatic reduction in overshoot is based partly on consideration of a heat transfer model for which only a very low flow of reactor coolant through the steam generator tubes was assumed, resulting in a significant h_{pri} contribution. The magnitude of coolant flow, which will be in effect to influence h_{pri} and heat transfer at any time following pump startup, is a function of the pump startup transient. If a flow startup transient is very slow, the assumption of low flow during the pressure transient would be valid and the setpoint overshoot response shown for the less conservative model in Figure 5.4 would be realistic.

FIGURE 5.4



5.5 EFFECT OF REACTOR COOLANT PUMP STARTUP TIME - HEAT INPUT CASES

The rate of heat transferred from the steam generator to the reactor coolant, and consequently, the rate of coolant pressure change and set-point overshoot obtained for the heat input analyses, is dependent on the quantity of colder reactor coolant exposed to the hotter steam generator secondary heat source at any particular moment. The rate at which the colder coolant displaces the hot coolant in the steam generator tubes is directly related to the rate at which the coolant flow rate increases with pump startup.

For the Westinghouse Model 93A pump startup, the LOFTRAN program calculates that full loop flow occurs in approximately 9 to 10 seconds, based on internal calculations performed using default homologous pump data provided in the program. This rate is faster than the startup rate normally considered as representative of the 93A pump.

All of the pressure transients and corresponding setpoint overshoots obtained with the LOFTRAN program for the heat input studies reflect this flow startup conservatism.

SECTION 6
OTHER CONSIDERATIONS

6.1 EFFECT OF PRESSURIZER WATER TEMPERATURE

In a water solid reactor coolant system, the compressibility of the coolant is related to its temperature. For the mass input studies, the analyses were to be performed for an isothermal coolant temperature equal to 100°F. However, for LOFTRAN to maintain a prescribed initial coolant pressure, P_0 , the pressurizer must be maintained at the saturation temperature, T_{sat} , corresponding to P_0 . In the analyses, T_{sat} for the range of P_0 considered (50 psig to 450 psig) varies between approximately 300°F and 460°F, which is several times higher than the isothermal (100°F) temperature required. Thus, the pressurizer water volume at $T_{sat} > 100^\circ\text{F}$ introduces into the model additional compressibility, which would reduce the setpoint pressure overshoot for the mass input transient.


The amount of overshoot defect is dependent on the volume of the warmer compressible mass, i.e., pressurizer water volume. Figure 6.1 illustrates this effect. From this figure, a reduction in hot (approximately 300°F) pressurizer water volume from 1021 ft³ (pressurizer volume plus surge line volume for the 6000 ft³ volume, 2 loop LOFTRAN model) to 100 ft³ produces a corresponding increase in setpoint overshoot of 22 psi (133 psi to 155 psi), or about 15 percent. Further reduction in pressurizer volume from 100 ft³ to 10 ft³ produces an increase in overshoot of only 3 psi (155 psi to 158 psi), or less than 2 percent.

To avoid problems with internal LOFTRAN computations associated with the use of a very small pressurizer, and since the 100 ft³ model produces only a negligible compressibility effect, the 100 ft³ pressurizer water volume was selected for use throughout the mass input and heat input analyses.

1223-03-00

FIGURE 6.1

COMPRESSIBILITY EFFECT OF
PRESSURIZER WATER VOLUME



6.2 EFFECT OF BACKPRESSURE ON RELIEF VALVE

The reference relief valve was considered to discharge into the pressurizer relief tank against a small backpressure caused by the nitrogen pressure in the tank. Normally this gas pressure will be less than 5 psig, but for this study the backpressure was considered to be 10 psig, which is above the typical high pressure alarm.

As the relief valve discharges into the relief tank, the nitrogen gas and vapor enclosed in the tank will be compressed as the water level in the tank rises. A continuous discharge into the tank will ultimately increase the gas pressure to 100 psig at which time the safety head (rupture disk) will open and the gas will be released to the containment. Therefore, the maximum static backpressure on the relief valve will be 100 psig.

The expected discharge flow rate from the reference relief valve is relatively small for the size of the discharge lines and relief tank when compared to the design flow rate from the pressurizer safety valves. Therefore, the dynamic backpressure on the reference relief valve is negligible.

To evaluate the effect of the change in static backpressure on the valve, a comparison was made between the setpoint pressure overshoot for the case of an extremely high mass input into a small system volume (limiting mass input case) with both a 10 psig and 100 psig backpressure.

For the first relief valve lift cycle, the peak pressure due to an overshoot of 154 psi above the 600 psig setpoint was found to be 754 psig. Then if the injection into the reactor coolant system continues, the backpressure will increase with each subsequent relief valve lift

cycle, reaching a maximum of 100 psig. With the 100 psig backpressure, the flow rate through the valve will be slightly decreased (see Figure 2.2.1) and the consequent pressure overshoot will increase to 159 psi above the setpoint, resulting in a peak pressure of 759 psig. Subsequent relief valve cycles after the relief tank has vented through the rupture disk will result in lower peak pressures.

If the reference case described above is considered to be typical of a 2 loop plant with a relief tank having a nominal volume of 800 cu.ft. and an initial gas volume of 172 cu.ft., the reference SI pump would cause the tank to fill and pressurize in about 1-1/2 minutes. Therefore, it is concluded that, for this example limiting mass input case, the relief valve first will cycle 8 to 10 times with the peak pressure for each subsequent cycle being perhaps 0.5 psi greater than for the previous cycle. Then, after the rupture disk opens, the backpressure will be removed and the subsequent pressure cycles will be similar to the first valve lift cycle.

6.3 CAPACITY OF MULTIPLE RELIEF VALVES


The analyses presented in this study considered the use of a single air-operated relief valve, i.e., the reference relief valve, to limit the pressure transients. In all cases, the single reference valve was capable of mitigating the transient since its capacity when full open was greater than any of the mass input rates.

To evaluate the effect of a change in relief valve capacity, a few cases were studied in which the relieving capacity was doubled by considering two reference relief valves in service. The results are shown in Figure 6.3.1 for two particular cases of mass input. With the expected rates of mass input from the charging/letdown flow mismatch case, the effect of the increased capacity on setpoint overshoot is insignificant; but there is a substantial effect on the rate of pressure decrease while the valves are relieving, which is primarily due to the slow closing time used in the analysis. It can be concluded that the capacity of two valves is much greater than required, and, coupled with the slow closing times, could be undesirable under certain circumstances.

For the case of a large mass input into a small reactor coolant volume, as described by the reference SI pump case shown in Figures 6.3.1 and 6.3.2, the doubled capacity provided by the second relief valve does cause the pressure transient to be mitigated earlier and results in a 23% decrease in the pressure overshoot, i.e., from about 155 to 119 psi. However, since the pressure increase is terminated by one valve, it can be concluded that one reference relief valve has ample capacity to mitigate this severe transient and, hence, the additional capacity, such as provided by a second valve, is not required.

The results of a typical study of the effects of multiple valves for a severe heat input case are shown in Figure 6.3.3. This figure also shows that, as a result of doubling the relief capacity, the pressure transient is mitigated earlier and that the pressure overshoot is reduced, e.g., for the 600 psig setpoint case the overshoot is decreased 21% from 140 to 111 psi. However, as in the case of the severe mass input case, the capacity of one reference relief valve was shown to be sufficient and additional capacity is not required.

FIGURE 6.3.1



MU 1 CCC U -

MC 1223-03-00 FIGURE 6.3.2

RCS PRESSURE TRANSIENT
FOR ONE CYCLE OF RELIEF
VALVE OPENING AND CLOSING

- INITIAL RCS PRESSURE = 50 PSIG
- RCS VOLUME = 6000 CU. FT.
- REFERENCE SI PUMP
- RELIEF VALVE SETPOINT = 600 psig





FIGURE 6.3.3

461510

K-E 10 X 10 TO THE CENTIMETER 19 X 35 CM.
KEUFFEL & SHERE CO. MADE IN U.S.A.



6.4 RELIEF VALVE CYCLING

The reference relief valve has a unique characteristic of operation in that its position is determined by an air pressure under a spring loaded diaphragm in the operator. When air is admitted or vented, the spring will be compressed or relaxed as the diaphragm moves. Air is controlled through a small solenoid valve which is positioned by an electric signal to either admit air into the valve operator or to vent the air from the operator to the atmosphere. If the solenoid is quickly signalled to change position (cycled), the air may not be capable of moving the diaphragm through a full valve stroke, i.e., the valve could theoretically float on a cushion of air.

In some of the analyses of this study it was found that the relief valve had excess capacity such that the relief valve did not reach the full open position before it was signalled to close. For these cases, the valve actually floated on the motive air as it stroked partly open and then returned to the closed position in preparation for another stroke.

The reference relief valve was considered to have a 3 second opening time, when stroked fully open, and either a 5 or 20 second closing time when stroked from fully open position. With the use of relatively short closing times, the valve will always return to the full closed position and all the air will be vented with each cycle; hence, the opening characteristic for each subsequent cycle will include the conservative time delay of 0.6 seconds before the valve starts to open again.

For the mass input cases, the relief valve was found to cycle open and closed to intermittently discharge the excess mass injected. The greater the rate of mass input the more rapid the valve cycling. As seen from Figure 6.4.1, for a typical case of a charging/letdown flow mismatch in the range of mass input of 40 to 120 gpm, the valve will cycle about every 17 seconds if the injection flow is about 120 gpm and every 42 seconds if the flow is 40 gpm. This valve cycling will continue until the operator intervenes to restore letdown or to stop the mass input. For an extreme case of a high mass input rate, as for example the reference SI pump injection at about 830 gpm, the relief valve would cycle open and closed every 8-1/2 seconds until the operator terminated the input.

The cycle time for the valve can be lengthened by slowing the rates at which the valve opens and closes but this would result in a larger pressure cycle. Figure 6.4.2 shows the effect of a longer closing time on a typical large mass input transient. For this example, the cycle time is almost doubled. However, since there is a minimum coolant pressure required to protect the reactor coolant pump seals from possible damage, it would not be acceptable to allow the pressure to decrease below about 300 psig. This is an economic consideration which must be included in the overall system design. Some plants, however, have closing times equivalent to the opening times (less than 3 seconds) and "undershoot" is not a problem.


Another consideration regarding relief valve cycling is the effect of two valves relieving simultaneously, which is a likely event. When the two valves are signalled to open, the effective capacity is double and neither valve has to lift as far for the pressure transient to be mitigated and the valves signalled to close. Figure 6.4.3 illustrates the

characteristics of the pressure response for both the credible charging/letdown flow mismatch case and the extreme mass injection case represented by the reference SI pump injection. As would be expected, the setpoint overshoot is reduced, but due to the high relief capacity during the valve closing period, the coolant pressure decreases markedly for the 2 valve case. For the charging flow case with these particular plant parameters, there would be a concern for the reactor coolant pump seals for relief valves with slow closure times and capacities greater than the reference valve. For those plants with valve closing times equal to opening times, the undershoot would be expected to be similar to the overshoot. Thus, the consideration of the pump seals would not be applicable.

FIGURE 6.4.1

EFFECT OF MASS INPUT RATE ON
CYCLIC PRESSURE RESPONSE

- INITIAL RCS PRESSURE = 50 PSIG
- RCS VOLUME = 6000 CU.FT.
- RELIEF VALVE SETPOINT = 600 PSIG



461510

K-E 10 X 10 TO THE CENTIMETER 15 X 25 CM.
KEUFFEL & ESSER CO. MADE IN U.S.A.

EFFECT OF RELIEF VALVE CLOSURE TIME

- INITIAL RCS PRESSURE = 450 PSIG
- RCS VOLUME = 6000 CU. FT.
- REFERENCE SI PUMP STARTUP
- 1 REFERENCE RELIEF VALVE





FIGURE 6.4.3



461510

K-E 10 X 10 TO THE CENTIMETER 10 X 25 CM.
KELUFFEL & ECKER CO. MADE IN U.S.A.

6.5 RELIEF VALVE CAPACITY CHANGE WITH FLASHING

The reference relief valve for this study is assumed to be located on the pressurizer (i.e., the power operated relief valve) and therefore the properties of the fluid released are those associated with the pressurizer. The analyses presented in this study are primarily based on past experience with operating PWR plants and an evaluation of the most likely conditions under which a relief valve actuation might be required. It was concluded that the cold shutdown, solid water mode of operation was the predominate one to study. However, during plant heatup and cool-down operations when the plant is being continuously monitored and carefully controlled manually by the several trained operators, there is a short period of time when the pressurizer is filled solid and its water temperature is at or near saturation for the particular reactor coolant pressure being maintained (350 to 450 psig). If the relief valve should lift at this time, there would be flashing of the fluid as it passed through the valve, with a consequent decrease in mass relief capacity.

To evaluate the effect of the reduced mass flow on a typical pressure transient, a reference SI pump mass input case was evaluated both with a cold pressurizer and with a relatively hot pressurizer. The cold pressurizer case is presented in other parts of the report and involves a pressurizer with a water temperature of 100°F (equal to reactor coolant temperature). For the hot pressurizer cases, the temperature of the water is considered to be at saturation for a pressure of either 415 psia (448°F) or 615 psia (489°F).

The mass flows of fluid through the relief valve for the saturated water flow cases were based on homogeneous, thermal-equilibrium, isentropic, expansion flow evaluated as follows:[†]

$$G = \frac{1}{v_c} \sqrt{2g_c J (h_o - h_c)}$$
$$= 1b/sec - ft^2$$

where h_o is the enthalpy at the upstream (saturated) condition and v_c and h_c are evaluated for the conditions at the exit plane.

The conditions of pressure and quality at the exit plane are found implicitly for each particular upstream condition and Figure 6.5.1 describes the mass flow through the valve at various upstream pressures for both the subcooled and saturated flow modes. As can be seen from the figure, the capacity of the valve for discharge of saturated flow is reduced to about 71% of the subcooled flow rate for the range of pressures between 350 and 450 psig.

From other parts of this study, the effect of changes in valve capacity can be estimated from the comparison between the transient pressure responses for a particular mass input case with either one (100% capacity) or two (200% capacity) reference relief valves. For this reference case, the pressure increases at about 125-135 psi/sec just prior to and for a short period after the relief valve reaches the setpoint. Therefore, there will be an overshoot of the setpoint of between 75 and 81 psi before the valve starts to relieve due to a 0.6 second time delay to fill the lines and valve operator with motive air.

[†] ANSI proposed standard N-661, Evaluation of Anticipated Transients Without Trip for Pressurized Water Reactors

From an inspection of the results of the pressure transients for the cases of one and two relief valves, it can be determined that the pressure overshoot during the time the valve(s) are relieving is 110 psi for one valve and 62 psi for two valves, both for a setpoint of 415 psia. By extrapolating the capacity of the valve at 200% and 100% to a value of 71% (for saturated flow), it is found the overshoot during the stroke time is 140 psi, giving a peak pressure of $415 + 81 + 140 = 636$ psia. This peak pressure is about 30 psi higher than that pressure reached with one relief valve relieving subcooled water flow. Figure 6.5.2 shows graphically the difference in overshoot for the case of flashing flow versus subcooled flow.

A similar comparison was made considering the pressurizer water was initially at a 615 psia saturated condition and again the difference between the flashing flow and the subcooled flow cases resulted in a difference in pressure overshoot of about 30 psi for the limiting mass input case and a relief valve setpoint of 615 psia (see Figure 6.5.3).

At lesser mass input rates relative to the system volume, the difference in pressure overshoot between a subcooled and a flashing flow case would be expected to be less than calculated for the above example. This conclusion can be reached because, at lesser mass input rates, the rate of change of coolant pressure is lower, and, hence, for any given valve stroke time, the pressure change during the stroke interval will be smaller. In the extreme, a zero rate of coolant pressure increase at the setpoint or an instantaneous opening time would theoretically result in a zero overshoot for all cases where the relief valve capacity exceeds the input flow rate.

The pressure transient versus time in the example case with a hot pressurizer is unrealistically conservative because it is based on the entire reactor coolant volume including the pressurizer being at a uniform cold temperature. A more realistic model would include a substantial volume of coolant (pressurizer volume) at a high temperature and, this less dense fluid being more compressible, consequently would be able to absorb some of the effect of the mass input similar to the action of an accumulator in a hydraulic system. (See Section 6.1 for additional discussion.) The result of the higher temperature pressurizer would be to slow the rate of the pressure transient and hence result in a lesser pressure overshoot.

K-E 10 X 10 TO THE CENTIMETER 18 X 25 CM
KEUFFEL & ESSER CO. MADE IN U.S.A.

461510

MC 1223-03-00

FIGURE 6.5.1






FIGURE 6.5.2

461510

K-E 10 X 10 TO THE CENTIMETER 18 X 25 CM
KEUFFEL & ESSER CO. NEW YORK U.S.A.





MC 1223·03-004

APPENDIX A

SUMMARY TABLES

APPENDIX A

SUMMARY TABLE - MASS INPUT RESULTS

RCS VOLUME = 6000 CU.FT.

A-2

INITIAL RCS PRESSURE (psig)	RELIEF VALVE	MASS INPUT MECHANISM	RESULTS	Appendix B Figure Number(s)							
				Appendix B Figure Number(s)							
50	50	600	1	L	3.0	0	SI	---	755	155	M18, M22, M26, M34, M4
50	50	600	1	L	3.0	0/C	SI	---	755	155	M9, M12, M28, M30, M32
50	50	600	2	L	3.0	0	SI	---	720	120	M26
50	50	600	2	L	3.0	0/C	SI	---	720	120	M12, M28
50	50	600	1	NL	3.0	0/C	SI	---	741	141	M30, M31, M32, M33
50	50	600	2	NL	3.0	0/C	SI	---	720	120	M32, M33
50	50	600	1	L	1.5	0	SI	---	635	35	M26
50	50	600	2	L	1.5	0	SI	---	635	35	M26
450	450	600	1	L	3.0	0	SI	---	751	151	M20, M24
450	450	600	2	L	3.0	0/C	SI	---	751	151	M29
450	450	500	3	L	3.0	0/C	SI	---	717	117	---
450	450	500	3	L	3.0	0	SI	---	667	167	M20, M25
500	500	500	2	L	3.0	0	SI	---	626	126	---

APPENDIX A
SUMMARY TABLE - MASS INPUT RESULTS

RCS VOLUME = 6000 CU.FT.

E-V

INITIAL RCS PRESSURE (psig)	RELIEF VALVE					MASS INPUT MECHANISM		RESULTS			
	Setpoint (psig)	Number of Valves	Linear (L) or Non-Linear (NL)	Max. Opening Time (sec)	Valve Opens (0) / Closes (C)	SI Pump SU (SI) or Charging/Letdown Isolation (C/LI)	CC Pump or PD Pump	Letdown Isolation At, sec	RCS P _{MAX} (psig)	P _{MAX} -P SETPOINT (psi)	Appendix B Figure Number(s)
50	400	1	L	3.0	0	SI	---	---	592	192	M18, M23, M27, M4
50	400	2	L	3.0	0	SI	---	---	544	144	M27
50	400	1	NL	3.0	O/C	SI	---	---	566	166	M31
50	400	2	NL	3.0	O/C	SI	---	---	543	143	M33
50	400	1	L	1.5	0	SI	---	---	485	85	M27
50	400	2	L	1.5	0	SI	---	---	449	49	M27
50	600	1	L	3.0	O/C	C/LI	CCP	2	610	10	M6, M9, M10
50	600	2	L	3.0	O/C	C/LI	CCP	2	610	10	M6, M10
50	600	1	L	3.0	0	C/LI	CCP	10	610	10	M8
50	600	1	L	3.0	O/C	C/LI	PDP	2	605	5	M7, M9
450	600	1	L	3.0	O/C	C/LI	CCP	2	610	10	M6
50	500	1	L	3.0	O/C	C/LI	PDP	2	505	5	M7
50	400	1	L	3.0	O/C	C/LI	CCP	2	405	5	M6
50	400	1	L	3.0	0	C/LI	CCP	10	410	10	M8

MC 1223-03-00

SUMMARY TABLE - MASS INPUT RESULTS
APPENDIX A

RCS VOLUME = 13,000 CU.FT.

RELIEF VALVE	MASS INPUT MECHANISM	RESULTS	INITIAL RCS PRESSURE (psig)	Appendix B Figure Number(s)									
			Setpoint (psig)	Number of Valves	Linear (L) or Non-Linear (NL)	Max. Opening Time (sec)	Valve Opens (O)/Closes (C)	SI Pump SU (SI) or Charging/Letdown Isolation (C/LI)	CC Pump or PD Pump	Letdown Isolation Δt, sec	RCS P _{MAX} (psig)	P _{MAX} -P _{SETPOINT} (psi)	
50	600	1	L	3.0	0	SI	--	675	75	M19, M22, M4			
50	600	2	L	3.0	0	SI	--	657	57	---			
50	600	1	NL	3.0	0	SI	--	667	67	---			
50	600	2	NL	3.0	0	SI	--	658	58	---			
50	600	1	1.5	1.5	0	SI	--	628	28	---			
50	600	2	1.5	1.5	0	SI	--	616	16	---			
450	600	1	3.0	3.0	0	SI	--	673	73	M21, M24			
450	600	2	3.0	3.0	0	SI	--	656	56	---			
450	500	1	3.0	3.0	0	SI	--	583	83	M21, M25			
450	500	2	3.0	3.0	0	SI	--	562	62	---			
400	400	1	3.0	3.0	0	SI	--	495	95	M19, M23, M4			
400	400	2	3.0	3.0	0	SI	--	470	70	---			
50	50	1	3.0	3.0	0	SI	--	480	80	---			

APPENDIX A
SUMMARY TABLE - MASS INPUT RESULTS

RCS VOLUME = 13,800 ~~cu ft~~

RELIEF VALVE	MASS INPUT MECHANISM	RESULTS		Appendix B Figure Number(s)
		RCS P _{MAX} (psig)	P _{MAX} -SETPOINT (psig)	
	Letdown Isolation At, sec	---	469	69
	CC Pump or PD Pump	---	440	40
	SI Pump SU (SI) or Charging/Letdown Isolation (C/LI)	---	422	22
	SI Pump SU (SI) or Charging/Letdown Isolation (C/LI)	---	605	5
	Valve Opens (O)/ Closes (C)	---	605	5
	Max. Opening Time (sec)	---	605	5
	Linear (L) or Non-Linear (NL)	---	605	5
	Number of Valves	---	605	5
	Setpoint (psig)	---	605	5
INITIAL RCS PRESSURE (psig)	50	400	2	NL
	50	400	1	L
	50	400	2	L
	50	600	1	L
	50	600	1	L
	50	600	1	L
	50	600	1	L
	50	400	1	L
	50	400	1	L
	50	400	1	L

APPENDIX A
SUMMARY TABLE - HEAT INPUT RESULTS

RCS VOLUME = 6000 CU.FT.

g-V	INITIAL SYSTEM TEMPERATURES (°F)			REFERENCE RELIEF VALVE	SG MODEL	RESULTS		
	ΔT	RCS	SG			Setpoint (psig)	Number	Appendix B Figure Number(s)
	20	180	200	500	C	515	15	H19
	50	100	150	500	C	531	31	H1, H4, H6
	50	140	190	500	C	562	62	H1, H4, H6
	50	180	230	500	C	598	98	H1, H4, H6, H19
	50	250	300	500	C	657	157	H1, H6
	100	100	200	600	C	745	145	H20, H22, H25
	100	100	200	600	C	710	110	H20
	100	100	200	600	LC	650	50	H22
	100	140	240	600	C	845	245	H23
	100	140	240	600	C	775	175	H23
	100	180	280	600	C	935	335	H24, H25, H27, H28, H36, H37
	100	180	280	600	C	825	225	H24
	100	180	280	600	LC	775	175	H27

APPENDIX A
SUMMARY TABLE - HEAT INPUT RESULTS

RCS VOLUME = 6000 CU.FT.

ΔT	INITIAL SYSTEM TEMPERATURES (°F)			REFERENCE RELIEF VALVE	SG MODEL	RESULTS				
	RCS	SG	Setpoint (psig)			Number	Conservative (C) or Less Conservative (LC)	RCS P _{MAX} (psig)	P _{MAX} -P _{SETPOINT} (psf)	Appendix B Figure Number(s)
100	100	200	500	1	C			640	140	H4, H20
100	100	200	500	2	C			610	110	H20
100	140	240	500	1	C			730	230	H4, H23
100	140	240	500	2	C			655	155	H23
100	180	280	500	1	C			780	280	H4, H24, H37
100	180	280	500	2	C			665	165	H24
100	100	200	400	1	C			540	140	H20, H21
100	100	200	400	2	C			510	110	H20
100	100	200	400	1	LC			460	60	H21
100	140	240	400	1	C			545	145	H23
100	140	240	400	2	C			485	85	H23
100	180	280	400	1	C			665	265	H24, H26, H37
100	180	280	400	2	C			515	115	H24
100	180	280	400	1	LC			547	147	H26

MC 1223-03-00

APPENDIX A
SUMMARY TABLE - HEAT INPUT RESULTS

RCS VOLUME = 13,000 CU.FT.

ΔT	INITIAL SYSTEM TEMPERATURES (°F)			REFERENCE RELIEF VALVE	SG MODEL	RESULTS		
	RCS	SG	Setpoint (psig)			RCS P _{MAX} (psig)	P _{MAX} -P _{SETPOINT} (psi)	Appendix B Figure Number(s)
50	100	150	500	1	C	527	27	H5
50	140	190	500	1	C	550	50	H5
50	180	230	500	1	C	569	69	H5
100	100	200	600	1	C	710	110	H29, H31
100	100	200	600	2	C	680	80	H29
100	100	200	600	1	LC	650	50	H31
100	140	240	600	1	C	775	175	H32
100	140	240	600	2	C	725	125	H32
100	180	280	600	1	C	908	308	H33, H36, H37
100	180	280	600	2	C	765	165	H33
100	180	280	600	1	LC	725	125	H34
100	100	200	500	1	C	608	108	H5, H29
100	100	200	500	2	C	575	75	H29

APPENDIX A
SUMMARY TABLE - HEAT INPUT RESULTS

RCS VOLUME = 13,000 CU.FT.

ΔT	INITIAL SYSTEM TEMPERATURES (°F)			REFERENCE RELIEF VALVE	SG MODEL	RESULTS			
	RCS	SG	Setpoint (psig)			Conservative (C) or Less Conservative (LC)	RCS P _{MAX} (psig)	P _{MAX} -P _{SETPOINT} (psf)	Appendix B Figure Number(s)
A-9	100	140	240	500	1	C	667	167	H5, H32
	100	140	240	500	2	C	615	115	H32
	100	180	280	500	1	C	855	355	H5, H33, H37
	100	180	280	500	2	C	650	150	H33
	100	100	200	400	1	C	495	95	H29, H30
	100	100	200	400	2	C	465	65	H29
	100	100	200	400	1	LC	435	35	H30
	100	140	240	400	1	C	577	177	H32
	100	140	240	400	2	C	490	90	H32
	100	180	280	400	1	C	793	393	H33, H37
	100	180	280	400	2	C	500	100	H33
	100	180	280	400	1	LC	505	105	H35

MC 1223-03-00

MC 1223·03-00

APPENDIX B

FIGURES

MASS INPUT

MU 1223-03-00
FIGURE M1

EFFECT OF MASS INPUT RATE
ON PRESSURE OVERSHOOT

600 PSIG RELIEF VALVE OPENING SETPOINT

46 1320

K+E 10 X 10 TO 14 INCH 7 X 10 INCHES,
KEUFFEL & ESSER CO. MADE IN U.S.A.

P_{MAX} - P_{SETPOINT}, PSI

200

100

0

RCS VOLUME, CU. FT.

6000

13000

100

200

MASS RATE, LB/SEC


FIGURE M2

EFFECT OF RELIEF VALVE
OPENING TIME ON RCS
PRESSURE OVERSHOOT

- LINEAR RELIEF VALVE
- NO TIME DELAY
- RELIEF VALVE SETPOINT = 600 PSIG
- INITIAL RCS PRESSURE = 50 PSIG
- RCS VOLUME = 6000 CU.FT.

461510

K+E 10 X 10 TO THE CENTIMETER 18 X 25 CM.
KEUFFEL & SHERE CO. NEW YORK U.S.A.



MC 1223-03-004

FIGURE M3

MASS INPUT

Reference Relief Valve
Stroke Time





FIGURE M4



461510

10 X 10 TO THE CENTIMETER 18 X 25 CM
MEUFFEL & ESSER CO. MADE IN U.S.A.

K-E

FIGURE M5

MASS INPUT TRANSIENTS

- INITIAL RCS PRESSURE = 450 PSIG
- RCS VOLUME = 6000 CU. FT.






FIGURE #6



RCS PRESSURE TRANSIENTS
FOR ONE CYCLE OF RELIEF
VALVE OPENING AND CLOSING
FOR 2 SEC. LETDOWN ISOLATION

FIGURE M6
REVISED



RCS PRESSURE TRANSIENT
FOR ONE CYCLE OF RELIEF
VALVE OPENING AND CLOSING

- CONSTANT MASS INPUT RATE OF 40 GPM
- 2 SEC. LETDOWN ISOLATION

- INITIAL RCS PRESSURE = 50 PSIG
- RCS VOLUME = 6000 CU. FT.






FIGURE M7
REVISED

RCS PRESSURE TRANSIENT
FOR ONE CYCLE OF RELIEF
VALVE OPENING AND CLOSING

- CONSTANT MASS INPUT RATE OF 40 GPM
- 2 SEC. LETDOWN ISOLATION

- INITIAL RCS PRESSURE = 50 PSIG
- RCS VOLUME = 6000 CU. FT.





46 1320

K-E 10 X 10 TO 1/4 INCH 7 X 10 INCHES
KEUFFEL & ESSER CO. MADE IN U.S.A.

MC 1223-03-00

FIGURE M9

EFFECT OF MASS INPUT RATE ON
CYCLIC PRESSURE RESPONSE

- INITIAL RCS PRESSURE = 50 PSIG
- RCS VOLUME = 6000 CU.FT.
- RELIEF VALVE SETPOINT = 600 PSIG

461510

K-E 10 X 10 TO THE CENTIMETER 18 X 95 CM
KEUFFEL & ESSER CO MADE IN U.S.A.




FIGURE M10
REVISED

COMPARISON OF 1 VERSUS 2 RELIEF VALVES

- INITIAL RCS PRESSURE = 50 PSIG
- RCS VOLUME = 6000 CU.FT.
- RELIEF VALVE SETPOINT = 600 PSIG

800

SI PUMP STARTUP

700

2 SEC. LETDOWN ISOLATION WITH CHARGING
(CENTRIFUGAL PUMP)

600

RCS PRESSURE, PSIA

500

400

300

200

100

0


— 2 RELIEF VALVES

— 1 RELIEF VALVE

0 10 20 30 40 50 60 70

TIME, SEC.

FIGURE M1Q



461510

K-E 10 X 10 TO THE CENTIMETER 10 X 25 CM
KEUFFEL & ESSER CO. MADE IN U.S.A.

RCS PRESSURE TRANSIENT
WITH RELIEF VALVE OPENING

- INITIAL RCS PRESSURE = 50 PSIG
- RCS VOLUME = 13,000 CU. FT.
- LETDOWN ISOLATION (2 SEC)





FIGURE M12

RCS PRESSURE TRANSIENT
WITH RELIEF VALVE OPENING

- INITIAL RCS PRESSURE = 50 PSIG
- RCS VOLUME = 13,000 CU. FT.
- LETDOWN ISOLATION (10 SEC)




1223-03-00

FIGURE M13

RCS PRESSURE TRANSIENT
FOR ONE CYCLE OF RELIEF
VALVE OPENING AND CLOSING

- INITIAL RCS PRESSURE = 50 PSIG
- RCS VOLUME = 13,000 CU. FT.
- LETDOWN ISOLATION (2 SEC)




RCS PRESSURE RESPONSE

FIGURE M14

- INITIAL RCS PRESSURE = 450 PSIG
- RCS VOLUME = 6000 CU. FT.

461510

K+E 10 X 10 TO THE CENTIMETER 18 X 25 CM
KEUFFEL & ESSER CO. MADE IN U.S.A.

MC 1223-03-00

FIGURE M15

461510



K-E 10 X 10 TO THE CENTIMETER 18 X 25 CM
KEUFFEL & ESSER CO. MADE IN U.S.A.


FIGURE M16



MC 1223-03-00

FIGURE M17


INITIAL RCS PRESSURE, PSIG



RCS PRESSURE OVERTHOO

- INITIAL RCS PRESSURE = 50 PSIG
- RCS VOLUME = 6000 CU.FT.
- SI PUMP STARTUP
- I REFERENCE RELIEF VALVE

FIGURE M18



461510

K+E 10 X 10 TO THE CENTIMETER 18 X 25 CM
KEUFFEL & ESSER CO. MADE IN U.S.A.

FIGURE M19

RCS PRESSURE TRANSIENT
WITH RELIEF VALVE OPENING

- INITIAL RCS PRESSURE = 50 PSIG
- RCS VOLUME = 13,000 CU. FT.
- REFERENCE SI PUMP STARTUP

461510


K+E 10 X 10 TO THE CENTIMETER 18 X .25 CM.
KEUFFEL & ESSER CO MADE IN U.S.A.

FIGURE M20





FIGURE M21



EFFECT OF RCS VOLUME ENVELOPE ON
PRESSURE OVERSHOOT

FIGURE M22

- INITIAL RCS PRESSURE = 50 PSIG
- REF. SI PUMP STARTUP
- RELIEF VALVE SETPOINT = 600 PSIG




FIGURE M23

461510



K+E 10 X 10 TO THE CENTIMETER 18 X 25 (1/4)
KEUFFEL & ESSER CO. MADE IN U.S.A.

FIGURE M24



461510


K+E 10 X 10 TO THE CENTIMETER 18 X 25 CM
KEUFFEL & ESSER CO. MADE IN U.S.A.

1223-03-00

FIGURE M25

RCS PRESSURE TRANSIENT
WITH RELIEF VALVE
ACTUATION AT 500 PSIG


- INITIAL RCS PRESSURE = 450 PSIG
- REFERENCE SI PUMP STARTUP



461510

K-E 10 X 10 TO THE CENTIMETER 18 X 25 CM
KEUFFEL & ESSER CO. MADE IN U.S.A.

FIGURE M26



461510

10 X 10 TO THE CENTIMETER 18 X 25 CM
KEUFFEL & TESSER CO. MADE IN U.S.A.

K+E

MC 1223-03-00

FIGURE M27

EFFECT OF RELIEF VALVE PARAMETERS
ON RCS PRESSURE TRANSIENT

- INITIAL RCS PRESSURE = 50 PSIG
- RCS VOLUME = 6,000 CU. FT.
- REFERENCE SI PUMP STARTUP






FIGURE M28



MC 1223 03-00 FIGURE M29

EFFECT OF RELIEF VALVE CLOSURE TIME


- INITIAL RCS PRESSURE = 450 PSIG
- RCS VOLUME = 6000 CU. FT.
- REFERENCE SI PUMP STARTUP
- 1 REFERENCE RELIEF VALVE



RCS PRESSURE TRANSIENT
FOR ONE CYCLE OF RELIEF
VALVE OPENING AND CLOSING

- INITIAL RCS PRESSURE = 50 PSIG
- RCS VOLUME = 6000 CU. FT.
- REFERENCE SI PUMP

FIGURE M30




MC 1223-03-00

FIGURE M31

RCS PRESSURE TRANSIENT
FOR ONE CYCLE OF RELIEF
VALVE OPENING AND CLOSING


- INITIAL RCS PRESSURE = 50 PSIG
- RCS VOLUME = 6000 CU. FT.
- REFERENCE SI PUMP STARTUP
- NON-LINEAR (QUICK OPENING) RELIEF VALVE



461510

KoΣ IN X 10 TO THE CENTIMETER 18 x 25 CM
PEIFFEL & FISCHER CO. MAY 1961

FIGURE M32



RCS PRESSURE TRANSIENT
FOR ONE CYCLE OF NON-LINEAR RELIEF
VALVE OPENING AND CLOSING

- INITIAL RCS PRESSURE = 50 PSIG
- RCS VOLUME = 6000 CU. FT.
- REFERENCE SI PUMP STARTUP

- 2 RELIEF VALVES





FIGURE M34



C 1223-03-00

FIGURE M35

C 1223-03-00

EFFECT OF MATERIAL EXPANSION ON
PRESSURE OVERSHOOT

- REFERENCE SI PUMP STARTUP
- RCS VOLUME = 6000 CU.FT.
- INITIAL RCS PRESSURE = 50 PSIG
- RELIEF VALVE SETPOINT = 600 PSIG





FIGURE M36



MC 1223·03-00

HEAT INPUT




FIGURE H2

EFFECT OF STEAM GENERATOR UA ON
PRESSURE OVERSHOOT

MC 1223-03-00





FIGURE N3

EFFECT OF STEAM GENERATOR UA ON
PRESSURE OVERSHOOT






FIGURE H5

461510


10 X 10 TO THE CENTIMETER 18 X 25 CM
KEUFFEL & ESSER CO. MADE IN U.S.A.

FIGURE M6





FIGURE H7



MC 1,223-03-00


FIGURE H8

EQUIVALENT MASS INPUT RATE FOR HEAT INPUT TRANSIENT

- INITIAL RCS PRESSURE = 300 PSIG

- RCS SU IN 1 LOOP WITH RCS/SG AT = 180°/280°

6000 CU.FT. (1 RCP SU IN 2 LOOPS)



461510

K+E 10 X 10 TO THE CENTIMETER 18 X 25 CM
KEUFFEL & ESSER CO. MADE IN U.S.A.


FIGURE H9

EFFECT OF HEAT INPUT RATE

- INITIAL RCS PRESSURE = 300 PSIG
- RCS VOLUME = 6000 CU. FT.
- RCP SU IN 1 LOOP
- NO RELIEF VALVE ACTUATION

461510

K+E 10 X 10 TO THE CENTIMETER 10 X 25 CM.
KEUFFEL & ESSER CO. MADE IN U.S.A.



461510


K+E
10 X 10 TO THE CENTIMETER 18 X 25 CM
HEIFFEL & ESSER CO. MADE IN U.S.A.

FIGURE H11

1600

1200

800

400

300

2600

2200

1800

1400

1000

600

200

RCS PRESSURE, PSIA

RCS/SG $\Delta T = 180^\circ/280^\circ$

RCS/SG $\Delta T = 200^\circ/250^\circ$

COMPARISON OF LOOP SEAL/RCS VERSUS RCS/SG
TEMPERATURE ASYMMETRIES

- INITIAL RCS PRESSURE = 300 PSIG
- RCS VOLUME = 6000 CU.FT.
- RCP SU IN 1 LOOP

LS/RCS $\Delta T = 80^\circ/200^\circ$

0

20

40

60

80

100

120

TIME, SEC.

NC 1223.U3-00 FIGURE H12

461510

K-E 10 X 10 TO THE CENTIMETER 18 X 25 CM
KLEINER & ESSER CO. MADE IN U.S.A.





FIGURE H13



MC 1223-03-00

FIGURE H14

RCS PRESSURE RESPONSE TO
HEAT INPUT TRANSIENT

- RCS PUMP STARTUP IN 1 LOOP
- INITIAL PRESSURE = 300 PSIG
- RCS/SG ΔT = $100^{\circ}/200^{\circ}$




FIGURE H15

RCS VOLUME, CU. FT.

6000 CU. FT.

13000 CU.FT.

RCS PRESSURE, PSIA.

4200

3800

3400

3000

2600

2200

1800

1400

1000

600

200

0

20

40

60

80

100

120

TIME, SEC.

RCS PRESSURE RESPONSE TO
HEAT INPUT TRANSIENT

- RCS PUMP STARTUP IN 1 LOOP
- INITIAL PRESSURE = 300 PSIG
- RCS/SG AT = 1400/240°




FIGURE H17




FIGURE H18

COMPARISON OF RCS PRESSURE
RESPONSE FOR MASS INPUT
AND HEAT INPUT TRANSIENTS

- INITIAL RCS PRESSURE = 450 PSIG
- RCS VOLUME = 13000 CU.FT.
- NO RELIEF VALVE





FIGURE H19

RCS PRESSURE RESPONSE TO
HEAT INPUT TRANSIENT WITH
RELIEF VALVE OPENING

- RCS PUMP STARTUP IN 1 LOOP
- RCS VOLUME = 6000 CU.FT.
- INITIAL PRESSURE = 300 PSIG
- RCS TEMPERATURE = 180°F
- RELIEF VALVE SETPOINT = 500 PSIG



MC 1223-03-00

FIGURE H20

RCS PRESSURE RESPONSE TO HEAT
INPUT TRANSIENT WITH RELIEF
VALVE OPENING

- RCS PUMP STARTUP IN 1 LOOP
- RCS VOLUME = 6000 CU.FT.
- RCS/SG AT = $100^{\circ}/200^{\circ}$





FIGURE H21

EFFECT OF RCS/SG ΔT MODEL
CONSERVATISMS ON RCS PRESSURE
RESPONSE

- INITIAL PRESSURE = 300 PSIG
- RCS VOLUME = 6000 CU.FT.
- RELIEF VALVE SETPOINT = 400 PSIG







FIGURE H23

RCS PRESSURE RESPONSE TO HEAT INPUT TRANSIENT WITH RELIEF VALVE OPENING

- RCS PUMP STARTUP IN 1 LOOP
- RCS VOLUME = 6000 CU.FT.
- RCS/SG ΔT = 1400/2400



MC 1223-03-00

FIGURE H24

RCS PRESSURE OVERSHOOT

- INITIAL RCS PRESSURE = 300 PSIG
- RCS VOLUME = 6000 CU.FT.
- RCS/SG ΔT = $180^\circ/280^\circ$
- RCP SU IN 1 LOOP





FIGURE H25
PRESSURE RESPONSE FOR 1 RELIEF VALVE CYCLE

- INITIAL RCS PRESSURE = 300 PSIG
- RCS VOLUME = 6000 CU.FT.
- RCP SU IN 1 LOOP WITH RCS/SG ΔT = 100°F
- RELIEF VALVE SETPOINT = 600 PSIG







FIGURE H27

EFFECT OF HEAT INPUT LOFTRAN MODEL CONSERVATISMS ON PRESSURE OVERSHOOT

- INITIAL PRESSURE = 300 PSIG
- RCS VOLUME = 6000 CU.FT.
- RELIEF VALVE SETPOINT = 600 PSIG



MC 1'223-03-00

FIGURE H28

EFFECT OF HEAT INPUT LOFTRAM MODEL
CONSERVATISMS ON PRESSURE OVERSHOOT

- INITIAL PRESSURE = 300 PSIG
- RCS VOLUME = 6000 CU.FT.
- RELIEF VALVE SETPOINT = 600 PSIG





FIGURE H29

RCS PRESSURE RESPONSE TO HEAT INPUT TRANSIENT WITH RELIEF VALVE OPENING

- RCS PUMP STARTUP IN 1 LOOP
- RCS VOLUME = 13000 CU.FT.
- RCS/SG ΔT = $100^{\circ}/200^{\circ}$



MC 1223-03-00

FIGURE H30

EFFECT OF RCS/SG AT MODEL
CONSERVATISMS ON RCS PRESSURE
RESPONSE

- INITIAL PRESSURE = 300 PSIG
- RCS VOLUME = 13000 CU.FT.
- RELIEF VALVE SETPOINT = 400 PSIG





FIGURE H31

EFFECT OF RCS/SG AT MODEL
CONSERVATISMS ON RCS PRESSURE
RESPONSE

- INITIAL PRESSURE = 300 PSIG
- RCS VOLUME = 13,000 CU. FT.
- RELIEF VALVE SETPOINT = 600 PSIG



MC 1223-03-00


FIGURE H32

RCS PRESSURE RESPONSE TO HEAT
INPUT TRANSIENT WITH RELIEF
VALVE OPENING

- RCS PUMP STARTUP IN 1 LOOP
- RCS VOLUME = 13000 CU.FT.
- RCS/SG AT = 1400/240°

46 1510

K-E 10 X 10 TO THE CENTIMETER 18 X 25 CM
KEUFFEL & ESSEN CO. MADE IN U.S.A.



RCS PRESSURE RESPONSE TO HEAT INPUT TRANSIENT WITH RELIEF VALVE OPENING

FIGURE H33

1000

- RCS PUMP STARTUP IN 1 LOOP
- RCS VOLUME = 13000 CU.FT.
- RCS/SG AT = $180^{\circ}/280^{\circ}$

900

800

700

600

500

400

300

200

100

0

RCS PRESSURE, PSIA

SETPOINT, PSIG

600

500

400

----- 2 RELIEF VALVES

——— 1 RELIEF VALVE

0 4 8 12 16 20 24 28 32 36 40 44 48 52 56

TIME, SEC.

MC 1223-03-00

FIGURE H34

EFFECT OF RCS/SG AT MODEL
CONSERVATISMS ON RCS PRESSURE
RESPONSE

- INITIAL PRESSURE = 300 PSIG
- RCS VOLUME = 13000 CU. FT.
- RELIEF VALVE SETPOINT = 600 PSIG





FIGURE H35



1223-03-00

FIGURE H36

EFFECT OF RCS VOLUME ENVELOPE
ON PRESSURE OVERSHOOT

- INITIAL RCS PRESSURE = 300 PSIG
- RCP SU IN 1 LOOP WITH RCS/SG $\Delta T = 180^\circ/280^\circ$
- RELIEF VALVE SETPOINT = 600 PSIG

461510



K-E 10 X 10 TO THE CENTIMETER 10 X 25 CM
HELIOTYPE & ESSECO MADE IN U.S.A.

FIGURE H37

Heat Input
RCS/SG ΔT - 180/280°F
Reference Relief Valve - 3 seconds



MC 1223-03-00

JUN 22 1975

115

775

APPENDIX C

TABLE 1

INCIDENTS OF PRESSURE

TRANSIENTS BEYOND TECH. SPEC. LIMITS

INCIDENT (Date)	CAUSE DESCRIPTION	PRESSURE TRANSIENT FROM (PSIG) TO	TECH SPEC LIMIT (PSIG)	TIME TO REACH PEAK PRESSURE (minutes)
1. Beaver Valley Unit No. 1 (2/24/76)	Operator error in transferring electrical buses caused instrument spike isolating letdown from RHR System	400	1000	440 (130 F)* Note 1
2. Indian Point Unit No. 2 (2/16/72)	Unknown	420	670	500 (140 F)* 2
3. Indian Point Unit No. 2 (2/17/72)	Operator isolated letdown without verifying availability of letdown thru RHR system	420	650	500 (180 F)* 2
4. Indian Point Unit No. 2 (3/8/72) C-2	Reactor coolant pump starting swept cold water thru hot steam generator-pressure increase due to thermal expansion	400	640	500 (115 F)* 1
5. Indian Point Unit No. 2 (4/6/72)	Operator inadvertently isolated letdown	420	680	500 (170 F)* 2
6. Indian Point Unit No. 2 (5/18/73)	Closure of certain air operator valves in reactor coolant letdown system caused by freezing of moisture in air supply line.	440	575	500 (130 F)* Note 1

INCIDENT (Date)	CAUSE DESCRIPTION	PRESSURE TRANSIENT FROM (PSIG) to	TECH SPEC LIMIT (PSIG)	TIME TO REACH PEAK PRESSURE (min.)
7. Indian Point Unit 2 (1/23/74)	Starting of a single reactor coolant pump caused pressure surge. A nitrogen blanket in the pressurizer to act as a surge volume had been established; however, the amount of nitrogen added to the pressurizer was insufficient.	425 525	500 (190 F)*	Note 1
8. Indian Point Unit No. 2 (2/22/74)	An inadvertent safety injection signal was generated which, by design, caused the accumulator discharge stop valves to open.	150 560	500 (115 F)*	Note 1
9. Oconee Nuclear Station Unit 2 (11/15/73)	During Zero Power Physics testing, test procedure instructions directed operating personnel to increase reactor coolant pressure to approximately 1860 psig violating the limits.	800 1860	1600 (300 F)*	30
10. Palisades (9/1/74)	A procedure "CAUTION" statement was not rigorously adhered to while performing a primary coolant system leak test	--- 960	Requires 160 F to pressurize above 885 (150 F)*	---

1223-03-00

INCIDENT (Date)	CAUSE DESCRIPTION	PRESSURE TRANSIENT FROM (PSIG)	TO	TECH SPEC LIMIT (PSIG)	TIME TO REACH PEAK PRESSURE (min.)
11. Point Beach Unit No. 2 (12/10/74)	Following repair, a safety injection pump was lined up for a test run. However, safety injection pump discharge was not isolated from injecting into the reactor coolant system. Pressure transient caused by starting of SI pump.	345	1400	615 (850) (170 F)*	30 Seconds
12. Point Beach Unit No. 2 (2/28/76)	Operational reasons required the RHR system to be isolated from the reactor coolant system. Reduced letdown resulted in pressure increase	400	830	615 (168 F)*	Note 1
13. Prairie Island Unit No. 1 (10/31/73)	Reactor coolant pump starting swept cold water thru hot steam generator-pressure increase due to thermal expansion	420	1100	720 (132 F)*	Note 1
14. Prairie Island Unit No. 1 (1/16/74)	While conducting Safeguards Logic Train A monthly surveillance test, a SI signal was initiated when a step which puts Train A in TEST was inadvertently missed. The SI signal opened No. 11 accumulator outlet isolation valve. RHR System isolation occurred as designed at 600 psig.	395	840	610 (90 F)*	Note 1

INCIDENT (Date)	CAUSE DESCRIPTION	PRESSURE TRANSIENT FROM (psig) TO	TECH SPEC LIMIT (Psig)	Time to Reach Peak Pressure (min.)
15. Prairie Island Unit No. 2 (11/27/74)	A test signal injected into the letdown controller instrument loop caused a letdown control valve to go closed. This isolated the letdown path. RHR System automatically isolated.	Note 1	900 800 (155 F)*	Note 1
16. St. Lucie Unit No. 1 (8/12/75)	Letdown isolation valve failed closed when I&C personnel removed cover from sealing relay associated with letdown isolation valve. When relay cover was removed, broken wires on relay became disconnected causing letdown valve to close.	210	600 (660) 520 (105 F)*	Note 1
17. Surry Unit No. 1 (1/28/73)	During process of filling and venting the RCS, "A" accumulator motor operated discharge isolation valve was opened to sweep any air trapped in accumulator discharge line into RCS. The opening of the valve caused the accumulator to cause the increase in RCS pressure.	450	590 500 (80 F)*	1
18. Trojan (7/22/75)	The RHR suction valve from the RCS was closed by an unknown person (i.e., this isolated letdown) while the positive displacement charging pump was operating.	400	3326 520 (between 100 and 105 F)*	10 to 12

10 1223-03-00

INCIDENT (Date)	CAUSE DESCRIPTION	PRESSURE TRANSIENT FROM (Psig) TO	TECH SPEC LIMIT (Psig)	Time to Reach Peak Pressure (min.)
19. Turkey Point Unit No. 3 (12/3/74)	In preparation for starting a reactor coolant pump, the operator placed the letdown control valve in automatic in order to increase reactor coolant pressure. At 455 psig the RHR system loop suction isolation valve automatically closed isolating letdown.	50 800	510 (105 F)*	Note 1
20. Zion Unit No. 1 (6/13/73)	Charging pump 1A, with suction from RWST, was started to increase reactor system pressure. Normal pressure control of continuous charging and letdown was not being used since VCT was unavailable. Operator was distracted by a telephone call and left the area of the pump control switch. Unattended pump continued to pressurize system. RHR suction relief valve failed to lift and RHR system later isolated automatically at 600 psig.	110 1290	460 (105 F)*	Note 1
21. Zion Unit No. 1 (6/3/75)	Operator failed to stop the centrifugal charging pump when he secured the RHR system to replace the RHR suction relief valve. When the RHR system was secured, letdown was also secured.	100 1100	480 (115 F)*	10

INCIDENT (date)	CAUSE DESCRIPTION	PRESSURE TRANSIENT FROM (Psig) TO	TECH SPEC LIMIT (Psig)	Time to Reach Peak Pressure (min.)
22. Zion Unit No. 2 (9/18/75)	Station personnel were performing a RHR valve interlock test in which the RHR System is automatically isolated from the reactor coolant system. When the applied test signal reached the set-point, the RHR isolation valves closed removing the letdown path.	95 1300	450 (88 F)*	15
23. Ginna	The NSSS vendor has indicated that this plant has had an overpressure incident. Further investigation is in progress.			
24. Point Beach Units 1 & 2				
25. Surry Unit No. 1				
26. D. C. Cook Unit No. 1	See item # 26 on next page			
27. Peach Bottom Unit No. 2 (3/6/74)	Following a main steam line isolation test, portions of the reactor vessel shell temperatures decayed to 125 F while reactor pressure remained at approximately 400 psig.	--- 400	250 (125 F)*	
28. Beaver Valley Unit No. 1 (3/5/76)	Instrument Technician tripped wrong B/S during MSP, then OPS placed inverter in service with output breaker open, deenergizing #1 vital bus, causing SIS which isolated letdown	400 1150	440 (150 F)*	Note 1

1223-03-00

INCIDENT (date)	CAUSE DESCRIPTION	PRESSURE TRANSIENT FROM (Psig) TO	TECH SPEC LIMIT (Psig)	TIME TO REACH PEAK PRESSURE (min.)
26. D.C. Cook Unit No. 1 (4/14/76)	During RPS testing, inadvertent letdown isolation was initiated.	Note 1	1040	470 (110 F)* Note 1
29. St. Lucie Unit No. 1 (6/17/76)	With Shutdown Cooling System secured, a reactor coolant pump was started and RCS temperature rose to 140°F - reason unknown as of 6/22/76	300 approx.	820	520 (90 - 100°F) 1

NOTE 1 - The available abnormal occurrence report does not provide this information.

* - Temperature of reactor vessel during transient

C-9

MC 1223.03-00

DL CHNUF
Design Engineering

December 6, 1977

(For copies in DE; please
TO: Utility Group Participants Pass on to REDay if
he has copy)

REFERENCE: "Pressure Mitigating Systems Transient Analysis Results,"
July 1977. (Westinghouse Report on RCS Solid Water Over-
pressurization)

Em.

Utility Group on Reactor Coolant System Overpressurization

Attached are three revised figures which should be substituted for the corresponding figures to be found in Appendix B of Reference 1. The revisions accommodate modifications made to the letdown isolation transients represented in these figures to upgrade the analytical basis and account for an input data correction.


Setpoint pressure overshoot has not been altered in any of the transients plotted in these figures; however, setpoint pressure undershoot has been modified in several of the letdown isolation transients. In every case, the modification has resulted in an improvement in (i.e., smaller) set-point pressure undershoot.

In both Figures M6 and M10, the common transient exhibiting RCS setpoint pressure undershoot response for two relief valve operation at a setpoint of 600 psig has been replotted to reflect valve closure at a reset pressure 20 psi below the setpoint. The original transient depicted in Figure M6 and Figure M10 of Reference 1 (Appendix B) represented valve closure at a reset pressure 120 psi below the 600 psig setpoint. As would be expected, the setpoint pressure under shoot has been significantly reduced to the extent that violation of the RCS pump seal pressure limit is no longer a consideration for this transient.

In Figure M7, the setpoint pressure undershoots for both the 500 psig and 600 psig relief valve setpoint transients have been adjusted to reflect a correction to the LOFTRAN input data. A reduction in setpoint pressure undershoot is evident in both transients.

Should you have any questions regarding the attachments, please contact the undersigned.

Very truly yours,



H. W. Gutzman, Project Engineer
Projects & Regional Support