



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ALABAMA POWER COMPANY

DOCKET NO. 50-348

JOSEPH M. FARLEY NUCLEAR PLANT, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 56
License No. NPF-2

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Alabama Power Company (the licensee) dated November 2, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-2 is hereby amended to read as follows:


8501070256 841226
PDR ADDCK 05000348
P PDR

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 56, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 26, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 56

AMENDMENT NO. 56 FACILITY OPERATING LICENSE NO. NPF-2

DOCKET NO. 50-348

Revised Appendix A as follows:

Remove Page

6-1a

Insert Page

6-1a

- f. Administrative procedures shall be developed and implemented to limit the working hours of unit staff who perform safety-related functions; e.g., senior reactor operators, reactor operators, health physics technicians, auxiliary operators, and key maintenance personnel. Adequate shift coverage shall be maintained without routine heavy use of overtime. The objective shall be to have operating personnel work a nominal 40-hour week while the plant is operating.

In the event that unforeseen problems require substantial amounts of overtime to be used, or during extended periods of shutdown for refueling, major maintenance or major plant modifications, on a temporary basis, the following guidelines shall be followed:

1. An individual will not be permitted to work more than 16 hours straight (not including shift turnover time).
2. There will be a break of at least 8 hours (which can include shift turnover time) between work periods.
3. An individual will not work more than 16 hours in any 24-hour period, nor more than 24 hours in any 48-hour period, nor more than 72 hours in any 7-day period (all excluding shift turnover time).
4. Except during extended shutdown periods, the use of overtime should be considered on an individual basis and not for the entire staff on a shift.
5. Any deviation from the above guidelines for the minimum shift complement defined in Technical Specification Table 6.2-1 and health physics technicians shall be reviewed and approved by the Plant Manager, his designee (Emergency Director) or higher authority. Any deviation from the above guidelines for key maintenance personnel shall be reviewed and approved by the maintenance superintendent or his designee (group supervisor).



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ALABAMA POWER COMPANY

DOCKET NO. 50-364

JOSEPH M. FARLEY NUCLEAR PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 47
License No. NPF-8


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Alabama Power Company (the licensee) dated November 2, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-8 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 47, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 26, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 47
AMENDMENT NO. 47 FACILITY OPERATING LICENSE NO. NPF-8
DOCKET NO. 50-364

Revised Appendix A as follows:

Remove Page

6-1a

Insert Page

6-1a

ADMINISTRATIVE CONTROLS

- f. Administrative procedures shall be developed and implemented to limit the working hours of unit staff who perform safety-related functions; e.g., senior reactor operators, reactor operators, health physics technicians, auxiliary operators, and key maintenance personnel. Adequate shift coverage shall be maintained without routine heavy use of overtime. The objective shall be to have operating personnel work a nominal 40-hour week while the plant is operating.

In the event that unforeseen problems require substantial amounts of overtime to be used, or during extended periods of shutdown for refueling, major maintenance or major plant modifications, on a temporary basis, the following guidelines shall be followed:

1. An individual will not be permitted to work more than 16 hours straight (not including shift turnover time).
2. There will be a break of at least 8 hours (which can include shift turnover time) between work periods.
3. An individual will not work more than 16 hours in any 24-hour period, nor more than 24 hours in any 48-hour period, nor more than 72 hours in any 7-day period (all excluding shift turnover time).
4. Except during extended shutdown periods, the use of overtime should be considered on an individual basis and not for the entire staff on a shift.
5. Any deviation from the above guidelines for the minimum shift complement defined in Technical Specification Table 6.2-1 and health physics technicians shall be reviewed and approved by the Plant Manager, his designee (Emergency Director) or higher authority. Any deviation from the above guidelines for key maintenance personnel shall be reviewed and approved by the maintenance superintendent or his designee (group supervisor).