



International Agreement Report

Assessment of RELAP5/MOD2 Using Semiscale Intermediate Break Loss-of-Coolant Experiment S-IB-3

Prepared by
Gung-Huei Chou, Tzing-Sheng Horng, Lih-Yih Lia

Institute of Nuclear Energy Research
P.O. Box 3, Lung-Tan 32500
Taiwan

Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555

June 1992

Prepared as part of
The Agreement on Research Participation and Technical Exchange
under the International Thermal-Hydraulic Code Assessment
and Application Program (ICAP)

Published by
U.S. Nuclear Regulatory Commission

9207140022 920630
PDR NUREG
IA-0080 R PDR

NOTICE

This report was prepared under an international cooperative agreement for the exchange of technical information. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

Available from

Superintendent of Documents
U.S. Government Printing Office
P.O. Box 37082
Washington, D.C. 20513-7082

and

National Technical Information Service
Springfield, VA 22161

NUREG/IA-0080



International Agreement Report

Assessment of RELAP5/MOD2 Using Semiscale Intermediate Break Loss-of-Coolant Experiment S-IB-3

Prepared by
Gung-Huei Chou, Tzing-Sheng Horng, Lih-Yih Lia

Institute of Nuclear Energy Research
P.O. Box 3, Lung-Tan 32500
Taiwan

Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555

June 1992

Prepared as part of
The Agreement on Research Participation and Technical Exchange
under the International Thermal-Hydraulic Code Assessment
and Application Program (ICAP)

Published by
U.S. Nuclear Regulatory Commission

NOTICE

This report documents work performed under the sponsorship of the Institute of Nuclear Energy Research of Taiwan. The information in this report has been provided to the USNRC under the terms of an information exchange agreement, Cooperative Program on Thermal-Hydraulic Code Assessment Between the Coordination Council for North American Affairs (CCNAA) and the American Institute in Taiwan (AIT), March 22, 1986. Taiwan has consented to the publication of this report as a USNRC document in order that it may receive the widest possible circulation among the reactor safety community. Neither the United States Government nor Taiwan or any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability of responsibility for any third party's use, or the results of such use, or any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

TABLE OF CONTENTS

	Page
ABSTRACT	1
ACKNOWLEDGMENTS	2
SUMMARY	3
1. INTRODUCTION	5
2. TEST FACILITY AND TRANSIENT DESCRIPTIONS	6
2.1 Test Facility	6
2.2 Transient Description	7
3. CODE AND MODEL DESCRIPTIONS	9
3.1 Computer Code	9
3.2 Model Descriptions	9
3.3 Initialization Process	13
4. RESULTS AND DISCUSSIONS	15
4.1 Base Case Analysis	15
4.2 Sensitivity Studies	23
5. RUN STATISTICS	28
6. CONCLUSIONS	28
REFERENCES	105
APPENDIX	

LIST OF FIGURES

<u>Figure</u>	<u>Page</u>
2.1 Semiscale Mod-2A System Configuration for Cold Leg Intermediate Break Test	40
2.2 Semiscale Mod-2A Heated Core Plan View	41
3.1 RELAP5/MOD2-Semiscale Intermediate Break Model Nodalization for Experiment S-IB-3	42
4.1 Comparison Between the Calculated and Measured Vessel Upper Plenum Pressure of Test S-IB-3	43
4.2 Comparison Between the Calculated and Measured Pressurizer Steam Dome Pressure of Test S-IB-3	44
4.3 Calculated Hot Leg and Saturation Temperature of Test S-IB-3 Simulation	45
4.4 Calculated Cold Leg and Saturation Temperature of Test S-IB-3 Simulation	46
4.5 Calculated Liquid Level in Pressurizer of Test S-IB-3 Simulation ..	47
4.6 Comparison Between the Calculated and Measured Differential Pressure in Broken Loop Pump Suction Upflow Leg of Test S-IB-3	48
4.7 Calculated Liquid Level in Broken Loop Pump Suction Upflow Leg of Test S-IB-3 Simulation	49
4.8 Comparison Between the Calculated and Measured Volumetric Flow Rate in Broken Loop Cold Leg Near Pump of Test S-IB-3	50
4.9 Calculated Guide Tube Mass Flow Rate of Test S-IB-3 Simulation	51
4.10 Calculated Core Bypass Line Mass Flow Rate of Test S-IB-3 Simulation	52
4.11 Comparison Between the Calculated and Measured Mass Flow Rate in Broken Loop Hot Leg of Test S-IB-3	53
4.12 Comparison Among the Calculated System, Intact Loop and Broken Loop Steam Generator Steam Dome Pressure of Test S-IB-3	54
4.13 Calculated Break Junction Void Fraction of Test S-IB-3 Simulation	55
4.14 Comparison Between the Calculated and Measured Break Mass Flow Rate of Test S-IB-3	56

LIST OF FIGURES (Continued)

<u>Figure</u>	<u>Page</u>
4.15 Comparison Between the Calculated and Measured Integrated Break Mass Flow of Test S-IB-3	57
4.16 Comparison Between the Calculated and Measured Mass Flow Rate of Component 361 Near Pump of Test S-IB-3	58
4.17 Comparison Between the Calculated and Measured Mass Flow Rate of Component 363 Near Vessel of Test S-IB-3	59
4.18 Calculated Broken Loop Cold Leg Flow Regime of Test S-IB-3 Simulation	60
4.19 Comparison Between the Calculated and Measured Liquid Level in Upper Head of Test S-IB-3	61
4.20 Calculated Liquid Level in Upper Head of Test S-IB-3 Simulation	62
4.21 Comparison Between the Calculated and Measured Differential Pressure in Intact Loop Pump Suction Upflow Leg of Test S-IB-3	63
4.22 Comparison Between the Calculated and Measured Differential Pressure in Intact Loop Pump Suction Downflow Leg of Test S-IB-3	64
4.23 Calculated Liquid Level in Intact Loop Pump Suction Upflow Leg of Test S-IB-3 Simulation	65
4.24 Comparison Between the Calculated and Measured Mass Flow Rate in Intact Loop Hot Leg of Test S-IB-3	66
4.25 Comparison Between the Calculated and Measured Mass Flow Rate in Intact Loop Cold Leg of Test S-IB-3	67
4.26 Comparison Between the Calculated and Measured Mass Flow Rate in Vessel Downcomer of Test S-IB-3	68
4.27 Comparison Between the Calculated and Measured Pressurizer Surge Line Volumetric Flow Rate of Test S-IB-3	69
4.28 Calculated Pressurizer Surge Line Mass Flow Rate of Test S-IB-3 Simulation	70
4.29 Calculated Volumetric Flow Rate of Accumulator and Low Pressure Injection System of Test S-IB-3 Simulation	71
4.30 Comparison Between the Calculated and Measured Volumetric Flow Rate in Vessel Downcomer of Test S-IB-3	72
4.31 Comparison Among the Calculated Cold Leg Density of Test S-IB-3 Simulation	73

LIST OF FIGURES (Continued)

<u>Figure</u>	<u>Page</u>
4.32 Comparison Between the Calculated and Measured Core Heater Temperature of Test S-IB-3	74
4.33 Comparison Between the Calculated and Measured Liquid Level in Vessel of Test S-IB-3	75
4.34 Comparison Between the Calculated and Measured Density in Vessel of Test S-IB-3	76
4.35 Comparison Among Calculated System Pressure of the BASE, PRESSB Cases and Test Data	77
4.36 Comparison Among Calculated Break Mass Flow Rate of the BASE, PRESSB Cases and Test Data	78
4.37 Comparison Among Calculated Cladding Temperature of the BASE, PRESSB Cases and Test Data	79
4.38 Comparison Among Calculated Vessel Density of the BASE, PRESSB Cases and Test Data	80
4.39 Comparison Among Calculated Vessel Liquid Level of the BASE, PRESSB Cases and Test Data	81
4.40 Comparison Among Calculated Intact Loop Hot Leg Mass Flow Rate of PRESSB, BASE Cases and Test Data	82
4.41 Comparison Among Calculated Broken Loop Hot Leg Mass Flow Rate of PRESSB, BASE Cases and Test Data	83
4.42 Comparison Among Calculated Broken Loop Hot Leg Mass Flow Rate of PB-IRFL, PRESSB, and BASE Cases	84
4.43 Comparison Among Calculated Intact Loop Hot Leg Mass Flow Rate of PB-IRFL, PRESSB and BASE Cases	85
4.44 Comparison Among Calculated Intact Loop Cold Leg Mass Flow Rate of PB-IRFL, PRESSB and BASE Cases	86
4.45 Comparison Among Calculated Vessel Downcomer Mass Flow Rate of PB-IRFL, PRESSB and BASE Cases	87
4.46 Comparison Among Calculated Break Mass Flow Rate of PUMPCD, BASE Cases and Test Data	88
4.47 Comparison Among Calculated Cladding Temperature of PUMPCD, BASE Cases and Test Data	89

LIST OF FIGURES (Continued)

<u>Figure</u>	<u>Page</u>
4.48 Comparison Among Calculated Intact Loop Hot Leg Mass Flow Rate of PUMPCD, BASE Cases and Test Data	90
4.49 Comparison Among Calculated Intact Loop Cold Leg Mass Flow Rate of PUMPCD, BASE Cases and Test Data	91
4.50 Comparison Among Calculated C163-C301 Junction Mass Flow Rate of CROSFJ, BASE Cases and Test Data	92
4.51 Comparison Among Calculated C263-C102 Junction Mass Flow Rate of CROSFJ, BASE Cases and Test Data	93
4.52 Comparison Among Calculated C163-C301 Junction Mass Flow Rate of CROSFJ, BASE Cases and Test Data	94
4.53 Comparison Among Calculated C102-C363 Junction Mass Flow Rate of CROSFJ, BASE Cases and Test Data	95
4.54 Comparison Among Calculated Break Mass Flow Rate of BREAKJ, BASE Cases and Test Data	96
4.55 Comparison Among Calculated C330-C340 Junction Mass Flow Rate of BREAKJ, BASE Cases and Test Data	97
4.56 Comparison Among Calculated C361-C362 Junction Mass Flow Rate of BREAKJ, BASE Cases and Test Data	98
4.57 Comparison Among Calculated C363 Junction Mass Flow Rate of BREAKJ, BASE Cases and Test Data	99
4.58 Comparison Among Calculated Break Mass Flow Rate of TDC-1.0, BASE Cases and Test Data	100
4.59 Comparison Among Calculated Pressurizer Steam Dome Pressure of TDC-1.0, BASE Cases and Test Data	101
4.60 Comparison Among Calculated Cladding Temperature of TDC-1.0, BASE Cases and Test Data	102
4.61 Comparison Among Calculated Vessel Liquid Level of TDC-1.0, BASE Cases and Test Data	103
4.62 Comparison Among Calculated Vessel Density of TDC-1.0, BASE Cases and Test Data	104

LIST OF TABLES

<u>Table</u>	<u>Page</u>
2.1 Chronology of Events for the Intermediate Break S-IB-3 Test	31
3.1 Revised Differential Pressure and Liquid Level in Intact Loop	32
3.2 Revised Differential Pressure and Liquid Level in Broken Loop	33
3.3 Revised Differential Pressure and Liquid Level in Vessel	34
3.4 Comparison of Specified, Measured and Calculated Initial Conditions	35
4.1 Comparison Between Calculated and Measured Sequence of Events	37
4.2 Cases Analyzed in the Sensitivity Studies of the Semiscale Test S-IB-3 Simulation	38
5.1 Run Statistics of the Semiscale Test S-IB-3 Simulation	39

ASSESSMENT OF RELAP5/MOD2 USING SEMISCALE
INTERMEDIATE BREAK LOSS-OF-COOLANT EXPERIMENT S-IB-3

by

Gung-Huei Chou, Tzing-Sheng Horng

Lih-Yih Liao

Institute of Nuclear Energy Research

Nuclear Engineering Division

P. O. Box 3-3, Lung-Tan, Taiwan, R.O.C.

ABSTRACT

This report presents the results of the RELAP5/MOD2 assessment utilizing a Semiscale intermediate break loss-of-coolant experiment S-IB-3. Comprehensive analysis with RELAP5/MOD2 is performed to predict the transient thermal-hydraulic responses of the experiment. Test S-IB-3 is a 21.7%, communicative cold leg break LOCA experiment using Semiscale Mod-2A facility in 1982, for the principal objective to provide reference data for comparison of Semiscale test results to LOBI facility B-R1M test results. Through extensive comparison between test data and best-estimate RELAP5 calculations, the capabilities of RELAP5/MOD2 to predict the intermediate break LOCA accident were assessed. Emphasis was located on the capability of the code to calculate core level depression and break flow rate during system blowdown, pump suction liquid seals phenomena, and temperature excursions behavior etc., throughout the whole experiment. Besides, some sensitivity studies involving the effect of steam generator secondary side pressure boundary, adjustment of two-phase discharge coefficient, intact loop pump coastdown behavior, and some interesting studies regarding break flow etc., were also investigated in this report.

ACKNOWLEDGMENTS

The authors gratefully acknowledge Mr. Jeng-Lang Chiou and Cheng-Chi Wu for offering technical assistance in assessing RELAP5/MOD2 code. The valuable comments of Dr. Laisu Yao on transient phenomena discussion were also much appreciated.

SUMMARY

This report includes the results and conclusions of the RELAP5/MOD2 code assessment in the analysis of Semiscale intermediate break test S-IB-3. Sensitivity studies of the S-IB-3 simulation with respect to various modelling options are performed as well as to investigate their impacts on the modified calculation results.

Semiscale S-IB-3 is performed to simulate a hypothetical LOCA which results from a 21.7%, communicative cold leg break of a typical pressurized water reactor. Test S-IB-3 was the last of the three-test Intermediate Break series which was conducted from an initial system pressure of 15.5 MPa, with core inlet temperature of 563 K, temperature rise of 33 K, flat radial profile and a total power of 1.45 MW. The principal objective of this test was to provide reference data for comparison of Semiscale test results to Loop Blowdown Investigation (LOBI) facility B-R1M test results.

RELAP5/MOD2 is an advanced, one-dimensional, two fluid, six-equation, thermal nonequilibrium reactor transient and accident analysis program. The objective of this assessment study is to provide systematic assessment of the RELAP5/MOD2 code relative to code development, code improvement, and the enhancement of user guidelines.

In this study, the test simulations using RELAP5/MOD2 begin with break initiation and subsequent blowdown, and continue through primary fluid saturation, loop liquid seals formation and clearance, two temperature excursions, refill/reflood phenomena, and terminate with core quench. Generally speaking, the primary system depressurization and break flow rate are well predicted by the RELAP5/MOD2 model. However, RELAP5/MOD2 fails to predict the pump

suction liquid seal clearing and the observed two temperature excursions phenomena. According to the extensive comparison between the calculated results and the test data, it is found that the time of primary fluid saturation, core bypass line and broken loop hot leg flow reversal, and broken loop steam generator secondary becoming energy source, are predicted with reasonable good agreement in comparison to the measured events. However, the sequence of events after broken loop pump suction liquid seal clearing occurrence in the experiment are presented with significant differences. The major differences between the calculated results and the test data including pump suction liquid seal formation and clearance, heatup phenomena and LPIS injection actuation etc., are discussed in this report.

Sensitivity analyses of the test simulation with respect to several different modellings or options in code input modifications, including the steam generator secondary side pressure boundary, impediment of reverse flow in both broken loop hot leg and upper plenum, adjustment of intact loop pump speed coastdown to a stop, junction options in modelling the loop-pipe connections to the reactor vessel, rearrangement of the connection direction of break junction, and increment of two-phase discharge coefficient are performed to investigate their impacts on overall system response. On the whole, the modified results indicate limited influence to the system thermal-hydraulic responses.

From the results of this scenario study, it is learned that the present RELAP5/MOD2 model fails to simulate the observed temperature excursions of heater rod. It is believed that the improper simulation of pump suction liquid seal formation and clearance, which would be suspected as the possible defect of the present RELAP5/MOD2 code.

1. INTRODUCTION

This report presents the assessment study of RELAP5/MOD2 using Semiscale Mod-2A facility at the U.S. Department of Energy's Idaho National Engineering Laboratory (INEL). Test S-IB-3 was the last of the three-test Intermediate Break series and was conducted on February 23, 1982. This test was a 21.7%, communicative, cold leg break loss-of-coolant experiment. The principal objective of this test was to provide reference data for comparison of Semiscale test results to Loop Blowdown Investigation (LOBI) facility (Ispra, Italy) B-R1M test results. Also, another important objective was to provide reference data for evaluation and assessment of reactor safety code capabilities to predict integral blowdown, refill/reflood experiments for intermediate break sizes. Still another important objective was to expand the break spectrum data base to cover the 10 to 200% range in order to determine if other phenomena are important to core cooling and to evaluate the Mod-2A system response to breaks in this range.

This report includes the results and conclusions of assessment study involving comparisons between data from Semiscale S-IB-3 [1] and RELAP5/MOD2 [2] code calculated (base case results), investigation of pump suction loop seals formation leading to vessel level depression and two temperature excursion occurrence. In addition, some sensitivity studies involving the effect of steam generator secondary side pressure boundary, increment of two-phase discharge coefficient, intact loop pump coastdown behavior, and some interesting studies regarding break flow etc., are also performed in this report.

2. TEST FACILITY AND TRANSIENT DESCRIPTIONS

2.1 Test Facility

Semiscale Mod-2A is a scaled model representation of a four-loop pressurized water reactor (PWR) nuclear generating plant, with a fluid volume of about 1/1705 of a PWR. The scaling philosophy followed in the design of the Mod-2A system (modified volume scaling) preserves most of the important first-order effects thought to be important during loss-of-coolant transient.

The system incorporates the major components of a PWR, including steam generators, vessel, pumps, pressurizer, and loop piping as shown in Figure 2.1. The loop piping consists of an intact loop and a broken loop, the former representing three "unaffected loops" of a four-loop PWR, the latter simulating the single "affected loop" in which a break is postulated to occur in a PWR. Each loop includes an active steam generator and coolant pump. The pressurizer is connected to the intact loop hot leg, and the pressure suppression header and tank are connected via the rupture disk assembly to the broken loop cold leg. Emergency core coolant (ECC) from an accumulator and high or low pressure (low pressure only for S-IB-3) injection system pumps are routed to the loop cold leg (intact loop only for S-IB-3). Feedwater is supplied to the two steam generators from a heated tank and the steam routed through control valves to the atmosphere, i.e., an open loop secondary coolant system is used.

For test S-IB-3, the vessel is multi-sectional consisting of an upper head, upper plenum, heated core region, lower plenum, and an external inlet annulus and downcomer pipe. The core simulator consists of a 5×5 array of electrically heated, 3.66-m-long, 1.072-cm-outside-diameter rods which simulate the fuel rods in a 15×15 type PWR core. Equal power was applied to the 23 heated rods as shown in

Figure 2.2; and two of the rods were unpowered. The peak to average power ratio is 1.55 and the total design power per rod is 116 kW at 380 Vdc. The maximum linear heat generation rate per rod is 36.8 kW/m and the maximum rod design temperature is 1275 K. The number of turns per inch of the electrical heating coil is varied along the rod length to give the staircase approximation of a cosine axial heat flux shape.

The intermediate break S-IB-3 test involved a break at the horizontal mid-plane of the cold leg pipe, between the broken loop pump and downcomer inlet, and at a position relative to that pipe simulating a break in its wall. This was accomplished by utilizing a communicative break assembly, with break orifice or break nozzle and rupture disk assembly connected to the pressure suppression system. The converging diverging nozzle with throat diameter 0.78867 cm was sized to preserve the ratio of break area to system volume for the LOBI B-R1M test.

Conditions in the system were monitored by an extensive network of metal and fluid thermocouples and differential pressure transducers. In the affected (broken loop) steam generator, both tubes were extensively instrumented with both primary- and secondary- side fluid thermocouples and several primary-side differential pressure transducers. Average fluid density was measured in the loops and vessel with gamma densitometers while volumetric flow was measured with turbine meters. Condensing systems and catch tanks were included to measure effluent from the steam generator atmospheric dump valves and the break assembly (break flow).

2.2 Transient Descriptions [3]

Test S-IB-3 was performed in the Semiscale Mod-2A facility. The experiment simulated intermediate break loss-of-coolant accident involving 21.7% break area

of the cold leg in a PWR with inverted top hat, non-UHI upper internals. This test duplicated, as closely as possible, a test of LOBI B-R1M conducted in March of 1981 in the Loop Blowdown Investigation Facility, which was a 25% break test in the LOBI facility in Ispra, Italy.

The test was conducted from initial conditions of 15.5 MPa and 563 K (average of both loops cold leg temperature at downcomer inlet) with a simulated break size (21.7%) of the broken loop cold leg piping at an initial core power level of 1.44 MW, and an initial core inlet flow rate of 7-8 kg/s adjusted to permit achievement of core 33 K temperature rise. After initiation of blowdown, the exact timing of the occurrence of the controlled events can be found in Table 2.1. Immediately after rupture of the pressure boundary, the core power and pump speeds began following controlled transients. Shortly after the pressurizer pressure reached 12.6 MPa, the broken loop steam generator steam valve was closed at 5 s. This was followed by closure of the broken and intact loop steam generator feedwater valves at 2.5 s and 30 s, respectively. Approximately 163 s after the depressurization of the primary system continued, and the accumulator actuation pressure (2.7 MPa) was reached, the accumulator flow was initiated. Upon reaching a primary system pressure of 1 MPa, the intact loop steam generator steam valve was closed, the power to the broken loop pump was tripped and Low-pressure Injection System (LPIS) flow was initiated shortly thereafter. The test were terminated upon reaching the end of available data acquisition space.

The depressurization of the primary system caused the vessel upper plenum fluid to reach saturation conditions within 1 to 2 s after rupture of the pressure boundary. As the vessel coolant was displaced from the core, the heater rod temperatures began to increase. Before the blowdown ends at the system pressure

of 1 MPa, the vessel lower plenum was refilled and reflooding of the core was initiated. Thereafter, the reflooding of the core associated with the flow of LPIS liquid led to the eventual quench of the core at 350 s.

3. CODE AND MODEL DESCRIPTIONS

3.1 Computer Code

The RELAP5/MOD2 Cycle 36.04 computer code is used to simulate the transient thermal-hydraulic response of the semiscale Mod-2A system during experiment S-IB-3. RELAP5/MOD2 is based on an one-dimensional, two fluid, six-equation, thermal non-equilibrium non-homogeneous hydrodynamic model and includes thermal-hydraulic and component models, to describe the processes that occur during the blowdown of a PWR. This computer code is developed at the INEL for the U.S. Nuclear Regulatory Commission (USNRC). Specific application of the code to the experiment S-IB-3 simulation is discussed in the following sections.

3.2 Model Descriptions [4]

The RELAP5/MOD2 model of the Semiscale S-IB-3 simulation is shown in Figure 3.1. The nodalization used in this study is based on the nodalization presented in Reference 5. This model consists of 142 hydraulic volumes, 139 junctions and 167 heat structures to describe the Semiscale Mod-2A system including reactor vessel, broken loop, intact loop, pressurizer, steam generator, and ECCS. Brief descriptions of the RELAP5/MOD2 model of the Semiscale Mod-2A facility are presented as follows.

3.2.1 Reactor Vessel

The reactor core is modelled by six control volumes of equal length covering the active length of the heated core (3.66m). The twelve-step axial power profile is modelled within these six volumes (two steps per volume). Equal power was applied to the 23 heated rods; two of the rods were unpowered. In modelling of the reactor vessel, a total of 36 hydraulic volumes and 42 junctions were used to represent the vessel hydraulic space.

The downcomer inlet annulus are branch components which connect the piping cold legs to the downcomer and upper head bypass line. In Semiscale, the annular downcomer of a PWR vessel is replaced with an external pipe to permit extensive instrumenting of both the core and downcomer regions. The downcomer control volume boundaries occur at the same elevations as control volumes in the vessel for ease in liquid level tracking. The lower plenum and upper plenum are divided into several control volumes and simulated by branch or single-volume components in the RELAP5/MOD2 model. Flow resistance and percent bypass flow through the upper head bypass line is adjusted at the junction between the two control volumes of component.

A total of 44 heat structures representing the flow ducts and reactor vessel are modelled to describe the appropriate heat transfer between different flow channels, and ambient. Heat transfer between physical structures and primary coolant is modelled by defining the appropriate geometry and boundary conditions in RELAP5/MOD2 heat structure components. The environmental heat loss components are bounded by a primary coolant volume and an ambient (air) volume. Besides, honeycomb and steam gap insulators were also appropriately modelled.

3.2.2 Broken Loop

Modelling of the broken loop deserves careful attention since the accuracy of the break flow calculation is of major importance in the predictions of the system responses. In this study, the broken loops (hot leg and cold leg) are simulated by a series of branch and pipe components, and the break junction is simulated by a trip valve with $4.885 \times 10^{-5} \text{ m}^2$ flow area of a converging/diverging nozzle. Downstream of the break junction, the broken loops are connected to time-dependent volume where the pressure boundary condition of the blowdown suppression tank is provided. Flow areas and flow resistances of the junctions along the broken loops are specified to simulate the pump suction, steam generator, and broken loop piping. Choked-flow model is applied to the junctions wherever the junction flow area is restricted.

Determination of the break geometry is also of importance in accurately calculating the break flow. A discharge coefficient is required to account for multi-dimensional effects at the break that cannot be calculated using one-dimensional computer codes. A recommended discharge coefficient of 1.0 and 0.84 are applied in the broken loop cold leg break for subcooled and saturated choked flow, respectively.

3.2.3 Intact Loop

In modelling of the intact loops, the hot leg, steam generator, primary coolant pump (PCP), and cold leg are simulated by branch, single-volume, pipe, and pump components. Control volumes are divided at interfaces of flow area change, branching locations or instrument locations. Pump characteristics (including head curves and torque curves) are provided for single-phase homologous conditions. A set of two-phase multiplier and difference curves are input, in conjunction with the single-phase curves, to calculate the two-phase pump performance. Two major branch locations are the pressurizer in the hot leg and ECC injection in the cold leg.

3.2.4 Pressurizer

In modelling of the pressurizer attached with the intact loop hot leg, five control volumes were used to model the pressurizer vessel. Five control volumes and related single-junction are modelled in the pressurizer surge line nodalization. A total pressurizer liquid mass (including surge line) of 10.1 kg is modelled with the liquid/vapor interface occurring at 85 in. above the hot leg centerline.

3.2.5 Steam Generator

The hydrodynamic model of both the intact and broken loop steam generators is very similar. It was developed to adequately represent the important geometric characteristics of the primary and secondary coolant flow paths. The steam generator primary side is represented by two single-volume components in modelling of the inlet and outlet plena, and an eight-section pipe (with four sections direct vertically upward and four sections direct downward) in simulating the steam generator U-tubes. In the secondary side, it is represented by a series of feedwater system, downcomer, boiler, separator, and riser simulations based on various components available in the RELAP5/MOD2 code. In modelling of the separator, the steam inlet and vapor outlet junction orientations, which can be freely defined in RELAP5/MOD1, were restricted according to the input requirement of RELAP5/MOD2. At the exit of the secondary side, a time-dependent volume is used to provide the pressure boundary conditions of the air-cooled condenser. Cylindrical heat structures representing the tubes are added to permit the heat exchange between the primary and the secondary sides of the steam generator. Additional heat structures are also used to simulate the heat loss to the environment.

3.2.6 ECCS

The emergency core cooling systems, including the accumulator and LPIS are simulated in the RELAP5/MOD2 model. The accumulator is represented as a time-dependent volume. It is actuated at a given time rather than by a specified low pressure of 2.7 MPa. The LPIS is modeled by a time-dependent junction which is activated by a low system pressure of 1 MPa. The LPIS is operated by centrifugal pump, which is controlled to inject coolant at a pre-programmed rate.

In addition to the system modelling, adequate control variables including fuel temperature, collapsed water level, pressure, and volumetric flow rate etc., are generated so that direct comparison with test data could be made. All input data are listed in the Appendix.

3.3 Initialization Process

The RELAP5/MOD2 model of the Semiscale S-IB-3 experiment simulation is initialized to a steady-state corresponding to the test initial conditions before it is utilized for the intermediate break LOCA transient analysis. During initialization, the following processes are taken:

- (1) Through reviewing the available documents in hand, no information about feedwater, break flow rate, and steam valve open rate have been provided. Besides, the measured hot leg temperature in broken loop presented in Table 5 (596.9 K) and Appendix (589.6 K) of Report No. EGG-SEMI-6013[6] are not consistent. Consequently, an effort was initiated to simulate feedwater flow rate and steam valve open rate using control system, which should be adjusted to meet the required energy balance and 1:3 loop steam flow ratio criteria. The measured break flow rate is calculated from the summation of

the product of the volumetric flow rate and density of control volume C362 and C363, which is adjacent to break junction near the pump side and vessel side, respectively. The measured hot leg temperature in broken loop is calculated from the mean value of the above two temperatures.

- (2) In broken loop pump behavior study according to the primary coolant pump rated parameters in Ref. 4, it is difficult to simulate the desired rated pump flow rate and pump head if initial rated pump speed is used in RELAP5/MOD2 model. To retrieve this situation, utilizing pump flow rate in the model was attempted to calculate a reasonable rated pump speed through using control system methodology.
- (3) By inspecting the measured and calculated differential pressure and liquid level in both loops and vessel during initialization process, many discrepancies were found between them. It is believed that the measured data offered in the document (Ref. 1) doesn't represent the actual pressure drop. The actual pressure drop can be obtained by taking into account the effect of gravitational pressure drop associated with the reference leg between them. Thus, the measured data need to be modified before they are compared with the calculated data. The revised differential pressure and liquid level are shown in Tables 3.1~3.3 for intact loop, broken loop and pressure vessel, respectively.
- (4) After revising the differential pressure and liquid level, and put them into the initialization model, the forward and reverse form loss coefficients (K factor) were adjusted in order to reach a steady state which is close to the test initial condition during initialization process. The liquid level of the steam generator

secondary side in intact loop (measured data is 732.7 cm) and broken loop (measured data is 713.8 cm) are not consistent with the differential pressure measured at the test's initial condition. Because there is no liquid level data during the transient, the differential pressure data is selected. Consequently, the liquid level of intact and broken loop were revised into 1050.0 cm and 982.0 cm, respectively.

Five hundred seconds of steady-state calculation was proceeded. It was achieved by using some initialization techniques including pressurizer pressure control, S/G steam valve and feed valve closure, pump coastdown, and ECCS actuation control, etc. The calculated initial conditions of the RELAP5/MOD2 model obtained by the initialization process are listed in Table 3.4 in comparison with the specified and measured data. The comparison shows minor differences between measured and calculated results, however, they almost matched quite well and were acceptable.

4. RESULTS AND DISCUSSIONS

In this section, analytical results of the experimental simulation of the thermal-hydraulic responses of S-IB-3 test are assessed through comparison of test data. Besides, effects of several different modellings are also independently investigated as sensitivity studies to compare with base case results and test data.

4.1 Base Case Analysis

4.1.1 General System Response

Test results of approximately 320 seconds of transient time were used to assess the RELAP5/MOD2 code. Following the test procedure in S-IB-3 simulation, the transient calculation initiated by the opening of break valves, has the following major calculated event timings as compared to the test data listed in Table 4.1.

Apparently, there is no significant difference between the calculated transient scenario and the test result during the first 30 seconds except that the upper plenum fluid saturation is delayed by about 14 seconds. However, the major phenomena, such as the formation of pump suction liquid seals, core heat up and refill/reflood phenomena occurrence, are not properly predicted by RELAP5/MOD2.

4.1.2 Reactor Vessel and Loop Hydraulic Response

The break was opened at 0 s and the primary system began a linear depressurization due to steam volume expansion in the pressurizer that was supplying liquid to the loops to compensate for inventory depletion through the break. Figure 4.1 and 4.2 shows the calculated upper plenum and pressurizer pressure, respectively, compared to the test data. It is illustrated that the system pressure response is well predicted and an extremely rapid system depressurization occurs during the first 15 seconds, then decreases gradually thereafter. Figure 4.1 shows that both the calculated and measured pressure drop from 15.5 MPa to 12 MPa immediately after the test initiation. As the pressure decreases, the temperature of the liquid in the vessel reaches saturation and flashing phenomenon occurs. Consequently, the depressurization rate is reduced by the voiding in the vessel as shown in both the calculated result and test data. At the first 130 seconds, the calculated pressure closely follows the test data, while it is slightly overpredicted thereafter by RELAP5/MOD2. The fluid reaches saturation condition and starts to flash by 3.6 seconds in the broken loop hot leg, and shortly afterward by 4.1 seconds in the intact loop hot leg, as shown in Figure 4.3. Figure 4.4 also compares the coil leg temperatures of both loops and saturation and shows that nearly all of the system became saturated by 15 to 20 seconds which is well approached to the experimental results. According to the calculated pressurizer water level response shown in Figure 4.5, the pressurizer empty occurs at 10 s after the test initiation is found to be delayed by 3 seconds in comparison with the test data.

By investigating the overall experimental phenomena, system behavior during the first 130 s of the transient was characterized by continuous voiding from the upper elevations going downward. The phenomena of interest include gravity drain, liquid holdup in the steam generator tubes and pump suction upflow legs due to steam flow, and the formation of liquid seals in the pump suction piping. The calculated differential pressure and liquid level of the broken loop pump suction upflow leg are presented in Figure 4.6 and 4.7, respectively. It shows that RELAP5/MOD2 underpredicts the formation of loop liquid seals from 10 to 25 seconds, whereas it fails to simulate the liquid seal clearance at 25 second. According to the experiment, hydraulic seals are formed in the pump suction loop U-bend piping as a result of the slow gravity dominated depletion of primary coolant. The liquid seals impede the flow of vapor (generated in the core) through the coolant loop piping thus preventing steam venting from the break and this in turn can induce a differential pressure between the reactor vessel and downcomer. As a result of failing to simulate the liquid seal clearance at 25 second, the calculated result is overpredicted by RELAP5/MOD2 during the period of 30 s to 150 s as shown in Figure 4.6. Thereafter, the restriction of vapor flow around the loops is reduced due to the fact that the pump suction liquid seal clears. Figure 4.8 represents the volumetric flow rate in broken loop cold leg. At 25 second, the measured volumetric flow rate increases as the result of vapor flow rate associated with the liquid seal clearance increased. The fact that this phenomena can't be calculated in the simulation provides another evidence which shows that the liquid seal clearance is not properly simulated.

Figure 4.9 represents the calculated mass flow rate from the upper head to the guide tube and shows that no reversed flow occurs in the guide tube while it is observed in the experiment. Since in the calculation, there is no liquid seals that formed in the pump suction legs, the vapor flow around the loops will not be impeded and the vapor in the vessel will not be forced to flow up the guide

tube into the upper head. On the other hand, the flow calculated in bypass line reverses at about 14.7 s as shown in Figure 4.10 and starts to flow down the bypass line to the downcomer inlet annulus. The occurrence timing is well predicted as compared to the experimental results. After initiation of blowdown, the flow in the broken loop is being restricted and actually stagnated at about 11.6 s as presented in Figure 4.11. This restricted flow caused the liquid which was being held up in the upflow leg of the steam generator tubes to fall back down the tubes and forced the flow in the broken loop hot leg to reverse.

The broken loop steam generator steam valve was essentially isolated prior to and throughout the blowdown, while the intact loop steam generator steam valve was specified to be left open at their steady state operating position until the system pressure reached 1 MPa, then closed. Thus, this effective isolation of the broken loop steam generator caused the secondary pressure in the broken loop steam generator to remain very near to the initial secondary pressure and consequently the broken loop steam generator became a heat source earlier. In Figure 4.12, it is noted that the time by which the broken loop steam generator becomes a heat source is about 12 s earlier than the test result of 22 s. It is suspected that the condition of broken loop steam generator secondary side (whether it is heat source or heat sink) has a major effect on the prediction of the broken loop hot leg flow reversal. Further discussion will be made in the sensitivity study later. In contrast, the intact loop steam generator became a heat source arisen by 300 s which occurred much later than the test result. This evidence is shown in Figure 4.12.

In Figure 4.13, it is seen that the calculated break flow transition from subcooled to saturated condition occurs at 10 s. That is, single-phase blowdown ends and two-phase blowdown begins at the cold leg break 10 s after the experiment initiation. The comparison between the calculated break mass flow rate and test one is shown in Figure 4.14. It indicates that the flow is characterized by a

large peak, followed by a rapid decrease as the homogeneous flow conditions at the break changed quickly from single-phase to two-phase. In general, there is a large drop in critical velocity when the flow changes from a subcooled state to a two-phase state. This sudden change often leads to unrealistic velocity oscillation and unstable flow regime. Therefore, an underrelaxation scheme is implemented in RELAP5/MOD2. The large dip at 10 second indicates that the underrelaxation scheme can be further improved. It is also seen that the subcooled break flow rate is underpredicted during the first 30 s, while a better agreement presents during the blowdown period thereafter. It is shown in Figure 4.15 that this underpredicted result consequently leads to less integrated break flow during the blowdown period in comparison with the experimental result. Additionally, the broken loop cold leg mass flow rate and flow regime adjacent to break junction near pump side and vessel side, respectively, are shown in Figures 4.16 through 4.18. The break junction mass flow rate near pump side is well predicted, however, slightly overpredicted near vessel side. The flow regime adjacent to break junction retains the bubbly flow during single-phase blowdown, but an unstable flow regime transition among the bubbly, slug and horizontal stratified flow during two-phase blowdown.

As discussed earlier, the upper head discharged liquid through the bypass line into the downcomer inlet annulus because of the reversed flow in the bypass line. The flow in the bypass line continued to be reversed from about 15 s until the end of the test (as shown in Fig. 4.10) with transition from liquid to vapor flow at about 60 s (earlier than experimental data) when the top of the bypass line uncovered, as shown in Figure 4.19. It is also noted in both Figures 4.19 and 4.20 that in the calculation the upper head was not completely drained of fluid. The water inventory in the upper head decreased slowly after the transition from liquid to vapor flow till the end of the test. It is different from the test result that the upper head was completely drained of fluid by about 140 s as shown in Figure 4.19.

Figure 4.21 and 4.22 presents the differential pressure in intact loop pump up-flow and downflow leg, respectively, which indicates that no liquid seals formation and clearance occurred during the blowdown period. It can also be seen from Figure 4.23 that liquid level in intact loop pump suction upflow retains a monotonous decrease, while no abrupt change in liquid level occurs during the clearout period of liquid seals from 89 to 160 s, which is evidently different from the experimental results. Thus, it is concluded that RELAP5/MOD2 fails to predict the liquid seals phenomena in intact loop pump suction. Furthermore, Figures 4.24 through 4.26 show the mass flow rates of intact loop hot leg, cold leg and vessel downcomer, respectively. It illustrates that intact loop acts as a "liquid slug amplifier" since the liquid slug calculated around 25 second is amplified along the loop downstream due to the condensation resulted from intact loop steam generator cooling and liquid-vapor mixing in the piping. Since this behavior is not observed in the test, it may partially explain the overprediction of intact loop flow rate during the first 150 s. The measured pressurizer volumetric flow rate in Figure 4.27 is shown to rise sharply at 7 s, characteristic of an abrupt transition from liquid to two-phase flow. The occurrence timing and the magnitude of peak flow rate are well predicted during the transition, while the slope change in a drastic reduction is steeper than the test data. In Figure 4.28, it is also noted that the calculated pressurizer surge line mass flow empty occurred at 10 s after the test initiation.

4.1.3 ECC and Core Thermal Response

As described earlier, the calculated accumulator liquid as shown in Figure 4.29 starts flowing into the intact loop cold leg at 163 seconds. It is virtually the same with the test results due to the fact that the accumulator is modelled by a time-dependent volume instead of pressure controlled actuation at 2.7 MPa.

According to the experimental phenomena, because of the condensation of steam at the injection point, a region of lower pressure was formed at the injection point, causing steam to flow up the external, single pipe downcomer. It can be seen in both the calculated and measured data of Figure 4.30. Also, owing to the pressure differential between the vessel and the break, the steam flow up the downcomer was of sufficient magnitude to force the ECC liquid around the downcomer inlet annulus and to the break (as shown in Figure 4.31), bypassing the core between 163 and 190 s. With the blowdown nearly over, the large driving force for flow up the downcomer diminished and the ECC was able to penetrate the downcomer and flow into the core [7]. However, Figure 4.29 also indicates that there is no LPIS injection during the blowdown transient. Since the LPIS pump is specified to inject liquid into the intact loop when the pressurizer pressure reaches 1 MPa, while the system pressure is always above 1 MPa throughout the blowdown.

In general, the accumulator water, the formation of pump suction liquid seals, and the core power are the major factors affecting the core thermal response during blowdown [8]. Before we discuss the calculated core thermal responses of S-IB-3 test, the experimental temperature excursions are described below. A composite core temperature trace for this test consists of a decrease in temperature corresponding to the saturation temperature in the core, followed by a rapid increase in temperature starting at about 50 seconds, to a peak temperature in the range of 740 K, and then followed by another, slower, decrease until the core is rewet at about 133 seconds, when a rapid decrease occurs. This is followed by a reduction in the cooling rate until the temperature levels out and starts to increase again at about 190 seconds. The temperature then peaks, in the range of 630 K, and starts to gradually decrease until the rod is rewet again at about 280 seconds. From this

point on the temperature drops close to and follows the saturation temperature until the end of the test.

As a matter of fact, the Semiscale heater rods experienced two temperature excursions during test S-IB-3. The first excursion was due to a severe level depression in the vessel caused by the intact loop liquid seal; the second was due to a loss of steam cooling caused by the boiloff of core coolant to an elevation below the bottom of the heated length. However, Figure 4.32 indicates that the RELAP5/MOD2 fails to predict any of the temperature excursions. The improper simulation of pump suction liquid seal formation and clearout phenomena could be considered as the major reason. Additionally, the other cause of disagreement that RELAP5/MOD2 predicts no heatup is suspected due to the fact that the calculated core coolant inventory is essentially homogeneous whereas core liquid was highly stratified in the experiment[7]; this is probably also responsible for the overprediction of core collapsed liquid level depression as shown in Figure 4.33.

From immediately after rupture until 2 seconds, there was a rapid rise in void fraction in the upper half of the core. Figure 4.34 shows that both the calculated and test data experience this phenomenon. This void formation was caused by boiling due to the release of stored energy from the heater rods and to decay heat transferred to the fluid. When the stored energy in the rod was reduced, some of the voids collapsed in the period from 2 to 3 seconds in the high power region of the core as shown in Figure 4.34. However, according to the experiment after liquid formed seals in the pump suction, the steam generated in the core was restricted from flowing freely around the loops to the break. Lack of a sufficient relief path for the steam resulted in the depression of the liquid level in the vessel and pump suction upflow legs. The lowered vessel level allowed the void fraction

in the entire core to get high enough to cause dryout on all of the heater rods. In contrast, RELAP5/MOD2 cannot give the prediction of the liquid formed seals in the pump suction, therefore, an unrestricted steam generated in the core can flow freely around the loops to the break, this leads to impediment of heatup. The overpredicted density in vessel during the blowdown as shown in Figure 4.34 can also be accounted for this result.

4.2 Sensitivity Studies

In addition to the base case calculation, sensitivity studies are performed to explore the effects of input modelling and code options. Scenario study and simple model modification, such as the effect of steam generator secondary side pressure boundary, intact loop pump coastdown behavior, and some interesting studies regarding break flow, etc., are also analyzed to elucidate the code capability. The identifications of the cases performed in this study are listed in Table 4.2 with the conditions which are different from that of the base case. The purpose and the results of the sensitivity studies are discussed in the following sections.

4.2.1 PRESSB This case study is used to identify the influences of primary coolant system thermal-hydraulic response predictions resulted from providing pressure boundaries in steam generator secondary sides. The calculated system pressure and break mass flow rate in this case as shown in Figure 4.35 and 4.36, respectively, indicates that results are similar with the base case except the break mass flow rate slightly overpredicts during 70 s to 110 s. In Figure 4.37, calculated cladding temperature in PRESSB case is shown. It is seen that there is still no heatup phenomena in the cladding temperature prediction resulted from no liquid seals formation in the pump suction. Also, there is no significant difference in vessel

response, except that less liquid inventory in vessel is seen during the period from 70 s to 110 s because of excess break flow as discussed above. Figure 4.38 and 4.39 shows the calculated density and liquid level in vessel, respectively, and illustrate the above results. Besides, loop flow responses are worthily mentioned. Figure 4.40 and 4.41 presents the intact loop and broken loop hot leg mass flow rate, respectively, and indicates that the calculated loop flow in this case give a better result than that of the base case. In the mean time, the occurrence timing of the broken loop hot leg flow reversal achieves a good agreement in comparison with the test data. As it is discussed in section 4.1.2, it is suspected that the condition in broken loop steam generator secondary side has a major effect on the prediction of broken loop hot leg flow reversal. The well match timing of broken loop flow reversal in PRESSB case confirms this hypothesis. As a whole, it is concluded that providing pressure boundaries in steam generator secondary sides can only give limited influence of primary coolant system thermal-hydraulic responses.

4.2.2 PB - IRFL In this case study, we are interested in impeding the reversed flow both from control volume 301 to 163 and from control volume 164 to 163 on the basis of the pressure boundary study above, to see if the initial liquid slug in the liquid slug amplification phenomena can be eliminated. After adjusting the junction reverse form loss coefficient to almost infinite, it is seen that there is negligible influence in broken loop flow rate as shown in Figure 4.42. Conversely, significant differences are shown in Figure 4.43 and 4.44, the intact loop flow, which results in a better improvement in comparison with the unreasonable overpredicted flow in the base case. Better improvement is also achieved in vessel downcomer mass flow as shown in Figure 4.45. It is concluded that impeding the reversed flow in both broken loop hot leg (C163-C301) and upper plenum (C163-

C164) can only improve the intact loop mass flow, however, there is negligible influence to the system response.

4.2.3 PUMPCD The purpose of this case study illustrates the effect of intact loop pump on intact loop flow rate and core heat up. In the PUMPCD case, intact loop pump speed is adjusted to coast to a stop from 20 s to the end of the test. Minor difference in the calculated break mass flow rate is seen from Figure 4.46 and indicates negligible effect resulted from pump coastdown actuation. The same result can be obtained in heater rod cladding temperature as shown in Figure 4.47. With regard to the influence of intact loop flow, similar results as PB-IRFL case are obtained from Figure 4.48 and 4.49. A better improvement in intact loop flow prediction is appraisable in this case study.

4.2.4 CROSFJ It is recommended that modelling of loop-pipe is connected to the reactor vessel should use the option for cross-flow connections [9]. However, normal junction is specified in RELAP5/MOD2 input as loop-pipe is connected to the reactor vessel in the base case study. Thus, a sensitivity study is needed to investigate the possible impacts of different junction types on the system response. According to the results from Figure 4.50 to 4.53, the hot leg and cold leg junction mass flow rate of both loops indicates that there is no significant influence using either normal or cross-flow junction.

4.2.5 BREAKJ It is interesting to give a sensitivity study in investigating the effects of changing direction of break junction from C362 to C363. It is seen from Figure 4.54 that the calculated break mass flow rate in single-phase blowdown almost approach that of the base case data, whereas a larger difference is presented during the two-phase blowdown period. It is due to the fact that the volume void

fraction of control volumes 362 and 363 in BREAKJ case is different from that of the base case. Also, by looking at the broken loop junction mass flow rates from Figure 4.55 through 4.57, it is concluded that changing the direction of break junction cannot improve the prediction of either break mass flow rate or system thermal-hydraulic responses in any way.

4.2.6 TDC - 1.0 The input of discharge coefficients to RELAP5/MOD2 modifies the flow area of the simulated break by a factor equal to the coefficient. Thus, discharge coefficients other than 1.0 are not representative of the true break area but rather are indicative of possible deficiencies in the break-flow models [9]. A discharge coefficient less than 1.0, however, can be justified as a method of compensating for two-dimensional effect, such as vena contracta, that are not simulated by the one-dimensional RELAP5/MOD2 code. Therefore a two-phase discharge coefficient of 0.84 is recommended as the best selection in the break flow model. In the TDC-1.0 case, the cold leg break two-phase discharge coefficient is increased from 0.84 in the base case to 1.0.

It is seen from Figure 4.58 that the calculated break mass flow rate increases in the two-phase blowdown period by this input change, especially with overpredicted result during 50 s to 110 s from the base case. The other parameters, including the system pressure and cladding temperature responses, shown in Figure 4.59 and 4.60, respectively, are both underpredicted due to the increased break mass flow rate. Additionally, the calculated liquid level and density in vessel as shown in Figure 4.61 and 4.62, respectively, illustrate a better agreement with the base case.

Incidentally, in modelling the junction flag option for ECC injection point, a computational failure occurred with flag 00120 assumption, however, this was

removed by using flag 20121 instead. The major differences between the flag options are the selection of centrally located or downward oriented junction and another selection of normal or cross-flow junction.

5. RUN STATISTICS

The computer run statistics of the RELAP5/MOD2 simulations are summarized in Table 5.1. The simulations are conducted on a FACOM M200 computer which is compatible to the IBM MVS system.

6. CONCLUSIONS

In this study, the intermediate break Semiscale test S-IB-3 is analyzed by the RELAP5/MOD2 model. The test simulations begin with break initiation and subsequent blowdown, and continue through primary fluid saturation, loop liquid seals formation and clearout, two temperature excursions, refill/reflood phenomena, and terminate with core quench. Generally speaking, the primary system depressurization and break flow rate are well predicted by the RELAP5/MOD2 model. However, RELAP5/MOD2 fails to predict the pump suction liquid seal clearing and the observed temperature excursions phenomena. Through extensive comparison with measurement and important sensitivity studies elaborated in the previous section, noticed differences and major findings are described in the following:

- (1) The calculated system pressure is well predicted and an extremely rapid system depressurization occurs during the first few seconds after the test initiation. All of the fluid in the system nearly becomes saturated by 15 to 20

seconds which is well matched with the experimental results, while a significant difference is calculated in estimating the occurrence timing of the upper plenum saturation.

- (2) The loss of primary coolant is predominantly a gravity-dominated drain during which the liquid located in the pump suctions would form hydraulic "seals" [10,11]. These loop seals would impede the flow of steam from passing through the hot legs to the break. One significant consequence during loop seal formation is that the break flow will be primarily liquid; thus, once the loop seal clears, less coolant will be available to mitigate any core heatup which could occur during the boiloff phase. Unfortunately, according to the base case results, it is concluded that RELAP5/MOD2 fails to predict the pump suction liquid seal formation and clearout phenomena. This result indicates a possible deficiency in the interphase drag model and/or flow stratification model of the present RELAP5/MOD2 code.
- (3) It is suspected that the condition of broken loop steam generator secondary side (whether it is heat source or heat sink) has a major effect on the prediction of the broken loop hot leg flow reversal. In addition, the occurrence timing prediction of the steam generator secondary side becoming energy source, in comparison with the test data gives an acceptable result in broken loop, whereas an extreme delay in intact loop. The major reason of its postponement may be due to the fact that system depressurization during the blowdown can hardly reach 1 MPa, which is specified as the pressure of the intact loop steam generator steam valve isolation.

- (4) RELAP5/MOD2 barely gives an acceptable result in the prediction of the cold leg break flow during the first 30 seconds, while a better agreement presents during the blowdown period thereafter. As a matter of fact, subcooled break flow rate is evidently underpredicted while saturated break flow rate is slightly underestimated. The underpredicted break flow rate results in the excessive water inventory retained in the vessel. In the sensitivity study, the two-phase discharge coefficient of 1.0 (instead of 0.84 in the base case) is used in the broken loop cold leg, it is found that the modified break flow rate is increased in the two-phase blowdown period by this input change, especially with overpredicted result during 50 s to 110 s. A discharge coefficient less than 1.0, however, can be justified as a method of compensating for two-dimensional effect, such as vena contracta, that are not simulated by the one-dimensional RELAP5/MOD2 code. Therefore a two-phase discharge coefficient of 0.84 is recommended as the best selection in the break flow model.
- (5) By investigating the intact loop mass flow rate, a "liquid slug amplification phenomena" is calculated and excessive liquid is predicted in intact loop. However, it is not observed in the experiment. In the sensitivity study of PB-IRFL and PUMPCD cases, either impeding the reversed flow in both broken loop hot leg and upper plenum, or adjusting intact loop pump speed coastdown to a stop at 20 s, giving a better agreement in the prediction of intact loop mass flow rate. However, both of them have negligible influence to the system thermal-hydraulic response.
- (6) Two observed temperature excursions of heater rod are not predicted. The improper simulation of pump suction liquid seal formation and clearout phe-

nomena could be the major reason. Besides, the other cause of disagreement that RELAP5/MOD2 predicts no heatup is suspected due to the fact that the calculated core coolant inventory is essentially homogeneous whereas core liquid was highly stratified in the experiment. Thus, it indicates that the loop fluid seal and vertical stratified flow modelling employed in this study is quite important in an intermediate break LOCA analyses.

- (7) In the sensitivity studies, the influence of providing pressure boundaries to the steam generator secondary sides was shown to be of limited significance relative to the primary coolant system response. Besides, modelling of loop-pipe connections to the reactor vessel with the option of either normal or cross-flow connections, may result in minor difference of overall system response. With regard to the change of pipe connection direction of break junction, it is found that a larger difference is presented during the two-phase blowdown period because of the different upstream volume void fraction prediction.
- (8) Finally, in modelling the junction flag option for ECC injection point, a computational failure occurred with flag 00120 assumption, however, it was removed by using flag 20121 instead. The major differences between the flag options are the selection of centrally located or downward oriented junction and another selection of normal or cross-flow junction.

Table 2.1
Chronology of Events for The Intermediate Break S-IB-3 Test

Events	Time, Seconds
Rupture initiated; Core power, pump speed transients initiated	0
Upper plenum fluid saturates	1.5
Broken loop steam generator feedwater valve closed	2.5
Intact loop steam generator feedwater valve closed	30
First temperature excursion starts	50
Accumulator flow starts	163
Lower plenum refilled; Reflood starts	190
Intact loop steam generator steam valve closed	240
Blowdown ends; LPIS flow starts; Power to broken loop pump tripped	240
Core quenched	350
Data acquisition system shut down	531

Table 3.1

Revised Differential Pressure and Liquid Level in Intact Loop

Measurement ID	ΔP , test (kPa)	Volume or Junction	Elevation Difference (cm)	ΔP , corrected (kPa)
D-V13A+11	7.8	16301/20102	33.0	11.03
DPI*1*3C	5.05	20102/20201	0.0	5.05
DPI*3C*5	1.26	20201/20301	58.0	6.94
DPI*5*9	117.0	20301/24002	39.0	120.82
DPI*9*14	15.1	24002/24005	-380.0	-22.14
DPI*14*18	-2.51	24005/24008	257.0	22.68
DPI*21*18	219.2	26102/24008	25.0	-216.55
DPI*21*22	1.06	26102/26201	0.0	1.06
D*122+VD29	6.04	26201/10101	10.0	7.02
LIS1117+50	50.79	60304/60201	-1067.0	-53.78

Table 3.2

Revised Differential Pressure and Liquid Level in Broken Loop

Measurement ID	ΔP , test (kPa)	Volume or Junction	Elevation Difference (cm)	ΔP , corrected (kPa)
D-V13A+50	6.85	16301/30102	33.0	11.08
DB+50+55	5.28	39102/30103	0.0	5.28
DB+55+57	0.63	30103/30104	61.0	6.61
DPB+57+62	112.96	30104/34002	9.0	113.84
DPB+62+65	15.83	34002/34005	-377.0	-21.12
DPB+65+73	1.10	34005/34007	233.0	23.93
DB+74+73	-254.74	36101/34007	58.0	-249.06
DB+74+76U	8.16	36101/36201	0.0	8.16
DB+76U+79	4.16	36201/36302	0.0	4.16
D+B79+VD29	0.15	36302/10101	25.0	2.60
LBS1117+50	49.39	70304/70201	-3567.0	-55.18

Table 3.3

Revised Differential Pressure and Liquid Level in Vessel

Measurement ID	ΔP , test (kPa)	Volume or Junction	Elevation Difference (cm)	ΔP , corrected (kPa)
LVD+29-578	35.47	10101/12001	-607.0	-23.99
LVD+29-170	15.76	10101/11003	-199.0	-3.742
LVD17C-435	17.27	11003/11008	-265.0	-8.70
LVD435-578	4.76	11008/12001	-143.0	-9.25
LV+421-578	-38.23	19401/12001	-999.0	-136.13
LV+421-13M	18.75	19401/16301	-434.0	-23.78
LV+421+160	6.11	19401/19101	-261.0	-19.47
LV-13M-578	-54.98	16301/12001	-565.0	-110.37
LV-13M-105	-10.67	16301/16101	-92.0	-19.69
LV-105-195	-19.29	16101/15005	-90.0	-28.11
LV-195-278	-7.67	15005/15004	-83.0	-15.81
LV-278-360	-7.54	15004/15003	-82.0	-15.58
LV-360-442	-4.90	15003/15001	-82.0	-12.94
LV-442-501	-1.56	15001/14001	-59.0	-7.34
LV-501-578	-15.53	14001/12001	-77.0	-23.08

Table 3.4
Comparison of Specified, Measured, and
Calculated Initial Conditions

	Specified	Measured	RELAP5/MOD2 Calculated
1. Primary Coolant System			
Intact/Broken loop flow rate	3:1	2.9:1	3:1
Pressurizer pressure (MPa)	15.5 ± 0.2	15.53	15.47
Upper plenum pressure (MPa)	15.5 ± 0.2	15.58	15.49
Cold leg temperature (K)			
Intact loop	563 ± 2	559.4	560.3
Broken loop	563 ± 2	566.4	568.0
Hot leg temperature (K)			
Intact loop	596 ± 2	596.1	593.6
Broken loop	596 ± 2	596.9	593.9
Core temperature rise (K)			
Intact loop	33	36.7	33.3
Broken loop	33	30.5	25.9
Total core electrical power (MW)	1.44 ± 0.05	1.45	1.45
Core inlet flow rate (kg/s)	7 ~ 8	8.02	8.01
Core bypass flow (% of Total)	2.5	3.7	3.44
Pressurizer liquid mass (kg)	8.2 ± 0.1	10.1	9.99

Table 3.4
 Comparison of Specified, Measured
 and Calculated Initial Conditions (Cont'd)

	Specified	Measured	RELAP5/MOD2 Calculated
2. Secondary Coolant System			
Steam Generator			
Secondaries Pressure:			
Intact loop (MPa)	5.4 ± 0.2	6.48	6.47
Broken loop (MPa)	5.4 ± 0.2	7.53	7.51
Feedwater Temperature:			
Intact loop (K)	483 ± 2	492.5	494
Broken loop (K)	483 ± 2	484.7	494
Steam Temperature:			
Intact loop (K)	542 ± 2	553.5	553.6
Broken loop (K)	542 ± 2	564.4	563.6
3. Coolant Injection System			
Intact loop accumulator			
Pressure (Mpa)	2.7 ± 0.1	2.6	2.6
Water temperature (K)	305 ± 10	298	299.6
4. Pressure Suppression System			
Suppression tank			
Pressure (Mpa)	0.024 ± 0.01	0.25	0.25

Table 4.1
Comparison Between Calculated and Measured Sequence of Events

Events	Time, Seconds	
	RELAP5/MOD2	Measured
Rupture initiated	0	0
Upper plenum fluid saturates	15.9	1.5
Fluid in intact loop hot leg saturates	4.1	2.2
Broken loop steam generator feed valve closed	B.C. ^a	2.5
Fluid in broken loop hot leg saturates	3.64	4.5
Pressurizer empties	9.96	7
Guide tube flow reverses	N/A ^b	14
Core bypass line flow reverses	14.68	14
Fluid in broken loop cold leg (downcomer to break) saturates	10	16
Fluid in intact loop cold leg saturates	13	17
Flow reverses in broken loop hot leg	11.6	22
Broken loop steam generator secondary becomes energy source	11.8	22
Broken loop pump suction liquid seal starts to clear	35	27
Intact loop steam generator feed valve closed	B.C.	30
Intact loop pump reaches steady (.37) of initial speed	B.C.	30
Broken loop pump reaches steady (.52) of initial speed	B.C.	30
First temperature excursion starts	N/A	50
Intact loop pump suction liquid seal starts to clear	N/A	89
Intact loop steam generator secondary becomes energy source	300	105
Accumulator liquid flow starts	B.C.	163
Accumulator liquid bypass ends, Refill starts, Secondary temperature excursion starts	N/A	190
Most of core quenched	N/A	280

a: Boundary Conditions

b: Unpredicted Events

Table 4.2
Cases Analyzed in the Sensitivity Studies of the
Semiscale Test S-IB-3 Simulation


Cases	Condition Descriptions
PRESSB	Providing pressure boundaries in steam generator secondary side
PB-IRFL	Infinite reverse form loss coefficients between the junctions C163-C301 and C163-C164 are used to impede the reversed flow
PUMPCD	Intact loop pump speed coasts to a stop from 20 s to the end of the test
CROSFJ	Cross-flow junction is used (instead of normal junction in the base case) in modeling of loop-pipe connections to the reactor vessel
BREAKJ	Change the direction of break junction from C362 to C363
TDC-1.0	Two-phase discharge coefficient of 1.0 (instead of 0.84 in the base case) is used in the broken loop cold leg

Table 5.1
Run Statistics of the Semiscale Test S-IB-3 Simulation

Cases	Transient Time (s)	CPU(s)	Number of Time Step	Number of Volume Cell	Performance Number *
BASE	323	7039.16	12255	142	4.045
PRESSB	320	6400.94	11080	142	4.068
PB-IRFL	50	1508.86	2500	142	4.250
PUMPCD	90	2653.01	4500	142	4.152
CROSFJ	35	1063.09	1750	142	4.278
EREAJ	30	926.49	1500	142	4.350
TDC-1.0	100	2880.43	5000	142	4.057

* Performance Number =

$$\text{CPU} \times 10^7 / [\text{Number of Time Step}] / [\text{Number of Volume Cell}]$$



Test S-1B-3
INEL 2 1058

Figure 2.1 Semiscale Mod-2A System Configuration for Cold Leg Intermediate Break Test




Figure 2.2 Seaiscale Mod-2A Heated Core Plan View




Figure 3.1 RELAP5/MOD2-Semiscale Intermediate Break Model Nodalization
for Experiment S-IB-3

SIB3 - PRESSURE IN VESSEL UPPER PLENUM




Figure 4.1 Comparison Between the Calculated and Measured Vessel Upper Plenum Pressure of Test S-IB-3

SIB3 - PRESSURE IN PRESSURIZER STEAM DOME




Figure 4.2 Comparison Between the Calculated and Measured Pressurizer Steam Dome Pressure of Test S-IB-3

SIB3 - HOT LEG AND SATURATION TEMPERATURE




Figure 4.3 Calculated Hot Leg and Saturation Temperature of Test S-IB-3 Simulation

SIB3 - COLD LEG AND SATURATION TEMPERATURE




Figure 4.4 Calculated Cold Leg and Saturation Temperature of Test S-IB-3 Simulation

SIB3 - LIQUID LEVEL IN PRESSURIZER




Figure 4.5 Calculated Liquid Level in Pressurizer of Test S-IB-3 Simulation

SIB3 - D/P IN BLP PUMP SUCTION UPFLOW LEG




Figure 4.6 Comparison Between the Calculated and Measured Differential Pressure in Broken Loop Pump Suction Upflow Leg of Test S-IB-3

SIB3 - W/L IN BLP PUMP SUCTION UPFLOW LEG




Figure 4.7 Calculated Liquid Level in Broken Loop Pump Suction Upflow Leg of Test S-IB-3 Simulation

VOLUMETRIC FLOW RATE IN BLP COLD LEG NEAR PUMP




Figure 4.8 Comparison Between the Calculated and Measured Volumetric Flow Rate in Broken Loop Cold Leg Near Pump of Test S-IB-3

SIB3 - COMPARISON OF GUIDE TUBE MASS FLOW RATE




Figure 4.9 Calculated Guide Tube Mass Flow Rate of Test S-IB-3 Simulation

SIB3 - BYPASS FLOW RATE




Figure 4.10 Calculated Core Bypass Line Mass Flow Rate of Test S-IB-3 Simulation

SIB3 - MASS FLOW RATE IN BROKEN LOOP HOT LEG




Figure 4.11 Comparison Between the Calculated and Measured Mass Flow Rate in Broken Loop Hot Leg of Test S-IB-3

COMPARISON OF SYSTEM AND ILP (BLP) PRESSURE




Figure 4.12 Comparison Among the Calculated System, Intact Loop and Broken Loop Steam Generator Steam Dome Pressure of Test S-IB-3

SIB3 - BREAK JUNCTION VOID FRACTION




Figure 4.13 Calculated Break Junction Void Fraction of Test S-IB-3 Simulation

SIB3 - BREAK FLOW RATE




Figure 4.14 Comparison Between the Calculated and Measured Break Mass Flow Rate of Test S-IB-3

COMPARISON OF INTEGRATED BREAK FLOW




Figure 4.15 Comparison Between the Calculated and Measured Integrated Break Mass Flow of Test S-IB-3

SIB3 - MASS FLOW RATE OF C361 NEAR PUMP




Figure 4.16 Comparison Between the Calculated and Measured Mass Flow Rate of Component 361 Near Pump of Test S-IB-3

SIB3 - MASS FLOW RATE OF C3663 NEAR VESSEL




Figure 4.17 Comparison Between the Calculated and Measured Mass Flow Rate of Component 363 Near Vessel of Test S-IB-3

SIB3 - COMPARISON OF BLP COLD LEG FLOW REGIME




Figure 4.18 Calculated Broken Loop Cold Leg Flow Regime of Test S-IB-3 Simulation

SIB3 - LIQUID LEVEL IN UPPER HEAD (19401-19101)




Figure 4.19 Comparison Between the Calculated and Measured Liquid Level in Upper Head of Test S-IB-3

SIB3 - LIQUID LEVEL IN UPPER HEAD




Figure 4.20 Calculated Liquid Level in Upper Head of Test S IB-3 Simulation

SIB3 - D/P IN INTACT LOOP PUMP SUCTION UPFLOW




Figure 4.21 Comparison Between the Calculated and Measured Differential Pressure in Intact Loop Pump Suction Upflow Leg of Test S-IB-3

SIB3 - D/P IN INTACT LOOP PUMP SUCTION DOWNFLOW




Figure 4.22 Comparison Between the Calculated and Measured Differential Pressure in Intact Loop Pump Suction Downflow Leg of Test S-IB-3

SIB3 - W/L IN INTACT LOOP PUMP SUCTION UPFLOW




Figure 4.23 Calculated Liquid Level in Intact Loop Pump Suction Upflow Leg
Simulation of Test S-IB-3

SIB3 - MASS FLOW RATE IN INTACT LOOP HOT LEG




Figure 4.24 Comparison Between the Calculated and Measured Mass Flow Rate in Intact Loop Hot Leg of Test S-IB-3

SIB3 - MASS FLOW RATE IN INTACT LOOP COLD LEG




Figure 4.25 Comparison Between the Calculated and Measured Mass Flow Rate in Intact Loop Cold Leg of Test S-IB-3

SIB3 - MASS FLOW RATE IN VESSEL DOWNCOMER




Figure 4.26 Comparison Between the Calculated and Measured Mass Flow Rate in Vessel Downcomer of Test S-IB-3

SIB3 - PRESSURIZER SURGE LINE FLOW RATE




Figure 4.27 Comparison Between the Calculated and Measured Pressurizer Surge Line Volumetric Flow Rate of Test S-IB-3

PRESSURIZER SURGE LINE MASS FLOW RATE




Figure 4.28 Calculated Pressurizer Surge Line Mass Flow Rate of Test S-IB-3 Simulation.

SIB3 - VOLUMETRIC FLOW RATE OF ACCUM. AND LPIS




Figure 4.29 Calculated Volumetric Flow Rate of Accumulator and Low Pressure Injection System of Test S-IB-3 Simulation

SIB3 - VESSEL DOWNCOMER VOLUMETRIC FLOW RATE




Figure 4.30 Comparison Between the Calculated and Measured Volumetric Flow Rate in Vessel Downcomer of Test S-IB-3 Simulation

SIB3 - COMPARISON OF COLD LEG DENSITIES




Figure 4.31 Comparison Among the Calculated Cold Leg Density of Test S-IB-3

SIB3 - CORE HEATER TEMPERATURE (ROD B-3)




Figure 4.32 Comparison Between the Calculated and Measured Core Heater Temperature of Test S-IB-3

SIB3 - LIQUID LEVEL IN VESSEL (15003-->15001)




Figure 4.33 Comparison Between the Calculated and Measured Liquid Level in Vessel of Test S-IB-3

SIB3 - DENSITY IN VESSEL (RV*23+183)




Figure 4.34 Comparison Between the Calculated and Measured Density in Vessel of Test S-IB-3

SIB3 - SYSTEM PRESSURE




Figure 4.35 Comparison Among Calculated System Pressure of the BASE, PRESSB Cases and Test Data

SIB3 - BREAK FLOW RATE




Figure 4.36 Comparison Among Calculated Break Mass Flow Rate of the BASE, PRESSB Cases and Test Data

SIB3 - CLADDING TEMP. ROD-B2




Figure 4.37 Comparison Among Calculated Cladding Temperature of the BASE, PRESSB Cases and Test Data

SIB3 - DENSITY IN VESSEL (RV*23+183)




Figure 4.38 Comparison Among Calculated Vessel Density of the BASE, PRESSB Cases and Test Data

SIB3 - WATER LEVEL IN VESSEL (1500i-14001)




Figure 4.39 Comparison Among Calculated Vessel Liquid Level of the BASE, RESB Cases and Test Data

MASS FLOW RATE IN INTACT LOOP HOT LEG









Figure 4.40 Comparison Among Calculated Intact Loop, Hot Leg Mass Flow Rate of PRESSB, BASE Cases and Test Data

1

IMAGE EVALUATION TEST TARGET (MT-3)



MASS FLOW RATE IN BROKEN LOOP HOT LEG




Figure 4.41 Comparison Among Calculated Broken Loop Hot Leg Mass Flow Rate of PRESSB, BASE Cases and Test Data

MASS FLOW RATE IN BROKEN LOOP HOT LEG




Figure 4.42 Comparison Among Calculated Broken Loop Hot Leg Mass Flow Rate of PB-IRFL, PRESSB, and BASE Cases

MASS FLOW RATE IN INTACT LOOP HOT LEG




Figure 4.43 Comparison Among Calculated Intact Loop Hot Leg Mass Flow Rate of PB-IRFL, PRESSB and BASE Cases

MASS FLOW RATE IN INTACT LOOP COLD LEG




Figure 4.44 Comparison Among Calculated Intact Loop Cold Leg Mass Flow Rate of PB-IRFL, PRESSB and BASE Cases

MASS FLOW RATE IN VESSEL DOWNCOMER




Figure 4.45 Comparison Among Calculated Vessel Downcomer Mass Flow Rate of PB-IRFL, PRESSB and BASE Cases

BREAK FLOW RATE




Figure 1.46 Comparison Among Calculated Break Mass Flow Rate of PUMPCD, BASE Cases and Test Data

CLADDING TEMPERATURE (ROD B2)




Figure 4.47 Comparison Among Calculated Cladding Temperature of PUMPCD, BASE Cases and Test Data

MASS FLOW RATE IN INTACT LOOP HOT LEG




Figure 4.48 Comparison Among Calculated Intact Loop Hot Leg Mass Flow Rate of PUMPCD, BASE Cases and Test Data

MASS FLOW RATE IN INTACT LOOP COLD LEG




Figure 4.49 Comparison Among Calculated Intact Loop Cold Leg Mass Flow Rate of PUMPCD, BASE Cases and Test Data

JUNCTION FLOW RATE (C163--C201)




Figure 4.50 Comparison Among Calculated C163-C201 Junction Mass Flow Rate of CROSFJ, BASE Cases and Test Data

JUNCTION FLOW RATE (C263--C102)




Figure 4.51 Comparison Among Calculated C263-C102 Junction Mass Flow Rate of CROSFJ, BASE Cases and Test Data

JUNCTION FLOW RATE (C163--C301)




Figure 4.52 Comparison Among Calculated C163-C301 Junction Mass Flow Rate of CROSFJ, BASE Cases and Test Data

JUNCTION FLOW RATE (C102-C363)




Figure 4.53 Comparison Among Calculated C102-C363 Junction Mass Flow Rate of CROSFJ, BASE Cases and Test Data




Figure 4.54 Comparison Among Calculated Break Mass Flow Rate of BREAKJ, BASE Cases and Test Data

JUNCTION FLOW RATE




Figure 4.55 Comparison Among Calculated C330-C340 Junction Mass Flow Rate of BREAKJ, BASE Cases and Test Data

JUNCTION FLOW RATE




Figure 4.56 Comparison Among Calculated C361-C362 Junction Mass Flow Rate of BREAKJ, BASE Cases and Test Data

JUNCTION FLOW RATE




Figure 4.57 Comparison Among Calculated C363 Junction Mass Flow Rate of BREAKJ, BASE Cases and Test Data

SIB3 - BREAK FLOW RATE




Fig. 1.58 Comparison Among Calculated Break Mass Flow Rate of TDC-1.0, BASE Cases and Test Data

SIB3 - PRESSURIZER STEAM DOME PRESSURE




Figure 4.5J Comparison Among Calculated Pressurizer Steam Dome Pressure of TDC-1.0, BASE Cases and Test Data

SIB3 - COMPARISON OF CLADDING TEMP. (ROD B-2)




Figure 4.60 Comparison Among Calculated Cladding Temperature of TDC-1.0, BASE Cases and Test Data

SIB3 - WATER LEVEL IN VESSEL (15001-14001)




Figure 4.61 Comparison Among Calculated Vessel Liquid Level of TDC-1.0, BASE Cases and Test Data

SIB3 - DENSITY IN VESSEL (RV*23+13)




Figure 4.62 Comparison Among Calculated Vessel Density of TDC-1.0, PASE Cases and Test Data

REFERENCES

1. K. E. Sackett and L.B. Clegg, "Experiment Data Report for Semiscale Mod-2A Intermediate Break Test Series (Test-S-IB-3)," EGG-2198, NUREG/CR-2738, June 1982.
2. V. Ransom, et al., "RELAP5/MOD2 Code Manual," NUREG/CR-4312, EGG-2396, August 1985.
3. T. J. Boucher, "Experiment Operating Specification (EOS) for Semiscale Mod-2A Experiment S-IB-3," EGG-SEMI-5787, February 1982.
4. M. T. Leonard, "RELAP5 Standard Model Description for the Semiscale Mod-2A System," EGG-SEMI-5692, December 1981.
5. M. T. Leonard, "Semiscale Mod-2A Test S-IB-3 Pretest Prediction Report," PN-36-82, February 1982.
6. T. J. Boucher and M. T. Leonard, "Quick Look Report for Semiscale Mod-2A Test S-IB-3," EGG-SEMI-6013, August 1982.
7. Yi-Shung Chen, et al., "Assessment of Research to Resolve Uncertainty of Core Heatup for Certain SBLOCAs in LWRs," pp. 2-166 to 2-172, 2nd International Topical Meeting on Nuclear Power Plant Thermal Hydraulics and Operations, April 1986, Tokyo, Japan.
8. T. J. Boucher and R. A. Dimenna, "Semiscale Mod-2A Intermediate Break Test Series-Test Results Comparison," NUREG/CR-5126, EGG-2238, January 1983.
9. W. E. Liskell and R. G. Hanson, "Summary of ICAP Assessments of RELAP5/MOD2," NUCLEAR SAFETY, Vol. 30, No. 3, July-September 1989.

10. L. Piplies, et al., "Highlights of First LOBI-MOD2 Tests," Specialists Meeting on Small Break LOCA Analyses in LWRs, pp.43-57, Vol. 2, Pisa, Italy, 23-27 June 1985.
11. E. A. Shaw and G.G. Loomis, "Vessel Coolant Mass Depletion During A 5% SBLOCA in The Semiscale MOD-2C Facility," Specialists Meeting on Small Break LOCA Analyses in LWRs, pp.159-175, Vol. 2, Pisa, Italy, 23-27 June 1985.

APPENDIX

SEMISCALE INTERMEDIATE BREAK TEST S-13-3 BASE CASE RUN

95 807-11

INPUT DATA BEGIN

*** NEW/RESTART STOT-ST/TRANSIT
0000100 NEW TRANSIT

*** IMP-CHK 7 RUN
0000101 RUN

*** IMP-UN OUT-UN
0000102 BRITISH BRITISH

0000104 NOACTION

*0000105 10.0 15.0 * W

TIME STEP CONTROL CARD

***	TIME-STEP	DT-MIN	DT-MAX	SSDT	MIN-ED	MAJ-ED	REST
0000201	50.0	1.0E-8	0.1	8003	1	250	250 * W
0000201	30.0	1.0E-8	0.02	8003	5	250	250 * W
0000202	400.0	1.0E-8	0.05	8003	10	400	400 * W

MINOR EDIT REQUESTS

*0003XX	VAR	PARAMETER	* REMARK
---------	-----	-----------	----------

*PRESSURE

0000301	CNTRLVAR	110	*999010000
0000302	CNTRLVAR	101	*110030000
0000303	CNTRLVAR	111	*601010000
0000304	CNTRLVAR	119	*701010000
0000305	CNTRLVAR	109	*201020000
0000306	CNTRLVAR	118	*301020000

*PRESSURIZER MASS

0000307 CNTRLVAR 910
* DELTA - P

0000308	CNTRLVAR	110
0000309	CNTRLVAR	151
0000310	CNTRLVAR	152
0000311	CNTRLVAR	153
0000312	CNTRLVAR	154
0000313	CNTRLVAR	155
0000314	CNTRLVAR	156
0000315	CNTRLVAR	157
0000316	CNTRLVAR	158
0000317	CNTRLVAR	159
0000318	CNTRLVAR	160
0000319	CNTRLVAR	161

```

0000320 CNTRLVAR 162
0000321 CNTRLVAR 163
0000322 CNTRLVAR 164
0000323 CNTRLVAR 165
0000324 CNTRLVAR 166
0000325 CNTRLVAR 167
0000326 CNTRLVAR 168
0000327 CNTRLVAR 169
0000328 CNTRLVAR 170
0000329 CNTRLVAR 171
0000330 CNTRLVAR 172
0000331 CNTRLVAR 173
0000332 CNTRLVAR 174
0000333 CNTRLVAR 175
0000334 CNTRLVAR 176
0000335 CNTRLVAR 177
0000336 CNTRLVAR 178
0000337 CNTRLVAR 179
0000338 CNTRLVAR 180
0000339 CNTRLVAR 181
0000340 CNTRLVAR 182

```

* VOLUMETRIC FLOW RATE

```

0000341 CNTRLVAR 60 #I.L.
0000342 CNTRLVAR 76 #B.L.

```

* MASS FLOW RATE

```

0000343 MFLOWJ 635000000
0000344 MFLOWJ 735000000
0000345 MFLOWJ 781010000
0000346 MFLOWJ 450000000

```

* TEMPERATURE

```

0000351 CNTRLVAR 1
0000352 CNTRLVAR 2
0000353 CNTRLVAR 8
0000354 CNTRLVAR 9
0000355 CNTRLVAR 15
0000356 CNTRLVAR 24
0000357 CNTRLVAR 19

```

* PUMP VELOCITY

```

0000358 PMPVEL 250
0000359 PMPVEL 350

```

* S/R #/L

```

0000360 CNTRLVAR 616 # I.L.
0000361 CNTRLVAR 714 # B.L.

```

* EXPANDED EDIT/PLT VARIABLES

```

-----
#20800001 FXALF 16301
#20800002 FXALJ 16301

```



```

* 503 -- INTACT LOOP S/G STEAM VALVES CLOSE *
* 503 -- NEVER TRUE
* 503 -- NEVER TRUE

```

	VAR	PARN	OP	VAR	PARN	CUST	L/N	THOF
0000501	TIME	0	GE	NULL	0	0.0	L	-1.0
0000502	TIME	0	GE	TIMEOF	501	1.0	L	-1.0
0000503	P	999010000	LE	NULL	0	1827.48	L	-1.0
0000504	P	999010000	LE	NULL	0	145.038	L	-1.0
0000505	TIME	0	SE	NULL	0	240.0	L	-1.0
0000598	TIME	0	LT	NULL	0	0.0	L	-1.0
0000599	TIME	0	LT	NULL	0	0.0	L	-1.0

```

*** TRIPS FOR CONTROL OF STEAM VALVE OPERATIONS ***

```

*0000552	P	601010000	GE	NULL	0	941.0	N	-1.0
*0000553	P	601010000	LE	NULL	0	935.0	N	-1.0
*0000564	CNTRLVAR	631	GT	NULL	0	-200.0	N	-1.0
*0000565	CNTRLVAR	631	LT	NULL	0	200.0	N	-1.0
*0000662	562	AND	564	N	-1.0			
*0000663	563	AND	565	N	-1.0			

```

*** TRIPS FOR CONTROL OF STEAM VALVE OPERATIONS ***

```

*0000572	P	701010000	GE	NULL	0	1093.0	N	-1.0
*0000573	P	701010000	LE	NULL	0	1091.0	N	-1.0
*0000574	CNTRLVAR	731	GT	NULL	0	-200.0	N	-1.0
*0000575	CNTRLVAR	731	LT	NULL	0	200.0	N	-1.0
*0000672	572	AND	574	N	-1.0			
*0000673	573	AND	575	N	-1.0			

```

***** HYDRODYNAMIC COMPONENTS *****

```

```

***** REACTOR VESSEL *****

```

```

***** DOWNCOMER INLET ANNULUS *****

```

	C	BRANCH					
1010000							
1010001	2	1					
1010001	0.105697	0.8750	0.0	0.0	-90.0		-0.875
1010102	0.0	0.142750	0				
1010200	3	2280.1	552.22				
**				0.0	0.0		00100
1011101	102000000	101010000	0.105697	0.0	0.0		00100
1011201	0.66344	0.0	0.0				00100
**				0.0	0.0		00100
1012101	101000000	101000000	7.46674-4	1.0	1.0		00100
1012201	0.66344	0.0	0.0				

 ***** DOWNCOMER INLET ANNULUS *****

ID	COMPONENT	BRANCH	1	2	3	4	5
1020000	C102	BRANCH					
1020001	3	1					
1020101	0.105697	1.00	0.0	0.0	-90.0	-1.000	
1020102	0.0	0.142750	0				
1020200	3	2260.4	552.57				
1021101	263010000	102000000	0.045239	3.5	3.5	00100	
1021201	13.282	0.0	0.0	3.7	3.7	00100	
1022101	102000000	363010000	0.0375539	0.0	0.0	00100	
1022201	-4.4692	0.0	0.0	3.5	3.5	00100	
1023101	102010000	110000000	0.026039	0.0	0.0	00300	
1023201	17.088	0.0	0.0	0.0	0.0	00300	

 ***** DOWNCOMER *****

ID	COMPONENT	PIPE	1	2	3	4	5
1100000	C110	PIPE					
1100001	10						
1100101	0.030975	1					
1100102	0.026039	8					
1100103	0.031502	9					
1100104	0.032270	10					
1100201	0.026039	8					
1100202	0.031502	9					
1100301	2.260833	1					
1100302	1.000833	2					
1100303	2.0	7					
1100304	1.465667	8					
1100305	1.434751	9					
1100306	0.962500	10					
1100601	-90.0	10					
1100701	-2.260833	1					
1100702	-1.000833	2					
1100703	-2.0	7					
1100704	-1.465667	8					
1100705	-1.207667	9					
1100706	-0.962500	10					
1100801	0.0	0.159535	1				

** USE REASONABLE VALUE OF HYDRO-D IN NO. 10
 ** SEE 3.4. REPORT PXXX

1100802	0.0	0.0	10				
1100901	0.1	0.1	7				
1100902	0.2	0.2	8				
1100903	1.193	1.193	8				
1101001	0	0.0	9				
1101101	00000		9				
1101201	3	2260.2	552.55	0.0	0.0	0.0	1
1101202	3	2260.3	552.54	0.0	0.0	0.0	2
1101203	3	2260.6	552.53	0.0	0.0	0.0	3
1101204	3	2261.0	552.52	0.0	0.0	0.0	4
1101205	3	2261.4	552.50	0.0	0.0	0.0	5

1101206	3	2261.9	552.49	0.0	0.0	0.0	6
1101207	3	2262.3	552.48	0.0	0.0	0.0	7
1101208	3	2262.7	552.47	0.0	0.0	0.0	8
1101209	3	2263.2	552.46	0.0	0.0	0.0	9
1101210	3	2263.5	552.45	0.0	0.0	0.0	10
1101300	1						
1101301	17.088	0.0	0.0				9

 ***** LOWER HEAD *****

1200000	C120	SNGLVOL					
1200101	0.510279	0.466667	0.0	0.0	-90.0	-0.466667	
1200102	0.0	0.381247	0				
1200200	3	2263.5	552.40	0.0			

 ***** LOWER PLENUM *****

1300000	C130	BRANCH					
1300001	3	1					
1300101	0.322478	0.721917	0.0	0.0	-90.0	-0.721917	
1300102	0.0	0.229414	0				
1300200	3	2263.3	552.40				
**				1.0	1.0	00100	
1301101	110010000	130000000	0.032270	1.0	1.0	00100	
1301201	17.088	0.0	0.0				
**				0.0	0.0	00100	
1302101	130000000	140000000	0.075189	1.0	1.0	00100	
1302201	17.087	0.0	0.0				
**				0.0	0.0	00100	
1303101	130010000	120000000	0.322478	0.0	0.0	00100	
1303201	6.4717-4	0.0	0.0				

 ***** CORE INLET *****

1400000	C140	SNGLVOL					
1400101	0.075189	1.635833	0.0	0.0	90.0	1.635833	
1400102	0.0	0.278329	0				
1400200	3	2262.7	552.33				

 ***** CORE INLET JUNCTION *****

1450000	J145	SNGLJUN					
**				0.0	0.0	00100	
1450101	140010000	150000000	0.030747	0.0	0.0	00100	
1450201	1	17.087	0.0	0.0			

 ***** CORE ACTIVE LENGTH *****

1500000	C150	PIPE					
1500001	6						
1500101	0.030747	6					
1500301	2.00	6					

1500601	90.0		6					
1500701	2.00		6					
1500801	0.0	0.033237	6					
**	0.0	0.0	5					
1500901	0.00	0.00	2					
1500902	1.00	1.00	5					
1501001	0	6						
1501101	00000	5						
1501201	3	2261.2	557.04	0.0	0.0	0.0		1
1501202	3	2259.9	568.10	0.0	0.0	0.0		2
1501203	3	2258.6	583.24	0.0	0.0	0.0		3
1501204	3	2256.5	597.64	0.0	0.0	0.0		4
1501205	3	2254.4	607.45	0.0	0.0	0.0		5
1501206	3	2252.3	611.47	0.0	0.0	0.0		6
1501300	1							
1501301	17.087	0.0	0.0	5				

 ***** CORE OUTLET 1 *****

1610000	C161	BRANCH						
1610001	4	1						
1610101	0.057359	1.000833	0.0	0.0	90.0	1.000833		
1610102	0.0	0.075610	0					
1610200	3	2250.1	611.42	*0.3	0.3			
1611101	150010000	161000000	0.030747	2.5	2.5	00000		
1611201	17.087	0.0	0.0	*0.5	0.5			
1612101	161010000	162000000	0.034560	1.5	1.5	00100		
1612201	15.196	0.0	0.0					
1613101	182010000	161010000	0.0016085	0.0	0.0	00100		
1613201	4.6911-7	0.0	0.0					
1614101	185010000	161010000	0.004606	0.43613	0.43613	00100		
1614201	-1.8911	0.0	0.0					

 ***** CORE OUTLET 2 *****

1620000	C162	BRANCH						
1620001	1	1						
1620101	0.043927	2.260833	0.0	0.0	90.0	2.260833		
1620102	0.0	0.131407	0					
1620200	3	2248.8	611.36					
1621101	185000000	162010000	0.076458	0.92664	0.77720	00000		
1621201	1.4526	0.0	0.0					

 ***** HOT LEG OUTLET *****

1630000	C163	BRANCH						
1630001	3	1						
1630101	0.045112	1.708333	0.0	0.0	90.0	1.708333		
1630102	0.0	0.158413	0					
1630200	3	2247.2	609.14	*2.5	2.5			
1631101	163010000	201000000	0.045112	5.8	5.8	00100		
1631201	13.281	0.0	0.0	*0.0	0.0			
1632101	163010000	301000000	0.0375539	2.0	2.0	00100		
1632201	4.4690	0.0	0.0	*0.0	0.0			
1633101	162010000	163000000	0.043927	2.7	2.7	00100		
1633201	16.647	0.0	0.0					

 ***** UPPER PLENUM 1 *****

*
 1640000 C164 BRANCH
 1640001 2 1
 1640101 0.054582 1.791667 0.0 0.0 90.0 1.791667
 1640102 0.0 0.133503 0
 1640200 3 2247.0 574.46 #JOU
 1641101 164010000 165000000 0.054582 0.0 0.0 00000
 1641201 -1.1015 0.0 0.0
 1642101 163010000 164000000 0.049112 0.0 0.0 00000
 1642201 -1.1015 0.0 0.0

 ***** UPPER PLENUM 2 *****

*
 1650000 C165 SINGLVOL
 1650101 0.055890 1.966667 0.0 0.0 90.0 1.966667
 1650102 0.0 0.167013 0
 1650200 3 2246.4 575.10 #JOU

 ***** CORE BYPASS LINE *****

 * UPDATE - 1 - (SEE REF. 02)

*
 1810000 C181 PIPE
 1810001 2
 1810101 7.46674E-4 2
 1810301 3.546917 1
 1810302 3.140583 2
 1810601 90.0 2
 1810701 3.546917 1
 1810702 3.140583 2
 1810801 0.0 0.0 2
 * 0.2701 0.2701 1 *** FOR 4.0% BYPASS FLOWRATE ***
 1810901 1.0 1.0 1 *** FOR 4.0% BYPASS FLOWRATE ***
 1811001 0 2
 1811101 00000 1
 1811201 3 2253.6 552.20 0.0 0.0 0.0 1
 1811202 3 2247.9 552.18 0.0 0.0 0.0 2
 1811300 1
 1811301 0.66344 0.0 0.0 1

 ***** CORE SUPPORT COLUMNS *****

*
 1820000 C182 PIPE
 1820001 1
 1820101 0.0016085 1
 1820301 8.8575 1
 1820601 -90.0 1
 1820701 -8.8575 1
 1820801 0.0 0.032000 1
 1821001 0 1
 1821201 3 2248.9 611.22 0.0 0.0 0.0 1

* ** CONTROL ROD GUIDE TUBE *****

* UPDATE - 1 - (SEE REF. 02)

1830000	C183	BR/NCH					
1830001	2	1					
1830101	2.19233E-3	6.549167	0.0	0.0	-90.0	-6.549167	
1830102	0.0	0.0	0				
1830200	3	2245.5	575.80				

* MODIFIED JUN AREA - (SEE REF. 04 PXXX)

1831101	183010000	165010000	3.9787-3	0.0	0.0	00100
1831201	1.1015	0.0	0.0			00000
1832101	183010000	184000000	2.19233-3	0.0	0.0	00000
1832201	-0.43841	0.0	0.0			00000

***** GUIDE TUBE SLOTTED SECTION *****

* UPDATE - 1 - (SEE REF. 02)

1840000	C184	PIPE					
1840001	1						
1840101	2.19233E-3	1					
1840301	5.466667	1					
1840601	-90.0	1					
1840701	-5.466667	1					
1840801	0.0	0.0	1				
1841001	0	1					
1841201	3	2247.8	611.40	0.0	0.0	0.0	1

***** GUID TUBE LOWER PART *****

* UPDATE - 1 - (SEE REF. 02)

1850000	C185	BRANCH					
1850001	1	1					
1850101	0.012718	2.260833	0.0	0.0	-90.0	-2.260833	
1850102	0.0	0.0	0				
1850200	3	2249.1	611.41				
1851101	184010000	185000000	2.19233E-3	0.43613	0.43613	00000	
1851201	-0.43841	0.0	0.0				

***** BOTTOM OF UPPER HEAD *****

1910000	C191	PIPE					
1910001	1						
1910101	0.044149	1					
1910301	0.476667	1					
1910601	-90.0	1					
1910701	-0.476667	1					
1910801	0.0	0.104161	1				
1911001	0	1					
1911201	3	2246.9	551.18	0.0	0.0	0.0	1

***** UPPER HEAD 1 *****

* UPDATE - 1 - (SEE REF. 02)

*

1920000	C192	BRANCH				
1920001	1	1				
1920101	0.05233	1.965833	0.0	0.0	-90.0	-1.965833
1920102	0.0	0.134597	0			
1920200	3	2246.5	551.18			
1921101	192010000	191000000	0.0	0.0	0.0	00000
1921201	5.1223-5	0.0	0.0			

*

***** UPPER HEAD 2 *****

* UPDATE - 1 - (SEE REF. 02)

*

1930000	C193	BRANCH				
1930001	2	1				
1930101	0.055694	3.453333	0.0	0.0	-90.0	+3.453333
1930102	0.0	0.148122	0			
1930200	3	2245.6	551.18			
1931101	193010000	192000000	0.0	0.0	0.0	00000
1931201	4.0019-4	0.0	0.0			+00100
1932101	181010000	193010000	7.46674-4	0.0	0.0	00100
1932201	0.66344	0.0	0.0			

*

*

***** UPPER HEAD 3 *****

* UPDATE - 1 - (SEE REF. 02)

*

1940000	C194	BRANCH				
1940001	2	1				
1940101	0.061685	2.88083	0.0	0.0	-90.0	-2.88083
1940102	0.0	0.196917	0			
1940200	3	2244.6	550.24			

*

*

* MODIFIED JUN AREA - (SEE REF. 04 PXXX)

*

1941101	194010000	183000000	8.42017E-4	0.0	0.0	00100
1941201	0.66307	0.0	0.0			00000
1942101	194010000	193000000	0.0	0.0	0.0	00000
1942201	-0.66306	0.0	0.0			00000

*

***** INTACT LOOP *****

*

***** HOT LEG NOZZLE *****

*

* COMPONENT 1 - HOT LEG NOZZLE

* COMPONENT 2 - SP - 1 AND 2

* COMPONENT 3 - SP - 3

*

2010000 C201 PIPE

2010001 3

2010101	0.045239		1					
2010102	0.037554		2					
2010103	0.024629		3					
2010201	0.037554		1					
2010202	0.024629		2					
2010301	0.720833		1					
2010302	3.2225		2					
2010303	2.5425		3					
2010601	0.0		3					
2010701	0.0		3					
2010801	0.0	0.0	3					
**	0.0	0.0	2					
2010901	0.0	0.0	1					
2010902	0.23	0.23	2					
2011001	0	3						
2011101	00000	2						
2011201	3	2245.7	609.12	0.0	0.0	0.0	1	
2011202	3	2245.6	609.06	0.0	0.0	0.0	2	
2011203	3	2244.9	609.02	0.0	0.0	0.0	3	
2011300	1							
2011301	13.281	0.0	0.0	2				

 ***** TO ELBOW *****

2020000	C202	BRANCH						
2020001	3	1						
2020101	0.024629	2.453333	0.0	0.0	0.0	0.0		
2020102	0.0	0.0	0					
2020200	3	2244.8	608.98					
**				0.0	0.0	00000		
2021101	201010000	202000000	0.024629	0.0	0.0	00000		
2021201	13.281	0.0	0.0					
**				0.0	0.0	00000		
2022101	202010000	203000000	0.024629	0.35	0.35	00000		
2022201	13.282	0.0	0.0					
**				0.0	0.0	00100		
2023101	997010000	202000000	7.4657-4	0.0	0.0	00100		
2023201	5.5927-4	0.0	0.0					

 ***** ELBOW *****

2030000	C203	PIPE						
2030001	2							
2030101	0.024629		2					
2030301	3.90542		1					
2030302	2.12625		2					
2030601	90.0		2					
2030701	3.727080		1					
2030702	1.728330		2					
2030801	0.0	0.0	2					
**	0.0	1.705	1					
2030901	0.0	1.705	1					
2031001	0	2						
2031101	00000	1						
2031201	3	2243.9	608.92	0.0	0.0	0.0	1	
2031202	3	2242.9	608.88	0.0	0.0	0.0	2	
2031300	1							
2031301	13.282	0.0	0.0	1				

```

*
*****
**** 203 - 210 JUN , ****
*****

```

```

*
2050000 J205 SNGLJUN
**
2050101 203010000 210000000 0.024629 0.0 1.35 00000
2050201 1 13.282 0.0 0.0 1.35 00300

```

```

*****
**** S. G. INLET PLENUM ****
*****

```

```

*
2100000 C210 SNGLVDL
2100101 0.080177 0.68750 0.0 0.0 90.0 0.68750
2100201 0.0 0.27514 0
2100200 3 2243.2 608.68

```

```

*****
**** 210 - 220 JUN , ****
*****

```

```

*
2150000 J215 SNGLJUN
**
2150101 210010000 220000000 0.019757 0.0 0.013 00100
2150201 1 13.282 0.0 0.0 0.013 00100

```

```

*****
**** S. G. U-TUBES ****
*****

```

```

* UPDATE - 1 - (SEE REF. 02 )

```

```

*
2200000 C220 PIPE
2200001 8
2200101 0.0197570 8
2200301 7.9525 1
2200302 7.9108334 3
2200303 6.6781367 5
2200304 7.9108334 7
2200305 7.9525 8
2200601 90.0 3
2200602 45.0 4
2200603 -45.0 5
2200604 -90.0 8
2200701 7.9525 1
2200702 7.9108334 3
2200703 6.6008367 4
2200704 -6.6008367 5
2200705 -7.9108334 7
2200706 -7.9525 8
2200801 0.0 0.0 8
** 0.1 0.026 4
2200901 0.1 0.026 4
** 0.1 0.0 7
2200902 0.1 0.0 7
2201001 0 8
2201101 00000 7
2201201 3 2235.4 593.31 0.0 0.0 0.0 1
2201202 3 2232.4 531.42 0.0 0.0 0.0 2
2201203 3 2229.3 572.15 0.0 0.0 0.0 3

```

2201204	3	2226.4	566.00	0.0	0.0	0.0	4
2201205	3	2225.8	560.88	0.0	0.0	0.0	5
2201206	3	2227.5	556.08	0.0	0.0	0.0	6
2201207	3	2229.4	552.31	0.0	0.0	0.0	7
2201208	3	2231.4	549.27	0.0	0.0	0.0	8
2201300	1						
2201301	13.282	0.0	0.0	7			

 ***** 220 - 230 JUN . *****

2250000	J225	SNGLJUN					
**				0.0	0.0	00100	
2250101	220010000	230000000	0.019757	3.4	0.0	00100	
2250201	1	13.282	0.0	0.0			

 ***** S. G. OUTLET PLENUM *****

2300000	C230	SNGLVOL					
2300101	0.080177	0.68750	0.0	0.0	-90.0	-0.68750	
2300102	0.0	0.27514	0				
2300200	3	2229.3	549.25				

 ***** 230 - 240 JUN . *****

2350000	J235	SNGLJUN					
2350101	230010000	210000000	0.024629	1.64	1.64	00000	
2350201	1	13.282	0.0	0.0			

 ***** PUMP SUCTION *****

- * COMPONENT 1 - SP - 8
- * COMPONENT 2 - SP - 8 , 9 AND 10
- * COMPONENT 3 - SP - 11 AND 12
- * COMPONENT 4 - SP - 13
- * COMPONENT 5 - SP - 13 TO BOTTOM P. S.
- * COMPONENT 6 - SP - BOTTOM OF P. S. TO SP - 15
- * COMPONENT 7 - SP - 16
- * COMPONENT 8 - SP - 17 AND 18

2400000	C240	PIPE					
2400001	8						
2400101	0.024629	3					
2400102	0.037554	8					
2400201	0.024629	3					
2400202	0.037554	7					
2400301	1.45958	1					
2400302	3.66625	2					
2400303	2.78417	3					
2400304	3.87500	4					
2400305	4.08908	5					
2400306	6.02658	6					
2400307	2.78158	7					
2400308	1.71083	8					
2400601	-90.0	5					

2400602	90.0							7
2400603	0.0							8
2400701	-1.18333							1
2400702	-3.66625							2
2400703	-2.78417							3
2400704	-3.87500							4
2400705	-3.87500							5
2400706	5.81250							6
2400707	2.56750							7
2400708	0.0							8
2400801	0.0	0.0						8
*2400901	3.12	0.0						3
*2400902	1.34	0.36						4
*2400903	0.0	0.36						6
*2400904	0.0	0.24						7
2400901	3.12	0.0						1
2400902	0.35	0.0						3
2400903	1.34	0.36						4
2400904	0.0	0.36						6
2400905	1.0	0.24						7
2401001	0	8						
2401101	0	7						
2401201	3	2227.9	549.23	0.0	0.0	0.0		1
2401202	3	2226.5	549.17	0.0	0.0	0.0		2
2401203	3	2227.2	549.13	0.0	0.0	0.0		3
2401204	3	2225.3	549.07	0.0	0.0	0.0		4
2401205	3	2229.1	549.00	0.0	0.0	0.0		5
2401206	3	2228.7	548.90	0.0	0.0	0.0		6
2401207	3	2227.3	548.84	0.0	0.0	0.0		7
2401208	3	2226.6	548.84	0.0	0.0	0.0		8
2401300	1							
2401301	13.282	0.0	0.0	7				

 ***** PUMP *****

 * UPDATE = 1 - (SEE REF. 02)
 * SEE G.A. REPORT PXXX
 * RATED PERFORMANCES SEE REF. - 01 PXXX
 *

2500000	C250	PUMP						
2500101	0.034951	4.120	0.0	0.0	90.0	0.840007	0	
** INLET			0.0	0.0	00000			
2500108	240010000	0.034951	0.0	0.0	00000			
** OUTLET			0.0	0.0	00000			
2500109	261000000	8.52212-3	0.0	0.0	00000			
2500200	3	2243.8	549.20					
2500201	1	13.282	0.0	0.0				
2500202	1	13.282	0.0	0.0				
2500301	0	0	0	-1	0	0	1	
2500302	3500.0	0.4953314	258.7	436.6	101.0	38.3		
2500303	62.3082	0.0	0.0	8.7200	0.0	0.0		
2500310	0.0	0.0	0.0					
**	SINGLE PHASE HOMOLOGOUS CURVES							
**	HEAD CURVES							
2501100	1	1						
2501101	0.0	1.2						
2501102	1.0	1.0						
2501200	1	2						
2501201	0.0	-0.35						
2501202	0.3	-0.2						
2501203	0.5	0.0						

2501204	0.8	0.545
2501205	1.0	1.0
2501300	1	3
2501301	-1.0	1.50
2501302	-0.8	1.275
2501303	-0.6	1.375
2501304	-0.4	1.375
2501305	0.0	1.200
25014 0	1	4
2501 1	-1.0	1.500
2501402	-0.8	1.150
2501403	-0.6	0.950
2501404	-0.4	0.830
2501405	-0.2	0.775
2501406	0.0	0.725
2501500	1	5
2501501	0.0	0.975
2501502	0.5	1.350
2501503	1.0	1.950
2501600	1	6
2501601	0.0	0.725
2501602	0.2	0.725
2501603	0.4	0.800
2501604	0.6	1.025
2501605	1.0	1.950
2501700	1	7
2501701	-1.0	0.175
2501702	-0.5	0.650
2501703	0.0	0.975
2501800	1	8
2501801	-1.0	0.175
2501802	-0.75	-0.15
2501803	-0.55	-0.30
2501804	-0.275	-0.40
2501805	0.0	-0.35
**	TORQUE	CURVES
2501900	2	1
2501901	0.0	0.540
2501902	0.2	0.590
2501903	0.4	0.650
2501904	0.6	0.770
2501905	0.8	0.950
2501906	0.9	0.980
2501907	0.95	0.960
2501908	1.0	0.870
2502000	2	2
2502001	0.0	-0.15
2502002	0.2	0.020
2502003	0.4	0.220
2502004	0.6	0.460
2502005	0.8	0.710
2502006	0.9	0.810
2502007	0.95	0.850
2502008	1.0	0.870
2502100	2	3
2502101	-1.0	0.620
2502102	-0.8	0.680
2502103	-0.6	0.530
2502104	-0.4	0.460
2502105	-0.2	0.490
2502106	0.0	0.540
2502200	2	4

2502201	-1.0	0.620
2502202	-0.8	0.530
2502203	-0.6	0.460
2502204	-0.4	0.420
2502205	-0.2	0.390
2502206	0.0	0.360
2502300	2	5
2502301	0.0	-0.63
2502302	0.2	-0.51
2502303	0.4	-0.39
2502304	0.6	-0.29
2502305	0.8	-0.20
2502306	0.9	-0.16
2502307	1.0	-0.13
2502400	2	6
2502401	0.0	0.360
2502402	0.2	0.320
2502403	0.4	0.270
2502404	0.6	0.180
2502405	0.8	0.050
2502406	1.0	-0.13
2502500	2	7
2502501	-1.0	-1.44
2502502	-0.8	-1.25
2502503	-0.6	-1.08
2502504	-0.4	-0.92
2502505	-0.2	-0.77
2502506	0.0	-0.63
2502600	2	8
2502601	-1.0	-1.44
2502602	-0.8	-1.12
2502603	-0.6	-0.79
2502604	-0.4	-0.52
2502605	-0.2	-0.31
2502606	0.0	-0.15
**	TOM - PHASE MULTIPLIER TABLES	
**	HEAD MULTIPLIER	
2503000	0	
2503001	0.00	0.00
2503002	0.10	0.00
2503003	0.15	0.05
2503004	0.24	0.80
2503005	0.30	0.96
2503006	0.40	0.98
2503007	0.60	0.97
2503008	0.80	0.90
2503009	0.90	0.80
2503010	0.96	0.50
2503011	1.00	0.0
**	TORQUE MULTIPLIER	
2503100	0	
2503101	0.00	-0.17
2503102	1.0E-4	-0.17
2503103	6.0E-3	0.00
2503104	0.10	0.00
2503105	0.15	0.05
2503106	0.24	0.56
2503107	0.80	0.56
2503108	0.96	0.45
2503109	1.00	0.00
**	TAD - PHASE DIFFERENCE TABLES	
**	HEAD CURVES	

2504100	1	1
2504101	0.0	0.00
2504102	0.1	0.83
2504103	0.2	1.09
2504104	0.5	1.02
2504105	0.7	1.01
2504106	0.9	0.94
2504107	1.0	1.0
2504200	1	2
2504201	0.0	0.00
2504202	0.1	-0.04
2504203	0.2	0.0
2504204	0.3	0.10
2504205	0.4	0.21
2504206	0.8	0.67
2504207	0.9	0.80
2504208	1.0	1.0
2504300	1	3
2504301	-1.0	-1.16
2504302	-0.9	-1.24
2504303	-0.8	-1.77
2504304	-0.7	-2.36
2504305	-0.6	-2.79
2504306	-0.5	-2.91
2504307	-0.4	-2.67
2504308	-0.25	-1.69
2504309	-0.1	-0.50
2504310	0.0	0.000
2504400	1	4
2504401	-1.0	-1.16
2504402	-0.9	-0.78
2504403	-0.8	-0.50
2504404	-0.7	-0.31
2504405	-0.6	-0.17
2504406	-0.5	-0.08
2504407	-0.35	0.000
2504408	-0.2	0.050
2504409	-0.1	0.080
2504410	0.0	0.110
2504500	1	5
2504501	0.0	0.000
2504502	0.2	-0.36
2504503	0.4	-0.65
2504504	0.6	-0.93
2504505	0.8	-1.19
2504506	1.0	-1.47
2504600	1	6
2504601	0.0	0.11
2504602	0.1	0.13
2504603	0.25	0.15
2504604	0.4	0.13
2504605	0.5	0.07
2504606	0.7	-0.04
2504607	0.7	-0.23
2504608	0.8	-0.51
2504609	0.9	-0.91
2504610	1.0	-1.47
2504700	1	7
2504701	-1.0	0.00
2504702	0.0	0.00
2504800	1	8
2504801	-1.0	0.00

2504802	0.0	0.00
**	TORQUE	CURVES
2504900	2	1
2504901	0.0	0.540
2504902	0.2	0.590
2504903	0.4	0.650
2504904	0.6	0.770
2504905	0.8	0.950
2504906	0.9	0.980
2504907	0.95	0.960
2504908	1.0	0.870
2505000	2	2
2505001	0.0	-0.15
2505002	0.2	0.020
2505003	0.4	0.220
2505004	0.6	0.460
2505005	0.8	0.710
2505006	0.9	0.810
2505007	0.95	0.850
2505008	1.0	0.870
2505100	2	3
2505101	-1.0	0.620
2505102	-0.8	0.680
2505103	-0.6	0.530
2505104	-0.4	0.460
2505105	-0.2	0.490
2505106	0.0	0.540
2505200	2	4
2505201	-1.0	0.620
2505202	-0.8	0.530
2505203	-0.6	0.460
2505204	-0.4	0.420
2505205	-0.2	0.390
2505206	0.0	0.360
2505300	2	5
2505301	0.0	-0.63
2505302	0.2	-0.51
2505303	0.4	-0.39
2505304	0.6	-0.29
2505305	0.8	-0.20
2505306	0.9	-0.16
2505307	1.0	-0.13
2505400	2	6
2505401	0.0	0.360
2505402	0.2	0.320
2505403	0.4	0.270
2505404	0.6	0.180
2505405	0.8	0.050
2505406	1.0	-0.13
2505500	2	7
2505501	-1.0	-1.44
2505502	-0.8	-1.25
2505503	-0.6	-1.08
2505504	-0.4	-0.92
2505505	-0.2	-0.77
2505506	0.0	-0.63
2505600	2	8
2505601	-1.0	-1.44
2505602	-0.8	-1.2
2505603	-0.6	-0.79
2505604	-0.4	-0.52
2505605	-0.2	-0.31


```

2505606 0.0 -0.15
** TIME DEPENDENT PUMP VELOCITY CNTRL CARD
** TRIP VAR NJM
*2506100 501
2506100 0 CNTRLVAR 725
** SRCH VAR PUMP VELOCITY
2506101 0.0 1733.6
*2506102 1000.0 1693.755
2506102 0.0 0.0
2506103 1.0E6 1.0E6

```

```

*****
**** COLD LEG ****
*****

```

```

* COMPONENT 1 - SP - 19 AND 20
* COMPONENT 2 - SP - 21 TO ECC TAP IN SP - 22

```

```

2610000 C261 PIPE
2610001 2
2610101 0.037554 2
2610301 2.854167 1
2610302 2.479170 2
2610601 0.0 2
2610701 0.0 2
2610801 0.0 0.0 2
** 0.0 0.0 1
2610901 0.0 0.0 1
2611001 0 2
2611101 00000 1
2611201 3 2261.2 549.27 0.0 0.0 0.0 1
2611202 3 2261.2 549.23 0.0 0.0 0.0 2
2611300 1
2611301 13.282 0.0 0.0 1

```

```

*****
**** ECC - TAP ****
*****

```

```

* ECC TAP THROUGH SP - 22

```

```

2620000 C262 BRANCH
2620001 3 1
2620101 0.037554 2.5960 0.0 0.0 0.0 0.0
2620102 0.0 0.0 0
2620200 3 2261.0 549.18
**
2621101 261010000 262000000 0.037554 0.87 0.53 00000
2621201 13.282 0.0 0.0 0.28 0.53 00000
**
2622101 262010000 263000000 0.037554 0.87 0.53 00000
2622201 13.282 0.0 0.0
**
** K.S. LIANG USED IN NH-1 DECK 0.0 0.0 00120
2623101 400010000 262000000 0.004995 0.0 0.0 20121
2623201 0.0 0.0 0.0

```

```

*****
**** COLD LEG NOZZLE ****
*****

```

```

2630000 C263 PIPE

```

2630001	1							
2630101	0.045239		1					
2630301	0.595833		1					
2630601	0.0		1					
2630701	0.0		1					
2630801	0.0	0.0		1				
2631001	0		1					
2631201	3	2260.9	549.17	0.0	0.0	0.0		1

 ***** PRESSURIZER *****

 ***** PRESSURIZER VESSEL *****

9990000	C999	PIPE						
9990001	5							
9990101	0.289667		2					
9990102	0.287295		3					
9990103	0.293841		4					
9990104	0.184446		5					
9990201	0.289667		1					
9990202	0.072423		2					
9990203	0.287295		3					
9990204	0.184446		4					
9990301	1.880252		1					
9990302	0.769748		2					
9990303	0.728611		3					
9990304	0.364306		4					
9990305	0.217500		5					
9990601	-90.0		5					
9990701	-1.880252		1					
9990702	-0.769748		2					
9990703	-0.728611		3					
9990704	-0.364306		4					
9990705	-0.217500		5					
9990801	0.0	0.444928	2					
9990802	0.0	0.471013	4					
9990803	0.0	0.307163	5					
**	0.0	0.0	4					
9990901	0.0	0.0	4					
9991001	0	5						
9991101	00000	1						
9991102	00100	2						
9991103	00000	4						
9991201	2	2243.8	1.0	0.0	0.0	0.0		1
9991202	0	2243.8	689.41	1052.8	0.66794	0.0		2
9991203	2	2244.0	0.0	0.0	0.0	0.0		3
9991204	2	2244.1	0.0	0.0	0.0	0.0		4
9991205	3	2244.2	650.49	0.0	0.0	0.0		5
9991300	0							
9991301	4.4759	3.8513-5	0.0				1	
9991302	1.4793-4	-1.7981	0.0				2	
9991303	5.0281-5	5.0281-5	0.0				3	
9991304	7.9243-5	7.9243-5	0.0				4	

 ***** 999 - 997 JUN . *****

```

9980000 J998 SNGLJUN
9980101 999010000 997000000 J.037583 0.0 0.0 00100
9980201 1 5.4932-4 0.0 0.0

```

```

*****
**** SURGE LINE ****
*****

```

```

*
9970000 C997 PIPE
9970001 5
9970101 0.037583 1
9970102 0.014053 2
9970103 0.003623 3
9970104 7.4667E-4 5
9970201 0.014053 1
9970202 0.003623 2
9970203 7.4667E-4 4
9970301 0.675000 1
9970302 0.583333 2
9970303 1.604167 3
9970304 4.416667 5
9970601 -90.0 5
9970701 -0.675000 1
9970702 -0.583333 2
9970703 -1.604167 3
9970704 -1.074583 5
9970801 0.0 0.0 5
** 502.83 502.83 1

```

```

* FOR R' = 1.4E+09 Mee-4 SEE REF. - 04 PXXX

```

```

9970901 1193.152 1193.152 1
** 33.42 33.42 2
9970902 33.42 33.42 2
** 1.42 1.42 4
9970903 1.42 1.42 4
9971001 0 5
9971101 00000 4
9971201 3 2244.3 649.34 0.0 0.0 0.0 1
9971202 3 2244.5 648.87 0.0 0.0 0.0 2
9971203 3 2244.8 648.43 0.0 0.0 0.0 3
9971204 3 2245.1 648.11 0.0 0.0 0.0 4
9971205 3 2245.4 647.40 0.0 0.0 0.0 5
9971300 1
9971301 5.5351-4 0.0 0.0 1
9971302 5.5509-4 0.0 0.0 2
9971303 5.5647-4 0.0 0.0 3
9971304 5.5741-4 0.0 0.0 4

```

```

*****
**** PRZ LIQUID LEVEL CONTRL ****
*****

```

```

* TEMPORARY CONTROL FOR INITIALIZATION

```

```

*900000 C990 THDPVOL
*900101 1.0 0.0 1.0 0.0 0.0
*900102 0.0 0.0 00
*900200 1 0 TEMPF 999050000
*900201 -0.0 649.97 0.0
*900202 0.0 0.0 0.0
*900203 1000.0 1000.0 0.0

```

```

*910000 J991 TMDPJUN
*910101 990000000 *99010000 1.0
*910200 1 0 CNTRLVAF 925
*910201 -1.1E6 0.0 0.0 0.0
*910202 -1.0E6 -1.0E6 0.0 0.0
*910203 0.0 0.0 0.0 0.0
*910204 1.0E6 1.0E6 0.0 0.0

```

```

*****
***** PRZ PRESSURE CONTRL *****
*****

```

* TEMPORARY CONTROL FOR INITIALIZATION

```

*
*500000 C950 TMDPVOL
*500101 1.0 0.0 1.0 0.0 0.0 0.0
*500102 0.0 0.0 00
*500200 2
*500201 0.1 2255.6 1.0

```

```

*
*510000 J931 SNGL UN
*510101 950000000 999000000 0.0 0.0 0.0 01000
*510201 0 0.0 0.0 0.0

```

```

*****
***** ECCS SYSTEM *****
*****

```

```

*****
***** ECCS HEADER *****
*****

```

```

4000000 C400 PIPE
4000001 1
4000101 0.004995 1
4000301 10.0 1
4000601 0.0 1
4000701 0.0 1
4000801 0.0 0.0 1
4001001 0 1
4001201 3 2261.0 77.060 0.0 0.0 0.0 1

```

* CHANGE ACCUM. TEMP. FROM 555.83 TO 77.0

```

*****
***** HPIS/LPIS SOURCE *****
*****

```

```

4100000 C410 TMDPVOL
4100101 10.0 10.0 0.0 0.0 0.0 0.0
4100102 0.0 0.0 00
4100200 3
4100201 0.0 12.3 80.0

```

```

*****
***** PIS JUNCTION *****
*****

```

* SEE Ref. - 03 - PXXX
* SEE O.A. REPORT PXXX

```

*
4110000 J411 TMDPJUN
4110101 410000000 400000000 0.004955
4110200 1 503 P 261010000
** PRESS FLOW-F FLOW-G VELJ

```

4110201	-1.3	0.0	0.0	0.0
4110202	0.0	0.0	0.0	0.0
4110203	29.01	0.209686	0.0	0.0
4110204	49.31	0.207890	0.0	0.0
4110205	57.62	0.172068	0.0	0.0
4110206	89.92	0.134490	0.0	0.0
4110207	118.93	0.090835	0.0	0.0
4110208	142.14	0.051852	0.0	0.0
4110209	145.04	0.0	0.0	0.0
4110210	0000.0	0.0	0.0	0.0

* SEE REF. - 04 - PXX (UPDATED BY CHOU 04/18/89)

*4200000	C420	ACCUM						
*4200101	0.7085	0.0	2.860515	0.0	90.0	4.037424		
*4200102	0.0	0.0	00					
*4200200	377.099	77.0	0.0					
**			12.0	12.0	00000			
*4201101	400000000	0.004955	12.0	12.0	00000			
**	LN-VOL	LN-LEV	LNLEN	ELEV	WTHCK	HFG	TKDEN	TKCP
*4202200	2.5307	0.0	30.0	0.0	4.7833E-3	0	0.0	0.0

4200000	C420	TMDPVCL						
4200101	10.0	10.0	0.0	0.0	0.0	0.0		
4200102	0.0	0.0	10					
4200200	3							
4200201	0.0	377.104	80.0					
4200202	50.0	377.104	80.0					
4200203	100.0	377.104	80.0					
4200204	150.0	377.104	80.0					
4200205	180.0	333.592	80.0					
4200206	200.0	275.576	80.0					
4200207	240.0	214.659	80.0					
4200208	280.0	176.747	80.0					
4200209	340.0	162.445	80.0					
4200210	400.0	134.887	80.0					
4200211	460.0	127.635	80.0					
4200212	520.0	120.333	80.0					

4210000	J421	TMDPJUN						
4210101	420000000	400000000	0.004955					
4210200	1	501						
4210201	0.0	0.0	0.0	0.0				
4210202	120.0	0.0	0.0	0.0				
4210203	140.0	0.0	0.0	0.0				
4210204	163.0	0.0	0.0	0.0				
4210205	170.0	0.18032	0.0	0.0				
4210206	180.0	0.27705	0.0	0.0				
4210207	200.0	0.32766	0.0	0.0				
4210208	220.0	0.33427	0.0	0.0				
4210209	240.0	0.32344	0.0	0.0				
4210210	260.0	0.31226	0.0	0.0				
4210211	280.0	0.29468	0.0	0.0				
4210212	300.0	0.26830	0.0	0.0				

 ***** HOT LEG NOZZLE *****

- * COMPONENT 1 - HOT LEG NOZZLE
- * COMPONENT 2 - SP - 50
- * COMPONENT 3 - SP - 55
- * COMPONENT 4 - SP - 56 , 57 AND 58
- * COMPONENT 5 - SP - 59

3015000	C301	PIPE						
3500001	5							
3010101	0.0075539		1					
3010102	0.0097643		5					
3010201	0.0097643		4					
3010301	1.3391667		1					
3010302	3.2342933		3					
3010303	3.7796910		4					
3010304	1.9973268		5					
3010601	0.0		3					
3010602	90.0		5					
3010701	0.0		3					
3010702	3.672667		4					
3010703	1.532500		5					
3010801	0.0	0.0	5					
**	0.0	0.0	4					
3010901	1.5	1.5	1					
3010902	1.0	1.0	2					
3010903	0.3	0.3	3					
3010904	0.0	0.0	4					
3011001	0	5						
3011101	00000	4						
3011201	3	2247.1	609.09	0.0	0.0	0.0	1	
3011202	3	2245.7	608.99	0.0	0.0	0.0	2	
3011203	3	2245.0	608.90	0.0	0.0	0.0	3	
3011204	3	2244.1	608.79	0.0	0.0	0.0	4	
3011205	3	2243.2	608.71	0.0	0.0	0.0	5	
3011300	1							
3011301	4.4490	0.0	0.0	4				

 ***** 301 - 310 JUN *****

3050000	J305	SNGLJUN					
**				0.868	0.868	00000	
3050101	301010000	310000000	0.0097643	1.868	1.868	00000	
3050201	1	4.4490	0.0	0.0			

 ***** S. G. INLET PLENUM *****

3100000	C310	SNGLVDL					
3100101	0.055513	0.8541667	0.0	0.0	90.0	0.8541667	
3100102	0.0	0.255822	0				
3100200	3	2242.3	608.72	0.0			

 ***** 310 - 320 JUN *****

```

3150000 J315 SNGLJUN
**
3150101 310010000 320000000 6.58566E-3 0.0 0.0 00100
3150201 1 4.4691 0.0 1.0 1.0 00100
*

```

```

*****
**** S. G. U-TUBES ****
*****
* UPDATE - 1 - (SEE REF. 02 )
*

```

```

3200000 C320 PIPE
3200001 8
3200101 6.58566E-3 8
3200301 7.9629167 1
3200302 7.82750 2
3200303 7.9108333 3
3200304 6.7190773 5
3200305 7.9108333 6
3200306 7.82750 7
3200307 7.9629167 8
3200501 -90.0 8
3200601 +90.0 3
3200602 +45.0 4
3200603 -45.0 5
3200604 -90.0 8
3200701 +7.9629167 1
3200702 +7.82750 2
3200703 +7.9108333 3
3200704 +6.6358363 4
3200705 -6.6358363 5
3200706 -7.9108333 6
3200707 -7.82750 7
3200708 -7.9629167 8
3200801 0.0 0.0 8
** 0.34 0.34 7
3200901 0.30 0.30 7
3201001 0 8
3201101 00000 7
3201201 3 2237.6 596.64 0.0 0.0 0.0 1
3201202 3 2233.7 587.43 0.0 0.0 0.0 2
3201203 3 2229.8 580.26 0.0 0.0 0.0 3
3201204 3 2226.2 575.35 0.0 0.0 0.0 4
3201205 3 2225.0 571.40 0.0 0.0 0.0 5
3201206 3 2225.9 568.08 0.0 0.0 0.0 6
3201207 3 2227.0 565.44 0.0 0.0 0.0 7
3201208 3 2228.1 563.31 0.0 0.0 0.0 8
3201300 2
3201301 4.4691 0.0 0.0 7
*

```

```

*****
**** 320 - 330 JUN ****
*****
* UPDATE - 1 - (SEE REF. 02 )
*

```

```

3250000 J325 SNGLJUN
**
3250101 320010000 330000000 6.58566E-3 0.0 0.0 00100
3250201 1 4.4691 0.0 0.0 1.0 1.0 00100
*

```

```

*****
**** S. G. OUTLET PLENUM ****
*****

```

```

*
3300000 C330      SNGLVOL
3300101 0.055513 0.8541667 0.0      0.0      -90.0      -0.8541667
3300102 0.0      0.255822 0
3300200 3      2228.1      563.31      0.0

```

```

*****
***** 330 - 340 JUN *****
*****

```

```

*
3350000 J335      SNGLJUN
**
3350101 330010000 340000000 0.0097643 1.0      1.0      00000
3350201 1      4.4691      0.0      0.0

```

```

*****
***** PUMP      SUCTION *****
*****

```

- * COMPONENT 1 - SP - 80
- * COMPONENT 2 - SP - 61 AND 62
- * COMPONENT 3 - SP - 63 AND 64 TO P-TAP
- * COMPONENT 4 - SP - 64
- * COMPONENT 5 - SP - 64 TO P. S. BOTTOM
- * COMPONENT 6 - SP - BOTTOM OF P. S. THROUGH SP - 72
- * COMPONENT 7 - SP - 73

```

*
3400000 C340      PIPE
3400001 7
3400101 0.0097643      7
3400301 1.6215085      1
3400302 2.3018333      2
3400303 1.3879167      3
3400304 4.8500      4
3400305 5.219115      5
3400306 6.757448      6
3400307 2.2966667      7
3400601 -90.0      5
3400602 90.0      7
3400701 -1.3526788      1
3400702 -2.3018333      2
3400703 -1.3879167      3
3400704 -4.8500000      5
3400705 6.3883333      6
3400706 2.2966667      7
3400801 0.0      0.0      7
**      2.45      2.45      1
3400901 2.45      2.45      1
**      0.45      0.45      2
3400902 0.0      0.0      2
**      1.24      1.24      5
3400903 0.0      0.0      4
3400904 1.24      1.24      5
**      0.58      0.58      6
3400905 0.58      0.58      6
3401001 0      7
3401101 00000      6
3401201 3      2227.4      563.25      0.0      0.0      0.0      1
3401202 3      2226.7      563.19      0.0      0.0      0.0      2
3401203 3      2227.2      563.15      0.0      0.0      0.0      3
3401204 3      2228.0      563.02      0.0      0.0      0.0      4
3401205 3      2229.3      562.98      0.0      0.0      0.0      5

```


3401206	3	2228.1	562.66	0.0	0.0	0.0	6
3401207	3	2226.2	562.59	0.0	0.0	0.0	7
3401300	1						
3401301	4.4691	0.0	0.0	6			

 ***** PUMP *****

* UPDATE - 1 - (SEE REF. 02)
 * SEE REF. - 04 - PXXX
 * SEE O.A. REPORT PXXX
 * RATED PERFORMANCES SEE REF. - 01 - PXXX

3500000	C350	PUMP					
3500101	0.015*57	1.9635	0.0	0.0	90.0	0.143928	0
**	INLET		0.0	0.0	00000		
3500108	340010000	0.0097643	0.0	0.0	00000		
**	OUTLET		0.0	0.0	00000		
3500109	361000000	0.0089295	2.0	2.0	00000		
3500200	3	2245.4	562.88				
3500201	1	4.4691	0.0	0.0			
3500202	1	4.4691	0.0	0.0			
3500301	0	0	0	-1	0	0	1
3500302	15250.7	0.77541	51.3	261.0	2.2	0.22	
3500303	62.3002	0.0	0.0	0.0	0.0	0.0	
3500310	0.0	0.0	0.0				

** SINGLE PHASE HOMOLOGOUS CURVES
 ** HEAD CURVES

3501100	1	1
3501101	0.0	1.7821
3501102	0.2845	1.7059
3501103	0.569	1.627
3501104	0.8535	1.1878
3501105	1.0	1.0
3501200	1	2
3501201	0.0	-1.6359
3501202	0.713	0.00
3501203	0.8271	0.2959
3501204	1.0	1.00
3501300	1	3
3501301	-1.0	1.50
3501302	-0.8	1.275
3501303	-0.6	1.375
3501304	-0.4	1.375
3501305	0.0	1.200
3501400	1	4
3501401	-1.0	1.500
3501402	-0.8	1.150
3501403	-0.6	0.950
3501404	-0.4	0.830
3501405	-0.2	0.779
3501406	0.0	0.725
3501500	1	5
3501501	0.0	0.975
3501502	0.5	1.350
3501503	1.0	1.950
3501600	1	6
3501601	0.0	0.725
3501602	0.2	0.725
3501603	0.4	0.800
3501604	0.6	1.025
3501605	1.0	1.950

3501700	1	7
3501701	-1.0	0.175
3501702	-0.5	0.650
3501703	0.0	0.975
3501800	1	8
3501801	-1.0	0.175
3501802	-0.75	-0.15
3501803	-0.53	-0.30
3501804	-0.275	-0.40
3501805	0.0	-0.35
**	TORQUE	CURVES
3501900	2	1
3501901	0.0	0.540
3501902	0.2	0.590
3501903	0.4	0.650
3501904	0.6	0.770
3501905	0.8	0.950
3501906	0.9	0.980
3501907	0.95	0.960
3501908	1.0	0.870
3502000	2	2
3502001	0.0	-0.15
3502002	0.2	0.020
3502003	0.4	0.220
3502004	0.6	0.460
3502005	0.8	0.710
3502006	0.9	0.810
3502007	0.95	0.850
3502008	1.0	0.870
3502100	2	3
3502101	-1.0	0.620
3502102	-0.8	0.680
3502103	-0.6	0.530
3502104	-0.4	0.460
3502105	-0.2	0.490
3502106	0.0	0.540
3502200	2	4
3502201	-1.0	0.620
3502202	-0.8	0.530
3502203	-0.6	0.460
3502204	-0.4	0.420
3502205	-0.2	0.390
3502206	0.0	0.360
3502300	2	5
3502301	0.0	-0.63
3502302	0.2	-0.51
3502303	0.4	-0.39
3502304	0.6	-0.29
3502305	0.8	-0.20
3502306	0.9	-0.16
3502307	1.0	-0.13
3502400	2	6
3502401	0.0	0.360
3502402	0.2	0.320
3502403	0.4	0.270
3502404	0.6	0.180
3502405	0.8	0.050
3502406	1.0	-0.13
3502500	2	7
3502501	-1.0	-1.44
3502502	-0.8	-1.25
3502503	-0.6	-1.08

3502504	-0.4	-0.92
3502505	-0.2	-0.77
3502506	1.0	-0.63
3502600	2	2
3502601	-1.0	-1.44
3502602	-0.8	-1.12
3502603	-0.6	-0.79
3502604	-0.4	-0.52
3502605	-0.2	-0.31
3502606	0.0	-0.15
**	TGM - PHASE MULTIPLIER TABLES	
**	HEAD MULTIPLIER	
3503000	0	
3503001	0.00	0.00
3503002	0.10	0.30
3503003	0.15	0.05
3503004	0.24	0.80
3503005	0.30	0.96
3503006	0.40	0.98
3503007	0.60	0.97
3503008	0.80	0.90
3503009	0.90	0.80
3503010	0.96	0.50
3503011	1.00	0.0
**	TORQUE MULTIPLIER	
3503100	0	
3503101	0.00	-0.17
3503102	1.0E-4	-0.17
3503103	6.0E-3	0.00
3503104	0.10	0.00
3503105	0.15	0.15
3503106	0.24	0.56
3503107	0.80	0.56
3503108	0.96	0.45
3503109	1.00	0.00
**	TWD - PHASE DIFFERENCE TABLES	
**	HEAD CURVES	
3504100	1	1
3504101	0.0	0.00
3504102	0.1	0.53
3504103	0.2	1.09
3504104	0.5	1.02
3504105	0.7	1.01
3504106	0.9	0.94
3504107	1.0	1.0
3504200	1	2
3504201	0.1	0.00
3504202	0.1	-0.04
3504203	0.2	0.0
3504204	0.3	0.10
3504205	0.4	0.21
3504206	0.8	0.67
3504207	0.9	0.80
3504208	1.0	1.0
3504300	1	3
3504301	-1.0	-1.16
3504302	-0.9	-1.24
3504303	-0.8	-1.77
3504304	-0.7	-2.36
3504305	-0.6	-2.79
3504306	-0.5	-2.91
3504307	-0.4	-2.67

3504303	-0.25	-1.69
3504309	-0.1	-0.50
3504310	0.0	0.000
3504400	1	4
3504401	-1.0	-1.16
3504402	-0.9	-0.78
3504403	-0.8	-0.50
3504404	-0.7	-0.31
3504405	-0.6	-0.17
3504406	-0.5	-0.08
3504407	-0.35	0.000
3504408	-0.2	0.050
3504409	-0.1	0.080
3504410	0.0	0.110
3504500	1	5
3504501	0.0	0.000
3504502	0.2	-0.034
3504503	0.4	-0.65
3504504	0.6	-0.93
3504505	0.4	-1.19
3504506	1.0	-1.47
3504600	1	6
3504601	0.0	0.11
3504602	0.1	0.13
3504603	0.25	0.15
3504604	0.4	0.13
3504605	0.5	0.07
3504606	0.6	-0.04
3504607	0.7	-0.23
3504608	0.8	-0.51
3504609	0.9	-0.91
3504610	1.0	-1.47
3504700	1	7
3504701	-1.0	0.00
3504702	0.0	0.00
3504800	1	8
3504801	-1.0	0.00
3504802	0.0	0.00
#	TORQUE	CURVES
3504900	2	1
3504901	0.0	0.540
3504902	0.2	0.590
3504903	0.4	0.650
3504904	0.6	0.770
3504905	0.8	0.950
3504906	0.9	0.980
3504907	0.95	0.960
3504908	1.0	0.870
3505000	2	2
3505001	0.0	-0.15
3505002	0.2	0.020
3505003	0.4	0.220
3505004	0.6	0.460
3505005	0.8	0.710
3505006	0.9	0.810
3505007	0.95	0.850
3505008	1.0	0.370
3505100	2	3
3505101	-1.0	0.620
3505102	-0.8	0.680
3505103	-0.6	0.530
3505104	-0.4	0.460

```

3505105 -0.2      0.490
3505106  0.0      0.540
3505200  2        4
3505201 -1.0      0.620
3505202 -0.8      0.530
3505203 -0.6      0.460
3505204 -0.4      0.420
3505205 -0.2      0.390
3505206  0.0      0.360
3505300  2        5
3505301  0.0      -0.63
3505302  0.2      -0.51
3505303  0.4      -0.39
3505304  0.6      -0.29
3505305  0.6      -0.20
3505306  0.9      -0.16
3505307  1.0      -0.13
3505400  2        6
3505401  0.0      0.360
3505402  0.2      0.320
3505403  0.4      0.270
3505404  0.6      0.180
3505405  0.8      0.050
3505406  1.0      -0.13
3505500  2        7
3505501 -1.0      -1.44
3505502 -0.8      -1.25
3505503 -0.6      -1.08
3505504 -0.4      -0.92
3505505 -0.2      -0.77
3505506  0.0      -0.63
3505600  2        8
3505601 -1.0      -1.44
3505602 -0.8      -1.12
3505603 -0.6      -0.79
3505604 -0.4      -0.52
3505605 -0.2      -0.31
3505606  0.0      -0.15
**      TIME DEPENDENT PUMP VELOCITY CNTRL CARD
**      TRIP      ( VAR )      ( NUM )
*3506100  501
3506100  0      CNTRLVAR 735
**      TIME      PUMP VELOCITY
3506101 -0.0      11825.0
*3506102  1.0E6      11095.0
3506102  0.0      0.0
3506103  1.0E6      1.0E6

```

```

*****
****      COLD      LEG      ****
*****

```

```

3610000  C361      BRANCH
3610001  1        1
3610101  0.0097643  1.970      0.0      0.0      0.0      0.1
3610102  0.0        0.0        0
3610200  3        2263.2      562.00
**
3611101  361010001  362000000  0.0097643  1.5      1.5      00700
3611201  4.4591      0.0        0.0      3.5      3.5      00300

```

```

*****

```

***** TO BREAK *****

* COMPONENT 1 - SP - 76 TO BREAK

ID	Material	Type	Value 1	Value 2	Value 3	Value 4	Value 5	Value 6
3620000	C362	PIPE						
3620001	1							
3620101	0.0097643	1						
3620301	0.755833	1						
3620601	0.0	1						
3620701	0.0	1						
3620801	0.0	0.0	1					
3621001	0	1						
3621201	3	2261.4	552.27	0.0	0.0	0.0	1	

***** COLD LEG NOZZLE *****

* COMPONENT 1 - BREAK THROUGH SP - 76

* COMPONE - SP - 79

* COMPONENT 3 - COLD LEG NOZZLE

ID	Material	Type	Value 1	Value 2	Value 3	Value 4	Value 5	Value 6
3630000	C363	PIPE						
3630001	3							
3630101	0.0097643	2						
3630102	0.0373539	3						
3630201	0.0097643	2						
3630301	0.891667	1						
3630302	2.334167	2						
3630303	1.276167	3						
3630601	0.0	3						
3630701	0.0	3						
3630801	0.0	0.0	3					
**	0.0	0.0	2					
3630901	0.0	0.0	1					
3630902	0.6	0.6	2					
3631001	0	3						
3631101	00000	2						
3631201	3	2250.4	552.84	0.0	0.0	0.0	1	
3631202	3	2260.3	552.73	0.0	0.0	0.0	2	
3631203	3	2260.4	552.73	0.0	0.0	0.0	3	
3631300	1							
3631301	4.4691	0.0	0.0	2				

***** 362 - 363 JUN *****

ID	Material	Type	Value 1	Value 2	Value 3	Value 4	Value 5	Value 6
3650000	J365	SINGLJUN						
**								
3650101	362010000	363000000	0.0097643	2.0	2.0	0.0	0.0	
3650201	1	4.4691	0.0	0.0				

***** C-L BREAK JUNCTION *****

* UPDATE - 1 - (SEE REF. 02)

ID	Material	Type	Value 1	Value 2	Value 3	Value 4	Value 5	Value 6
3750000	BREAK-V	VALVE						
**								
3750101	211000	400000000	5.251364	0.0	0.0	0.0	0.0	

```

3750102 1.00 0.84
3750201 1 0.0 0.0 0.0
3750300 TRPVLV
3750301 501

```

```

*
*****
** SLOWDOWN AMBIENT VOLUMES **
*****
* SEE S.A. REPORT PXXX
*

```

```

9000000 C900 1MOPVIL
9000101 10.0 1.0 0.0 0.0 0.0
9000102 0.0 0.0 10
9000200 2
9000201 0.0 36.1435 1.0
9000202 1.6 36.9962 1.0
9000203 2.0 37.1586 1.0
9000204 5.2 35.7984 1.0
9000205 12.4 36.5495 1.0
9000206 16.0 36.1435 1.0
9000207 20.8 36.8135 1.0
9000208 25.6 36.6307 1.0
9000209 26.8 36.6510 1.0
9000210 30.4 35.8796 1.0
9000211 32.8 36.3262 1.0
9000212 35.2 35.7578 1.0
9000213 37.6 36.1435 1.0
9000214 40.0 36.1435 1.0
9000215 42.4 36.0623 1.0
9000216 46.0 36.7119 1.0
9000217 49.6 35.3314 1.0
9000218 55.6 37.5443 1.0
9000219 5.0 35.4532 1.0
9000220 61.6 37.9300 1.0
9000221 67.6 30.2558 1.0
9000222 76.0 19.1085 1.0
9000223 80.8 17.8089 1.0
9000224 86.8 17.5450 1.0
9000225 94.0 18.1135 1.0
9000226 98.8 17.8496 1.0
9000227 120.4 19.2507 1.0
9000228 131.2 21.0935 1.0
9000229 140.8 23.4945 1.0
9000230 152.8 27.3321 1.0
9000231 154.0 27.5351 1.0
9000232 166.0 34.5594 1.0
9000233 172.0 28.3270 1.0
9000234 182.8 38.5797 1.0
9000235 188.8 30.0934 1.0
9000236 197.2 38.0518 1.0
9000237 203.2 35.1690 1.0
9000238 209.2 35.9202 1.0
9000239 218.8 36.1435 1.0
9000240 220.0 36.0623 1.0
9000241 233.2 36.1435 1.0
9000242 244.0 36.1435 1.0
9000243 246.4 35.6765 1.0
9000244 250.0 35.6563 1.0
9000245 259.6 35.6563 1.0
9000246 263.2 35.4733 1.0
9000247 264.4 35.6563 1.0
9000248 269.2 35.4126 1.0

```

9000249	281.2	35.5750	1.0
9000250	292.0	35.6563	1.0
9000251	314.8	35.6563	1.0
9000252	320.8	35.7984	1.0
9000253	326.0	35.8999	1.0
9000254	340.0	35.8999	1.0
9000255	349.6	35.6563	1.0
9000256	359.2	35.6563	1.0
9000257	362.8	35.4735	1.0
9000258	367.6	35.6563	1.0
9000259	379.6	35.4126	1.0
9000260	382.0	35.4126	1.0
9000261	390.4	35.8187	1.0
9000262	400.0	36.1232	1.0
9000263	401.2	36.1435	1.0
9000264	408.4	36.1435	1.0
9000265	419.2	35.6563	1.0
9000266	433.6	35.6563	1.0
9000267	434.8	35.5750	1.0
9000268	438.4	35.4126	1.0
9000269	440.8	35.5750	1.0
9000270	444.4	35.6360	1.0
9000271	451.6	35.9811	1.0
9000272	456.4	35.9202	1.0
9000273	460.0	36.1435	1.0
9000274	500.0	36.1435	1.0

*

 *****SECONDARY SIDE OF STEAM GENERATOR INTACT LOOP*****

*

 ***** RISING SECONDARY - BOILER SECTION *****

 * UPDATE - 1 - (SEE REF. 02)
 *

6000000	C600	PIPE					
6000001	4						
6000101	0.0	4					
6000201	0.04249	3					
6000301	7.9525	1					
6000302	7.9108334	3					
6000303	7.47625	4					
6000401	0.8881853	1					
6000402	0.8846853	3					
6000403	0.8994333	4					
6000601	90.0	4					
6000701	7.9525	1					
6000702	7.9108334	3					
6000703	7.47625	4					
6000801	0.0	0.1019770	3				
6000802	0.0	0.1333038	4				
**	0.0	0.0	3				
6000901	0.0	0.0	3				
6001001	0	4					
6001101	09100	3					
6001201	0	946.03	526.99	1111.7	0.01252	0.0	1
6001202	0	944.12	529.60	1111.8	0.51503	0.0	3
6001203	0	942.49	529.85	1111.8	0.61988	0.0	3
6001204	0	940.99	529.69	1111.8	0.67410	0.0	4
6001301	0						
6001301	2.6922	4.0900	0.0	1			

6001302 3.6730 5.6450 0.0 2
 6001303 4.4561 7.2345 0.0 3

 ***** BOILER UP-PLENUM *****

* UPDATE - 1 - (SEE REF. 02)
 * SEE O.A. REPORT PXXX

*
 6060000 C606 BRANCH
 6060001 1 0
 6060101 0.0 5.94875 2.6797920 0.0 -30.0 -5.94875
 6060102 0.0 0.0 0
 6060200 0 940.62 529.59 1111.9 0.99999
 6061101 600010000 606010000 0.03939 0.0 0.0 01000
 6061201 -16.913 4.2229-3 0.0

* SEE O.A. REPORT PXXX

*
 *6070000 C607 BRANCH
 *6070001 0 0
 *6070101 0.0 2.974375 1.3398960 0.0 90.0 2.974375
 *6070102 0.0 0.0 0
 *6070200 0 940.45 529.56 1111.9 1.0

 ***** STEAM DOME *****

*
 6010000 C601 SINGLVOL
 6010101 0.9122177 1.3125 0.0 0.0 90.0 1.3125
 6010102 0.0 0.0 0
 6010200 0 939.32 529.39 1111.9 0.99999

 ***** SEPARATOR/UPPER DOWNCOMER *****

* UPDATE - 1 - (SEE REF. 02)
 * SEE O.A. REPORT PXXX

*
 6020000 C602 SEPARATR
 6020001 3 0
 6020101 0.0 5.94875 2.6797920 0.0 90.0 5.94875
 6020102 0.0 0.0 0
 6020200 0 939.94 529.63 1111.8 0.38004
 ** STEAM OUTLET
 6021101 602010000 601000000 0.6263259 0.0 0.0 01000
 6021201 -2.4272-2 1.3383 0.0
 ** LIQUID FALLBACK
 6022101 602000000 603000000 0.4464736 0.0 0.0 01000
 6022201 0.41467 0.29383 0.0
 ** STEAM INLET
 6023101 600010000 602000000 0.450479848 0.0 0.0 01000
 6023201 1.2775 2.0907 0.0

* SEE O.A. REPORT PXXX

*
 *6080000 C608 BRANCH
 *6080001 1 0
 *6080101 0.0 2.974375 1.3398960 0.0 -90.0 -2.974375
 *6080102 0.0 0.0

```

*6080200 0 940.86 529.57 1111.9 0.21470
*6081101 603010000 603000000 0.4464736 0.0 0.0 61000
*6081201 0.26685 0.20698 0.0

```

```

*****
**** DOWNCOMER ****
*****

```

* UPDATE - 1 - (SEE REF. 02)

```

*
6030000 C603 PIPE
6030001 4
6030101 0.0278071 4
6030301 7.47625 1
6030302 7.9108334 3
6030303 7.9525 4
6030601 -90.0 4
6030701 -7.47625 1
6030702 -7.9108334 3
6030703 -7.9525 4
6030801 0.0 0.03357905 4
6030901 0.0 0.0 3
6031001 0 4
6031101 00000 3
6031201 3 941.12 537.18 0.0 0.0 0.0 1
6031202 3 942.73 537.12 0.0 0.0 0.0 2
6031203 3 944.40 537.06 0.0 0.0 0.0 3
6031204 3 946.03 523.57 0.0 0.0 0.0 4
6031300 0
6031301 6.6573 6.6573 0.0 1
6031302 6.6566 6.6566 0.0 2
6031303 6.6559 6.6559 0.0 3

```

```

*****
**** 603 - 600 JUN. ****
*****

```

* UPDATE - 1 - (SEE REF. 02)

```

*
6040000 JA04 SNGLJUN
**
6040101 603010000 600000000 0.0278071 0.0 0.0 00300
6040201 0 7.5454 7.6914 0.0

```

```

*****
**** MAIN FEEDWATER SOURCE ****
*****

```

* SEE O.A. REPORT PXXX

```

*
6300000 C630 TMDPVOL
6300101 0.012 0.0 0.12 0.0 0.0 0.0
6300102 0.0 0.0 10
6300200 3
6300201 0.0 952.0 429.8

```

```

*****
**** MAIN FEEDWATER JUNCTION****
*****

```

* UPDATE - 1 - (SEE REF. 02)

* SEE REF. - 04 - PXXX

* SEE O.A. REPORT PXXX

```

*
6100000 J510 TMDPJUN
6100101 630000000 603010000 0.012
6100201 1 501

```

6100201 0.0 1.3427 0.0 0.0
 6100202 30.0 0.0000 0.0 0.0 * FEEDWATER VALVE CLOSE
 6100203 1000.0 0.0000 0.0 0.0 * AT TIME = 30.0 SEC

*
 *6100000 RJ610 TNDPJUN
 *6100101 630000000 603010000 0.012
 *6100200 1 0 CNTPLVAR 610
 *6100201 -1.1E6 1.3231 0.0 0.0
 *6100202 -1.0E6 -1.0E6 0.0 0.0
 *6100203 0.0 0.0 0.0 0.0
 *6100204 1.0E6 1.0E6 0.0 0.0

 **** RELIEF VALVE ****

*
 *6340000 V634 VALVE
 *6340101 601010000 640000000 0.021 0.0 0.0 00100
 *6340102 0.6 0.8
 *6340201 1 0.0 0.0 0.0
 *6340300 TRPVLV
 *6340301 599

 **** STEAM DISCHARGE ****

* UPDATE - 1 - (SEE REF. 02)
 * SEE O.A. REPORT PXXX
 * STEAM VALVE WITH CHOKE !!

*
 *6350000 V635 VALVE
 **
 *6350101 601010000 640000000 0.007 204.67 204.67 00100
 *6350201 0 0.87895 0.90582 0.0 204.67 204.67 00100
 *6350300 HTRVLV
 **
 *6350301 598 CL-TPN SLOP INT-PDS TABLE
 504 0.2 9.5413 2 0 * CL 504
 *6350300 SRVVLV
 **
 *6350301 637
 *6350301 637

*
 *6350000 V635 VALVE
 *6350101 601010000 640000000 0.007 204.67 204.67 00100
 *6350201 0 0.88872 0.90335 0.0
 *6350300 SRVVLV
 *6350301 637

 **** STEAM LINE ****

*
 *6400000 C640 BRANCH
 *6400001 1 0
 *6400101 0.70584 10.0 0.0 0.0 0.0 0.0
 *6400102 0.0 0.0 0
 *6400200 0 14.010 177.74 1076.5 0.99269
 *6401101 640010000 650000000 0.70584 0.0 0.0 01300
 *6401201 0.7776 51.084 0.0
 *
 *6400000 C640 TNDPVUL
 *6400101 0.70584 10.0 0.0 0.0 0.0 0.0

```

*6400102 0.0      0.0      00
*6400200 2
*6400201 0.0      937.0     1.00

```

```

*****
**** ATOMSPHERIC DISCHARGE ****
*****

```

```

6500000 C650      TMDPVOL
6500101 0.70584  10.0      0.0      0.0      0.0      0.0
6500102 0.0      0.0      10
6500200 2
6500201 0.0      14.0      1.00

```

```

*****
**** S/G LIQUID LEVEL CONTRL ****
*****

```

```

* TEMPORARY CONTROL FOR INITIALIZATION

```

```

*6900000 C690      TMDPVOL
*6900101 1.0      0.0      1.0      0.0      0.0      0.0
*6900102 0.0      0.0      10
*6900200 1          0          TEMPF      603040000
*6900201 -0.0      517.03    0.0
*6900202 0.0      0.0      0.0
*6900203 1000.0    1000.0    0.0

```

```

*6910000 J691      TMDPJUN
*6910101 690000000 603010000 1.0
*6910200 1          0          CNTRLVAR   694
*6910201 -1.1E6    0.0      0.0      0.0
*6910202 -1.0E6    -1.0E6    0.0      0.0
*6910203 0.0      0.0      0.0      0.0
*6910204 1.0E6    1.0E6    0.0      0.0

```

```

*****
**** SECONDARY SIDE OF STEAM GENERATOR BROKEN LOOP *****
*****

```

```

**** RISING SECONDARY - BOILER SECTION ****
*****

```

```

* UPDATE - 1 - (SEE REF. 02 )

```

```

*
7000000 C700      PIPE
7000001 4
7000101 0.0      4
7000201 0.04976944 3
7000301 7.9629167 1
7000302 7.82750 2
7000303 7.9109333 3
7000304 6.6354363 4
7000401 0.4541449 1
7000402 0.4464939 2
7000403 0.4512499 3
7000404 0.3931984 4
7000601 93.0 4
7000701 7.9629167 1
7000702 7.82750 2
7000703 7.9109333 3
7000704 6.6354363 4

```

7000801	0.0	0.0655926	4				
**	0.0	0.0	3				
7000901	0.0	0.0	3				
7001001	0	4					
7001101	00100	3					
7001201	0	1095.8	549.01	1107.5	0.17322	0.0	1
7001202	0	1093.8	551.40	1107.6	0.32407	0.0	2
7001203	0	1092.1	551.89	1107.6	0.43349	0.0	3
7001204	0	1090.7	551.84	1107.7	0.46223	0.0	4
7001300	0						
7001301	2.2588	3.0842	0.0				1
7001302	2.7170	3.7104	0.0				2
7001303	3.1796	4.3255	0.0				3

*

 ***** BOILER UP-PLENUM *****

 * UPDATE - 1 - (SEE REF. 02)
 * SEE O.A. REPORT PXXX
 *

7060000	C706	BRANCH					
7060001	1	0					
7060101	0.0	6.862087	2.6230297	0.0	-90.0	-6.862087	
7060102	0.0	0.0	0				
7060200	0	1090.1	551.73	1107.7	0.99993		
7061101	700010000	70010000	0.04976944	0.0	0.0	01000	
7061201	-2.6636	8.3956-3	0.0				

* SEE O.A. REPORT PXXX
 *
 *7070000 C707 BRANCH
 *7070001 0 0
 *7070101 0.0 3.4310435 1.31151485 0.0 90.0 3.4310435
 *7070102 0.0 0.0 0
 *7070200 0 1064.3 548.03 1108.8 1.0

 ***** STEAM DOME *****

7010000	C701	SNGLVCL					
7010101	0.9122177	1.3125	0.0	0.0	90.0	1.3125	
7010102	0.0	0.0	0				
7010200	2	1089.3	1.0				

 ***** SEPARATOR/UPPER DOWNCOMER *****

 * UPDATE - 1 - (SEE REF. 02)
 * SEE O.A. REPORT PXXX
 *

7020000	C702	SEPARATR					
7020001	3	0					
7020101	0.0	6.862087	2.6230297	0.0	90.0	6.862087	
7020102	0.0	0.0	0				
7020200	0	1089.7	551.73	1107.7	0.69237		
**	STEAM OUTLET			0.0	0.0	01100	
7021101	702010000	701000000	0.42473177	0.0	0.0	01000	
7021201	-5.8775	0.32770	0.0				
**	LIQUID FALLBACK		0.0	0.0	0.0	01000	
7022101	702000000	703000000	0.4464736	0.0	0.0	01000	
7022201	0.22619	-1.3684-2	0.0				
**	STEAM INLET			0.0	0.0	01100	

7023101 700010000 702000000 0.38224955 0.0 0.0 01000
 7023201 0.49128 0.78934 0.0

*
 * SEE O.A. REPORT PXXX
 *

*7080000 C708 BRANCH
 *7080001 1 0
 *7080101 0.0 3.4310435 1.4572732 0.0 -90.0 -3.4310435
 *7080102 0.0 0.0 0
 *7080200 0 1064.8 547.99 1108.6 0.27345
 *7081101 708010000 703000000 0.44647360 0.0 0.0 01000
 *7081201 0.15240 0.10838 0.0

 ***** DOWNCOMER *****

* UPDATE - 1 - (SEE REF. 02)
 *

7030000 C703 PIPE
 7030001 4
 7030101 0.01763669 4
 7030301 6.6358363 1
 7030302 7.9108333 2
 7030303 7.82750 3
 7030304 7.9629167 4
 7030601 -90.0 4
 7030701 -6.6358363 1
 7030702 -7.9108333 2
 7030703 -7.82750 3
 7030704 -7.9629167 4
 7030801 0.0 0.033338 4
 7030901 0.0 0.0 3
 7031001 0 4
 7031101 00000 3
 7031201 3 1090.7 555.08 0.0 0.0 0.0 1
 7031202 3 1092.3 554.96 0.0 0.0 0.0 2
 7031203 3 1094.2 554.85 0.0 0.0 0.0 3
 7031204 3 1096.0 546.88 0.0 0.0 0.0 4
 7031300 0
 7031301 5.7248 5.7248 0.0 1
 7031302 5.7235 5.7235 0.0 2
 7031303 5.7222 5.7222 0.0 3

*

 ***** 703 - 700 JUN *****

 * UPDATE - 1 - (SEE REF. 02)
 *

7040000 J704 SNGLJUN
 ** 0.0 0.0 00100
 7040101 703010000 700000000 0.01763669 0.0 0.0 00100
 7040201 0 6.0736 6.3084 0.0

 ***** MAIN FEEDWATER SOURCE *****

*
 7300000 C730 TRDFVOL
 7300101 0.004 10.0 0.0 0.0 0.0
 7300102 0.0 0.0 10
 7300200 3
 7300201 0.0 1097.0 429.8
 *

 ***** MAIN FEEDWATER JUNCTION *****

* UPDATE - 1 - (SEE REF. 02)
 * SEE REF. - 04 - PXXX
 * SEE S.A. REPORT PXXX

*7100000	J710	TMDPJUN				
*7100101	730000000	703010000	0.004			
*7100200	1	501				
*7100201	0.0	0.34464	0.0	0.0		
*7100202	1.0	0.34464	0.0	0.0		
*7100203	2.5	0.00000	0.0	0.0		* FEEDWATER VALVE CLOSE
*7100204	1000.0	0.00000	0.0	0.0		* AT TIME = 2.5 SEC

*7100000	RJ710	TMDPJUN			
*7100101	730000000	703010000	0.004		
*7100200	1	0	CNTRLVAR	710	
*7100201	-1.1E6	0.35527	0.0	0.0	
*7100202	-1.0E6	-1.0E6	0.0	0.0	
*7100203	0.0	0.0	0.0	0.0	
*7100204	1.0E6	1.0E6	0.0	0.0	

 ***** RELIEF VALVE *****

*7340000	V734	VALVE				
*7340101	701010000	740000000	0.007	0.0	0.0	00100
*7340102	0.6	0.8				
*7340201	1	0.0	0.0	0.0		
*7340300	TRPVLV					
*7340301	599					

 ***** STEAM DISCHARGE *****

* UPDATE - 1 - (SEE REF. 02)
 * SEE S.A. REPORT PXXX
 * STEAM VALVE WITH CHOKE !!

*7350000	V735	VALVE				
*7350101	701010000	740000000	0.007	1022.36	1022.36	00100
*7350201	0	0.47875	0.48546	1022.36	1022.36	00100
*7350300	MTRVLV					
*7350301	598	501	0.2	2.07153-2		* W CL 504
*7350300	SRVVLV					
*7350301	737					

*7350000	V735	VALVE				
*7350101	701010000	740000000	0.007	1022.36	1022.36	00100
*7350201	0	0.48020	0.47372	1022.36	1022.36	00100
*7350300	SRVVLV					
*7350301	737					

 ***** STEAM LINE *****

*
7400000 C740 BRANCH
7400001 1 0
7400101 0.28649847 10.0 0.0 0.0 0.0 0.0
7400102 0.0 0.0 0
7400200 0 14.004 171.70 1076.7 0.99948
7401101 740010000 750000000 0.28649847 0.0 0.0 01000
7401201 1.5900 32.184 0.0

*
*7400000 R740 TMDPVOL
*7400101 0.28649847 10.0 0.0 0.0 0.0 0.0
*7400102 0.0 0.0 00
*7400200 2
*7400201 0.0 1066.5 1.0

***** ATMOSPHERIC DISCHARGE *****

*
7500000 C750 TMDPVOL
7500101 0.28649847 10.0 0.0 0.0 0.0 0.0
7500102 0.0 0.0 10
7500200 2
7500201 0.0 14.0 1.0

***** S/G LIQUID LEVEL CONTRL *****

* TEMPORARY CONTROL FOR INITIALIZATION

*
*7900000 C790 TMDPVOL
*7900101 1.0 0.0 1.0 0.0 0.0 0.0
*7900102 0.0 0.0 00
*7900200 1 0 TEMPF 703040000
*7900201 -0.0 541.02 0.0
*7900202 0.0 0.0 0.0
*7900203 1000.0 1000.0 0.0

*
*7910000 J791 TMDPVOL
*7910101 790000000 703010000 1.0
*7910200 1 0 CNTRLVAR 794
*7910201 -1.1E6 0.0 0.0 0.0
*7910202 -1.0E6 -1.0E6 0.0 0.0
*7910203 0.0 0.0 0.0 0.0
*7910204 1.0E6 1.0E6 0.0 0.0

** HEAT LOSS FOR VESSEL UPPER **

*
8000000 C800 TMDPVOL
8000101 10.0 1.0 0.0 0.0 1.0 0.0
8000102 0.0 0.0 00
8000200 1
8000201 0.0 80.0 1.0

** HEAT LOSS FOR CONDENSER **

```

8010000 C801      TMDPVOL
8010101 10.0      1.0      0.0      0.0      0.0      0.0
8010102 0.0        0.0      00
8010200 1
8010201 0.0        80.0      1.0

```

```

*****
** HEAT LOSS FOR OTHER VESSEL **
*****

```

```

8020000 C802      TMDPVOL
8020101 10.0      1.0      0.0      0.0      0.0      0.0
8020102 0.0        0.0      00
8020200 1
8020201 0.0        80.0      1.0

```

```

*****
** HEAT LOSS FOR IL PIPING **
*****

```

```

8030000 C803      TMDPVOL
8030101 10.0      1.0      0.0      0.0      0.0      0.0
8030102 0.0        0.0      00
8030200 1
8030201 0.0        80.0      1.0

```

```

*****
** HEAT LOSS FOR BL PIPING **
*****

```

```

8040000 C804      TMDPVOL
8040101 10.0      1.0      0.0      0.0      0.0      0.0
8040102 0.0        0.0      00
8040200 1
8040201 0.0        80.0      1.0

```

```

*****
** HEAT LOSS FOR IL S/G **
*****

```

```

8050000 C805      TMDPVOL
8050101 10.0      1.0      0.0      0.0      0.0      0.0
8050102 0.0        0.0      00
8050200 1
8050201 0.0        80.0      1.0

```

```

*****
** HEAT LOSS FOR BL S/G **
*****

```

```

8060000 C806      TMDPVOL
8060101 10.0      1.0      0.0      0.0      0.0      0.0
8060102 0.0        0.0      00
8060200 1
8060201 0.0        80.0      1.0

```

```

*****
** HEAT STRUCTURE COMPONENTS **
*****

```

 ***** VESSEL COMPONENTS *****

 ***** INLET ANNULUS *****
 ***** HEAT LOSS *****

11010000 1 7 2 1 0.271375
 11010100 0 1
 11010101 2 0.279708
 11010102 1 0.283850
 11010103 2 0.359375
 11010104 1 0.526042
 11010201 1 2
 11010202 13 3
 11010203 1 5
 11010204 8 6
 11010301 0.0 6
 11010400 -1
 11010401 548.11 547.83 547.55 435.53 436.07 433.83 384.82
 11010501 101010000 0 1 1 0.8750 1
 11010601 801010000 0 4100 1 0.8750 1
 11010701 0 0.0 0.0 0.0 1
 11010801 0 0.0 0.0 0.8750 1
 11010901 0 0.0 0.0 0.8750 1

11020000 1 7 2 1 0.271375
 11020100 0 1
 11020101 2 0.279708
 11020102 1 0.283850
 11020103 2 0.359375
 11020104 1 0.526042
 11020201 1 2
 11020202 13 3
 11020203 1 5
 11020204 8 6
 11020301 0.0 6
 11020400 -1
 11020401 551.84 551.56 551.23 441.71 439.24 436.97 387.54
 11020501 102010000 0 1 1 1.00 1
 11020601 801010000 0 4100 1 1.00 1
 11020701 0 0.0 0.0 0.0 1
 11020801 0 0.0 0.0 1.00 1
 11020901 0 0.0 0.0 1.00 1

 ***** INLET ANNULUS *****
 ***** HOLLOW CENTER *****

12010000 1 6 2 1 0.125000
 12010100 0 1
 12010101 2 0.187500
 12010102 1 0.191667
 12010103 2 0.200000
 12010201 1 2
 12010202 13 3
 12010203 1 5
 12010301 0.0 5

12010400	-1						
12010401	558.98	558.55	551.46	552.63	552.51	552.50	
12010501	0	0	0	1	0.8750	1	
12010601	101010000	0	1	1	0.8750	1	
12010701	0	0.0	0.0	0.0	1		
12010801	0	0.0	0.0	0.8750	1		
12010901	0	0.0	0.0	0.8750	1		

*

12020000	1	6	2	1	0.125000		
12020100	0	1					
12020101	2	0.187500					
12020102	1	0.191667					
12020103	2	0.200000					
12020201	1	2					
12020202	13	3					
12020203	1	5					
12020301	0.0	5					

12020400	-1						
12020401	559.09	559.05	558.95	552.41	552.59	552.38	
12020501	0	0	0	1	1.0000	1	
12020601	102010000	0	1	1	1.0000	1	
12020701	0	0.0	0.0	0.0	1		
12020801	0	0.0	0.0	1.0000	1		
12020901	0	0.0	0.0	1.0000	1		

 ***** DOWNCOMER PIPE *****
 ***** HEAT LOSS *****

#

11100000	9	9	2	1	0.091042		
11100100	0	1					
11100101	1	0.092542					
11100102	2	0.107825					
11100103	1	0.109325					
11100104	3	0.145833					
11100105	1	0.312500					
11100201	10	1					
11100202	12	3					
11100203	10	4					
11100204	1	7					
11100205	8	8					
11100301	0.0	8					
11100400	0						
11100401	552.00	2	466.60	3	387.60	4	387.45
11100402	385.46	7	384.60	8	338.15	9	386.40
11100501	110010000	0		1		1	2.2608333
11100502	110020000	0		1		1	1.0833333
11100503	110030000	010000		1		1	2.0000000
11100504	110080000	0		1		1	1.465667
11100505	110090000	0		1		1	1.434751
11100601	801010000	0		4100		1	2.2608333
11100602	801010000	0		4100		1	1.0833333
11100603	801010000	0		4100		1	2.0000
11100604	801010000	0		4100		1	2.0000
11100605	801010000	0		4100		1	2.0000
11100606	801010000	0		4100		1	2.0000
11100607	801010000	0		4100		1	2.0000
11100608	801010000	0		4100		1	1.465667
11100609	801010000	0		4100		1	1.434751
11100701	0	0.0	0.0	0.0	0		
11100801	0	0.0	0.0	0.0	16.244534	9	

11100901 3 0.0 0.0 1.00 9

***** DOWNCOMER DISTRIB *****
***** ANNULUS HEAT LOSS *****

*
11110000 1 9 2 1 0.244875
11110100 0 1
11110101 1 0.246542
11110102 2 0.256958
11110103 1 0.236625
11110104 3 0.411542
11110105 1 0.577821
11110201 10 1
11110202 11 3
11110203 10 4
11110204 1 7
11110205 6 8
11110301 0.0 8
11110400 0
11110401 551.80 2 50².31 3 459.81 4 459.65 5 459.60 6
11110402 452.06 7 448.94 8 398.61 9
11110501 110100000 0 1 0.96250 1
11110601 801010000 0 4100 1 0.96250 1
11110701 0 0.0 0.0 0.0 1
11110801 0 0.0 0.198130 0.96250 1
11110901 0 0.0 0.0 0.96250 1
*

***** DOWNCOMER DISTRIB *****
***** ANNULUS TO CORE INLET *****

*
11140000 1 3 2 1 0.179667
11140100 0 1
11140101 2 0.188958
11140201 1 2
11140301 0.0 2
11140400 -1
11140401 552.11 552.14 552.17
11140501 140010000 0 1 1 0.96250 1
11140601 110100000 0 1 1 0.96250 1
11140701 0 0.0 0.0 0.0 1
11140801 0 0.0 0.0 0.96250 1
11140901 0 0.0 0.256760 0.96250 1
*

***** LOWER HEAD *****
***** HEAT LOSS *****

*
11200000 1 8 2 1 0.412500
11200100 0 1
11200101 1 0.614167
11200102 2 0.424833
11200103 1 0.426250
11200104 2 0.740417
11200105 1 0.907083
11200201 10 1
11200202 11 3
11200203 13 4

```

11200204 1 6
11200205 8 7
11200301 0.0 7
11200400 0
11200401 533.80 2 423.74 3 315.40 5 285.05 6
11200402 262.66 7 127.44 8
11200501 120010000 0 1 1 0.466667 1
11200601 802010000 0 4200 1 0.466667 1
11200701 0 0.0 0.0 0.0 1
11200801 0 0.0 0.0 0.466667 1
11200901 0 0.0 0.0 0.466667 1

```

```

*****
**** LOWER PLENUM ****
**** HEAT LOSS ****
*****

```

```

*
11300000 1 8 2 1 0.363403
11300100 0 1
11300101 1 0.365070
11300102 2 0.375487
11300103 1 0.377153
11300104 2 0.691320
11300105 1 0.857987
11300201 10 1
11300202 11 3
11300203 10 4
11300204 1 6
11300205 8 7
11300301 0.0 7
11300400 0
11300401 540.50 2 427.31 3 315.70 5 285.25 6
11300402 262.62 7 127.11 8
11300501 130010000 0 1 1 0.721917 1
11300601 802010000 0 4200 1 0.721917 1
11300701 0 0.0 0.0 0.0 1
11300801 0 0.0 0.0 0.721917 1
11300901 0 0.0 0.0 0.721917 1

```

```

*****
**** CORE INLET ****
**** HEAT LOSS ****
*****

```

```

*
11400000 1 5 2 1 0.149340
11400100 0 1
11400101 3 0.482674
11400102 1 0.649340
11400201 1 3
11400202 8 4
11400301 0.0 4
11400400 0
11400401 547.29 1 486.83 2 443.97 3 411.05 4
11400402 158.93 5
11400501 140010000 0 1 1 0.673333 1
11400601 802010000 0 4200 1 0.673333 1
11400701 0 0.0 0.0 0.0 1
11400801 0 0.0 0.0 0.673333 1
11400901 0 0.0 0.0 0.673333 1

```

```

*****
**** CORE HEATER ROD ****
*****

```

***** (ACTIVE) *****

***** USING REFLOOD OPTION *****

*11500000	12	18	2	1	0.0					
11500000	12	18	2	1	0.0	1	1	8		
11500100	0	1								
11500101	1	0.002917								
11500102	4	0.009375								
11500103	4	0.014500								
11500104	4	0.015500								
11500105	4	0.017583								
11500201	3	1								
11500202	4	5								
11500203	5	9								
11500204	1	13								
11500205	1	17								
11500301	0.0	1								
11500302	1.0	5								
11500303	0.0	17								
11500400	-1									
11500401	649.0	649.0	647.1	642.3	635.0	625.2	615.1	605.1	598.0	
+	590.6	589.1	587.6	586.1	584.7	581.8	578.9	576.2	573.3	
11500402	725.1	725.1	721.5	712.4	698.4	679.4	651.0	644.2	629.0	
+	615.1	612.7	609.4	606.7	604.0	598.4	593.1	587.9	582.4	
11500403	815.5	815.5	810.2	796.4	775.2	747.3	719.5	694.9	672.4	
+	651.8	647.6	643.4	639.3	635.3	627.1	619.1	611.4	603.8	
11500404	901.8	901.8	894.6	875.6	846.6	808.3	771.3	738.0	707.8	
+	680.0	674.2	668.6	663.0	657.6	646.3	635.6	625.0	614.7	
11500405	972.0	972.0	963.4	941.0	906.8	861.6	818.8	780.3	745.1	
+	712.7	706.1	699.5	693.1	686.7	673.7	661.1	648.7	636.7	
11500406	1000.0	1000.0	990.7	966.6	929.8	881.1	835.4	794.2	756.6	
+	721.9	714.7	707.7	700.8	694.0	680.3	666.5	653.2	640.3	
11500407	1012.4	1012.4	1003.1	979.0	942.2	893.6	843.1	807.1	769.6	
+	735.1	728.1	721.1	714.2	707.4	693.6	680.1	666.9	654.1	
11500408	984.6	984.6	976.0	953.7	919.4	874.2	831.7	793.3	758.3	
+	726.2	719.6	713.1	706.6	700.3	687.4	674.8	662.6	650.6	
11500409	936.8	936.8	929.6	910.6	881.6	843.3	806.9	774.1	744.2	
+	716.8	711.2	705.7	700.2	694.9	683.9	673.2	662.0	652.7	
11500410	851.7	851.7	846.3	832.5	811.4	793.4	756.2	731.1	709.7	
+	689.4	685.3	681.2	677.2	673.2	665.2	657.3	649.7	642.3	
11500411	776.6	776.6	773.1	763.9	749.9	731.4	712.9	696.5	681.6	
+	668.0	665.3	662.5	659.9	657.2	651.8	646.6	641.5	636.6	
11500412	702.1	702.1	700.2	695.4	689.0	678.3	668.4	659.6	651.7	
+	644.5	643.0	641.6	640.1	638.7	635.9	633.1	630.4	627.8	
11500501	0	0	0	0	0	0.0				
11500601	150010000	0	1	0	0	2.5410249	1			
11500602	150010000	0	1	0	0	2.5410249	2			
11500603	150020000	0	1	0	0	2.5410249	3			
11500604	150020000	0	1	0	0	2.5410249	4			
11500605	150030000	0	1	0	0	2.5410249	5			
11500606	150030000	0	1	0	0	2.5410249	6			
11500607	150040000	0	1	0	0	2.5410249	7			
11500608	150040000	0	1	0	0	2.5410249	8			
11500609	150050000	0	1	0	0	2.5410249	9			
11500610	150050000	0	1	0	0	2.5410249	10			
11500611	150060000	0	1	0	0	2.5410249	11			
11500612	150060000	0	1	0	0	2.5410249	12			
11500701	900	0.02584	0.0	0.0	0.0	1				
11500702	900	0.04917	0.0	0.0	0.0	2				
11500703	900	0.07416	0.0	0.0	0.0	3				

11500704	900	0.10166	0.0	0.0	4
11500705	900	0.12001	0.0	0.0	5
11500706	900	0.12916	0.0	0.0	6
11500707	900	0.12916	0.0	0.0	7
11500708	900	0.12001	0.0	0.0	8
11500709	900	0.10166	0.0	0.0	9
11500710	900	0.07416	0.0	0.0	10
11500711	900	0.04917	0.0	0.0	11
11500712	900	0.02584	0.0	0.0	12
11500801	0	0.0	0.0	12.000	12
11500901	0	0.0	0.043992	12.000	12

 ***** CORE BARREL *****
 ***** HEAT LOSS *****

11501000	6	13	2	1	0.132114					
11501100	0	1								
11501101	2	0.133964								
11501102	1	0.135531								
11501103	2	0.143864								
11501104	3	0.200256								
11501105	2	0.272256								
11501106	2	0.438955								
11501201	1	2								
11501202	2	3								
11501203	1	5								
11501204	1	8								
11501205	1	10								
11501206	8	12								
11501301	0.0	12								
11501400	-1									
11501401	562.4	562.1	561.7	346.8	345.1	343.5	336.7	330.7	325.2	
+	316.0	308.0	209.9	123.3						
11501402	573.6	573.2	572.8	352.8	351.1	349.6	342.5	336.3	330.7	
+	321.2	313.1	212.8	126.1						
11501403	588.9	588.5	588.1	361.2	359.4	357.7	350.5	344.1	338.3	
+	328.6	320.2	217.0	127.3						
11501404	603.5	603.2	602.8	369.3	367.5	365.7	358.3	351.6	345.7	
+	335.6	327.0	220.9	128.4						
11501405	613.3	612.9	612.5	374.7	372.8	371.0	363.4	356.7	350.6	
+	340.4	331.5	223.6	129.2						
11501406	617.3	616.9	616.5	376.9	375.0	373.2	365.5	358.7	352.5	
+	342.2	333.4	224.7	129.5						
11501501	150010000	0		1		1	2.0000		1	
11501502	150020000	0		1		1	2.0000		2	
11501503	150030000	0		1		1	2.0000		3	
11501504	150040000	0		1		1	2.0000		4	
11501505	150050000	0		1		1	2.0000		5	
11501506	150060000	0		1		1	2.0000		6	
11501601	802010000	0		4200		1	2.0000		1	
11501602	802010000	0		4200		1	2.0000		2	
11501603	802010000	0		4200		1	2.0000		3	
11501604	802010000	0		4200		1	2.0000		4	
11501605	802010000	0		4200		1	2.0000		5	
11501606	802010000	0		4200		1	2.0000		6	
11501701	0	0.0	0.0	0.0	0.0				6	
11501801	0	0.0	0.0	0.129439	12.000				6	
11501901	0	0.0	0.0	0.0	12.000				6	

***** UPPER PLENUM *****
 ***** HEAT LOSS *****

11600000	4	12	2	1	0.133854								
11600100	0	1											
11600101	2	0.142184											
11600102	1	0.146351											
11600103	3	0.200518											
11600104	4	0.422392											
11600105	1	0.589059											
11600201	1	2											
11600202	2	3											
11600203	1	6											
11600204	1	10											
11600205	8	11											
11600301	0.0	11											
11600400	-1												
11600401	616.4	615.4	614.5	240.2	235.6	231.4	227.6	217.9	210.0				
+	203.1	197.8	106.9										
11600402	614.8	613.8	612.8	239.9	235.2	231.1	227.3	217.6	209.8				
+	203.2	197.5	106.8										
11600403	544.7	544.0	543.2	227.8	218.9	215.3	212.0	203.3	196.3				
+	190.4	185.4	104.4										
11600404	541.7	540.8	540.0	218.3	214.3	210.8	207.6	199.2	192.4				
+	186.7	181.8	103.7										
11600501	162010000	0		1		1		2.260833	1				
11600502	163010000	0		1		1		1.708333	2				
11600503	164010000	0		1		1		1.791667	3				
11600504	165010000	0		1		1		1.966667	4				
11600601	802010000	0		4200		1		2.260833	1				
11600602	802010000	0		4200		1		1.708333	2				
11600603	802010000	0		4200		1		1.791667	3				
11600604	802010000	0		4200		1		1.966667	4				
11600701	0	0.0	0.0	0.0		0.0			4				
11600801	0	0.0	0.0	0.0		2.260833			1				
11600802	0	0.0	0.0	0.0		1.708333			2				
11600803	0	0.0	0.0	0.0		1.791667			3				
11600804	0	0.0	0.0	0.0		1.966667			4				
11600901	0	0.0	0.0	0.0		0.0			4				

***** CORE OUTLET *****
 ***** HEAT LOSS *****

11610000	1	12	2	1	0.132114								
11610100	0	1											
11610101	2	0.133964											
11610102	1	0.135531											
11610103	2	0.143864											
11610104	3	0.200256											
11610105	2	0.560256											
11610106	1	0.726920											
11610201	1	2											
11610202	2	3											
11610203	1	5											
11610204	1	8											
11610205	1	10											
11610206	8	11											
11610301	0.0	11											
11610400	-1												


```

11610401 615.3 615.8 615.4 346.4 344.3 342.2 333.6 325.0 319.0
+      274.8 247.1 116.9
11610501 161010000 0      1      1      1.0 0833 1
11610601 802010000 0      4200      1      1.000833 1
11610701 0      0.0      0.0      0.0      1
11610801 0      0.0      0.173513 1.030833 1
11610901 0      0.0      0.0      1.000833 1

```

```

*****
*****      UPPER CORE      *****
*****      SUPPORT PLATE      *****
*****

```

```

*
11690000 1      4      1      1      0.0
11690100 0      1
11690101 3      0.65400
11690201 1      3
11690301 0.0 3
11690400 -1
11690401 562.8      578.1      592.0      605.2
11690501 165010000 0      1      0      0.1263155 1
11690601 191010000 0      1      0      0.1263155 1
11690701 0      0.0      0.0      0.0      1
11690801 0      0.0      0.0      0.476667 1
11690901 0      0.0      0.0      0.476667 1

```

```

*****
*****      UPPER HEAD      *****
*****      HEAT LOSS      *****
*****

```

```

*
11910000 2      10      2      1      0.134417
11910100 0      1
11910101 2      0.142750
11910102 1      0.146917
11910103 2      0.207292
11910104 3      0.276042
11910105 1      0.442708
11910201 1      2
11910202 2      3
11910203 1      5
11910204 1      3
11910205 5      0
11910301 0.0 9
11910400 -1
11910401 600.9 600.4 599.9 405.4 401.6 398.3 396.2 394.2 392.4
+      331.4

```

```

11910402 549.3 548.7 548.2 369.5 366.1 363.2 361.3 359.0 358.0
+      304.4
11910501 192010000 0      1      1      1.965833 1
11910502 193010000 0      1      1      3.453333 2
11910601 800010000 0      4100      1      1.965833 1
11910602 800010000 0      4100      1      3.453333 2
11910701 0      0.0      0.0      0.0      2
11910801 0      0.0      0.0      1.965833 1
11910802 0      0.0      0.0      3.453333 2
11910901 0      0.0      0.0      0.0      2

```

```

*
11910000 2      10      2      1      0.134417
11920100 0      1
11920101 2      0.142750
11920102 1      0.146917

```

11920103	2	0.207292									
11920104	3	0.413542									
11920105	1	0.580208									
11920201	1	2									
11920202	2	3									
11920203	1	5									
11920204	1	8									
11920205	8	9									
11920301	0.0	9									
11920400	-1										
11920401	598.5	598.0	597.4	377.1	372.8	369.1	362.4	357.2	352.9		
+	302.5										
11920402	546.0	545.4	544.8	344.7	340.8	337.6	331.7	327.2	323.4		
+	279.5										
11920501	191010000	0		1	1		0.476667		1		
11920502	194010000	0		1	1		2.88083		2		
11920601	800010000	0		4100	1		0.476667		1		
11920602	800010000	0		4100	1		2.88083		2		
11920701	0	0.0	0.0	0.0	0.0				2		
11920801	0	0.0	0.0	0.0	0.476667				1		
11920802	0	0.0	0.0	0.0	2.88083				2		
11920901	0	0.0	0.0	0.0	0.0				2		

 LOOP PIPING COMPONENTS *****

 INTACT LOOP *****
 3-IN SCH-160 PIPE *****

 BAND HEATERS *****

12001000	4	11	2	1	0.109333						
12001100	0	1									
12001101	2	0.145833									
12001102	1	0.145866									
12001103	1	0.148470									
12001104	3	0.158887									
12001105	1	0.161491									
12001106	2	0.328158									
12001201	1	2									
12001202	13	3									
12001203	1	4									
12001204	9	7									
12001205	1	8									
12001206	16	10									
12001301	0.0	10									
12001400	-1										
12001401	555.8	552.7	550.3	548.8	548.5	545.4	542.4	539.5	539.2		
+	320.4	139.1									
12001402	555.7	552.7	550.3	548.8	548.5	545.4	542.3	539.4	539.2		
+	320.4	139.1									
12001403	555.5	552.5	550.1	548.7	548.4	545.3	542.3	539.4	539.1		
+	320.4	139.1									
12001404	555.4	552.5	550.1	548.6	548.3	545.2	542.2	539.3	539.0		
+	320.4	139.1									
12001501	240040000	0		1	1		2.50000		1		
12001502	240050000	0		1	1		2.08333		2		
12001503	240060000	0		1	1		2.95833		3		

12001504	240070000	0	1	1	0.16667	4
12001601	803010000	0	4500	1	2.50000	1
12001602	803010000	0	4500	1	2.08333	2
12001603	803010000	0	4500	1	2.95833	3
12001604	803010000	0	4500	1	0.16667	4
12001701	111	0.0	0.0	0.0	1	
12001702	111	0.0	0.0	0.0	2	
12001703	111	0.0	0.0	0.0	3	
12001704	111	0.0	0.0	0.0	4	
12001801	0	0.0	0.0	2.50000	1	
12001802	0	0.0	0.0	2.08333	2	
12001803	0	0.0	0.0	2.95833	3	
12001804	0	0.0	0.0	0.16667	4	
12001901	0	0.0	0.0	2.50000	1	
12001902	0	0.0	0.0	2.08333	2	
12001903	0	0.0	0.0	2.95833	3	
12001904	0	0.0	0.0	0.16667	4	

***** HEATER TAPE *****

12002000	7	8	2	1	0.109333			
12002100	0	1						
12002101	2	0.145833						
12002102	1	0.145933						
12002103	2	0.156350						
12002104	2	0.323016						
12002201	1	2						
12002202	13	3						
12002203	9	5						
12002204	16	7						
12002301	0.0	7						
12002400	-1							
12002401	615.0	612.5	610.2	605.6	600.6	595.7	351.2	145.4
12002402	555.7	552.8	550.5	546.1	541.6	537.3	318.4	138.6
12002403	555.5	552.7	550.4	546.0	541.5	537.2	318.4	138.6
12002404	555.7	552.9	550.6	546.1	541.5	537.2	318.4	138.6
12002405	555.6	552.8	550.5	546.0	541.5	537.1	318.3	138.6
12002406	614.5	612.4	610.5	606.7	602.6	598.5	400.4	240.7
12002407	565.2	563.2	561.5	558.0	554.4	550.9	369.4	228.4
12002501	201020000	0	1	1	0.72757	1		
12002502	240050000	0	1	1	0.36379	2		
12002503	240060000	0	1	1	0.36379	3		
12002504	261020000	0	1	1	0.36379	4		
12002505	262010000	0	1	1	0.18189	5		
12002506	301010000	0	1	1	0.72757	6	* V-NOZZLE	
12002507	363030000	0	1	1	0.36378	7	* V-NOZZLE	
12002601	803010000	0	4500	1	0.72757	1		
12002602	803010000	0	4500	1	0.36379	2		
12002603	803010000	0	4500	1	0.36379	3		
12002604	803010000	0	4500	1	0.36379	4		
12002605	803010000	0	4500	1	0.18189	5		
12002606	804010000	0	4300	1	0.72757	6	* V-NOZZLE	
12002607	804010000	0	4300	1	0.36378	7	* V-NOZZLE	
12002701	110	0.0	0.0	0.0	1			
12002702	110	0.0	0.0	0.0	2			
12002703	110	0.0	0.0	0.0	3			
12002704	112	0.0	0.0	0.0	4			
12002705	112	0.0	0.0	0.0	5			
12002706	110	0.0	0.0	0.0	6			
12002707	112	0.0	0.0	0.0	7			
12002801	0	0.0	0.0	0.0	0.72757	1		
12002802	0	0.0	0.0	0.0	0.36379	2		

12002803	0	0.0	0.0	0.36379	3
12002804	0	0.0	0.0	0.36379	4
12002805	0	0.0	0.0	0.18189	5
12002806	0	0.0	0.0	0.72757	6
12002807	0	0.0	0.0	0.36378	7
12002901	0	0.0	0.0	0.72757	1
12002902	0	0.0	0.0	0.36379	2
12002903	0	0.0	0.0	0.36379	3
12002904	0	0.0	0.0	0.36379	4
12002905	0	0.0	0.0	0.18189	5
12002906	0	0.0	0.0	0.72757	6
12002907	0	0.0	0.0	0.36378	7

*
 ***** UP HEATED *****
 *

12003000	9	5	2	1	0.109333		
12003100	0	1					
12003101	2	0.182333					
12003102	2	0.349000					
12003201	1	2					
12003202	16	4					
12003301	0.0	4					
12003400	-1						
12003401	614.9	609.5	605.0	360.9	147.8		
12003402	615.0	609.6	605.1	361.0	147.8		
12003403	555.7	549.5	545.2	326.9	140.8		
12003404	555.5	549.4	545.2	326.9	140.8		
12003405	555.3	549.4	545.1	326.9	140.8		
12003406	555.2	549.3	545.1	326.9	140.8		
12003407	555.5	549.4	545.1	326.9	140.8		
12003408	555.4	549.3	545.0	326.8	140.7		
12003409	555.2	549.2	544.9	326.7	140.7		
12003501	201010000	0		1		0.720833	1
12003502	201020000	0		1		2.49493	2
12003503	240040000	0		1		1.37500	3
12003504	240050000	0		1		1.64196	4
12003505	240060000	0		1		2.70446	5
12003506	240070000	0		1		2.61491	6
12003507	261020000	0		1		2.11538	7
12003508	262010000	0		1		2.41411	8
12003509	263010000	0		1		0.59583	9
12003601	803010000	0		4500	1	0.720833	1
12003602	803010000	0		4500	1	2.49493	2
12003603	803010000	0		4500	1	1.37500	3
12003604	803010000	0		4500	1	1.64196	4
12003605	803010000	0		4500	1	2.70446	5
12003606	803010000	0		4500	1	2.61491	6
12003607	803010000	0		4500	1	2.11538	7
12003608	803010000	0		4500	1	2.41411	8
12003609	803010000	0		4500	1	0.59583	9
12003701	0	0.0	0.0	0.0	0.0		9
12003801	0	0.0	0.0	0.0	0.218666		9
12003901	0	0.0	0.0	0.0	0.218666		7

 ***** INTACT LUMP *****
 ***** 2.5 - IN SCH-160 PIPE *****

***** HEATER TUBE *****
 *
 12004000 7 1 2 1 0.084542

12004100	0	1							
12004101	2	0.119792							
12004102	1	0.119892							
12004103	2	0.130309							
12004104	2	0.296975							
12004201	1	2							
12004202	13	3							
12004203	9	5							
12004204	16	7							
12004301	0.0	7							
12004400	-1								
12004401	615.1	612.8	610.6	605.7	600.3	595.1	345.3	143.7	
12004402	615.1	612.8	610.6	605.7	600.3	595.1	345.3	143.7	
12004403	615.1	612.8	610.6	605.7	600.3	595.1	345.3	143.7	
12004404	615.1	612.8	610.6	605.7	600.3	595.1	345.3	143.7	
12004405	556.4	553.6	551.4	546.7	541.7	537.2	313.2	137.1	
12004406	556.4	553.6	551.4	546.7	541.7	537.2	313.2	137.1	
12004407	556.4	553.6	551.4	546.7	541.7	537.2	313.2	137.1	
12004501	201030000	0		1	1		1.77146	1	
12004502	202010000	0		1	1		1.99289	2	
12004503	203010000	0		1	1		1.55003	3	
12004504	203020000	0		1	1		0.88573	4	
12004505	240010000	0		1	1		0.88573	5	
12004506	240020000	0		1	1		1.55003	6	
12004507	240030000	0		1	1		1.77146	7	
12004601	803010000	0	4500		1		1.77146	1	
12004602	803010000	0	4500		1		1.99289	2	
12004603	803010000	0	4500		1		1.55003	3	
12004604	803010000	0	4500		1		0.88573	4	
12004605	803010000	0	4500		1		0.88573	5	
12004606	803010000	0	4500		1		1.55003	6	
12004607	803010000	0	4500		1		1.77146	7	
12004701	110	0.0	0.0		0.0		1		
12004702	110	0.0	0.0		0.0		2		
12004703	110	0.0	0.0		0.0		3		
12004704	110	0.0	0.0		0.0		4		
12004705	110	0.0	0.0		0.0		5		
12004706	110	0.0	0.0		0.0		6		
12004707	110	0.0	0.0		0.0		7		
12004801	0	0.0	0.0			0.177084	7		
12004901	0	0.0	0.0			0.177084	7		

*
 ***** UNHEATED *****
 *

12005000	7	5	2	1	0.082542				
12005100	0	1							
12005101	2	0.151042							
12005102	2	0.317709							
12005201	1	2							
12005202	16	4							
12005301	0.0	4							
12005400	-1								
12005401	615.1	610.1	606.1	355.9	146.2				
12005402	615.1	610.1	606.1	355.9	146.2				
12005403	615.1	610.1	606.1	355.9	146.2				
12005404	615.1	610.1	606.1	355.9	146.2				
12005405	556.2	550.4	546.4	322.4	139.4				
12005406	556.2	550.4	546.4	322.4	139.4				
12005407	556.2	550.4	546.4	322.4	139.4				
12005501	201030000	0		1	1		0.77104	1	
12005502	202010000	0		1	1		0.46044	2	
12005503	203010000	0		1	1		2.35539	3	

12005504	240020000	0	1	1	1.24052	4
12005505	240010000	0	1	1	0.57385	5
12005506	240020000	0	1	1	2.11622	6
12005507	240030000	0	1	1	1.01271	7
12005601	803010000	0	4500	1	0.77104	1
12005602	803010000	0	4500	1	0.46044	2
12005603	803010000	0	4500	1	2.35539	3
12005604	803010000	0	4500	1	1.24052	4
12005605	803010000	0	4500	1	0.57385	5
12005606	803010000	0	4500	1	2.11622	6
12005607	803010000	0	4500	1	1.01271	7
12005701	0	0.0	0.0	0.0	7	
12005801	0	0.0	0.0	0.177084	7	
12005901	0	0.0	0.0	0.177084	7	

 ***** BROKEN LOOP *****
 ***** 1.5 - IN SCH-160 PIPE *****

***** BAND HEATERS *****

13001000	4	11	2	1	0.055750					
13001100	0	1								
13001101	2	0.079167								
13001102	1	0.079200								
13001103	1	0.081804								
13001104	3	0.092221								
13001105	1	0.094825								
13001106	2	0.261492								
13001201	1	2								
13001202	13	3								
13001203	1	4								
13001204	9	7								
13001205	1	8								
13001206	16	10								
13001301	0.0	10								
13001400	-1									
13001401	566.3	564.5	563.0	561.4	561.1	557.9	554.8	551.9	551.6	
+	355.0	217.2								
13001402	566.1	564.3	562.8	561.2	560.9	557.7	554.6	551.6	551.4	
+	354.8	217.1								
13001403	565.9	564.0	562.5	560.9	560.6	557.4	554.3	551.3	551.0	
+	354.6	217.0								
13001404	565.8	564.0	562.4	560.9	560.5	557.3	554.2	551.2	550.9	
+	334.4	216.9								
13001501	340040000	0	1	1	2.29167	1				
13001502	340050000	0	1	1	2.08333	2				
13001503	340060000	0	1	1	3.20833	3				
13001504	340070000	0	1	1	0.20833	4				
13001601	804010000	0	4300	1	2.29167	1				
13001602	804010000	0	4300	1	2.08333	2				
13001603	804010000	0	4300	1	3.20833	3				
13001604	804010000	0	4300	1	0.20833	4				
13001701	111	0.0	0.0	0.0	1					
13001702	111	0.0	0.0	0.0	2					
13001703	111	0.0	0.0	0.0	3					
13001704	111	0.0	0.0	0.0	4					
13001801	0	0.0	0.0	0.11150	4					
13001901	0	0.0	0.0	0.11150	4					

***** HEATED TAPE *****

13002708	110	0.0	0.0	0.0	8
13002709	110	0.0	0.0	0.0	9
13002710	110	0.0	0.0	0.0	10
13002711	110	0.0	0.0	0.0	11
13002712	110	0.0	0.0	0.0	12
13002713	110	0.0	0.0	0.0	13
13002714	110	0.0	0.0	0.0	14
13002801	0	0.0	0.0	0.11150	14
13002901	0	0.0	0.0	0.11150	14

*
 ***** UNHEATED *****

13003000	15	5	2	1	0.055750		
13003100	C	1					
13003101	2	0.102584					
13003102	2	0.269251					
13003201	1	2					
13003202	16	4					
13003301	0.0	4					
13003400	-1						
13003401	614.9	611.1	608.1	392.3	235.0		
13003402	614.9	611.1	608.1	392.3	235.0		
13003403	614.9	611.1	608.1	392.3	235.0		
13003404	614.9	611.1	608.1	392.3	235.0		
13003405	565.8	562.2	559.5	362.2	221.0		
13003406	565.8	562.2	559.5	362.2	221.0		
13003407	565.8	562.2	559.5	362.2	221.0		
13003408	565.8	562.2	559.5	362.2	221.0		
13003409	565.8	562.2	559.5	362.2	221.0		
13003410	565.8	562.2	559.5	362.2	221.0		
13003411	565.8	562.2	559.5	362.2	221.0		
13003412	565.8	562.2	559.5	362.2	221.0		
13003413	565.8	562.2	559.5	362.2	221.0		
13003414	565.8	562.2	559.5	362.2	221.0		
13003415	565.8	562.2	559.5	362.2	221.0		
13003501	301020000	0		1	1	2.89923	1
13003502	301030000	0		1	1	0.55379	2
13003503	301040000	0		1	1	2.43943	3
13003504	301050000	0		1	1	0.99214	4
13003505	340010000	0		1	1	0.95138	5
13003506	340020000	0		1	1	1.63170	6
13003507	340030000	0		1	1	0.71779	7
13003508	340040000	0		1	1	1.21808	8
13003509	340050000	0		1	1	2.29891	9
13003510	340060000	0		1	1	3.36615	10
13003511	340070000	0		1	1	2.08834	11
13003512	361010000	0		1	1	1.63494	12
13003513	362010000	0		1	1	0.42077	13
13003514	363010000	0		1	1	0.55661	14
13003515	363020000	0		1	1	1.99911	15
13003601	804010000	0	4300	1	1	2.89923	1
13003602	804010000	0	4300	1	1	0.55379	2
13003603	804010000	0	4300	1	1	2.43943	3
13003604	804010000	0	4300	1	1	0.99214	4
13003605	804010000	0	4300	1	1	0.95138	5
13003606	804010000	0	4300	1	1	1.63170	6
13003607	804010000	0	4300	1	1	0.71779	7
13003608	804010000	0	4300	1	1	1.21808	8
13003609	804010000	0	4300	1	1	2.29891	9
13003610	804010000	0	4300	1	1	3.36615	10
13003611	804010000	0	4300	1	1	2.08834	11
13003612	804010000	0	4300	1	1	1.63494	12

13003613	804010000	0	4300	1	0.42077	13
13003614	804010000	0	4300	1	0.55661	14
13003615	804010000	0	4300	1	1.99911	15
13003701	0	0.0	0.0	0.0	15	
13003801	0	0.0	0.0	0.11150	15	
13003901	0	0.0	0.0	0.11150	15	

 ***** VESSEL NOZZLES *****
 ***** 3 - IN SCH-160 PIPE *****

***** UNHEATED *****

13004000	2	5	2	1	0.109333	
13004100	0	1				
13004101	2	0.145833				
13004102	2	0.312500				
13004201	1	2				
13004202	16	4				
13004301	0.0	4				
13004400	-1					
13004401	614.48	612.41	610.50	406.18	243.03	
13004402	565.16	563.19	561.45	374.38	228.46	
13004501	301010000	0	1	1	0.61160	1
13004502	303030000	0	1	1	0.91239	2
13004601	804010000	0	4300	1	0.61160	1
13004602	804010000	0	4300	1	0.91239	2
13004701	0	0.0	0.0	0.0	2	
13004801	0	0.0	0.0	0.218666	2	
13004901	0	0.0	0.0	0.218666	2	

 ***** S/G COMPONENTS *****

***** INTACT LOOP *****

 ***** U-TYPES (UPSIDE) *****

12200000	4	5	2	1	0.032375	
12200100	0	1				
12200101	4	0.036458				
12200201	5	4				
12200301	0.0	4				
12200400	-1					
12200401	521.43	572.95	564.68	556.63	548.77	
12200402	575.10	568.48	562.04	555.78	549.67	
12200403	569.18	563.79	558.54	553.46	548.47	
12200404	564.82	560.31	555.93	551.67	547.52	
					47.71	198
					47.00	3
					40.00	4
					47.00	198
					47.4650000	3
					40.0638200	4
12200501	220010000	0	1	1	64.4152497	1x1.35
12200502	220020000	010000	1	1	64.0777500	3
12200503	220040000	0	1	1	54.0929070	4
12200601	800010000	0	1	1	64.4152497	1x1.35

12200602	600020000	010000	1	1	64.0777500	3
12200603	600040000	0	1	1	54.0929070	4
12200701	0	0.0	0.0	0.0	4	
12200801	0	0.0	0.0	29.5000	4	
12200901	0	0.0	0.1629349	29.5000	3	
12200902	0	0.0	0.2383660	29.5000	4	

***** U-TUBES (DOWNSIDE) *****

12210000	4	5	2	1	0.032375	
12210100	0	1				
12210101	4	0.036458				
12210201	5	4				
12210301	0.0	4				
12210400	-1					
12210401	561.12	557.33	553.64	550.06	546.57	
12210402	557.48	554.37	551.35	548.42	545.56	
12210403	554.46	551.93	549.48	547.10	544.78	
12210404	551.45	549.28	547.17	545.12	543.12	
12210501	220050000	0	1	1	54.0929070	1
12210502	220060000	010000	1	1	64.0777500	3
12210503	220080000	0	1	1	54.4152497	4
12210601	600040000	0	1	1	54.0929070	1
12210602	600030000	0	1	1	64.0777500	2
12210603	600020000	0	1	1	64.0777500	3
12210604	600010000	0	1	1	64.4152497	4
12210701	0	0.0	0.0	0.0	4	
12210801	0	0.0	0.0	29.50	4	
12210901	0	0.0	0.238366	29.50	1	
12210902	0	0.0	0.162994	29.50	4	

***** SECONDARY HEAT LOSS (RISER) *****

16000000	5	13	2	1	0.245364				
16000100	0	1							
16000101	2	0.368332							
16000102	1	0.370833							
16000103	2	0.382400							
16000104	1	0.384900							
16000105	1	0.396000							
16000106	1	0.398500							
16000107	2	0.447917							
16000108	2	0.697917							
16000201	14	2							
16000202	15	3							
16000203	1	5							
16000204	15	6							
16000205	1	7							
16000206	15	8							
16000207	1	10							
16000208	15	12							
16000301	0.0	12							
16000400	-1								
16000401	535.3	499.9	486.8	485.3	485.2	485.1	483.8	483.6	482.5
+	482.1	481.7	480.5	387.5					
16000402	537.8	524.7	515.1	513.7	513.6	513.5	512.1	511.9	510.
+	510.2	509.8	455.1	409.0					
16000403	537.7	526.1	516.7	515.3	515.2	515.1	513.8	513.6	512.7
+	511.8	511.4	456.5	410.2					
16000404	537.6	526.0	516.6	515.2	515.1	515.0	513.7	513.4	512.7
+	511.7	511.3	456.4	410.1					
16000405	537.5	525.9	516.5	515.2	515.1	515.0	513.6	513.3	512.1

+	511.7	511.3	456.3	410.1			
16000501	600010000	0		1	1	6.8038055	1
16000502	600020000	010000		1	1	6.7681574	3
16000503	600030000	0		1	1	6.3963472	4
16000504	606010000	0		1	1	1.17554194	5
16000601	805010000	0		4400	1	6.8038055	1
16000602	805010000	0		4400	1	6.7681574	3
16000603	805010000	0		4400	1	6.3963472	4
16000604	805010000	0		4400	1	1.17554194	5
16000701	0	0.0		0.0	0.0	5	
16000801	0	0.0		0.0	0.0	5	
16000901	0	0.0		0.0	0.0	5	

**** SECONDARY HEAT LOSS (S-DOME) ****

16701000	6	5	2	1	0.671833		
16701100	0	1					
16701101	2	0.750000					
16701102	2	1.000000					
16701201	1	2					
16701202	17	4					
16701301	0.0	4					
16701400	-1						
16701401	537.49	536.97	536.54	437.86	344.69		
16701402	537.47	536.94	536.52	437.83	344.69		
16701403	552.51	552.05	551.62	450.05	353.44		
16701404	552.51	552.05	551.62	450.05	353.44		
16701405	552.51	552.05	551.62	450.05	353.44		
16701406	552.51	552.05	551.62	450.05	353.44		
16701501	601010000	0		1	1	1.500000	1
16701502	602010000	0		1	1	2.2871875	2
16701503	602010000	0		1	1	2.2871875	3
16701504	701010000	0		1	1	1.500000	4 * B-LOOP
16701505	702010000	0		1	1	2.2871875	5 * S-LOOP
16701506	702010000	0		1	1	2.2871875	6 * B-LOOP
16701601	805010000	0		4400	1	1.500000	1
16701602	805010000	0		4400	1	2.2871875	2
16701603	805010000	0		4400	1	2.2871875	3
16701604	806010000	0		4400	1	1.500000	4 * B-LOOP
16701605	806010000	0		4400	1	2.2871875	5 * B-LOOP
16701606	806010000	0		4400	1	2.2871875	6 * B-LOOP
16701701	0	0.0		0.0	0.0	5	
16701801	0	0.0		0.0	1.500000	1	
16701802	0	0.0		0.0	2.2871875	3	
16701803	0	0.0		0.0	1.500000	4 * B-LOOP	
16701804	0	0.0		0.0	2.2871875	6 * B-LOOP	
16701901	0	0.0		0.0	0.0	5	

**** SECONDARY HEAT LOSS (DWCMP) ****

16703000	10	5	2	1	0.398500		
16703100	0	1					
16703101	2	0.447917					
16703102	2	0.697917					
16703201	1	2					
16703202	17	4					
16703301	0.0	4					
16703400	-1						
16703401	537.48	537.09	536.77	430.59	337.62		
16703402	537.47	537.11	536.82	430.62	337.65		
16703403	537.54	537.24	536.95	430.73	337.72		
16703404	537.50	536.83	535.96	429.00	336.49		

16703405	507.62	482.75	476.11	370.55	294.89		
16703406	552.51	552.14	551.87	442.58	346.12		
16703407	552.55	552.71	551.90	442.62	346.15		
16703408	552.64	552.17	551.81	442.54	346.09		
16703409	548.29	543.92	542.21	434.08	340.13		
16703410	491.37	483.15	480.42	384.32	304.69		
16703501	602010000	0	1	1	1.3743749	1	
16703502	603010000	0	1	1	7.4762500	2	
16703503	603020000	0	1	1	7.9108334	3	
16703504	603030000	0	1	1	7.9108334	4	
16703505	603040000	0	1	1	7.9325000	5	
16703506	702010000	0	1	1	2.2877054	6	* B-L
16703507	703010000	0	1	1	6.6358363	7	* B-L
16703508	703020000	0	1	1	7.9108333	8	* B-L
16703509	703030000	0	1	1	7.8275000	9	* B-L
16703510	703040000	0	1	1	7.9629167	10	* B-L
16703601	805010000	0	4400	1	1.3743749	1	
16703602	805010000	0	4400	1	7.4762500	2	
16703603	805010000	0	4400	1	7.9108334	3	
16703604	805010000	0	4400	1	7.9108334	4	
16703605	805010000	0	4400	1	7.9525000	5	
16703606	806010000	0	4400	1	2.2877054	6	* B-L
16703607	806010000	0	4400	1	6.6358363	7	* B-L
16703608	806010000	0	4400	1	7.9108333	8	* B-L
16703609	806010000	0	4400	1	7.8275000	9	* B-L
16703610	806010000	0	4400	1	7.9629167	10	* B-L
16703701	0	0.0	0.0	0.0	10		
16703801	0	0.0	0.0	0.0	10		
16703901	0	0.0	0.0	0.0	10		

* ***** RISER TO DOWNCOMER *****

16003000	5	6	2	1	0.245364		
16003100	0	1					
16003101	2	0.368333					
16003102	1	0.370833					
16003103	2	0.382400					
16003201	14	2					
16003202	15	3					
16003203	1	5					
16003301	0.0	5					
16003400	-1						
16003401	534.45	489.60	488.85	505.16	507.53	511.04	
16003402	537.99	536.39	537.31	537.61	537.64	537.69	
16003403	537.87	537.64	537.64	537.62	537.63	537.65	
16003404	537.72	537.49	537.49	537.50	537.51	537.54	
16003405	537.54	537.45	537.61	537.59	537.59	537.59	
16003501	600010000	0	1	1	1.1486944	1	
16003502	600020000	010000	1	1	1.1426759	3	
16003503	600040000	0	1	1	1.0799028	4	
16003504	506010000	0	1	1	0.198520833	5	
16003601	603040000	0	1	1	1.1486944	1	
16003602	603030000	0	1	1	1.1426759	2	
16003603	603020000	0	1	1	1.1426759	3	
16003604	603010000	0	1	1	1.0799028	4	
16003605	602010000	0	1	1	0.198520833	5	
16003701	0	0.0	0.0	0.0	5		
16003801	0	0.0	0.19352495	0.0	0.0	3	
16003802	0	0.0	0.234145932	0.0	0.0	4	
16003803	0	0.0	0.27476691	0.0	0.0	5	
16003901	0	0.0	0.162638317	0.0	0.0	5	

 ***** BROKEN LOOP *****

***** U-TUBES (UPSIDE) *****

```

13200000 4 5 2 1 0.032375
13200100 0 1
13200101 4 0.036458
13200201 5 4
13200301 0.0 4
13200400 -1
13200401 588.66 581.54 574.69 567.99 561.45
13200402 582.54 576.85 571.32 565.94 560.69
13200403 577.93 572.96 568.52 564.21 560.01
13200404 573.80 569.93 566.28 562.67 559.17
13200501 320010000 0 1 1 22.296176 1 * ORIGINAL
13200502 320020000 0 1 1 21.917000 2 *
13200503 320030000 0 1 1 22.150324 3 *
13200504 320040000 0 1 1 18.813396 4 *
13200601 700010000 0 1 1 22.296176 1 * X 1.40
13200602 700020000 0 1 1 21.917000 2 *
13200603 700030000 0 1 1 22.150324 3 *
13200604 700040000 0 1 1 18.813396 4 *
13200701 0 0.0 0.0 0.0 4
13200801 0 0.0 0.0 29.5 4
13200901 0 0.0 0.195538 29.5 4

```

***** U-TUBES (DOWNSIDE) *****

```

13210000 4 5 2 1 0.032375
13210100 0 1
13210101 4 0.036458
13210201 5 4
13210301 0.0 4
13210400 -1
13210401 570.66 567.50 564.43 561.44 558.54
13210402 567.76 565.23 562.77 560.38 558.05
13210403 565.35 563.28 561.28 559.33 557.43
13210404 563.04 561.29 559.58 557.93 556.32
13210501 320050000 0 1 1 18.813396 1
13210502 320060000 0 1 1 22.150324 2
13210503 320070000 0 1 1 21.917000 3
13210504 320080000 0 1 1 22.296176 4
13210601 700040000 0 1 1 18.813396 1
13210602 700030000 0 1 1 22.150324 2
13210603 700020000 0 1 1 21.917000 3
13210604 700010000 0 1 1 22.296176 4
13210701 0 0.0 0.0 0.0 4
13210801 0 0.0 0.0 29.50 4
13210901 0 0.0 0.195538 29.50 4

```

***** SECONDARY HEAT LOSS (RISER) *****

```

17000000 5 13 2 1 0.172413
17000100 0 1
17000101 2 0.356597
17000102 1 0.359097
17000103 2 0.371030
17000104 1 0.373530
17000105 1 0.396000
17000106 1 0.398500

```

17000107	2	0.447917						
17000108	2	7.697917						
17000201	14	2						
17000202	15	3						
17000203	1	5						
17000204	15	6						
17000205	1	7						
17000206	15	8						
17000207	1	10						
17000208	16	12						
17000301	0.0	12						
17000400	-1							
17000401	529.66	482.60	467.37	466.14	466.03	465.92	464.79	
+	464.42	463.38	452.99	462.63	413.79	372.94		
17000402	550.28	513.49	487.92	496.56	496.44	496.33	495.05	
+	434.64	493.46	493.04	492.64	440.06	395.85		
17000403	552.01	515.18	499.50	498.12	498.01	497.89	496.61	
+	406.20	495.00	494.53	494.19	441.41	197.03		
17000404	552.17	525.02	509.56	508.14	508.02	507.90	506.58	
+	506.14	504.90	504.46	504.05	450.04	404.59		
17000405	552.39	531.08	515.97	514.54	514.42	514.30	512.92	
+	512.50	511.21	510.77	510.36	455.56	409.42		
17000501	700010000	0	1	1		7.9629200	1	
17000502	700020000	0	1	1		7.8275000	2	
17000503	700030000	0	1	1		7.9108300	3	
17000504	700040000	0	1	1		6.6358330	4	
17000505	706010000	0	1	1		2.2877070	5	
17000601	806010000	0	4400	1		7.9629200	1	
17000602	806010000	0	4400	1		7.8275000	2	
17000603	806010000	0	4400	1		7.9108300	3	
17000604	806010000	0	4400	1		6.6358330	4	
17000605	806010000	0	4400	1		2.2877070	5	
17000701	0	0.0	0.0	0.0				
17000801	0	0.0	0.3364087	0.0		5		
17000901	0	0.0	0.0	0.0		5		

***** RISES TO DOWNCOMER *****

17003000	5	6	2	1	0.172418			
17003100	0	1						
17003101	2	0.356597						
17003102	1	0.359097						
17003103	2	0.371030						
17003201	14	2						
17003202	15	3						
17003203	1	5						
17003301	0.0	5						
17003400	-1							
17003401	530.00	490.04	485.21	491.77	492.72	494.19		
17003402	551.24	539.96	544.09	548.48	543.94	549.54		
17003403	552.68	546.37	551.84	552.59	552.65	552.71		
17003404	552.62	550.32	552.31	552.57	552.59	552.61		
17003405	552.55	552.54	552.57	552.59	552.59	552.59		
17003501	700010000	0	1	1		0.4423843	1	
17003502	700020000	0	1	1		0.4348611	2	
17003503	700030000	0	1	1		0.4394907	3	
17003504	700040000	0	1	1		0.3686575	4	
17003505	706010000	0	1	1		0.1270944	5	
17003601	703040000	0	1	1		0.4423843	1	
17003602	703030000	0	1	1		0.4348611	2	
17003603	703020000	0	1	1		0.4394907	3	
17003604	703010000	0	1	1		0.3686575	4	

```

17003605 702010000 0 1 1 0.1270948 5
17003701 0 0.0 0.0 0.0 5
17003801 0 0.0 0.3364087 0.0 3
17003901 0 0.0 0.27842689 0.0 5

```

```

*****
*
* HEAT STRUCTURE MATERIAL PROPERTIES *
*
*****

```

```

*****
* 316L STAINLESS STEEL *
*****

```

```

20100100 TBL/FCTN 1 1
* TEMP. COND. TEMP. COND.
20100101 32.0 0.00215 100.0 0.00215
20100102 400.0 0.00306 1500.0 0.00397
20100103 4000.0 0.00397
* TEMP. CP. TEMP. CP.
20100151 32.0 61.30 400.0 61.30
20100152 600.0 64.60 800.0 67.10
20100153 1000.0 69.35 4000.0 69.35

```

```

*****
* AVERAGE TWO-PHASE *
*****

```

```

20100200 TBL/FCTN 1 1
* TEMP. COND. TEMP. COND.
20100201 32.0 0.000006 212.0 0.000006
20100202 572.0 0.000008 4000.0 0.000008
* TEMP. CP. TEMP. CP.
20100251 32.0 1.0 212.0 1.0
20100252 572.0 64.0 4000.0 64.0

```

```

*****
* BORON NITRIDE *
*****

```

```

20100300 TBL/FCTN 1 1
* TEMP. COND. TEMP. COND.
20100301 32.0 0.00255 200.0 0.00241
20100302 500.0 0.00216 1000.0 0.00174
20100303 1500.0 0.00133 2000.0 0.00079
20100304 2500.0 0.000491 3000.0 0.00029
20100305 3500.0 0.000074 4000.0 0.00004
* TEMP. CP. TEMP. CP.
20100351 32.0 37.50 400.0 37.5
20100352 800.0 48.3 1200.0 54.6
20100353 1500.0 58.3 2000.0 60.0
20100354 2400.0 61.40 3400.0 62.5
20100355 4000.0 62.5

```

```

*****
* INSTANTAN *
*****

```

```

20100400 TBL/FCTN 1 1

```

	TEMP.	COND.	TEMP.	COND.
20100401	0.0	0.00389	3000.0	0.00389
20100402	4000.0	0.00389		
	TEMP.	CP.	TEMP.	CP.
20100451	32.0	56.00	212.0	56.0
20100452	572.0	61.0	932.0	67.0
20100453	1472.0	73.0	2192.0	78.0
20100454	2352.0	84.0	3000.0	90.0
20100455	4000.0	90.0		

 ***** INCONEL 600 *****

	TEMP.	COND.	TEMP.	COND.
20100500 TBL/FCTN	1		1	
20100501	32.0	0.00236	100.0	0.00236
20100502	300.0	0.00267	500.0	0.00294
20100503	700.0	0.00322	900.0	0.00350
20100504	1100.0	0.00378	4000.0	0.00378
	TEMP.	CP.	TEMP.	CP.
20100551	32.0	52.225	4000.0	52.225

 ***** GRAFOIL *****

	TEMP.	COND.	TEMP.	COND.
20100600 TBL/FCTN	1		1	
20100601	32.0	0.000799	250.0	0.000799
20100602	500.0	0.000683	750.0	0.000579
20100603	1000.0	0.000509	1250.0	0.000434
20100604	1500.0	0.000468	2000.0	0.000463
20100605	3000.0	0.000486	4000.0	0.000486
	TEMP.	CP.	TEMP.	CP.
20100651	32.0	11.9	87.4	11.9
20100652	170.4	14.7	260.4	17.15
20100653	350.4	19.6	440.4	21.35
20100654	530.4	22.4	620.4	23.8
20100655	710.4	25.2	800.4	26.32
20100656	4000.0	26.32		

 ***** COPPER CA 102 *****

	TEMP.	COND.	TEMP.	COND.
20100700 TBL/FCTN	1		1	
20100701	32.0	0.0622	212.0	0.0606
20100702	572.0	0.0589	932.0	0.0575
20100703	4000.0	0.0575		
	TEMP.	CP.	TEMP.	CP.
20100751	32.0	51.336	4000.0	51.336

 ***** CAL-TEMP INSULATION *****
 * --- (INCREASED BY FACTOR 25.0 *
 * FOR VESSEL HEAT LOSS) --- *

	TEMP.	COND.	TEMP.	COND.
20100800 TBL/FCTN	1		1	
20100801				

20100801	0.0	3.241E-4	100.0	3.241E-4
20100802	200.0	3.442E-4	300.0	3.850E-4
20100803	400.0	4.054E-4	500.0	4.453E-4
20100804	600.0	4.861E-4	700.0	5.329E-4
20100805	800.0	5.872E-4		
*	TEMP.	CP.	TEMP.	CP.
20100851	0.0	2.898	1000.0	2.898

```

*****
***** ALUMINA *****
* --- ( ALUMINUM OXIDE ) --- *
*****

```

20100900	TBL/FCTN	1	1	
*	TEMP.	COND.	TEMP.	COND.
20100901	0.0	3.4722E-4	3300.0	3.4722E-4
*	TEMP.	CP.	TEMP.	CP.
20100951	0.0	55.2	3300.0	55.20

```

*****
***** INCONEL 718 *****
*****

```

20101000	TBL/FCTN	1	1	
*	TEMP.	COND.	TEMP.	COND.
20101001	0.0	0.0021667	200.0	0.0024778
20101002	400.0	0.0023333	600.0	0.0025556
20101003	800.0	0.0028056	1000.0	0.0030556
20101004	1200.0	0.0033333	1400.0	0.0035556
20101005	1600.0	0.0038333		
*	TEMP.	CP.	TEMP.	CP.
20101051	0.0	48.5797	200.0	53.7597
20101052	400.0	56.458	600.0	61.5912
20101053	800.0	65.184	1000.0	69.29
20101054	1200.0	74.4227	1400.0	76.989
20101055	1600.0	81.121		

```

*****
***** HONEYCOMB *****
* -- ( HEXAGONAL MATRIX CORE ) -- *
*****

```

20101100	TBL/FCTN	1	1	
*	TEMP.	COND.	TEMP.	COND.
20101101	0.0	2.6111E-5	700.0	2.6111E-5
*	TEMP.	CP.	TEMP.	CP.
20101151	0.0	2.28969	200.0	2.53081
20101152	400.0	2.6512	600.0	2.89224
20101153	800.0	3.06095	1000.0	3.2537
20101154	1200.0	3.49379	1400.0	3.6153
20101155	1600.0	3.8563		

```

*****
***** HONEYCOMB *****
* -- ( SQUARE MATRIX CORE ) -- *
*****

```

20101200	TBL/FCTN	1	1	
*	TEMP.	COND.	TEMP.	COND.
20101201	0.0	2.2778E-5	700.0	2.2778E-5
*	TEMP.	CP.	TEMP.	CP.
20101201	0.0	2.15978	200.0	2.35713

20101252	400.0	2.5008	600.0	2.71815
20101250	800.0	2.88729	1000.0	3.0691
20101254	1200.0	3.29651	1400.0	3.41018
20101255	1600.0	3.6375		

 ***** CONTACT RESISTANCE *****
 * -- (HEATER TO PIPING) -- *

20101300	TBL/FCTN	1	1		
*	TEMP.	COND.	TEMP.	COND.	
20101301	0.0	3.575E-6	80.0	4.211E-6	
20101302	170.0	4.819E-6	260.0	5.40E-6	
20101303	350.0	5.95E-6	440.0	6.431E-6	
20101304	530.0	6.997E-6	620.0	7.478E-6	
20101305	710.0	7.95E-6	800.0	8.394E-6	
20101306	890.0	8.842E-6	930.0	9.275E-6	
*	TEMP.	CP.	TEMP.	CP.	
20101351	0.0	0.0	3310.	0.0	

 ***** S/G FILLER PIECE *****
 * -- (FROM TEST GRB-14 oz) -- *

20101400	TBL/FCTN	1	1		
*	TEMP.	COND.	TEMP.	COND.	
20101401	80.0	3.028E-4	260.0	3.361E-4	
20101402	440.0	3.695E-4	620.0	4.028E-4	
20101403	800.0	4.361E-4			
*	TEMP.	CP.	TEMP.	CP.	
20101451	0.0	13.0	1000.0	13.0	

 ***** WATER *****
 * -- (SATURATED) -- *

20101500	TBL/FCTN	1	1		
*	TEMP.	COND.	TEMP.	COND.	
20101501	32.0	88.611E-6	104.0	100.833E-6	
20101502	176.0	107.222E-6	248.0	110.000E-6	
20101503	356.0	108.037E-6	464.0	101.994E-6	
20101504	500.0	98.055E-6	572.0	86.666E-6	
20101505	700.0	86.666E-6			
*	TEMP.	CP.	TEMP.	CP.	
20101551	32.0	63.033	104.0	61.996	
20101552	176.0	60.95	248.0	59.495	
20101553	356.0	58.553	464.0	57.445	
20101554	500.0	57.989	572.0	60.999	
20101555	700.0	62.576			

 ***** CAL-TEMP INSULATION *****
 * -- (INCREASED BY FACTOR 7.0 FOR PIPING HEAT LOSS) -- *

20101600	TBL/FCTN	1	1		
*	TEMP.	COND.	TEMP.	COND.	
20101601	0.0	6.4810E-5	170.0	6.4810E-5	

20101602	200.0	6.8330E-5	300.0	7.7000E-5
20101603	400.0	8.1080E-5	500.0	8.9050E-5
20101604	600.0	9.7220E-5	700.0	10.6580E-5
20101605	800.0	11.7440E-5		
*	TEMP.	CP.	TEMP.	CP.
20101651	0.0	2.898	1000.0	2.898

 ***** CAL-TEMP INSULATION *****
 * --- (INCREASED BY FACTOR 2.6125 *
 * FOR ILSG HEAT LOSS) --- *

20101700	TBL/FCTN	1	1	
*	TEMP.	COND.	TEMP.	COND.
20101701	0.0	2.4189E-5	100.0	2.4189E-5
20101702	200.0	2.5697E-5	300.0	2.8740E-5
20101703	400.0	3.0255E-5	500.0	3.3233E-5
20101704	600.0	3.6596E-5	700.0	3.9784E-5
20101705	800.0	4.3987E-5		
*	TEMP.	CP.	TEMP.	CP.
20101751	0.0	2.898	1000.0	2.898

 ***** GENERAL REFERENCE TABLES *****

* -- POWER TABLES FOR PIPING HEATER OF IL/BL HOT LEG --
 * (TABLE USED FOR 110)

* TYPE	TRIP	T-COEFF.	P-COEFF.
20211000 POWER	599	1.0	8.00E-3
* TIME	POWER (MW)		
20211001 0.0	1.0000		
20211002 10000.0	1.0000		

* -- POWER TABLES FOR PIPING HEATER OF BL PUMP SUCTION --
 * (TABLE USED FOR 111)

* TYPE	TRIP	T-COEFF.	P-COEFF.
20211100 POWER	599	1.0	4.20E-3
* TIME	POWER (MW)		
20211101 0.0	1.0000		
20211102 10000.0	1.0000		

* -- POWER TABLES FOR PIPING HEATER OF IL/BL COLD LEG --
 * (TABLE USED FOR 112)

* TYPE	TRIP	T-COEFF.	P-COEFF.
20211200 POWER	599	1.0	3.30E-3

```

*
*      TIME      POWER (MW)
*
20211201 0.0      1.0000
20211202 10000.0  1.0000
*
* -- POWER TABLES FOR PIPING HEATER OF IL PUMP SUCTION --
*      ( TABLE USED FOR 113 )
*
*      TYPE      TRIP      T-COEFF.  P-COEFF.
*
20211300 POWER      599      1.0      8.50E-3
*
*      TIME      POWER (MW)
*
20211301 0.0      1.0000
20211302 10000.0  1.0000
*
* -- POWER TABLES FOR PIPING HEATER OF VESSEL & DMCB --
*      ( TABLE USED FOR 116 )
*
*      TYPE      TRIP      T-COEFF.  P-COEFF.
*
20211600 POWER      599      1.0      20.0E-3
*
*      TIME      POWER (MW)
*
20211601 0.0      1.0000
20211602 10000.0  1.0000
*
* -- POWER TABLES FOR CORE AVERAGE RODS --
*      ( TABLE USED FOR 900 )
*
*      TYPE      TRIP      T-COEFF.  P-COEFF.
*
20290000 POWER      501      1.0      1.451
*
*      TIME      POWER (MW)
*
20290001 0.00      1.000
20290002 1.60      1.000
20290003 2.80      0.718
20290004 4.00      0.617
20290005 5.20      0.518
20290006 6.40      0.338
20290007 7.60      0.336
20290008 10.0     0.336
20290009 11.2     0.174
20290010 12.4     0.163
20290011 14.8     0.163
20290012 16.0     0.129
20290013 17.2     0.112
20290014 19.6     0.112
20290015 20.8     0.100
20290016 22.0     0.072
20290017 100.0    0.072
20290018 101.2    0.025
20290019 102.4    0.021
20290020 500.0    0.021
*
*
* -- HEAT TRANSFER COEFFICIENT FOR VESSEL INSULATION --

```

```

*           ( TABLE USED FOR 4100 )
*
20210000 HTC-TEMP 0           1.0           0.0           0.1
*
*           TEMP           HT. COEFF. (BTU/S-FT2-F)
*
20210001 100.0           0.00136
20210002 150.0           0.00206
20210003 200.0           0.00247
20210004 300.0           0.00302
20210005 500.0           0.00374
20210006 750.0           0.00438
*
* -- HEAT TRANSFER COEFFICIENT FOR RV INSULATION --
*           ( TABLE USED FOR 4200 )
*
20220000 HTC-TEMP 0           1.0           0.0           3.0
*
*           TEMP           HT. COEFF. (BTU/S-FT2-F)
*
20220001 100.0           0.00136
20220002 150.0           0.00206
20220003 200.0           0.00247
20220004 300.0           0.00302
20220005 500.0           0.00374
20220006 750.0           0.00438
*
* -- HEAT TRANSFER COEFFICIENT FOR BL INSULATION --
*           ( TABLE USED FOR 4300 )
*
20230000 HTC-TEMP 0           1.0           0.0           0.2
*
*           TEMP           HT. COEFF. (BTU/S-FT2-F)
*
20230001 100.0           0.00136
20230002 150.0           0.00206
20230003 200.0           0.00247
20230004 300.0           0.00302
20230005 500.0           0.00374
20230006 750.0           0.00438
*
* -- HEAT TRANSFER COEFFICIENT FOR S/G INSULATION --
*           ( TABLE USED FOR 4400 )
*
20240000 HTC-TEMP 0           1.0           0.0           0.025
*
*           TEMP           HT. COEFF. (BTU/S-FT2-F)
*
20240001 100.0           0.00136
20240002 150.0           0.00206
20240003 200.0           0.00247
20240004 300.0           0.00302
20240005 500.0           0.00374
20240006 750.0           0.00438
*
* -- HEAT TRANSFER COEFFICIENT FOR IL INSULATION --
*           ( TABLE USED FOR 4500 )
*
20250000 HTC-TEMP
*
*           TEMP           HT. COEFF. (BTU/S-FT2-F)
*

```

```

20250001 100.0 0.00136
20250002 150.0 0.00206
20250003 200.0 0.00247
20250004 300.0 0.00302
20250005 500.0 0.00374
20250006 750.0 0.00438

```

```

*
*
* -- INTACT LOOP PUMP SPEED TABLE (NORMALIZED SPEED) --
* ( TABLE USED FOR 725 )

```

```

* TABLE TRIP
*
20225000 REAC-T 501

```

```

* TIME NORM PUMP SPEED
*
20225001 -1.0 1.0000
20225002 0.00 1.0000
*20225003 28.00 0.0
*20225004 1000.00 0.0
20225003 2.80 1.0000
20225004 4.00 0.9950
20225005 5.20 0.9658
20225006 6.40 0.9337
20225007 7.60 0.9022
20225008 8.80 0.8692
20225009 10.00 0.8391
20225010 11.20 0.8094
20225011 12.40 0.7764
20225012 13.60 0.7434
20225013 14.80 0.7144
20225014 16.00 0.6901
20225015 17.20 0.6617
20225016 18.40 0.6272
20225017 19.60 0.5910
20225018 20.80 0.5572
20225019 22.00 0.5267
20225020 23.20 0.4955
20225021 24.40 0.4644
20225022 25.60 0.4337
20225023 26.80 0.4032
20225024 28.00 0.3710
20225025 100.0 0.366
20225026 1000.0 0.366

```

```

*
* -- BROKEN LOOP PUMP SPEED TABLE (NORMALIZED SPEED) --
* ( TABLE USED FOR 735 )

```

```

* TABLE TRIP
*
20235000 REAC-T 501

```

```

* TIME NORM PUMP SPEED
*
20235001 -1.0 1.0000
20235002 0.00 1.0000
20235003 2.80 1.0000
20235004 4.00 0.9776
20235005 5.20 0.9536
20235006 6.40 0.9235
20235007 7.60 0.8939

```

20235008	8.80	0.8671
20235009	10.00	0.8321
20235010	11.20	0.8131
20235011	12.40	0.7886
20235012	13.60	0.7529
20235013	14.80	0.7308
20235014	16.00	0.7097
20235015	17.20	0.6669
20235016	18.40	0.6374
20235017	19.60	0.6147
20235018	20.80	0.5955
20235019	22.00	0.5693
20235020	23.20	0.5567
20235021	24.40	0.5473
20235022	25.60	0.5379
20235023	26.80	0.5278
20235024	28.00	0.5205
20235025	29.20	0.5203
20235026	30.40	0.5297
20235027	31.60	0.5261
20235028	239.2	0.5261
20235029	240.4	0.3423
20235030	241.6	0.1986
20235031	242.8	0.1277
20235032	244.0	0.0680
20235033	245.2	0.0164
20235034	246.4	0.0000
20235035	1000.0	0.0000

```

*
*****
*
****                                CONTROL VARIABLES                                ****
*
*****
*

```

```

-----
****                                IMPORTANT PARAMETERS FOR COMPARISON                                ****
-----

```

```

* == TEMPERATURES = CTRL 001 -- 029

```

*205XXX00	NAME	TYPE	COEFF	INIT-VAL	FLG
20500100	TFVLP552	SUM	1.0	0.0	1
20500101	0.0	1.0	TEMPF	130010000	
20500200	TFI1	SUM	1.0	0.0	1
20500201	0.0	1.0	TEMPF	201020000	
20500300	TFI5	SUM	1.0	0.0	1
20500301	0.0	1.0	TEMPF	203010000	
20500400	TFIS1117	SUM	1.0	0.0	1
20500401	0.0	1.0	TEMPF	601010000	
20500500	TFI9	SUM	1.0	0.0	1
20500501	0.0	1.0	TEMPF	240020000	
20500600	TFI15	SUM	1.0	0.0	1

20500601	0.0	1.0	TEMPF	240160000	
*					
20500700	TF121	SUM	1.0	0.0	1
20500701	0.0	1.0	TEMPF	261020000	
*					
20500800	TF122	SUM	1.0	0.0	1
20500801	0.0	1.0	TEMPF	262010000	
*					
20500900	TFB50	SUM	1.0	0.0	1
20500901	0.0	1.0	TEMPF	301020000	
*					
20501000	TFB57	SUM	1.0	0.0	1
20501001	0.0	1.0	TEMPF	301040000	
*					
20501100	TFB51117	SUM	1.0	0.0	1
20501101	0.0	1.0	TEMPF	701010000	
*					
20501200	TFB62	SUM	1.0	0.0	1
20501201	0.0	1.0	TEMPF	340020000	
*					
20501300	TFB73	SUM	1.0	0.0	1
20501301	0.0	1.0	TEMPF	340070000	
*					
20501400	TFB74	SUM	1.0	0.0	1
20501401	0.0	1.0	TEMPF	361010000	
*					
20501500	TFB79	SUM	1.0	0.0	1
20501501	0.0	1.0	TEMPF	363010000	
*					
20501600	TFVDC84	SUM	1.0	0.0	1
20501601	0.0	1.0	TEMPF	110010000	
*					
20501700	TFVDC270	SUM	1.0	0.0	1
20501701	0.0	1.0	TEMPF	110050000	
*					
20501800	TFVDC436	SUM	1.0	0.0	1
20501801	0.0	1.0	TEMPF	110080000	
*					
20501900	TFVA4361	SUM	1.0	0.0	1
20501901	0.0	1.0	TEMPF	150060000	
*					
20502000	TFVB3162	SUM	1.0	0.0	1
20502001	0.0	1.0	TEMPF	150030000	
*					
20502100	TFVB3045	SUM	1.0	0.0	1
20502101	0.0	1.0	TEMPF	150010000	
*					
20502300	TFVU4282	SUM	1.0	0.0	1
20502301	0.0	1.0	TEMPF	193010000	
*					
20502400	TFVU4402	SUM	1.0	0.0	1
20502401	0.0	1.0	TEMPF	194010000	
*					
20502500	TFVBPS	SUM	1.0	0.0	1
20502501	0.0	1.0	TEMPF	181020000	
*					
20502600	TFPRZ132	SUM	1.0	0.0	1
20502601	0.0	1.0	TEMPF	997010000	
*					
*					
*	==	FLOW (L/SEC) =	CTRL	030	-- 049
*					

20503000	0G-DC423	MULT	2.4191	0.0	1
20503001	VOIDGJ	110070000	VELGJ	110070000	
20503100	0F-DC423	MULT	2.4191	0.0	1
20503101	VOIDFJ	110070000	VELFJ	110070000	
20503200	0FDC423	SUM	1.0	0.0	1
20503201	0.0	1.0	CNTRLVAR	30	
20503202		1.0	CNTRLVAR	31	
20503400	0G-UP1	MULT	4.0809	0.0	1
20503401	VOIDGJ	163030000	VELGJ	163030000	
20503500	0F-UP1	MULT	4.0809	0.0	1
20503501	VOIDFJ	163030000	VELFJ	163030000	
20503600	0FUP1	SUM	1.0	0.0	1
20503601	0.0	1.0	CNTRLVAR	34	
20503602		1.0	CNTRLVAR	35	
20503800	0G-GT321	MULT	7.8226-2	0.0	1
20503801	VOIDGJ	194010000	VELGJ	194010000	
20503900	0F-GT321	MULT	7.8226-2	0.0	1
20503901	VOIDFJ	194010000	VELFJ	194010000	
20504000	0FGT321	SUM	1.0	0.0	1
20504001	0.0	1.0	CNTRLVAR	38	
20504002		1.0	CNTRLVAR	39	
20504200	0G-11	MULT	2.2881	0.0	1
20504201	VOIDGJ	201020000	VELGJ	201020000	
20504300	0F-11	MULT	2.2881	0.0	1
20504301	VOIDFJ	201020000	VELFJ	201020000	
20504400	0F11	SUM	1.0	0.0	1
20504401	0.0	1.0	CNTRLVAR	42	
20504402		1.0	CNTRLVAR	43	
20504600	0G-PRZ	MULT	6.9368-2	0.0	1
20504601	VOIDGJ	997030000	VELGJ	997030000	
20504700	0F-PRZ	MULT	6.9328-2	0.0	1
20504701	VOIDFJ	997030000	VELFJ	997030000	
20504800	0FPRZ	SUM	1.0	0.0	1
20504801	0.0	1.0	CNTRLVAR	46	
20504802		1.0	CNTRLVAR	47	
20505000	0G-16	MULT	2.2881	0.0	1
20505001	VOIDGJ	205000000	VELGJ	205000000	
20505100	0F-16	MULT	2.2881	0.0	1
20505101	VOIDFJ	205000000	VELFJ	205000000	
20505200	0F16	SUM	1.0	0.0	1
20505201	0.0	1.0	CNTRLVAR	50	
20505202		1.0	CNTRLVAR	51	
20505400	0G-115	MULT	3.4819	0.0	1

20505401	VD10GJ	240050000	VELGJ	240050000
* 20505500	WF-115	MULT	3.4889 0.0	1
20505501	VD10FJ	240050000	VELFJ	240050000
* 20505600	WF115	SUM	1.0 0.0	1
20505601	0.0	1.0	CNTRLVAR 54	
20505602		1.0	CNTRLVAR 55	
* 20505800	WG-121	MULT	0.79173 0.0	1
20505801	VD10GJ	250020000	VELGJ	250020000
* 20505900	WF-121	MULT	0.79173 0.0	1
20505901	VD10FJ	250020000	VELFJ	250020000
* 20506000	W121	SUM	1.0 0.0	1
20506001	0.0	1.0	CNTRLVAR 58	
20506002		1.0	CNTRLVAR 59	
* 20506200	WG-122	MULT	3.4889 0.0	1
20506201	VD10GJ	262010000	VELGJ	262010000
* 20506300	WF-122	MULT	3.4889 0.0	1
20506301	VD10FJ	262010000	VELFJ	262010000
* 20506400	W122	SUM	1.0 0.0	1
20506401	0.0	1.0	CNTRLVAR 62	
20506402		1.0	CNTRLVAR 63	
* 20506600	WG-850	MULT	0.907133 0.0	1
20506601	VD10GJ	301020000	VELGJ	301020000
* 20506700	WF-850	MULT	0.907133 0.0	1
20506701	VD10FJ	301020000	VELFJ	301020000
* 20506800	W850	SUM	1.0 0.0	1
20506801	0.0	1.0	CNTRLVAR 66	
20506802		1.0	CNTRLVAR 67	
* 20507000	WG-873	MULT	0.907133 0.0	1
20507001	VD10GJ	350010000	VELGJ	350010000
* 20507100	WF-873	MULT	0.907133 0.0	1
20507101	VD10FJ	350010000	VELFJ	350010000
* 20507200	W873	SUM	1.0 0.0	1
20507201	0.0	1.0	CNTRLVAR 70	
20507202		1.0	CNTRLVAR 71	
* 20507400	WG-874	MULT	0.829577 0.0	1
20507401	VD10GJ	350020000	VELGJ	350020000
* 20507500	WF-874	MULT	0.829577 0.0	1
20507501	VD10FJ	350020000	VELFJ	350020000
* 20507600	W874	SUM	1.0 0.0	1
20507601	0.0	1.0	CNTRLVAR 74	
20507602		1.0	CNTRLVAR 75	
* 20507800	WG-879	MULT	0.907133 0.0	1
20507801	VD10GJ	363010000	VELGJ	363010000
*				

20507900	9F-279	MULT	0.907133	0.0	1
20507901	VOIDFJ	363010000	VELFJ	363010000	
*					
20508000	9B79	SUM	1.0	0.0	1
20508001	0.0	1.0	CNTRLVAR	78	
20508002		1.0	CNTRLVAR	79	
*					
*20508200	9G-1A3	MULT	0.46405	0.0	1 * W
*20508201	VOIDGJ	420010000	VELGJ	420010000	* W
*					
*20508300	9F-1A3	MULT	0.46405	0.0	1 * W
*20508301	VOIDFJ	420010000	VELFJ	420010000	* W
*					
*20508400	9CIA3	SUM	1.0	0.0	1 * W
*20508401	0.0	1.0	CNTRLVAR	82 * W	
*20508402		1.0	CNTRLVAR	83 * W	
*					
20508600	9G-LP1S	MULT	0.46405	0.0	1
20508601	VOIDGJ	411000000	VELGJ	411000000	
*					
20508700	9F-LP1S	MULT	0.46405	0.0	1
20508701	VOIDFJ	411000000	VELFJ	411000000	
*					
20508800	9CLP1S	SUM	1.0	0.0	1
20508801	0.0	1.0	CNTRLVAR	86	
20508802		1.0	CNTRLVAR	87	
*					
20509000	9MBREAK	SUM	1.0	0.0	1
20509001	0.0	1.0	MFLOWJ	375000000	
*					
20509100	9MFLSGI	SUM	1.0	0.0	1
20509101	0.0	1.0	MFLOWJ	635000000	
*					
20509200	9MFLSGB	SUM	1.0	0.0	1
20509201	0.0	1.0	MFLOWJ	735000000	
*					
*	**	PRESSURES	=	CTRL	100 -- 149
*					
*205XXX00	NAME	TYPE	COEFF	INIT-VAL	FLG
*					
20510000	PTRIP	TRIPUNIT	1.0	0.0	1
20510001		501			
*					
20510100	PDC435	SUM	1.0E-6	0.0	1
20510101	0.0	1.0	P	110080000	
*					
20510200	LOWLTD	SUM	9.75	0.0	1
20510201	0.0	1.0	CNTRLVAR	100	
*					
20510300	PDC435L	STDFUNCTN	1.0	9.75	0
20510301		MIN	CNTRLVAR	101	
20510302			CNTRLVAR	102	
*					
20510400	9MPL3	SUM	1.0E-6	0.0	1
20510401	0.0	1.0	P	143010000	
*					
20510500	9MPL573	SUM	1.0E-6	0.0	1
20510501	0.0	1.0	P	130010000	
*					
20510600	LOWLTD	SUM	9.64	0.0	1

20510601	0.0	1.0	CNTRLVAR	100	
*					
20510700	PLP578L	STDFUNCTN	1.0	9.64	0
20510701		MIN	CNTRLVAR	105	
20510702			CNTRLVAR	106	
*					
20510800	PVU4421	SUM	1.0E-6	0.0	1
20510801	0.0	1.0	P	194010000	
*					
20510900	PI1	SUM	1.0E-6	0.0	1
20510901	0.0	1.0	P	201020000	
*					
20511000	PPRZ	SUM	1.0E-6	0.0	1
20511001	0.0	1.0	P	999010000	
*					
20511100	PIS1117	SUM	1.0E-6	0.0	1
20511101	0.0	1.0	P	601010000	
*					
20511200	PI14	SUM	1.0E-6	0.0	1
20511201	0.0	1.0	P	240050000	
*					
20511300	LOWLTD	SUM	9.62	0.0	1
20511301	0.0	1.0	CNTRLVAR	100	
*					
20511400	PI14L	STDFUNCTN	1.0	9.62	0
20511401		MIN	CNTRLVAR	112	
20511402			CNTRLVAR	113	
*					
20511500	PI22	SUM	1.0E-6	0.0	1
20511501	0.0	1.0	P	27010000	
*					
20511600	LOWLTD	SUM	3.52	0.0	1
20511601	0.0	1.0	CNTRLVAR	100	
*					
20511700	PI22L	STDFUNCTN	1.0	3.52	0
20511701		MIN	CNTRLVAR	115	
20511702			CNTRLVAR	116	
*					
20511800	PS50	SUM	1.0E-6	0.0	1
20511801	0.0	1.0	P	301020000	
*					
20511900	PS1117	SUM	1.0E-6	0.0	1
20511901	0.0	1.0	P	701010000	
*					
20512000	PS74	SUM	1.0E-6	0.0	1
20512001	0.0	1.0	P	361010000	
*					
20512100	LOWLTD	SUM	9.55	0.0	1
20512101	0.0	1.0	CNTRLVAR	100	
*					
20512200	PS74L	STDFUNCTN	1.0	9.55	0
20512201		MIN	CNTRLVAR	120	
20512202			CNTRLVAR	121	
*					
20512300	PS79	SUM	1.0E-6	0.0	1
20512301	0.0	1.0	P	38020000	
*					
20512400	LOWLTD	SUM	9.62	0.0	1
20512401	0.0	1.0	CNTRLVAR	100	
*					
20512500	PS79L	STDFUNCTN	1.0	9.62	0
20512501		MIN	CNTRLVAR	122	

```

20512502
*
20512600          PACU4      SUM      1.0E-6      0.0      1
20512601          0.0      1.0      P      420010000
*
* == DIFFERENTIAL PRESSURE ( KPA ) == CTRL 150 == 149
*
*
20515000 LV029578 SUM      1.0E-3      0.0      1
20515001 0.0 1.0 P 101010000 +1.5351 RHD 101010000
20515002 -1.0 P 120010000 -0.3300 RHD 120010000
*
20515100 LV131578 SUM      1.0E-3      0.0      1
20515101 0.0 1.0 P 163010000 0.8384 RHD 163010000
20515102 -1.0 P 120010000 -0.3300 RHD 120010000
*
20515200 LV421378 SUM      1.0E-3      0.0      1
20515201 0.0 1.0 P 194010000 -4.0506 RHD 194010000
20515202 -1.0 P 120010000 -0.3300 RHD 120010000
*
20515300 LV421134 SUM      1.0E-3      0.0      1
20515301 0.0 1.0 P 194010000 -4.0506 RHD 194010000
20515302 -1.0 P 163010000 -0.8384 RHD 163010000
*
20515400 DVC29421 SUM      1.0E-3      0.0      1
20515401 0.0 1.0 P 101010000 -1.5351 RHD 101010000
20515402 -1.0 P 194010000 -4.0506 RHD 194010000
*
20515500 LIS1117 SUM      1.0E-3      0.0      1
20515501 0.0 1.0 P 603040000 6.9772 RHD 603040000
20515502 -1.0 P 602010000 2.7928 RHD 602010000
*
20515600 DV13A11 SUM      1.0E-3      0.0      1
20515601 0.0 1.0 P 163010000 0.83839 RHD 163010000
20515602 -1.0 P 201020000 -0.15582 RHD 201020000
*
20515700 DP113C SUM      1.0E-3      0.0      1
20515701 0.0 1.0 P 201020000 0.15582 RHD 201020000
20515702 -1.0 P 202010000 -0.15582 RHD 202010000
*
20515800 DP13C5 SUM      1.0E-3      0.0      1
20515801 0.0 1.0 P 202010000 0.15582 RHD 202010000
20515802 -1.0 P 203010000 -0.03828 RHD 203010000
*
20515900 DP159 SUM      1.0E-3      0.0      1
20515901 0.0 1.0 P 203010000 0.03828 RHD 203010000
20515902 -1.0 P 240020000 2.06493 RHD 240020000
*
20516000 DP1914 SUM      1.0E-3      0.0      1
20516001 0.0 1.0 P 240020000 -2.06493 RHD 240020000
20516002 -1.0 P 240050000 -4.02035 RHD 240050000
*
20516100 DP11418 SUM      1.0E-3      0.0      1
20516101 0.0 1.0 P 240050000 4.02035 RHD 240050000
20516102 -1.0 P 240080000 1.92080 RHD 240080000
*
20516200 DP12113 SUM      1.0E-3      0.0      1
20516201 0.0 1.0 P 261010000 -0.45756 RHD 261010000
20516202 -1.0 P 240080000 1.92080 RHD 240080000

```

```

*
20516300 DP12122 SUM 1.0E-3 0.0 1
20516301 0.0 1.0 P 261010000 -0.43766 RHO 261010000
20516302 -1.0 P 262010000 0.43766 RHO 262010000
*
20516400 DP122V29 SUM 1.0E-3 0.0 1
20516401 0.0 1.0 P 262010000 -0.43766 RHO 262010000
20516402 -1.0 P 101010000 1.53517 RHO 101010000
*
20516500 LBS1117 SUM 1.0E-3 0.0 1
20516501 0.0 1.0 P 703040000 6.9927 RHO 703040000
20516502 -1.0 P 702010000 3.4748 RHO 702010000
*
20516600 DV13850 SUM 1.0E-3 0.0 1
20516601 0.0 1.0 P 163010000 0.23839 RHO 163010000
20516602 -1.0 P 301020000 -0.15582 RHO 301020000
*
20516700 DB5055 SUM 1.0E-3 0.0 1
20516701 0.0 1.0 P 301020000 0.15582 RHO 301020000
20516702 -1.0 P 301030000 -0.15582 RHO 301030000
*
20516800 DB5557 SUM 1.0E-3 0.0 1
20516801 0.0 1.0 P 301030000 0.15582 RHO 301030000
20516802 -1.0 P 301040000 0.33698 RHO 301040000
*
20516900 DB5762 SUM 1.0E-3 0.0 1
20516901 0.0 1.0 P 301040000 -0.33698 RHO 301040000
20516902 -1.0 P 340020000 -1.36552 RHO 340020000
*
20517000 DB6265 SUM 1.0E-3 0.0 1
20517001 0.0 1.0 P 340020000 1.36552 RHO 340020000
20517002 -0.5 P 340050000 -4.49859 RHO 340050000
20517003 -0.5 P 340060000 -3.64736 RHO 340060000
*
20517100 DB6573 SUM 1.0E-3 0.0 1
20517101 0.0 0.5 P 340050000 4.49859 RHO 340050000
20517102 0.5 P 340060000 3.64736 RHO 340060000
20517103 -1.0 P 340070000 -1.43195 RHO 340070000
*
20517200 DB7473 SUM 1.0E-3 0.0 1
20517201 0.0 1.0 P 340070000 -0.39230 RHO 340070000
20517202 -1.0 P 340070000 -1.43195 RHO 340070000
*
20517300 DB79V029 SUM 1.0E-3 0.0 1
20517301 0.0 1.0 P 363020000 0.22834 RHO 363020000
20517302 -1.0 P 101010000 1.53517 RHO 101010000
*
20517400 LPR2158 SUM 1.0E-3 0.0 1
20517401 0.0 1.0 P 997030000 -0.33414 RHO 997030000
20517402 -1.0 P 999010000 2.08813 RHO 999010000
* ADDED FOLLOWING BY JDU
20517500 LV421160 SUM 1.0E-3 0.0 1
20517501 0.0 1.0 P 194010000 -4.7506 RHO 194010000
20517502 -1.0 P 191010000 -0.32556 RHO 191010000
*
20517600 LV442501 SUM 1.0E-3 0.0 1
20517601 0.0 1.0 P 150010000 -2.2712 RHO 150010000
20517602 -1.0 P 140010000 1.01940 RHO 140010000
*
20517700 LV134135 SUM 1.0E-3 0.0 1
20517701 0.0 1.0 P 163010000 0.23839 RHO 163010000

```

20517722	-1.0	P	161010000	0.9450	RHO	161010000
20517800	LV105195	SUM	1.0E-3	0.0	1	
20517801	0.0 1.0	P	161010000	-0.9450	RHO	161010000
20517802	-1.0	P	150050000	2.581	RHO	150050000
20517900	LV195278	SUM	1.0E-3	0.0	1	
20517901	0.0 1.0	P	150050000	-2.581	RHO	150050000
20517902	-1.0	P	150040000	0.421	RHO	150040000
20518000	LV278367	SUM	1.0E-3	0.0	1	
20518001	0.0 1.0	P	150040000	-0.421	RHO	150040000
20518002	-1.0	P	150030000	-1.641	RHO	150030000
20518100	LV360442	SUM	1.0E-3	0.0	1	
20518101	0.0 1.0	P	150030000	1.641	RHO	150030000
20518102	-1.0	P	150010000	2.271	RHO	150010000
20518200	LV501578	SUM	1.0E-3	0.0	1	
20518201	0.0 1.0	P	140010000	-1.9206	RHO	140010000
20518202	-1.0	P	120010000	-0.3308	RHO	120010000
* ** WATER LEVELS (CM) * CTRL 200 -- 249						
20520100	WLDNCR	DIV	10204.082	0.0	1	
20520101	RHOF	120010000		CNTRLVAR	150	
20520200	WLDNCR-1	SUM	1.0	0.0	1	
20520201	-578.0	1.0		CNTRLVAR	201	
20520300	WLDNCR-2	SUM	1.0	0.0	1	
20520301	-578.0	10.30715		CNTRLVAR	150	
20520400	WLDNCR-3	SUM	30.48	0.0	1	
20520401	-19.086	0.873000		VOIDF	101010000	
20520402		1.000000		VOIDF	102010000	
20520403		2.260833		VOIDF	110010000	
20520404		1.000833		VOIDF	110020000	
20520405		2.000000		VOIDF	110030000	
20520406		2.000000		VOIDF	110040000	
20520407		2.000000		VOIDF	110050000	
20520408		2.000000		VOIDF	110060000	
20520409		2.000000		VOIDF	110070000	
20520410		1.465667		VOIDF	110080000	
20520411		1.207667		VOIDF	110090000	
20520412		0.962500		VOIDF	110100000	
20520413		0.721917		VOIDF	130010000	
20520414		0.466667		VOIDF	120010000	
20520600	WLCORE	DIV	10204.082	0.0	1	
20520601	RHOF	120010000		CNTRLVAR	151	
20520700	WLCORE-1	SUM	1.0	0.0	1	
20520701	1.0	1.0		CNTRLVAR	205	
20520800	WLCORE-2	SUM	1.0	0.0	1	
20520801	1.0	10.30715		CNTRLVAR	151	
20520900	WLCORE-3	SUM	30.48	0.0	1	
20520901	-14.086	1.708333		VOIDF	163010000	
20520902		2.260833		VOIDF	162010000	

20520903		1.000833	VOIDF	161010000	
20520904		2.000000	VOIDF	150060000	
20520905		2.000000	VOIDF	150050000	
20520906		2.000000	VOIDF	150040000	
20520907		2.000000	VOIDF	150030000	
20520908		2.000000	VOIDF	150020000	
20520909		2.000000	VOIDF	150010000	
20520910		1.635833	VOIDF	140010000	
20520911		0.721917	VOIDF	130010000	
20520912		0.466667	VOIDF	120010000	
*					
20521100	WLUPHD	DIV	10204.082	0.0	1
20521101	RHDF	163010000		CNTRLVAR	152
*					
20521200	WLUPHD-1	SUM	1.0	0.0	1
20521201	-13.0	1.0		CNTRLVAR	211
*					
20521300	WLUPHD-2	SUM	1.0	0.0	1
20521301	-13.0	10.30715		CNTRLVAR	152
*					
20521400	WLUPHD-3	SUM	30.48	0.0	1
20521401	-1.0	2.880830	VOIDF	194010000	
20521402		6.549167	VOIDF	183010000	
20521403		5.466667	VOIDF	184010000	
*					
20521500	WLUPHD-4	SUM	30.48	0.0	1
20521501	5.12	2.880830	VOIDF	194010000	
20521502		3.453333	VOIDF	193010000	
20521503		1.965833	VOIDF	192010000	
20521504		0.476667	VOIDF	191010000	
*					
20521600	WLVESL	DIV	10204.082	0.0	1
20521601	RHDF	120010000		CNTRLVAR	153
*					
20521700	WLVESL-1	SUM	1.0	0.0	1
20521701	-578.0	1.0		CNTRLVAR	216
*					
20521800	WLVESL-2	SUM	1.0	0.0	1
20521801	-578.0	10.30715		CNTRLVAR	153
*					
20521900	WLVESL-3	SUM	30.48	0.0	1
20521901	-19.086	0.466667	VOIDF	120010000	
20521902		0.721917	VOIDF	130010000	
20521903		1.635833	VOIDF	140010000	
20521904		2.000000	VOIDF	150010000	
20521905		2.000000	VOIDF	150020000	
20521906		2.000000	VOIDF	150030000	
20521907		2.000000	VOIDF	150040000	
20521908		2.000000	VOIDF	150050000	
20521909		2.000000	VOIDF	150060000	
20521910		1.000833	VOIDF	1610.000	
20521911		2.260833	VOIDF	162010000	
20521912		1.708333	VOIDF	163010000	
*					
20522100	WLUPHD	DIV	10204.082	0.0	1
20522101	RHDF	101010000		CNTRLVAR	154
*					
20522200	WLUPHD-1	SUM	1.0	0.0	1
20522201	+29.0	1.0		CNTRLVAR	221
*					
20522300	WLUPHD-2	SUM	1.0	0.0	1
20522301	+29.0	10.30715		CNTRLVAR	154

*					
20522400	WLUHDM-3	SUM	30.48	0.0	1
20522401	W.C	2.880830	VOIDF	194010000	
20522402		3.453333	VOIDF	193010000	
20522403		3.140583	VOIDF	181020000	
20522404		3.546917	VOIDF	181010000	
20522405		0.8750	VOIDF	101010000	
*					
20522600	WLIS50	DIV	10204.082	0.0	1
20522601	RHDF	603040000		CNTRLVAR	155
*					
20522700	WLIS50-1	SUM	1.0	0.0	1
20522701	+50.0	1.0		CNTRLVAR	226
*					
20522800	WLIS50-2	SUM	1.0	0.0	1
20522801	+50.0	10.30715		CNTRLVAR	155
*					
20522900	WLIS50-3	SUM	30.48	0.0	1
20522901	0.0	5.9487500	VOIDF	602010000	
20522902		7.4702500	VOIDF	603010000	
20522903		7.9108334	VOIDF	603020000	
20522904		7.9108334	VOIDF	603030000	
20522905		7.9525000	VOIDF	603040000	
*					
20523100	WLIPDN	DIV	10204.082	0.0	1
20523101	RHDF	240050000		CNTRLVAR	160
*					
20523200	WLIPDN-1	SUM	1.0	0.0	1
20523201	-263.0	1.0		CNTRLVAR	231
*					
20523300	WLIPDN-2	SUM	1.0	0.0	1
20523301	-263.0	10.30715		CNTRLVAR	160
*					
20523400	WLIPDN-3	SUM	30.48	0.0	1
20523401	-9.2200	3.665250	VOIDF	240020000	
20523402		2.784170	VOIDF	240030000	
20523403		3.875000	VOIDF	240040000	
20523404		3.875000	VOIDF	240050000	
*					
20523600	WLIPUP	DIV	10204.082	0.0	1
20523601	RHDF	240050000		CNTRLVAR	161
*					
20523700	WLIPUP-1	SUM	1.0	0.0	1
20523701	-263.0	1.0		CNTRLVAR	236
*					
20523800	WLIPUP-2	SUM	1.0	0.0	1
20523801	-263.0	10.30715		CNTRLVAR	161
*					
20523900	WLIPUP-3	SUM	30.48	0.0	1
20523901	-9.2200	3.812500	VOIDF	240060000	
20523902		2.567500	VOIDF	240070000	
*					
20524100	WLBS50	DIV	10204.082	0.0	1
20524101	RHDF	703040000		CNTRLVAR	165
*					
20524200	WLBS50-1	SUM	1.0	0.0	1
20524201	+50.0	1.0		CNTRLVAR	241
*					
20524300	WLBS50-2	SUM	1.0	0.0	1
20524301	+50.0	10.30715		CNTRLVAR	165
*					
20524400	WLBS50-3	SUM	30.48	0.0	1

20524401	0.0	6.8620870	VOIDF	702010000	
20524402		6.6358363	VOIDF	703010000	
20524403		7.9108333	VOIDF	703020000	
20524404		7.8275000	VOIDF	703030000	
20524405		7.9629167	VOIDF	703040000	
*					
20524600	WLBPDN	DIV	10204.082	0.0	1
20524601	RHUF	340050000		CNTRLVAR	170
*					
20524700	WLBPDN-1	SUM	1.0	0.0	1
20524701	-287.0	1.0		CNTRLVAR	246
*					
20524800	WLBPDN-2	SUM	1.0	0.0	1
20524801	-287.0	10.30715		CNTRLVAR	170
*					
20524900	WLBPDN-3	SUM	30.48	0.0	1
20524901	-8.82893	2.301833	VOIDF	340020000	
20524902		1.387917	VOIDF	340030000	
20524903		4.850000	VOIDF	340040000	
20524904		4.850000	VOIDF	340050000	
*					
20525100	WLBPUF	DIV	10204.082	0.0	1
20525101	R	340060000		CNTRLVAR	171
*					
20525200	WLBPUF-1	SUM	1.0	0.0	1
20525201	-287.0	1.0		CNTRLVAR	251
*					
20525300	WLBPUF-2	SUM	1.0	0.0	1
20525301	-287.0	10.30715		CNTRLVAR	171
*					
20525400	WLBPUF-3	SUM	30.48	0.0	1
20525401	-8.82893	6.383333	VOIDF	340060000	
20525402		2.296667	VOIDF	340070000	
*					
20526100	WLPFZ	DIV	10204.082	0.0	1
20526101	RHUF	997050000		CNTRLVAR	174
*					
20526200	WLPFZ-1	SUM	1.0	0.0	1
20526201	0.70833	1.0		CNTRLVAR	261
*					
20526300	WLPFZ-2	SUM	1.0	0.0	1
20526301	0.70833	10.30715		CNTRLVAR	174
*					
20526400	WLPFZ-3	SUM	30.48	0.0	1
20526401	0.70833	1.074583	VOIDF	997050000	
20526402		1.074583	VOIDF	997040000	
20526403		1.604167	VOIDF	997030000	
20526404		0.583333	VOIDF	997020000	
20526405		0.675000	VOIDF	997010000	
20526406		0.217500	VOIDF	999050000	
20526407		0.364306	VOIDF	999040000	
20526408		0.728611	VOIDF	999030000	
20526409		0.769748	VOIDF	999020000	
20526410		1.880252	VOIDF	999010000	
*					
*					
20527100	WLCFZ	SUM	30.48	0.0	1
20527101	-16.26167	2.000	VOIDF	150010000	
20527102		2.000	VOIDF	150020000	
20527103		2.000	VOIDF	150030000	
20527104		2.000	VOIDF	150040000	
20527105		2.000	VOIDF	150050000	

20527108		2.000	VOIDF	150060000	
*					
20527200	WLIUTUP	SUM	30.48	0.0	1
20527201	6.851243	7.9525000	VOIDF	220010000	
20527202		7.9108334	VOIDF	220020000	
20527203		7.9108334	VOIDF	220030000	
20527204		6.6008367	VOIDF	220040000	
*					
20527300	WLIUTDN	SUM	30.48	0.0	1
20527301	6.851243	7.9510000	VOIDF	220080000	
20527302		7.910334	VOIDF	220070000	
20527303		7.910334	VOIDF	220060000	
20527304		6.6003367	VOIDF	220050000	
*					
20527400	WLBUTUP	SUM	30.48	0.0	1
20527401	6.767667	7.9629167	VOIDF	320010000	
20527402		7.8275000	VOIDF	320020000	
20527403		7.9103334	VOIDF	320030000	
20527404		6.6358363	VOIDF	320040000	
*					
20527500	WLBUTDN	SUM	30.48	0.0	1
20527501	6.767667	7.9629167	VOIDF	320080000	
20527502		7.8275000	VOIDF	320070000	
20527503		7.9108334	VOIDF	320060000	
20527504		6.6358363	VOIDF	320050000	

* ** HEATED ROD TEMPERATURES * CTRL 300 -- 399

20530100	RTC-01	SUM	1.0	0.0	1
20530101	0.0	1.0	HTTEMP	150000114	
*					
20530200	RTC-02	SUM	1.0	0.0	1
20530201	0.0	1.0	HTTEMP	150000214	
*					
20530300	RTC-03	SUM	1.0	0.0	1
20530301	0.0	1.0	HTTEMP	150000314	
*					
20530400	RTC-04	SUM	1.0	0.0	1
20530401	0.0	1.0	HTTEMP	150000414	
*					
20530500	RTC-05	SUM	1.0	0.0	1
20530501	0.0	1.0	HTTEMP	150000514	
*					
20530600	RTC-06	SUM	1.0	0.0	1
20530601	0.0	1.0	HTTEMP	150000614	
*					
20530700	RTC-07	SUM	1.0	0.0	1
20530701	0.0	1.0	HTTEMP	150000714	
*					
20530800	RTC-08	SUM	1.0	0.0	1
20530801	0.0	1.0	HTTEMP	150000814	
*					
20530900	RTC-09	SUM	1.0	0.0	1
20530901	0.0	1.0	HTTEMP	150000914	
*					
20531000	RTC-10	SUM	1.0	0.0	1
20531001	0.0	1.0	HTTEMP	150001014	
*					
20531100	RTC-11	SUM	1.0	0.0	1

```

20531101  0.0      1.0      HTTEMP      150001114
*
20531200  STC-12      SUM      1.0      0.0      1
20531201  0.0      1.0      HTTEMP      150001214
*
20532100  STC-01      SUM      1.0      0.0      1
20532101  0.0      1.0      HTTEMP      150000114
*
20532200  STC-02      SUM      1.0      0.0      1
20532201  0.0      1.0      HTTEMP      150000214
*
20532300  STC-03      SUM      1.0      0.0      1
20532301  0.0      1.0      HTTEMP      150000314
*
20532400  STC-04      SUM      1.0      0.0      1
20532401  0.0      1.0      HTTEMP      150000414
*
20532500  STC-05      SUM      1.0      0.0      1
20532501  0.0      1.0      HTTEMP      150000514
*
20532600  STC-06      SUM      1.0      0.0      1
20532601  0.0      1.0      HTTEMP      150000614
*
20532700  STC-07      SUM      1.0      0.0      1
20532701  0.0      1.0      HTTEMP      150000714
*
20532800  STC-08      SUM      1.0      0.0      1
20532801  0.0      1.0      HTTEMP      150000814
*
20532900  STC-09      SUM      1.0      0.0      1
20532901  0.0      1.0      HTTEMP      150000914
*
20533000  STC-10      SUM      1.0      0.0      1
20533001  0.0      1.0      HTTEMP      150001014
*
20533100  STC-11      SUM      1.0      0.0      1
20533101  0.0      1.0      HTTEMP      150001114
*
20533200  STC-12      SUM      1.0      0.0      1
20533201  0.0      1.0      HTTEMP      150001214

```

```

-----
* * * * *          CONTROL BLOCK FOR PRZ MASS (KG)          * * * * *
-----

```

```

* 205XXX00      NAME      TYPE      COEFF      INIT-VAL      FLO
*
20591000      PRZ-MAS      SUM      1.0      0.0      1
20591001      0.0      0.01542270      RHO      999010000
20591002      0.00631382      RHO      999020000
20591003      0.00592746      RHO      999030000
20591004      0.00303126      RHO      999040000
20591005      0.00113599      RHO      999050000
20591006      7.16357E-4      RHO      997010000
20591007      2.32130E-4      RHO      997020000
20591008      1.64575E-4      RHO      997030000
20591009      9.33831E-5      RHO      997040000
20591010      9.33831E-5      RHO      997050000
*
20599900      ZZZZ      TRN      MIT      1.0      0.0      1
20599901      501
*

```

```

20592100   PRZERR   SUM      1.0      0.0      1
20592101   10.1     -1.0     CNTRLVAR  910
*
20592500   PRZFW    SUM      2.2046   0.0      0
20592501   0.0      0.0     CNTRLVAR  921
*

```

```

-----
****          CONTROL BLOCK FOR ILSG FW FLOWRATE          ****
-----

```

```

*
20561000   ILSGOUT  SUM      1.0      1.35     1
20561001   0.0      2.2046  MFLOWJ   635000000
*
*20561100   ILSGOUT  SUM      1.0      1.35     1
*20561101   0.0      2.2046  MFLOWJ   610000000
*
*20561200   ILSGOUT  SUM      0.74074  0.0      1
*20561201   0.0      1.0     CNTRLVAR  610
*20561202   -1.0     -1.0    CNTRLVAR  611
*

```

```

-----
*
*          CONTROL BLOCK FOR STEAM VALVE OPERATION
*
-----

```

```

*
*20563000 PERR     SUM      -1.0     0.0      1
*20563001 6.4800E6 -1.0     P        601010000
*
*20563100 DPERR    DIFFREND 1.0      0.0      1
*20563101 CNTRLVAR 630
*
*20563200 POSDPDT TRIPUNIT 1.0      0.0      1
*20563201 662
*
*20563300 NEGDPDT TRIPUNIT 1.0      0.0      1
*20563301 663
*
*20563400 DPENVLV  MULT     1.0      0.0      1
*20563401 CNTRLVAR 630     CNTRLVAR  632
*
*20563500 CLOSVLV  MULT     1.0      0.0      1
*20563501 CNTRLVAR 630     CNTRLVAR  633
*
*20563600 RATE     SUM      1.0E-9   0.0      0
*20563601 0.0      1.0     CNTRLVAR  634
*20563602 1.0      1.0     CNTRLVAR  635
*
*20563700 VLVPOSH INTEGRAL 1.0      8.34180E-2 0
*20563701 CNTRLVAR 636
*

```

```

-----
****          CONTROL BLOCK FOR ILSG LEVEL          ****
-----

```

```

*205XXX00   NAME     TYPE     COEFF     INIT-VAL  FLG
*
20561600   ILSGDCI  SUM      30.44    0.0      1
20561601   0.0      7.4762500 VDIFF    603010000
20561602   7.9108334 VDIFF    603020000
20561603   7.9108334 VDIFF    603030000
20561604   7.9525000 VDIFF    603040000

```

```

20561605          3.9487500 VOIDF      602010000
*
20569100  IDELTL  SUM      1.0      0.0      1
20569101  1050.0  -1.0      CNTRLVAR  616
*
20569200  * 732.7  FACT1  STDFNCTN 0.1      0.0      1
20569201  ABS      CNTRLVAR      691
*
20569300  FACT1  STDFNCTN 1.0      1.0      1
20569301  MIN      CNTRLVAR      692
20569302  CNTRLVAR      999
*
20569400  FACT1  MULT      *1.00-5  2.00-5  0.0      1
20569401  CNTRLVAR  693
20569402  RHD  603040000
20569403  CNTRLVAR  691

```

```

-----
****          CONTROL BLOCK FOR BLSG FW FLOWRATE          ****
-----

```

```

*
20571000  BLSGOUT  SUM      1.0      0.40      1
20571001  0.0      2.2046  MFLOWJ  735000000
*
*20571100  BLSGOUT  SUM      1.0      0.40      1
*20571101  0.0      2.2046  MFLOWJ  710000000
*
*20571200  BLSGOUT  SUM      3.125   0.0      1
*20571201  0.0      1.0      CNTRLVAR  710
*20571202  -1.0     CNTRLVAR  711

```

```

=====
*
*          CONTROL BLOCK FOR STEAM VALVE OPERATION
*
=====

```

```

*
*20573000  PERR      SUM      -1.0     0.0      1
*20573001  7.53  P      1.0      P      701010000
*
*20573100  OPERA     DIP-REND 1.0      0.0      1
*20573101  CNTRLVAR  730
*
*20573200  POSDPDT  TRIPUNIT 1.0      0.0      1
*20573201  672
*
*20573300  NEGDPDT  TRIPUNIT 1.0      0.0      1
*20573301  673
*
*20573400  OPENVLV  MULT      1.0      0.0      1
*20573401  CNTRLVAR  730  CNTRLVAR  732
*
*20573500  CLOSVLV  *          1.0      0.0      1
*20573501  CNTRLVAR  CNTRLVAR  733
*
*20573600  RATE      SUM      *5.0E-6  5.0E-7  0.0      0
*20573601  0.0      1.0      CNTRLVAR  734
*20573602  1.0      CNTRLVAR  735
*
*20573700  VI-MODSN  INTEGRAL 1.0      2.3107E-2  0
*20573701  CNTRLVAR  736

```

 **** CONTROL BLOCK FOR BLSG LEVEL ****

20571600	BLSGDCL	SUM	30.48	0.0	1
20571601	0.0		6.6358363	VOIDF	703010000
20571602			7.9108333	VOIDF	703020000
20571603			7.8275000	VOIDF	703030000
20571604			7.9629167	VOIDF	703040000
20571605			6.8620670	VOIDF	702010000
20579100	BDELTL	SUM	1.0	0.0	1
20579101	932.0	-1.0	CNTRLVAR	716	
	713.8				
20579200	FACT1	STDFUNCTN	0.2	0.0	1
20579201	ABS	CNTRLVAR		791	
20579300	FACT1	STDFUNCTN	1.0	1.0	1
20579301	MIN	CNTRLVAR		792	
20579302		CNTRLVAR		999	
20579400	FACT1	MULT	*1.00-5		
20579401			2.00-5	0.0	1
20579402			CNTRLVAR	793	
20579403			RHO	703040000	
			CNTRLVAR	791	

 **** CONTROL BLOCK FOR PUMPS ****

**** STEADY STATE ****

FACT LOOP PUMP SPEED ----- INPUT DESIRED FLOW RATE (KG/S)

NAME	TYPE	COEFF	INIT-VAL	FLG	
*205XXX00					
*20572000	ILMERR	SUM	1.0	0.0	1
*20572001	8.008	-1.0	CNTRLVAR	64	
*20572500	ILPSPD	INTEGRAL	250.0	1693.76	0
*20572501	CNTRLVAR	720			
** BROKEN LOOP PUMP SPEED ----- INPUT DESIRED FLOW RATE (KG/S)					
*20574000	BLMERR	SUM	1.0	0.0	1
*20574001	2.750	-1.0	CNTRLVAR	76	
*20574500	BLPSPD	INTEGRAL	750.0	11000.0	0
*20574501	CNTRLVAR	740			

**** TRANSIENT ****

20572500	ILPSPD	FUNCTION	*1693.755		
20572501	TIME	0	1733.6	0.0	1
			250		
20573500	BLPSPD	FUNCTION	*11095.0		
20573501	TIME	0	11825.0	0.0	1
			390		

 **** CONTROL BLOCK FOR HEAT LOSS ****

```

-----
*
20580000  HLSVUH  SUM  1.0  0.0  1
20580001  0.0  1.0E-3  0  800010000
*
20580100  HLSNCR  SUM  1.0  0.0  1
20580101  0.0  1.0E-3  0  801010000
*
20580200  HLSPV  SUM  1.0  0.0  1
20580201  0.0  1.0E-3  0  802010000
*
20580300  HLSILP  SUM  1.0  0.0  1
20580301  0.0  1.0E-3  0  803010000
*
20580400  HLSBLP  SUM  1.0  0.0  1
20580401  0.0  1.0E-3  0  804010000
*
20580500  HLSISG  SUM  1.0  0.0  1
20580501  0.0  1.0E-3  0  805010000
*
20580600  HLSRSG  SUM  1.0  0.0  1
20580601  0.0  1.0E-3  0  806010000
*

```

```

-----
*** CONTROL VARIABLES FOR S/G HEAT TRANSFER ( KW ) ***
-----

```

```

*
*205XXX00  NAME  TYPE  COEFF  INIT-VAL  FLG
*
20585000  ILSG0  SUM  -1.0E-3  0.0  1
20585001  0.0  1.0  0  220010000
20585002  1.0  0  220020000
20585003  1.0  0  220030000
20585004  1.0  0  220040000
20585005  1.0  0  220050000
20585006  1.0  0  220060000
20585007  1.0  0  220070000
20585008  1.0  0  220080000
*
20585500  RLSG0  SUM  -1.0E-3  0.0  1
20585501  0.0  1.0  0  320010000
20585502  1.0  0  320020000
20585503  1.0  0  320030000
20585504  1.0  0  320040000
20585505  1.0  0  320050000
20585506  1.0  0  320060000
20585507  1.0  0  320070000
20585508  1.0  0  320080000
*

```

```

-----
*** CONTROL VARIABLES FOR CORE HEAT TRANSFER (KW) ***
-----

```

```

*
*205XXX00  NAME  TYPE  COEFF  INIT-VAL  FLG
*
20586100  HTR-01  SUM  0.23607E-3  0.0  1
20586101  0.0  1.0  HTRNP  150000101
*
20586200  HTR-02  SUM  0.23607E-3  0.0  1
20586201  0.0  1.0  HTRNP  150000201
*
20586300  HTR-03  SUM  0.23607E-3  0.0  1

```


20586301	0.0	1.0	HTRNP	150000301
*				
20586400	HTR-04	SUM	0.23607E-3	0.0 1
20586401	0.0	1.0	HTRNR	150000401
*				
20586500	HTR-05	SUM	0.23607E-3	0.0 1
20586501	0.0	1.0	HTRNR	150000501
*				
20586600	HTR-06	SUM	0.23607E-3	0.0 1
20586601	0.0	1.0	HTRNR	150000601
*				
20586700	HTR-07	SUM	0.23607E-3	0.0 1
20586701	0.0	1.0	HTRNR	150000701
*				
20586800	HTR-08	SUM	0.23607E-3	0.0 1
20586801	0.0	1.0	HTRNR	150000801
*				
20586900	HTR-09	SUM	0.23607E-3	0.0 1
20586901	0.0	1.0	HTRNR	150000901
*				
20587000	HTR-10	SUM	0.23607E-3	0.0 1
20587001	0.0	1.0	HTRNR	150001001
*				
20587100	HTR-11	SUM	0.23607E-3	0.0 1
20587101	0.0	1.0	HTRNR	150001101
*				
20587200	HTR-12	SUM	0.23607E-3	0.0 1
20587201	0.0	1.0	HTRNR	150001201
*				
20588000	CORPWR	SUM	1.0	0.0 1
20588001	0.0	1.0	CNTRLVAR	861
20588002		1.0	CNTRLVAR	862
20588003		1.0	CNTRLVAR	863
20588004		1.0	CNTRLVAR	864
20588005		1.0	CNTRLVAR	865
20588006		1.0	CNTRLVAR	866
20588007		1.0	CNTRLVAR	867
20588008		1.0	CNTRLVAR	868
20588009		1.0	CNTRLVAR	869
20588010		1.0	CNTRLVAR	870
20588011		1.0	CNTRLVAR	871
20588012		1.0	CNTRLVAR	872

*** EXPANDED EDIT/PLOT VARIABLES ***

20590100	CORPWR	SUM	1.0	0.0 1
20590101	0.0	1.0	FVALF	163010000
*				
20590200	CORPWR	SUM	1.0	0.0 1
20590201	0.0	1.0	FVALG	163010000
*				
20590300	CORPWR	SUM	1.0	0.0 1
20590301	0.0	1.0	FVALF	164010000
*				
20590400	CORPWR	SUM	1.0	0.0 1
20590401	0.0	1.0	FVALG	164010000
*				
20590500	CORPWR	SUM	1.0	0.0 1
20590501	1.0	1.0	FVALF	165010000

*	20590600		CORPWR	SUM	1.0	0.0	1
	20590601	0.0	1.0	FWALG		165010000	
*	20590700		CORPWR	SUM	1.0	0.0	1
	20590701	0.0	1.0	FIJ		164010000	
*	20590800		CORPWR	SUM	1.0	0.0	1
	20590801	0.0	1.0	FORMFJ		164010000	
*	20590900		CORPWR	SUM	1.0	0.0	1
	20590901	0.0	1.0	FORMGJ		164010000	
*	20591000		CORPWR	SUM	1.0	0.0	1
	20591001	0.0	1.0	FIJ		164020000	
*	20591100		CORPWR	SUM	1.0	0.0	1
	20591101	0.0	1.0	FORMFJ		164020000	
*	20591200		CORPWR	SUM	1.0	0.0	1
	20591201	0.0	1.0	FORMGJ		164020000	
*	.END						

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

1. REPORT NUMBER
(Assigned by NRC, Add Vol., Supp., Rev.,
and Addendum Numbers, if any.)

NUREG/IA-0080

2. TITLE AND SUBTITLE

Assessment of RELAP5/MOD2 Using Semiscale Intermediate
Break Loss-of-Coolant Experiment S-IB-3

3. DATE REPORT PUBLISHED

MONTH YEAR

June 1992

FIN OR GRANT NUMBER

A4682

5. AUTHOR(S)

Gung-Huei Chou, Tzing-Sheng Horng, Lih-Yih Lia

6. TYPE OF REPORT

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Institute of Nuclear Energy Research
P.O. Box 3, Lung-Tan 32500
Taiwan

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)

Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555

10. SUPPLEMENTARY NOTES

11. ABSTRACT (200 words or less)

This report presents the results of the RELAP5/MOD2 assessment utilizing a Semiscale intermediate break loss-of-coolant experiment S-IB-3. Comprehensive analysis with RELAP5/MOD2 is performed to predict the transient thermal-hydraulic responses of the experiment. Test S-IB-3 is a 21.7% communicative cold leg break LOCA experiment using Semiscale Mod-2A facility in 1982, for the principal objective to provide reference data for comparison of Semiscale test results to LOBI facility B-RIM test results. Through extensive comparison between test data and best-estimate RELAP5 calculations, the capabilities of RELAP5/MOD2 to predict the immediate break LOCA accident were assessed. Emphasis was located on the capability of the code to calculate core level depression and break flow rate during system blowdown, pump section liquid seals phenomena, and temperature excursions behavior etc., throughout the whole experiment. Besides some sensitivity studies involving the effect of steam generator secondary side pressure boundary, adjustment of two-phase discharge coefficient, intact loop pump coastdown behavior, and some interesting studies regarding break flow etc., were also investigated in this report.

12. KEY WORDS/DESCRIPTORS (Use words or phrases that will assist researchers in locating the report.)

RELAP5/MOD2
Semiscale Intermediate Break
Loss-of-Coolant
Experiment S-IB-3

13. AVAILABILITY STATEMENT

Unlimited

14. SECURITY CLASSIFICATION

(This Page)

Unclassified

(This Report)

Unclassified

15. NUMBER OF PAGES

16. PRICE

THIS DOCUMENT WAS PRINTED USING RECYCLED PAPER

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SPECIAL FOURTH-CLASS RATE
POSTAGE AND FEES PAID
USNRC
PERMIT NO. G-87

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300

120555139531 1 JAN10
US NRC-DADM
DIV FOIA & PUBLICATIONS SVCS
IPS-PDR-NUREG
P-211
WASHINGTON DC 20555