



Southern Nuclear Operating Company

Dave Morey
Vice President
Farley Project

April 4, 1996

the southern electric system

Docket Nos.: 50-348
50-364

10 CFR 50.54

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555-0001

Joseph M. Farley Nuclear Plant
30-Day Response to NRC Bulletin 96-01
Control Rod Insertion Problems

Ladies and Gentlemen:

By letter dated March 8, 1996, the NRC issued Bulletin 96-01, "Control Rod Insertion Problems," requiring actions to be taken by utilities regarding the susceptibility and evaluation of the Rod Control System to the phenomena of control rod failure to completely insert. The Bulletin was issued to accomplish two goals; first, to alert addressees to problems encountered during recent events in which control rods failed to completely insert upon the scram signal, and second, to assess the operability of control rods, particularly in high burnup fuel assemblies. The Bulletin requested licensees provide a 30-day response which assesses the operability of the control rods.

Provided in Attachments 1 and 2 is the Southern Nuclear Operating Company (SNC) 30-day response for the Farley Nuclear Plant (FNP). Southern Nuclear Operating Company considers that the control rods for both units are operable based on a review of plant specific data and current industry data as noted in our enclosed response. Should you have any questions, please advise.

9604110107 960404
PDR ADOCK 05000348
G PDR

110025

Respectfully submitted,

Dave Morey
Dave Morey

Sworn to and subscribed before me this 4th day of April 1996

Marcha Gayle Dow
Notary Public

My Commission Expires: November 1, 1997

WAS/clt:bul_9601.doc
Attachments

cc: Mr. S. D. Ebnetter, Region II Administrator
Mr. B. L. Siegel, NRR Senior Project Manager
Mr. T. M. Ross, FNP Sr. Resident Inspector

JES7

ATTACHMENT 1

Attachment 1
SNC RESPONSE

NRC Required Response (1)

Within 30 days of the date of this bulletin, a report certifying that control rods are determined to be operable; actions taken for Requested Actions (1) and (2); and the plans for implementing Requested Action (3) and (4).

SNC Response:

Requested Action (1)

Promptly inform operators of recent events (reactor trips and testing) in which control rods did not fully insert and subsequently provide necessary training, including simulator drills, utilizing the required procedures for responding to an event in which the control rods do not fully insert upon reactor trip (e.g., boration of a pre-specified amount).

SNC Response:

All licensed personnel assigned to on-shift duties have been notified of the recent industry events, the potential impact to FNP should such an event occur there, and the proper compensatory actions to take in the event of such an event. Simulator time is being provided for the operating crews during the requalification cycle now in progress. During this session the crews will observe an event similar to that addressed by the bulletin and training on procedures to be used for addressing the event will be re-emphasized. This training has been incorporated in the 1996 License Requalification Program and will be completed by May 1, 1996, for appropriate individuals.

Requested Action (2)

Promptly determine the continued operability of control rods based on current information. As new information becomes available from plant rod drop tests and trips, licensees should consider this new information together with data already available from Wolf Creek, South Texas, North Anna, and other industry experience, and make a prompt determination of control rod operability.

SNC Response:

The FNP control rods are operable. Proper rod movement has been verified by periodic rod stepping during power operation as required by Technical Specifications. There have been no instances of rods failing to fully insert after a trip for FNP Units 1 or 2. In addition, recorded rod drop times and rod stepping tests show no indications of control rod sticking.

At FNP, a standard 12-foot active fuel length core design is used on both units which consists of LOPAR and/or Vantage 5 fuel. A review of burnup data for FNP rodged assemblies was performed to determine the highest burnup in a rodged assembly during near end of cycle reactor trips since Vantage 5 fuel has been in the core. Burnups in excess of 41,800 MWD/MTU in Vantage 5 fuel and 52,300 MWD/MTU in LOPAR fuel were present during the trips with no instances of a failure of a control rod to insert.

A review of drag testing performed on rodged fuel assemblies since Vantage 5 fuel has been used at FNP indicated no instances of abnormal or excessive drag.

As of February 29, 1996, all fuel assemblies which house control rod assemblies on both FNP units had burnups which were less than 43,000 MWD/MTU. The maximum estimated burnup at EOL of any assembly currently in service which houses a control rod assembly is less than 49,000 MWD/MTU.

Both Farley Unit 1, Cycle 14 and Unit 2, Cycle 11 have shutdown margin in excess of the minimum required by Technical Specification 3.1.1.1 (which accounts for the most reactive control rod stuck fully withdrawn from the core).

Additional industry data has been compiled by the WOG. This information indicates that for data on 24 plants received thus far, 501 rodged assemblies had accumulated burnup greater than 40 MWD/MTU and 106 rodged assemblies had accumulated burnup greater than 45 MWD/MTU (the large numbers of fuel assemblies are based upon receiving data from multiple cycles over up to a five year period). None of these plants reported problems with control rod insertion. FNP will continue to follow this issue with the industry.

Requested Action (3)

Measure and evaluate at each outage of sufficient duration during calendar year 1996 (end of cycle, maintenance, etc.), the control rod drop times and rod recoil data for all control rods. If appropriate plant conditions exist where the vessel head is removed, measure and evaluate drag forces for all rodged fuel assemblies.

- a. Rods failing to meet the rod drop time in the technical specifications shall be deemed inoperable.
- b. Rods failing to bottom or exhibiting high drag forces shall require prompt corrective action in accordance with Appendix B to Part 50 of Title 10 of the Code of Federal Regulations (10 CFR Part 50).

SNC Response:

For FNP Units 1 and 2, the following actions will be performed:

- If a planned or unplanned shutdown of sufficient length occurs in 1996, the unit will be tripped prior to completely driving the rods in. Rod insertion will be observed and hot rod drop time testing with rod recoil measurement will be performed for the first shutdown on a unit only, unless timely complete rod insertion does not occur.
- If the unit trips in 1996, timely rod insertion will be confirmed. If timely rod insertion is not observed, hot rod drop testing with rod recoil measurement will be performed.
- For the Unit 2, Fall 1996 Refueling Outage:
 - * The unit will be ramped down and tripped prior to completely driving the rods in. Rod insertion will be observed.
 - * Hot rod drop time testing with rod recoil measurement will be performed prior to cooling down.
 - * Control rod drag testing will be performed in either the reactor vessel prior to core offload or in the spent fuel pool after offload.
 - * Rod drop time testing with rod recoil measurement will be performed when coming out of the outage.
 - * No further testing is planned to be performed on the unit after the scheduled outage due to low burnup.

Requested Action (4)

For each reactor trip during calendar year 1996, verify that all control rods have promptly fully inserted (bottomed) and obtain other available information to assess the operability and any performance trend of the rods. In the event that all rods do not fully insert promptly, conduct tests to measure and evaluate rod drop times and rod recoil.

SNC Response:

If either unit trips in 1996, timely rod insertion will be confirmed. If timely rod insertion is not observed, hot rod drop time testing with rod recoil measurement will be performed.

NRC Required Response (2)

Within 30 days of the date of this bulletin, a core map of rodded fuel assemblies indicating fuel type (materials, grids, spacers, guide tube inner diameter) and current and projected end of cycle burnup of each rodded assembly for the current cycle; when available, provide the same information for the next cycle.

SNC Response:

The requested information is provided for the current fuel cycles in Attachment 2. The information in Attachment 2 is organized as follows for each unit: a core map indicating for each rod location the control rod bank identification, the assembly identification number, the burnup as of February 29, 1996, and the projected end of cycle burnup. In addition, a table of the physical assembly characteristics of the regions of fuel which contain control rods.

The requested information for the next cycle for each unit is not currently available, as those designs are not finalized and are still subject to change. The requested information will be provided for the next cycle on each unit within 30 days following the initial criticality of that cycle.

NRC Required Response (3)

Within 30 days after completing Requested Action (3) for each outage, a report that summarizes the data and that documents the results obtained; this is also applicable to Requested Action (4) when any abnormal rod behavior is observed.

SNC Response:

To be submitted when required by the above evaluations performed in 1996.

ATTACHMENT 2

PHYSICAL CHARACTERISTICS OF RODDED ASSEMBLIES

PLANT FARLEY UNIT 1 CYCLE 14

	REGION 2E	REGION 2F
Assembly Type	Vantage-5*	Vantage-5*
Clad Material	Zirc-4	Zirc-4
Grid Material		
Mid-span grids	Zirc-4	Zirc-4
Bottom/Top grid	Inconel-718	Inconel-718
Guide Tube Material	Zirc-4	Zirc-4
Guide Tube O.D. (inches)		
Above dashpot	0.4740	0.4740
At dashpot	0.4300	0.4300
Guide Tube I.D. (inches)		
Above dashpot	0.4420	0.4420
At dashpot	0.3970	0.3970

*17x17 assemblies with optimized fuel rod O.D. of 0.360 in. and with intermediate flow mixing (IFM) grids

PHYSICAL CHARACTERISTICS OF RODDED ASSEMBLIES

PLANT FARLEY UNIT 2 CYCLE 11

	REGION W	REGION 2M	REGION 2N
Assembly Type	LOPAR ⁽¹⁾	Vantage-5 ⁽²⁾	Vantage-5 ⁽²⁾
Clad Material	Zirc-4	Zirc-4	Zirc-4 ⁽³⁾
Grid Material			
Mid-span grids	Inconel-718	Zirc-4	Zirc-4
Bottom/Top grid	Inconel-718	Inconel-718	Inconel-718
Guide Tube Material	Zirc-4	Zirc-4	Zirc-4
Guide Tube O.D. (inches)			
Above dashpot	0.4820	0.4740	0.4740
At dashpot	0.4300	0.4300	0.4300
Guide Tube I.D. (inches)			
Above dashpot	0.4500	0.4420	0.4420
At dashpot	0.3970	0.3970	0.3970

- (1) 17x17 assemblies with standard fuel rod O.D. of 0.374 in. without intermediate flow mixing (IFM) grids.
- (2) 17x17 assemblies with optimized fuel rod O.D. of 0.360 in. and with intermediate flow mixing (IFM) grids.
- (3) Two assemblies (2N41 and 2N52) each contain 12 ZIRLO™ clad fuel rods for demonstration.

Farley Unit 1 Cycle 14

R	P	N	M	L	K	J	H	G	F	E	D	C	B	A	
															1
					A		D		A						2
					2E08 24243 33559		2F22 4609 21707		2E03 24390 33600						3
						SA		SA							4
						2F02 5799 25818		2F04 5803 25840							5
			C		B				B		C				6
			2E50 25393 38365		2E58 30860 48368				2E59 30882 48398		2E49 25032 31365				7
				SB					SB						8
				2E20 32685 48792					2E26 32665 48792						9
A		B			D		C		D		B		A		10
2E06 24496 33600		2E55 31100 48398			2E25 31782 47241		2F36 5940 26564		2E32 31661 47241		2E57 30925 48368		2E05 24096 33559		11
	SA				SB			SB			SA				12
	2F05 5958 25840				2F53 5801 25894			2F54 5704 25894			2F06 5823 25818				13
	D				C				C				D		14
	2F21 4684 21707				2F46 6050 26564				2F43 5945 26564				2F32 4606 21707		15
		SA			SB			SB			SA				
		2F07 5973 25818			2F55 5825 25894			2F56 5765 25894			2F01 5869 25840				
A		B			D		C		D		B		A		
2E01 24631 33559		2E61 30619 48368			2E18 31909 47241		2F39 6036 26564		2E33 31844 47241		2E56 31053 48398		2E07 24392 33600		
			SB						SB						
			2E28 32722 48792						2E30 32932 48792						
		C			B				B		C				
		2E51 25222 38365			2E60 31186 48398				2E54 31232 48368		2E46 25070 38365				
						SA		SA							
						2F08 6000 25840		2F03 6040 25818							
					A		D		A						
					2E02 24120 33600		2F27 4712 21707		2E04 24491 33559						

LEGEND

- ROD BANK
- ASSY. NUMBER
- CURR. BURNUP*
- PROJ. BURNUP
- @ EOC 14**
- (MWD/MTU)

* As of 2/29/96.
** Based on Design

Farley Unit 2 Cycle 11

R	P	N	M	L	K	J	H	G	F	E	D	C	B	A	
															1
					A W48 42444 47103		D 2N44 12469 24280		A W33 42139 47081						2
						SA 2M56 32139 42662		SA 2M57 32381 42883							3
		C 2N01 11469 21889		B 2M33 35523 45263				B 2M10 35308 45358			C 2N02 11408 21871				4
			SB 2M12 35344 44900							SB 2M24 35430 44933					5
A W33 42139 47081		B 2M39 35563 45370		D 2M07 34650 44158		C 2M34 36083 45871		D 2M02 33975 44121		B 2M26 35115 45271			A W40 42204 47087		6
	SA 2M42 32657 42849				SB 2M45 31143 41698		SB 2M44 31909 42048				SA 2M60 32298 42765				7
	D 2N41 12541 24211			C 2M15 35680 45820				C 2M09 35712 45808					D 2N52 12278 24210		8
	SA 2M49 32171 42764				SB 2M47 31589 42097		SB 2M50 31826 42072				SA 2M41 32249 42850				9
A W01 42187 47075		B 2M25 35531 45270		D 2M03 34317 44128		C 2M13 35406 45924		D 2M06 33721 44145		B 2M14 35231 45374			A W34 41901 47090		10
			SB 2M29 35214 44931							SB 2M32 35301 44938					11
		C 2N03 11454 21871		B 2M38 35294 45342					B 2M21 35029 45212		C 2N04 11421 21876				12
					SA 2M55 32314 42840		SA 2M46 32570 42760								13
					A W38 42098 47093		D 2N46 12415 24247		A W19 42646 47081						14
															15

LEGEND

- ROD BANK
- ASSY. NUMBER
- CURR. BURNUP*
- PROJ. BURNUP
- @ EOC 11**
- (MWD/MTU)

* As of 2/29/96.

** Based on Design