



**Entergy
Operations**

Entergy Operations, Inc.
Route 3 Box 1370
Russellville, AR 72801
Tel: 501-964-8865

Neil S. "Buzz" Carns
Vice President
Operations AND

July 9, 1992

2CAN079207

U.S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, DC 20555

Subject: Arkansas Nuclear One - Unit 2
Docket No. 50-368
License No. NPF-6
Technical Specification Change Request
Containment Building Pressure Trip Setpoints

Gentlemen:

Attached for your review and approval is a proposed Technical Specifications (TS) change revising TS Table 2.2-1 Reactor Protective Instrumentation Trip Setpoint Limits and TS Table 3.3-4 Engineered Safety Feature Actuation System (ESFAS) Instrumentation Trip Values. During the upcoming refueling outage for Arkansas Nuclear One - Unit 2 (ANO-2) the narrow range containment building pressure transmitters will be replaced, requiring a change in the Reactor Protective Instrumentation and ESFAS setpoints associated with containment building pressure due to a larger calculated instrument loop error. The replacement of the narrow range transmitters is required to upgrade the existing obsolete transmitters which are nearing the end of their environmentally qualified lifetimes.

The proposed changes have been evaluated in accordance with 10CFR50.91 (a) (1) using criteria in 10CFR50.92(c) and it has been determined that no significant hazards considerations are involved. The bases for these determinations are included in the enclosed submittal.

Although this TS change request is neither exigent nor emergency, restart from the upcoming ANO-2 refueling outage is contingent upon incorporation of this change. Therefore, Entergy Operations requests your approval of this change by October 12, 1992 and that the effective date for this change be upon NRC issuance of the amendment.

Very truly yours,

Guillermo Yelverton
B. N. S. C.

NSC/jmt

Attachments

140856

9207140240 920709
PDR ADOCK 05000368
P PDR

ADD 1

U. S. NRC
July 9, 1992
Page 2

cc: Mr. James L. Milhoan
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Arkansas Nuclear One - ANO-1 & 2
Number 1, Nuclear Plant Road
Russellville, AR 728C1

Mr. Thomas W. Alexion
NRR Project Manager, Region IV/ANO-1
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

Ms. Sheri R. Peterson
NRR Project Manager, Region IV/ANO-2
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

STATE OF ARKANSAS)
)
COUNTY OF LOGAN) SS

Affidavit

I, J. W. Yelverton, being duly sworn, subscribe to and say that I am General Manager, Plant Operations AND Energy Operations, that I have full authority to execute this affidavit; that I have read the document numbered 2CAN079207 and know the contents thereof; and that to the best of my knowledge, information and belief the statements in it are true.

J. W. Yelverton
J. W. Yelverton

SUBSCRIBED AND SWORN TO before me, a Notary Public in and for the County and State above named, this 9th day of July, 1992.

Sandy Siebenmeyer
Notary Public

My Commission Expires:

May 11, 2000