



South Carolina Electric & Gas Company
P.O. Box 88
Jenkinsville, SC 29065
(803) 345-4344

Gary J. Taylor
Vice President
Nuclear Operations

April 11, 1996

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Gentlemen:

Subject: VIRGIL C. SUMMER NUCLEAR STATION
DOCKET NO. 50/395
OPERATING LICENSE NO. NPF-12
SPECIAL REPORT (SPR 960002)

South Carolina Electric & Gas Company (SCE&G) is submitting this report pursuant to the requirements of Technical Specification 3.3.3.10.a. The Digital Metal Impact Monitor System (DMIMS) has one channel (Steam Generator 'B') which has been inoperable in excess of 30 days, requiring a 10 day report.

On March 5, 1996, the Loose Parts Monitoring Panel, XPN6042, was declared inoperable. The DMIMS is currently being replaced to enhance its reliability. The operability of this system will be re-established prior to the end of Refueling Outage 9, which is scheduled to start on April 15, 1996.

Should you have any questions please call Mr. Jeffrey Pease at (803) 345-4124, at your convenience.

Very truly yours,

Stephen A. Burne FOR GJT
STEPHEN A. BURNER

Gary J. Taylor

JWP/GJT/nkk

c: J. L. Skolds
R. R. Mahan
R. J. White
J. I. Zimmerman
J. B. Knotts, Jr.
S. D. Ebnetter
Marsh & McLennan

INPO Records Center
NRC Resident Inspector
NSRC
S. F. Fipps
DMS (RC-96-0107)
RTS (ONO 960083 & ONO 960141)
File (818.08, 818.05)

9604150183 960411
PDR ADOCK 05000395
S PDR



IE22
1/0