

DCS No:
Date: January 3, 1985

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-I-85-01

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility: Boston Edison Company
Pilgrim Nuclear Power Station
Plymouth, Massachusetts
DN-50-293

Licensee Emergency Classification:
 Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

Subject: SHUTDOWN IN EXCESS OF 48 HOURS

The reactor will be shut down for about 3 days for repairs to the Standby Liquid Control System (SLCS).

On December 24, 1984, the reactor was started up following a one year extended outage for piping replacement. On January 1, 1985, during routine surveillance testing, the SLCS was found to be inoperable due to debris (rubber gloves) in the piping and the resulting blockage of relief valves. The reactor was shut down at 11:07 p.m. on January 1. The licensee plans to clean the SLCS piping and the 4,000 gallon storage tank to ensure no debris remains in the system.

This information is accurate as of 10:00 a.m., January, 3, 1985.

The Commonwealth of Massachusetts has been informed.

CONTACT: J. Johnson 617-747-0565

G. Meyer 488-1120

DISTRIBUTION:

H. St. _____	MNBB _____	Phillips <u>3:07</u>	E/W _____	Willste _____	Mail: ADM:DMB
Chairman Palladino	EDO	NRR	IE	NMSS	DOT:Trans only
Comm. Zech	PA		OIA	RES	
Comm. Bernthal	MPA		AEOD		
Comm. Roberts	ELD				
Comm. Asselstine					
ACRS		Air Rights	INPO----		
SECY		SP	NSAC----		
CA					
PDR		Regional Offices _____		TMI Resident Section <u>3:05</u>	
				RI Resident Office <u>3:09</u>	

Licensee: _____
(Reactor Licensees)

Region I Form 83
(Rev. July, 1984)

8501080361 850103
PDR I&E
PNO-I-85-001 PDR

IE-34
0/1