

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
NEW YORK WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

General Offices • Seiden Street, Berlin, Connecticut

P.O. BOX 270
HARTFORD, CONNECTICUT 06141-0270
(203) 665-5000

July 10, 1992
MP-92-742

Re: 10CFR50.71(a)

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Reference: Facility Operating License No. NPF-49
Docket No. 50-423

Dear Sir:

In accordance with reporting requirements of technical specifications Section 6.9.1.5, the Millstone Nuclear Power Station - Unit 3 Monthly Operating Report 92-07 covering operation for the month of June is hereby forwarded.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

FOR: Stephen E. Scace
Director, Millstone Station

BY: Fred R. Dacimo
Millstone Site Services Director

Attachment

cc: T.T. Martin, Region I Administrator
W.J. Raymond, Senior Resident Inspector, Millstone Unit Nos. 1,2 & 3
V. L. Rooney, NRC Project Manager, Millstone Unit No. 3

9207150174 920630
PDR ADOCK 05000423
R PDR

TE24
||

***** NRC OPERATING STATUS REPORT COMPLETED BY REACTOR ENGINEERING *****

1. DOCKET.....50-423 OPERATING STATUS
 2. REPORTING PERIOD...JUNE 1992 OUTAGE + ONLINE HOURS... 87.6 + 632.4 = 720.0
 3. UTILITY CONTACT.....A. L. Elms 203-444-5388 *****
 4. LICENSED THERMAL POWER..... 3411 * MILLSTONE *
 5. NAMEPLATE RATING (GROSS MWE)..... 1,253 MW * UNIT 3 *
 6. DESIGN ELECTRICAL RATING (NET MWE)..... 1,153.6 *****
 7. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE)..... 1,184.2
 8. MAXIMUM DEPENDABLE CAPACITY (NET MWE)..... 1,137.0
 9. IF CHANGES OCCUR ABOVE SINCE LAST REPORT, REASONS ARE.....
 N/A
 10. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE).....N/A
 11. REASON FOR RESTRICTION, IF ANY....N/A

	MONTH	YEAR TO DATE	CUMULATIVE TO DATE
	=====	=====	=====
12. HOURS IN REPORTING PERIOD	720.0	4,367.0	54,263.0
13. NUMBER OF HOURS THE REACTOR WAS CRITICAL	669.9	2,987.9	39,535.2
14. REACTOR RESERVE SHUTDOWN HOURS	0.0	828.1	6,566.5
15. HOURS GENERATOR ONLINE	632.4	2,879.1	38,696.9
16. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
17. GROSS THERMAL ENERGY GENERATED (MWH)	2,009,608.0	9,282,225.0	126,226,371.0
18. GROSS ELECTRICAL ENERGY GENERATED (MWH)	714,684.0	3,233,502.5	43,584,864.0
19. NET ELECTRICAL ENERGY GENERATED (MWH)	676,745.4	3,050,775.7	41,464,237.5
20. UNIT SERVICE FACTOR	87.8	65.9	71.3
21. UNIT AVAILABILITY FACTOR	87.8	65.9	71.3
22. UNIT CAPACITY FACTOR (USING MDC NET)	82.7	61.4	67.0
23. UNIT CAPACITY FACTOR (USING DER NET)	81.5	60.6	66.2
24. UNIT FORCED OUTAGE RATE	0.0	26.2	18.4
25. UNIT FORCED OUTAGE HOURS	0.0	1,020.4	8,749.5
SHUTDOWNS SCHEDULED OVER NEXT SIX MONTHS (TYPE, DATE, AND DURATION OF EACH).....			
N/A			
IF CURRENTLY SHUTDOWN, ESTIMATED STARTUP DATE.....N/A			

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-423
 UNIT MILLSTONE UNIT 3
 DATE July 8, 1992
 COMPLETED BY A. L. Sims 203-444-5388

MONTH June 1992

DAY	AVERAGE DAILY POWER LEVEL (MWE - NET)	DAY	AVERAGE DAILY POWER LEVEL (MWE - NET)
1	<u>0</u>	16	<u>1123</u>
2	<u>0</u>	17	<u>1123</u>
3	<u>0</u>	18	<u>1115</u>
4	<u>53</u>	19	<u>1123</u>
5	<u>623</u>	20	<u>1118</u>
6	<u>1090</u>	21	<u>1118</u>
7	<u>1098</u>	22	<u>1122</u>
8	<u>1125</u>	23	<u>1122</u>
9	<u>1127</u>	24	<u>1083</u>
10	<u>1125</u>	25	<u>1073</u>
11	<u>1126</u>	26	<u>1068</u>
12	<u>1126</u>	27	<u>1071</u>
13	<u>1118</u>	28	<u>1069</u>
14	<u>1128</u>	29	<u>1064</u>
15	<u>1122</u>	30	<u>1063</u>

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-423
 UNIT NAME MILLSTONE 3
 DATE 07-08-92
 COMPLETED BY A. L. Elms
 TELEPHONE (203) 444-5388

No.	Date	Type (1)	Duration Hours	Reason (2)	Method of Shut down Reactor(3)	Licensee Event Rept No.	System Code	Component Code	Cause and Corrective Action to Prevent Recurrence
92-04	06/01/92	S	87.6	B	4	N/A	AB	RV	Manually shutdown the reactor for planned pressurizer PORV and safety valve repair.

1: F: Forced
 S: Scheduled

2: Reasons:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Exam
 F-Administrative
 G-Operational Error (Explain)
 H-Other

3: Method
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Continued from previous month
 5-Power Reduction (duration = 0)
 9-Other (Explain)

4: Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5: Exhibit 1 - Same Source

REFUELING INFORMATION REQUEST

June 1992

1. Name of facility: Millstone 3.
2. Scheduled date for next refueling shutdown: June 5, 1993
3. Scheduled date for restart following refueling: August 14, 1993
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?
N/A
5. Scheduled date for submitting licensing action and supporting information.
N/A
6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design of performance analysis methods, significant changes in fuel design, new operating procedures:
N/A
7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool:
(a): 193 (b): 248
8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies:
Present size - 756.
No increase requested.
9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity:
End of cycle 5.