

# Duquesne Light Company

Beaver Valley Power Station  
P.O. Box 4  
Shippingport, PA 15077-0004

SUSHIL C. JAIN  
Division Vice President  
Nuclear Services  
Nuclear Power Division

(412) 393-5512  
Fax (412) 643-8069

April 8, 1996

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555-0001

**Subject: Beaver Valley Power Station, Unit No. 2  
Docket No. 50-412, License No. NPF-73  
ISI (Inservice Inspection) Program: Relief Request**

The purpose of this submittal is to request NRC review and approval of a proposed relief request applicable to the Unit No. 2 First Ten-Year Interval ISI Program. The current 10-year interval ends on November 17, 1997. The ISI Program is based on the 1983 Edition through the Summer 1983 Addenda of ASME Boiler and Pressure Vessel Code, Section XI.

Relief Request BV2-C1.30, Rev. 0 is attached for review. The examinations represented by this relief request were originally evaluated by the NRC following completion of preservice inspections. The NRC approved relief request BV2-C1.10-2 in an August 22, 1991, safety evaluation of the first ten-year interval ISI Program Plan (TAC No. 62873). Since then the component has become a significant source of radiation exposure during normal operation. It is proposed to substitute visual examinations in accordance with the attached relief request in order to reduce occupational radiation exposure. A proposed alternative to the requirements, with supporting basis is included in the attached request for relief. 10 CFR 50.55a(a)(3)(ii) provides for NRC approval of proposed alternatives to the ASME Code requirements when it can be demonstrated that compliance would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety. It is proposed that the attached relief request satisfies this acceptance criteria.

It is requested that this review be completed before July 8, 1996, in order to allow sufficient time to plan and prepare for any follow-up examinations that may be required during the sixth refueling outage tentatively scheduled to begin August 30, 1996.

9604160274 960408  
PDR ADOCK 05000412  
G PDR

150115

*photos located in Central Files*




*A04711*

Beaver Valley Power Station, Unit No. 2  
ISI (Inservice Inspection) Program: Relief Request  
Page 2

If you have any questions regarding this issue, please contact Mr. Roy K. Brosi at  
(412) 393-5210.

Sincerely,



Sushil C. Jain

Attachment

- c: Mr. L. W. Rossbach, Sr. Resident Inspector
- Mr. T. T. Martin, NRC Region I Administrator
- Mr. D. S. Brinkman, Sr. Project Manager

DUQUESNE LIGHT COMPANY

Beaver Valley Power Station Unit No. 2

RELIEF REQUEST NO. BV2-C1.30, Rev. 0

**COMPONENT**

Regenerative Heat Exchanger (2CHS\*E23) - Tubesheet to Shell Welds 2, 3, 6, 7, 10, and 11

**DRAWING NO.**

ISI-E-2C

**SECTION XI REQUIREMENT (83S83)**

Item No. C1.30 (IWC-2500-1, Category C-A) requires volumetric examination.

**BASIS OF RELIEF**

The general radiation levels in the area of this heat exchanger are between 500 mR/hr and 3000 mR/hr and up to 5000 mR/hr on contact (based on surveys taken in the second and fifth refueling outages). The manrem estimate to prepare, inspect, and reinsulate these six welds is 9800 mRem. This estimate is based on working space dose rates and estimated work duration as noted on the attached manrem estimate. ALARA and leak before break considerations suggest a visual examination for leakage would provide an acceptable inservice inspection for these welds.

The design and function of this component give rise to areas where "hot spots" can readily occur due to corrosion and wear products buildup. Flushing provides little benefit toward reducing radiation fields in this area. The location of the welds, between two branch connections with a welded support between the two welds, make shielding of these areas impractical. Reference attached drawing and preservice photographs.

The proposed visual examination for leakage, in this situation, is a more practical examination for monitoring the integrity of the component than the required examination. The required UT examinations are limited by component geometric restrictions. Approximately 1/3 of the required volume of each weld could not be examined in the preservice inspection due to the adjacent branch connections and the welded pad, plates and lugs of the support located between the two welds on each of the three sections of the heat exchanger. (Note: Relief Request BV2-C1.10-2 identified these limitations and was approved in the SER dated August 22, 1991.) Preservice ultrasonic examinations performed on welds 2, 3, 6, 7, and 10 had no reportable indications. Examination of weld 11 found a manufacturing defect that was subsequently repaired and reexamined satisfactorily.

Several methods are available to detect leakage from these welds if sufficient weld degradation occurred to cause a through-wall leak. Listed below are some examples:

- a. The control room operators perform Operation Surveillance Test (OST) 2.6.2A "Reactor Coolant System Water Inventory Balance" every three days when the plant is operating at steady conditions. Leakage through the subject welds would be discovered by the conduct of this OST.
- b. Containment airborne radiation monitors continuously sample the containment atmosphere and alarm in the control room. This method is sensitive enough to detect a 1 gpm leak in less than 1 hour.
- c. Two leakage monitoring systems are available in the containment sump. One system uses the flow indication of the containment sump pumps to determine leak rates. A programmable controller monitors the flow and pump operating times so that a 1 gpm leak could be detected by this method in 1 hour. A second system uses changes in the water level of the sump to determine a leak rate. The containment sump level is continuously monitored by instruments that alarm in the control room. This system is capable of detecting a 5 gpm leak in 1 hour.

The Regenerative Heat Exchanger is readily isolable should a leak occur. Double valve isolation from the reactor coolant system is provided by valves 2CHS\*LCV460A and 460B.

### ALTERNATIVE EXAMINATION

A visual examination of these welds for leakage is performed in conjunction with the boric acid walkdown, every shutdown while the RCS and associated piping remain at operating pressure and temperature. Also, the regenerative heat exchanger is included in the Mode 3 walkdown of the RCS boundary, performed during each startup following refueling outages. Both these activities are performed by qualified VT-2 examiners. These examinations are augmented by the leakage detection methods noted above.

**2CHS-E23 EXAMINATIONS  
WELDS 2, 3, 6, 7, 10 and 11  
MANREM ESTIMATE**

**2CHS-E23 Regenerative Heat Exchanger**

General area radiation level: 500 mR/hr to 3000 mR/hr

Contact radiation level: 1000 to 5000 mR/hr

<u>WORK TASK</u>	<u># OF WORKERS AND JOB CLASS</u>		<u>TIME IN RAD FIELD (hrs)</u>		<u>EXPOSURE RATE (mR/hr)</u>		<u>ESTIMATED EXPOSURE (mRem)</u>	
CONSTRUCT SCAFFOLDING	(2) CARPENTERS	x	1	x	600	=	1200	
REMOVE INSULATION	(2) INSULATORS	x	1	x	600	=	1200	
WELD PREPARATION	(2) FITTERS	x	1	x	800	=	1600	
WELD INSPECTION	(2) EXAMINERS	x	2.5	x	800	=	4000	
REINSTALL INSTALLATION	(2) INSULATORS	x	1	x	600	=	1200	
REMOVE SCAFFOLDING	(2) CARPENTERS	x	.5	x	600	=	<u>600</u>	
<b>TOTAL FOR SIX WELDS:</b>								<b>9800 mRem</b>

# MAP 03211 B. V. P. - UNIT 2



## REACTOR CONTAINMENT EL. 718"6"

### REGEN. HEAT EXCH.

B.V.P.S. Unit 2

Circled numbers are radiation levels in mR/hr.

ALL SMEARS ARE < 450 pCi/100 cm<sup>2</sup> EXCEPT:



REACTOR POWER	0	
SURVEY DATE	9/12/90	TIME 1000
SURVEY BY	M. J. A. H. H.	
EWP # / RACP #	16748	
INST. TYPE	log	SR # 3752
INST. TYPE	retector	SR # 63645
OTHER	R.M. 14 1121	

REVIEWED BY

*[Signature]*

DATE 9/12/90

# REACTOR CONTAINMENT EL. 718"6"

## REGEN. HEAT EXCH.


B.V.P.S. Unit 2

Read numbers are radiation levels in mR/hr.

In still Insulation on Regen HX




(15)

ALL SMEARS ARE  $< \frac{1000 \text{ dpm}/100}{450 \text{ pCi}/100} \text{ cm}^2$  EXCEPT:



REACTOR POWER SHUT Down  
SURVEY DATE 4/17/95 TIME 0930  
SURVEY BY DARRYL L. JAMES  
EMP # / RACP # 295-2035  
INST. TYPE RC2A SR # 3601  
INST. TYPE Rm-14 SR # 1950  
OTHER \_\_\_\_\_

REVIEWED BY J. Beltrich w6876 DATE 4-17-95




LOCATION PLAN  
REGENERATIVE HEAT EXCHANGER UNIT 2

REGENERATIVE HEAT EXCHANGER CALIBRATION INDEX

UNIT NO.	APPLICATOR NAME	DATE
101-1	REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54
101-2	REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54
101-3	REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54
101-4	REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54
101-5	REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54
101-6	REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54
101-7	REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54
101-8	REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54
101-9	REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54
101-10	REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54

- NOTES
1. THIS UNIT IS TO BE CALIBRATED BY THE APPLICATOR.
  2. THE UNIT IS TO BE CALIBRATED AT THE TIME OF THE REGENERATIVE HEAT EXCHANGER UNIT 2 CALIBRATION.
  3. THE UNIT IS TO BE CALIBRATED AT THE TIME OF THE REGENERATIVE HEAT EXCHANGER UNIT 2 CALIBRATION.
  4. THE UNIT IS TO BE CALIBRATED AT THE TIME OF THE REGENERATIVE HEAT EXCHANGER UNIT 2 CALIBRATION.
  5. THE UNIT IS TO BE CALIBRATED AT THE TIME OF THE REGENERATIVE HEAT EXCHANGER UNIT 2 CALIBRATION.



**CONTROLLED  
BVP'S UNIT 2**




S.A. CATEGORY 1  
MECHANICAL SAFETY RELATED

REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54
REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54
REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54
REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54
REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54
REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54
REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54
REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54
REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54
REGENERATIVE HEAT EXCHANGER UNIT 2	10/15/54







ELEVATION

SECTION A-A


MS-D

SECTION B-B

1WS-D

ANSTEC  
APERTURE  
CARD

Also Available on  
Aperture Card



LOCATION PLAN  
REGENERATIVE HEAT EXCHANGER 2CHS+E23  
REACTOR CONTAINMENT BLDG. (EL. 718'-6")

REGENERATIVE HEAT EXCHANGER CALIBRATION BLOCK


CALIBRATION BLOCK NO.	EXAM CAT. ITEM NO.	APPLICATION WELDS	CALIBRATION BLOCK DWG. NO.
8V1-54	CL18	REGENERATIVE HEAT EXCHANGER SHELL CIRCUMFERENTIAL WELDS C-2 C-3 C-6 C-7 C-10 C-11	8788-1S1-C-882R
8V1-54	CL28	REGENERATIVE HEAT EXCHANGER HEAD CIRCUMFERENTIAL WELDS C-1 C-4 C-5 C-8 C-9 C-12	8788-1S1-C-882R

NOTES:

- ALL MARK NOS. AND WELD NOS. ON THIS DWG ARE PRECEDED BY 2CHS+E23.
- MATERIAL DATA  
SHELL - 1/2" THK. SA 248 TP 304 L  
HEADS - 1/2" THK. SA 351 CP 8A  
9.50" DIA. 38.00" CIRC.  
TUBESHEET - SA 182 F 304  
INTERCONNECTING PIPING:  
TUBE SIDE - 3" SCH. 80, SA-312 TP 304  
SHELL SIDE - 3" SCH. 80, SA-312 TP 316  
SUPPORTS: (I) MECHANICALLY ATTACHED  
(II) INTEGRALLY WELDED  
3. FOR ADDITIONAL SUPPORT DETAILS, SEE V.T.L. 2584-188-881-881.
- ISI CLASS 2.
- ISI CONTINUATION ISOMETRICS  
INLET BUTLET  
TUBE 187485 187481  
SHELL 187418 187418

REFERENCES:

- 884-79C
- 884-2C
- FP 2884-140-001-005A
- FP 2884-140-001-004E
- 2584-188-881-881 (V.T.L.)



D. A. CATEGORY I  
NUCLEAR SAFETY RELATED

CONTROLLED  
BVPS UNIT 2

9604160274-01

		PITTSBURGH, PA		BEAVER VALLEY POWER STATION UNIT 2	
DATE 3-14-95 DRAWN BY MCB CHECKED BY JCF DESIGNED BY JCF		REVISIONS NO. 00014 DATE 8-19-95		REGENERATIVE HEAT EXCHANGER 2CHS+E23 REACTOR CONT. BLDG. EL. 718'-6" 10088-1S1-E-2C 1	