# INDEX

SECTION	NUMBER OF PAGES
Average Daily Unit Power Level	
Operating Data Report	2
Refueling Information	1
Monthly Operating Summary	1
Summary of Changes, Tests, and Experiments	

2

DOCKET NO.: <u>50-354</u> UNIT: <u>Hope Creek</u> DATE: <u>4/10/96</u> COMPLETED BY: <u>D. W. Lyons</u> TELEPHONE: (<u>609) 359-3517</u>

### AVERAGE DAILY UNIT POWER LEVEL

### MONTH MARCH 1996

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>0</u>	17	<u>0</u>
2	<u>0</u>	18	Q
3	<u>0</u>	19	Q
4	<u>0</u>	20	<u>0</u>
5	Q	21	<u>0</u>
6	Q	22	<u>0</u>
7	Q	23	<u>0</u>
8	<u>0</u>	24	Q
9	<u>0</u>	25	<u>104</u>
10	<u>0</u>	26	<u>167</u>
11	Q	27	<u>407</u>
12	Q	28	522
13	<u>0</u>	29	<u>926</u>
14	<u>0</u>	30	1077
15	<u>0</u>	31	1017
16	<u>0</u>		

## OPERATING DATA REPORT OPERATING STATUS

1.	Reporting Period March 1996 Gross Hours in Report Period	<u>744</u> .	
2.	Currently Authorized Power Level (MWt)	3293	
	Max. Dopend. Capacity (MWe-Net)	1031	
	Design Electrical Rating (MWe-Net)	1067	
3.	Power Level to which restricted (if any) (MWe-Net)	None	

4. Reasons for restriction (if any)

- - -

		This Month	Yr To Date	Cumulative
5.	No. of hours reactor was critical	322.2	322.2	67246.1
6.	Reactor reserve shutdown hours	0.0	0.0	0.0
7.	Hours generator on line	164.4	164.4	66106.0
8	Unit reserve shutdown hours	0.0	0.0	0.0
9.	Gross thermal energy generated (MWH)	333272	333272	211107521
10.	Gross electrical energy generated (MWH)	106701	106701	69932323
11.	Net electrical energy generated (MWH)	89788	73553	66790788
12.	Reactor service factor	43.3	14.8	82.7
13.	Reactor availability factor	43.3	14.8	82.7
14.	Unit service factor	22.1	7.5	81.3
15.	Unit availability factor	22.1	7.5	81.3
16.	Unit capacity factor (using MDC)	11.7	3.3	79.6
17.	Unit capacity factor (using Design MWe)	11.3	3.2	76.9
18.	Unit forced outage rate	0.0	0.0	5.1

19. Shutdowns scheduled over next 6 months (type, date, & duration):

20. If shutdown at end of report period, estimated date of start-up:

DOCKET NO .:	50-354	
UNIT:	Hope Creek	
DATE:	4/10/96	
COMPLETED BY:	D. W. Lyons	
TELEPHONE:	(609) 339-3517	

## OPERATING DATA REPORT UNIT SHUTDOWNS AND POWER REDUCTIONS

### MONTH MARCH 1996

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER (2)	CORRECTIVE ACTION/COMMENTS
1.	03/01/96, 0000 hrs to 03/25/96, 0141 hrs	S S S S	11/95 - 478.4 12/95 - 744.0 01/96 - 744.0 02/96 - 696.0 .03/96 - 577.7	с	4	Refueling Outage
2	03/25/96, 0141 hrs - to 03/29/96, 2220 hrs	S	0	С	5	This was the planned start up and power ascension testing program following the refueling outage.

## **REFUELING INFORMATION**

### MONTH MARCH 1996

. .

1.	Refueling information has changed from last	month:				
	Yes	No	X			
2.	Scheduled date for next refueling (RF07):			4/5/97		
3.	Scheduled date for restart following refuelin	g		6/4/97		
4A. Will Technical Specification changes or other license amendments be required						
	Yes	No	X			
B	Has the Safety Evaluation covering the COL Review Committee (SORC)?	.R been r	eviewed	d by the Station Operating		
	Yes	No	X			
	If no, when is it scheduled? To Be Determi	ined for (	ycle 8	COLR		
5.	Scheduled date(s) for submitting proposed li	icensing a	action			
	Not required.					
6.	Important licensing considerations associated with refueling:					
	<u>N/A</u>					
7.	Number of Fuel Assemblies:					
	<ul> <li>A. Incore (prior to current refueling outage</li> <li>B. In Spent Fuel Storage (prior to RF06)</li> <li>C. In Spent Fuel Storage (after RF06)</li> </ul>	)		$\frac{764}{1240}$ 1472		
8.	Present licensed spent fuel storage capacity: Future spent fuel storage capacity:			<u>4006</u> 4006		
9.	Date of last refueling that can be discharged to spent fuel pool assuming the present licen		city:	<u>5/3/2006</u> (EOC13)		
	(Does allow for full-core off- (Assumes 244 bundle reloads every 18 m (Does not allow for smaller reloads due t	nonths un				

#### MONTHLY OPERATING SUMMARY

#### MONTH MARCH 1996

The Hope Creek Generating Station commenced start up after the Sixth Refueling Outage at 0627 hours on March 18, 1996 when the operators moved the mode switch to "start up." Criticality was achieved at 1350 hours on March 18, 1996. The initial synchronization of the unit was at 0141 hours on March 25, 1996. At 1025 hours the generator was removed from service and the post-outage overspeed test was successfully performed. At 1219 hours on March 25, 1996 the unit was resynchronized and power ascension resumed. The outage was officially ended when 100% power was achieved at 2220 hours on March 29, 1996. This resulted in unplanned off-line energy losses of 471398.7 MWHRS (96-04) for the outage extension, planned off-line energy losses of 174161.2 MWHRS (96-05) for the start-up, and planned on-line losses of 77460.1 MWHRS (96-06) for the power ascension.

A stuck TIP probe, rod adjustments, and weekly turbine valve surveillances occurred between 0805 hours on March 30, 1996 and 1318 hours on March 31, 1996. These activities caused 2187.2 MWHRS of unplanned energy losses (96-08) and 150 MWHRS of planned energy losses for the surveillance (96-07).

On March 31, 1996 between 1630 hours and 1800 hours power was reduced to remove 6C Feedwater Heater from service for maintenance. This resulted in 39.1 MWHRS of unplanned losses. (96-09)

As of March 31, 1996 the unit had been on-line for seven days.

### SUMMARY OF CHANGES, TESTS, AND EXPERIMENTS FOR THE HOPE CREEK GENERATING STATION

#### MONTH MARCH 1996

• There will be no summaries of changes to the plant submitted this month. Starting with next month's report, summaries of changes will be reported with a one month delay (e.g. Changes made in March 1996 will be reported with the April operating data.)