

APPENDIX A
NOTICE OF VIOLATION

Gulf States Utilities
River Bend Station

Docket: 50-458/84-34
Permit: CPPR-145

Based on the results of an NRC inspection conducted during the period of November 1 through December 31, 1984, and in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C, 49 FR 8587, Dated March 8, 1984), the following violation was identified:

Failure to Follow Preoperational Test Procedure

10 CFR Part 50, Appendix B, Criterion V, and the licensee's approved quality assurance program require that activities affecting the quality of safety-related systems and components be conducted in accordance with approved instructions, procedures, and drawings.

The Preoperational Test Procedure, 1-PT-309-2, Revision 1, for the Standby Diesel Generator, a safety and a quality-related component, required, in part, the following:

- o That the "READY TO LOAD" condition be verified (Section 7.12.3.1.C).
- o That the generator be paralleled to IENS*SWG1B and loaded to 1740 KW in accordance with Procedure IOI 302.2 (Section 7.12.15).

Contrary to the above, during the conduct of Preoperational Test Procedure 1-PT-309-2, Revision 1, Section 7.12.3.1.C was signed off as completed without verification of the "READY TO LOAD" condition and with the "READY TO LOAD" light deenergized and without Procedure IOI 302.2 available to the operator (at the test location) who was responsible for paralleling and loading the Standby Diesel Generator.

This is a Severity Level IV Violation. (Supplement II D) (458-8434-02)

Pursuant to the provisions of 10 CFR 2.201, Gulf States Utilities is hereby required to submit to this office, within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Dated: JAN 28 1985

8502050232 850128
PDR ADOCK 05000458
G PDR