

July 9, 1992

Docket File

Docket No. 50-322

Mr. Leslie Hill
Resident Manager
Long Island Power Authority
Shoreham Nuclear Power Station
Post Office Box 628
North Country Road
Wading River, New York 11792

Dear Mr. Hill:

SUBJECT: CLARIFICATION OF CHANGE - CONTROL OF HEAVY LOADS
SHOREHAM NUCLEAR POWER STATION LSNRC-1970

We have reviewed your commitment related to heavy loads as provided in LIPA's (S. Klimberg) letter LSNRC-1874 dated December 6, 1991, your Defueled Technical Specifications (DTS) "Crane Travel" 3/4.5.3, and your letter (L. Hill) LSNRC-1970 dated July 1, 1992, and conclude that Shoreham's DTS control movement of heavy loads over the Spent Fuel Storage Pool (SFSP).

Therefore, changes to the Decommissioning Plan that involve DTS would require a license amendment. Based on the staff's analysis documented in the staff's Safety Evaluation Report (SER) and Environmental Assessment (EA), the removal for disposal of components stored in the SFSP are within the scope of the Decommissioning Plan as long as the movements of loads over the SFSP are conducted in accordance with existing DTS requirements.

Should you have any questions you can call Larry Bell, NMSS/LLDR at (301) 504-2171.

Sincerely,
Original signed by:
Stewart W. Brown, Project Manager
Non-Power Reactors, Decommissioning and
Environmental Project Directorate
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

cc: See next page

[CSFSP.SB]

DISTRIBUTION:

Docket File
NRC & Local PDRs
PDNP R/F
BBoger
Sweiss
EHylton

RDudley *L. Bell, NMSS*
SBrown
OGS
ACRS (10)
Region I
[deh], RI

PDNP: CA
EHylton
07/9/92

PDNP: PM
SBrown: lb
07/9/92

PDNP: SC
RDudley
07/9/92

PDNP: D
Sweiss
07/9/92

NRC FILE CENTER COPY

9207160389 920709
PDR ADOCK 05000323
W PDR

*DFOL
110*



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

July 9, 1992

Docket No. 50-322

Mr. Leslie Hill
Resident Manager
Long Island Power Authority
Shoreham Nuclear Power Station
Post Office Box 628
North Country Road
Wading River, New York 11792

Dear Mr. Hill:

SUBJECT: CLARIFICATION OF CHANGE - CONTROL OF HEAVY LOADS
SHOREHAM NUCLEAR POWER STATION LSNRC-1970

We have reviewed your commitment related to heavy loads as provided in LIPA's (S. Klimberg) letter LSNRC-1874 dated December 6, 1991, your Defueled Technical Specifications (DTS) "Crane Travel" 3/4.5.3, and your letter (L. Hill) LSNRC-1970 dated July 1, 1992, and conclude that Shoreham's DTS control movement of heavy loads over the Spent Fuel Storage Pool (SFSP).

Therefore, changes to the Decommissioning Plan that involve DTS would require a license amendment. Based on the staff's analysis documented in the staff's Safety Evaluation Report (SER) and Environmental Assessment (EA), the removal for disposal of components stored in the SFSP are within the scope of the Decommissioning Plan as long as the movements of loads over the SFSP are conducted in accordance with existing DTS requirements.

Should you have any questions you can call Larry Bell, NMSS/LLDR at (301) 504-2171.

Sincerely,

A handwritten signature in cursive script that reads "Stewart W. Brown".

Stewart W. Brown, Project Manager
Non-Power Reactors, Decommissioning and
Environmental Project Directorate
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

cc: See next page

Mr. Leslie M. Hill

Shoreham Nuclear Power Station
Long Island Power Authority
Docket No. 50-322

cc:

Mr. Stanley B. Klimberg
President of Shoreham Project
and General Counsel
Long Island Power Authority
200 Garden City Plaza
Garden City, New York 11530

Mr. Richard M. Kessel
Chairman & Executive Director
New York State Consumer Protection
Board
250 Broadway
New York, New York 10007

Herbert M. Leiman, Esq.
Assistant General Counsel
Long Island Lighting Company
175 East Old County Road
Hicksville, New York 11801

Ms. Donna Ross
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

W. Taylor Reveley, III, Esq.
Hunton & Williams
Riverfront Plaza, East Tower
951 East Byrd Street
Richmond, Virginia 23219-4074

Nicholas S. Reynolds, Esq.
David A. Repka, Esq.
Winston & Strawn
1400 L Street, N.W.
Washington, D.C. 20005

Mr. Stephen Schoenwiesner
Shoreham Nuclear Power Station
P. O. Box 628
Wading River, New York 11792

Commissioner James T. McFarland
New York Public Service Commission
814 Ellicott Building
295 Main Street
Buffalo, New York 14203

Mr. John D. Leonard, Jr.
Vice President Office of Nuclear
Long Island Lighting Company
Shoreham Nuclear Power Station
P. O. Box 628
Wading River, New York 11792

Gerald C. Goldstein, Esq.
Office of General Counsel
New York Power Authority
1633 Broadway
New York, New York 10019

Mr. Barry S. Norris
Project Inspector (Shoreham)
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Carl R. Schenker, Jr., Esq.
O'Melveny & Myers
555 13th Street, N.W.
Washington, D.C. 20004

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Mr. John C. Brons, President
New York Power Authority
123 Main Street
White Plains, New York 10601

July 9, 1992

Docket Nu. 50-322

Mr. Leslie Hill
Resident Manager
Long Island Power Authority
Shoreham Nuclear Power Station
Post Office Box 628
North Country Road
Wading River, New York 11792

Dear Mr. Hill:

SUBJECT: CLARIFICATION OF CHANGE - CONTROL OF HEAVY LOADS
SHOREHAM NUCLEAR POWER STATION LSNRC-1970

We have reviewed your commitment related to heavy loads as provided in LIPA's (S. Klimberg) letter LSNRC-1874 dated December 6, 1991, your Defueled Technical Specifications (DTS) "Crane Travel" 3/4.5.3, and your letter (L. Hill) LSNRC-1970 dated July 1, 1992, and conclude that Shoreham's DTS control movement of heavy loads over the Spent Fuel Storage Pool (SFSP).

Therefore, changes to the Decommissioning Plan that involve DTS would require a license amendment. Based on the staff's analysis documented in the staff's Safety Evaluation Report (SER) and Environmental Assessment (EA), the removal for disposal of components stored in the SFSP are within the scope of the Decommissioning Plan as long as the movements of loads over the SFSP are conducted in accordance with existing DTS requirements.

Should you have any questions you can call Larry Bell, NMSS/LLDR at (301) 504-2171.

Sincerely,
Original signed by:
Stewart W. Brown, Project Manager
Non-Power Reactors, Decommissioning and
Environmental Project Directorate
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

cc: See next page

[CSFSP.SB]

DISTRIBUTION:

Docket File
NRC & Local PDRs
PDNP R/F
BBoger
SWeiss
EHylton

RDudley
SBrown
OGS
ACRS (10)
Region I
CHEhl, RI

L. Bell, NMSS

PDNP: CA
EHylton
07/9/92

PDNP: EM
SBrown: lb
07/9/92

PDNP: SC
RDudley
07/9/92

PDNP: D
SWeiss
07/9/92

Sfw