



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401-1927
Telephone (612) 330-5500

July 13, 1992

10 CFR Part 50, Appendix E

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
Docket Nos. 50-282 License Nos. DPR-42
50-306 DPR-60

Revision to Emergency Response Data System Data Point Library

Revisions to the Data Point Libraries for the implementation of the Emergency Response Data System at Prairie Island are attached. These revisions to the Prairie Island Emergency Response Data System Data Point Libraries clarify problem areas identified by the NRC Staff during their review of the original Data Point Libraries transmitted to the NRC by our letter dated October 28, 1991. The following changes were incorporated into the Prairie Island Emergency Response Data System Data Point Libraries by the attached revisions:

1. The following Data Point Library data points were clarified:

- Point ID 1U5011A - Reactor Vessel Level
- Point ID 1U5007A - Pressurizer Level
- Point ID 1U5153A - Containment Sump Narrow Range Level
- Point ID 1U5017A - Containment Sump Wide Range Level
- Point ID 1D5026A - Steam Generator Blowdown Radiation
- Point ID 1D5068A - Refueling Water Storage Tank Level
- Point ID 1D4109A - Wind Direction

2. The Data Point Library high and low range headings were corrected.

Please contact us if you have any questions with respect to the attached information.

Eugene Eckholt

for
Thomas M Parker
Manager
Nuclear Support Services

c: Regional Administrator - Region III, NRC
Senior Resident Inspector, NRC
NRR Project Manager, NRC
J E Silberg

Attachments: 1. Revision 1 to Prairie Island Unit 1 Emergency Response Data System Data Point Library

2. Revision 1 to Prairie Island Unit 2 Emergency Response Data System Data Point Library

9207170044 920713
PDR ADOCK 05000282
F PDR

AD24

ATTACHMENT 1

REVISION 1 TO

PRAIRIE ISLAND UNIT 1

EMERGENCY RESPONSE DATA SYSTEM

DATA POINT LIBRARY

Heading definitions used in this report are:

PID = Point ID.
 EU = Engineering units.
 P/S = PROC or SENS. (Processed or sensor value)
 #SNSR = Number of sensors.
 Anlg/Dig = Analog or digital point type.
 Process = How processed.
 CV-AVG = Chauvenet Validated Average of.
 QV = Quality validation against constants.
 Location = Sensor location.
 HI RANGE = Instrument highest range.
 LO RANGE = Instrument lowest range.
 ZERO REF = Zero reference point.

Other notes:

The data fields NI power supply cut off and turn on levels are not provided because the power supplies are not cut off.

 Temperature compensation for DP transmitters is mentioned in the unique system description if applicable. Else the answer is no.

 Level reference leg only applies to SG LEVEL 1/A & 2/B.
 See unique system description for these two points.

 ERCS is the Emergency Response Computer System at the plant & is the feeder for all of the data used by ERDS.

***** ERDS DPL SUMMARY *****

#	PID	NRC PARAMETER	ERCS POINT DESCRIPTION	#	PID	NRC PARAMETER	ERCS POINT DESCRIPTION	#	PID	NRC PARAMETER	ERCS POINT DESCRIPTION
1	1U5048A	NI POWER RNG	SAS avg pwr rng pwr level	16	1U5049A	HL TEMP 1/A	SAS hot leg 1 Temperature	31	1U5022A	CNTMNT RAD	SAS High CNTMT radiation
2	1U5082A	NI INTER RNG	Avg intermed rng power level	17	1U5051A	HL TEMP 2/B	SAS hot leg 2 Temperature	32	1R0009A	RCS LTDN RAD	RC letdown line radiation
3	1U5081A	NI SOURC RNG	Avg srce rng pwr level	18	1U5053A	CL TEMP 1/A	SAS cold leg 1 Temperature	33	1U5143A	MAIN SL 1/A	SAS main steamline A rad'n
4	1U5011A	REAC VES LEV	SAS avg reactor vessel level	19	1U5055A	CL TEMP 2/B	SAS cold leg 2 Temperature	34	1U5144A	MAIN SL 2/B	SAS main steamline B rad'n
5	1U5510A	TEMP CORE EX	SAS 1st hottest incore T/C	20	1U5001A	RCS PRESSURE	SAS avg RCS pressure	35	1U5026A	SG BD RAD	SAS stm gen blowdown rad'n
6	1U5077A	SUB MARGIN	SAS RCS subcooling margin	21	1U5007A	PRZR LEVEL	SAS avg PRZR H2O lvl (NR)	36	1U5015A	CNTMNT PRESS	SAS avg containment press
7	1U5152A	CORE FLOW	RC avg flow	22	1F0128A	RCS CHG/MU	Charge pmp disch hdr flow	37	1U5013A	CNTMNT TEMP	SAS avg containment temp
8	1U5032A	SG LEVEL 1/A	SAS avg stm gen 1 H2O level	23	1U5154A	HP SI FLOW	Total safety injection flow	38	1U5021A	H2 CONC	SAS avg containment H2 conc
9	1U5034A	SG LEVEL 2/B	SAS avg stm gen 2 H2O level	24	1U0651A	LP SI FLOW	Total RHR flow	39	1U5068A	BWST LEVEL	SAS avg RWST level
10	1U5036A	SG PRESS 1/A	SAS avg stm gen 1 presure	25	1U5153A	CTMNT SMP NR	Sump B avg level NR	40	1U4105A	WIND SPEED	Met twr 10M avg wind spd A
11	1U5038A	SG PRESS 2/B	SAS avg stm gen 2 presure	26	1U5017A	CTMNT SMP WR	SAS avg contnment sump lvl	41	1U4106A	WIND SPEED	Met twr 10M avg wind spd B
12	1U5040A	MN FD FL 1/A	SAS avg stm gen1 feed flow	26	1U5061AL	EFF GAS RAD	Shld bld gas efflnt low rng	42	1Y4109A	WIND DIR	Met twr 10M wind dir A
13	1U5042A	MN FD FL 2/B	SAS avg stm gen2 feed flow	28	1U5062AH	EFF GAS RAD	Shld bld gas efflnt hi rng	43	1Y4110A	WIND DIR	Met twr 10M wind dir B
14	1U5044A	AX FD FL 1/A	SAS avg stm gen1 aux fd fl	29	1R0021A	EFF LIQ RAD	Circ wtr disch rad mnt'r	44	1U2907A	STAB CLASS	Met twr 50M avg delta temp A
15	1U5045A	AX FD FL 2/B	SAS avg stm gen2 aux fd fl	30	1U5024A	COND A/E RAD	SAS air ejector radiation	45	1U2908A	STAB CLASS	Met twr 50M avg delta temp B

PiD	NRC ERDS PARAMETER	EU	ANLG/DIG	Lo, Hi		CONVERSION	Unique system description
				LO RANGE	ALRM/TRIP		
FEEDER	ERCS POINT DESCRIPTION	P/S	PROCESS	FAIL MODE		DP TEMP COMP	
DATE	GENERIC/COND DESCRIPTION	#SNSR	LOCATION				
1U5048A	NI POWER RNG	X	Analog	0.0	N/A	N/A	This point reflects the CV-AVG of N41, N42, N43 & N44 power range reactor power level sensors.
ERCS #1	SAS avg pwr rng pwr level	P	CV-AVG	120.0	N/A	N/A	
07/02/91	Avg power range pwr level	4	Excore	LOW		N/A	
1U5082A	NI INTER RNG	MCAMP	Analog	1.0E-5	N/A	N/A	This point reflects the CV-AVG of 35B & 36B neutron flux intermediate range level sensors. Note: MCAMP EU = micro-amps.
ERCS #1	Avg intermed rng power level	P	CV-AVG	1.0E03	N/A	N/A	
10/16/91	Avg intermed range pwr level	2	Excore	LOW		N/A	
1U5081A	NI SOURC RNG	CPS	Analog	0.1	N/A	N/A	This point reflects the CV-AVG of 31E & 32F neutron flux source range level. The power supply does not shut off for these sensors.
ERCS #1	Avg srce rng pwr	P	CV-AVG	1.0E6	N/A	N/A	
10/16/91	Avg source range pwr level	2	Excore	LOW		N/A	
1U5011A	REAC VES LEV	X	Analog	0.0	0.0	4.4 Inch/X	This point reflects the CV-AVG of the reactor vessel level based on reactor coolant pump operation. If RCPs are off then wide range RVLIS sensors are used. Else, dynamic head RVLIS sensors are used. RVLIS is Westinghouse reactor vessel level indication system. Note: DP temp compensation is provided in the RVLIS computer which supplies this value to the ERCS computer. Note: Top of fuel = 56.7%. Bottom of fuel = 24%.
ERCS #1	SAS avg reactor vessel level	P	CV-AVG	120.0	120.0	FROM RVLIS	
07/02/91	Avg reactor vessel level	4	Contrmnt	Failed			
1U5510A	TEMP CORE EX	DegF	Analog	32.0	N/A	N/A	This point reflects the CV-AVG hottest reactor incore thermocouple. Note: T/C = thermocouple.
ERCS #1	SAS 1st hottest incore T/C	P	CV AVG	2300.0	N/A	N/A	
07/02/91		36	Incore	Failed		N/A	
1U5077A	SUB MARGIN	DegF	Analog	-200.0	N/A	N/A	This point reflects the result of a two term linear equation using RCS saturation temperature (Temp. saturated vapor as a function of pressure based on the 1967 ASME steam tables) and avg core exit temp (CV-AVG of the incore thermocouples).
ERCS #1	SAS RCS subcooling margin	P	See note	1000.0	N/A	N/A	
07/02/91	RCS subcooling margin	3		Failed		N/A	
1U5152A	CORE FLOW	X	Analog	0.0	N/A	N/A	This point reflects the CV-AVG of these 6 flow values: (A-RC 411, PID=F0400A), (A-RC 412, PID=F0401A), (A-RC 413, PID=F0402A), (B-RC 414, PID=F0420A), (B-RC 415, PID=F0421A), (B-RC 416, PID=F0422A)
ERCS #1	RC avg flow	P	CV-AVG	115.0	N/A	N/A	
07/17/91		6		Failed		N/A	

PID	NRC ERDS PARAMETER	EU	ANLG/DIG	Lo/Hi		CONVERSION	Unique system description
				LO RANGE	HI RANGE		
FEEDER	ERCS POINT DESCRIPTION	P/S	PROCESS	ALRM/TRIP	SET-POINT	ZERO REF	
DATE	GENERIC/COND DESCRIPTION	#SNSR	LOCATION	FAIL	MCDE	DP TEMP COMP	
1U5032A	SG LEVEL 1/A	%	Analog	0.0	20.0	1%180gal @STP	*1=Sensor located 433" above the tube sheet. NR sensors cover a span of 144"
ERCS #1	SAS avg stm gen 1 H2O level	P	CV-AVG	100.0	67.0	Note *2	*2=Zero reference 23" above tube bundle, 420" = top of tube bundle.
07/02/91	Avg stm gen 1 H2O level	3	Note *1	Failed		Note *5	*3=This point reflects CV-AVG of loop A stm gen level (NR461, NR462 & NR463) *4=level reference leg=yes, water filled with condenser pot. *5=DP temp compensation not used.
1U5034A	SG LEVEL 2/B	%	Analog	0.0	20.0	1%180gal @STP	*1=Sensor located 433" above the tube sheet. NR sensors cover a span of 144"
ERCS #1	SAS avg stm gen 2 H2O lev	P	CV-AVG	100.0	67.0	Note *2	*2=Zero reference 23" above tube bundle, 420" = top of tube bundle.
07/05/91	Avg stm gen 2 H2O level	3	Note *1	Failed		N/A	*3=This point reflects CV-AVG of loop B stm gen level (NR471, NR472 & NR473) *4=level reference leg=yes, water filled with condenser pot.
1U5036A	SG PRESS 1/A	PSIG	Analog	0.0	500.0		N/A CV-AVG of loop A stm gen pressure (468, 469, 482).
ERCS #1	SAS avg stm gen 1 presure	P	CV-AVG	1400.0	1075.0		N/A
07/05/91	Avg stm gen 1 pressure	3		Failed			N/A
1U5038A	SG PRESS 2/B	PSIG	Analog	0.0	500.0		N/A CV-AVG of loop B stm gen pressure (478, 479, 483).
ERCS #1	SAS avg stm gen 2 presure	P	CV-AVG	1400.0	1075.0		N/A
07/05/91	Avg stm gen 2 pressure	3		Failed			N/A
1U5040A	MN FD FL 1/A	Lb/Hr	Analog	0.0	N/A		N/A CV-AVG of loop A fw flow 466(xmtr) & 467(xmtr).
ERCS #1	SAS avg stm gen1 feed flow	P	CV-AVG	4470000	N/A		N/A *1=DP comp not used.
07/05/91	Avg steam gen 1 feed flow	2		Failed		Note *1	
1U5042A	MN FD FL 2/B	Lb/Hr	Analog	0.0	N/A		N/A CV-AVG of loop B fw flow 476(xmtr) & 477(xmtr).
ERCS #1	SAS avg stm gen2 feed flow	P	CV-AVG	4470000	N/A		N/A *1=DP comp not used.
07/05/91	Avg stm gen 2 feed flow	2		Failed			N/A
1U5044A	AX FD FL 1/A	GPM	Analog	0.0	N/A		N/A This point reflects the quality validation of AFW flow to A steam generator
ERCS #1	SAS avg stm gen1 aux fd fl	P	QV	200.0	N/A		N/A against the SAS constants of steam aux feed flow Lo EU & Hi EU. The
07/05/91	Stm gen 1 aux feed flow	1		Failed			N/A constants are currently set at 0.0 and 200.0. *1=DP comp not used.
1U5045A	AX FD FL 2/B	GPM	Analog	0.0	N/A		N/A This point reflects the quality validation of AFW flow to B steam generator
ERCS #1	SAS avg stm gen2 aux fd fl	P	QV	200.0	N/A		N/A against the SAS constants of steam aux feed flow Lo EU & Hi EU. The
07/05/91	stm gen 2 aux feed flow	1		Failed			N/A constants are currently set at 0.0 and 200.0. *1=DP comp not used.

PID	NRC ERDS PARAMETER	EU	ANLG/DIG	Lo/Hi		CONVERSION	Unique system description
				LO RANGE	ALRM/TRIP		
FEEDER	ERCS POINT DESCRIPTION	P/S	PROCESS	HI RANGE	SET-POINT	ZERO REF	
DATE	GENERIC/COND DESCRIPTION	#SHSR	LOCATION	FAIL MGDE		DP TEMP COMP	
1U5049A	HL TEMP 1/A	DegF	Analog	50.0	N/A	N/A	This point reflects the quality validation of A-RC hot leg temp 450A against the SAS constants of hot leg temp Lo EU and Hi EU. The constants are currently set at 50.0 and 700.0.
ERCS #1	SAS hot leg 1 Temperature	P	QV	700.0	N/A	N/A	
07/05/91	Hot leg 1 temperature	1		Failed		N/A	
1U5051A	HL TEMP 2/B	DegF	Analog	50.0	N/A	N/A	This point reflects the quality validation of B-RC hot leg temp 451A against the SAS constants of hot leg temp Lo EU and Hi EU. The constants are currently set at 50.0 and 700.0.
ERCS #1	SAS hot leg 2 Temperature	P	QV	700.0	N/A	N/A	
07/05/91	Hot leg 2 temperature	1		Failed		N/A	
1U5053A	CL TEMP 1/A	DegF	Analog	50.0	@FP 520	N/A	This point reflects the quality validation of A-RC cold leg temp 450B against the SAS constants of cold leg temp Lo EU and Hi EU. The constants are currently set at 50.0 and 700.0. Note: Alarm setpoints are at full power. In other modes, setpoints are calculated based on system pressure.
ERCS #1	SAS cold leg 1 Temperature	P	QV	700.0	@FP 555	N/A	
07/05/91	Cold leg 1 temperature	1		Failed		N/A	
1U5055A	CL TEMP 2/B	DegF	Analog	50.0	@FP 520	N/A	This point reflects the quality validation of B-RC cold leg temp 451B against the SAS constants of cold leg temp Lo EU and Hi EU. The constants are currently set at 50.0 and 700.0. Note: Alarm setpoints are at full power. In other modes, setpoints are calculated based on system pressure.
ERCS #1	SAS cold leg 2 Temperature	P	QV	700.0	@FP 555	N/A	
07/05/91	Cold leg 2 temperature	1		Failed		N/A	
1U5001A	RCS PRESSURE	PSIG	Analog	0.0	@FP 1900	N/A	CV-AVG of the 4 narrow range pressure sensors. If the validated quality of the sensors is bad, then use CV-AVG of 2 wide range pressure sensors. Note: At other than full power mode, SAS calculates Hi and Lo alarm limits.
ERCS #1	SAS avg RCS pressure	P	CV-AVG	3000.0	@FP 2385	N/A	
07/06/91	Avg RCS pressure	6				N/A	
1U5007A	PRZR LEVEL	%	Analog	0.0	14.8	64.6 Gal/%	This point represents the CV-AVG of PRZR 426, 427 & 428 level sensors. Note *1: DP comp not used. Note *1: Note: Zero % level is 18" above top of fuel.
ERCS #1	SAS avg PRZR H2O lvl (NR)	P	CV-AVG	100.0	90.0	527 Gal @zero	
07/06/91	Avg pressurizer H2O level	3		Failed			
1F0128A	RCS CHG/MJ	Gpm	Analog	0.0	N/A	N/A	Sensor located 20 feet above discharge pump.
ERCS #1	Charge pmp disch hdr flow	S		100.0	N/A	N/A	
07/06/91		1	note	Low		N/A	

PID	NRC ERDS PARAMETER	EU	ANLG/DIG	Lo/Hi		CONVERSION	Unique system description
				LO RANGE	ALRM/TRIP		
FEEDER	ERCS POINT DESCRIPTION	P/S	PROCESS	HI RANGE	SET-POINT	ZERO REF	
DATE	GENERIC/COND DESCRIPTION	#SNSR	LOCATION	FAIL MODE		DP TEMP COMP	
1U5154A	HP SI FLOW	Gpm	Analog	0.0	NONE	N/A	Sum of PID->(1F0922A SI flow to cold legs) & (1F0923A SI flow to rx val)
ERCS #1	Total safety injection flow	P		1500.0	NONE	N/A	
10/09/91		2				N/A	
1U0651A	LP SI FLOW	Gpm	Analog	-1.0	1250.0	N/A	Sum of PID->(1F0626a RHR loop flow) & (1F0928A RHR flow to val)
ERCS #1	Total RHR flow	P		9000.0	2500.0	N/A	
10/09/91		2				N/A	
1U5153A	CTMNT SMP NR (narrow rng)	%	Analog	0.0	N/A	14.7 gal/%	Average of 2 values (sump B 725 PID=F0922A) & (sump B 726 PID=F0923A) NR (narrow range) levels. Sump area = 42 sq ft. Depth=47". Conversion = 14.7 gal / % up to 84%. Above 48% conversion = 1903 gal / %.
ERCS #1	Sump B avg level NR	P	CV-AVG	100.0	N/A	zero	
07/17/91		2		Failed		N/A	
1U5017A	CTMNT SMP WR (wide range)	%	Analog	0.0	0.0	4685 gal/%	This point reflects the CV-AVG of containment levels 727 WR & 728 WR. Range in ft = 0 to 11.5 (100%). Containment area = 5446 sq ft. Conversion factor is 40,741 gal/ft or 4685 gal/%. Accuracy is +/- 17.2% due to complexities.
ERCS #1	SAS avg contnment sump lvl	P	CV-AVG	120.0	0.5	0.0 Ft	
07/06/91	Avg containment sump level	2		Failed		N/A	
1U5061AL	EFF GAS RAD	MCI/HR	Analog	5.3E-3		N/A	This point is the shield bldg stack effluent radiation in milli-curries/hr xenon 133 equivalent. Computed using (1R0022A mr/hr * 5.26E-04) / 1F5429A. 1F5429A is stack flow rate in CFM. 1R0022A is low range rad monitor.
ERCS #1	stack effl radn low rng	P		526		N/A	
10/10/91		2				N/A	
1U5061AH	EFF GAS RAD	MCI/HR	Analog	5.3E-5		N/A	This point is the shield bldg stack effluent radiation in milli-curries/hr xenon 133 equivalent. Computed using (1R0050A mr/hr * 52.674) / 1F5429A. 1F5429A is stack flow rate in CFM. 1R0050A is hi range rad monitor.
ERCS #1	stack effl radn high rng	P		5260		N/A	
10/10/91		2				N/A	
1R0021A	EFF L10 RAD	CPM	Analog	10.0	N/A	N/A	
ERCS #1	Circ wtr disch r	S		1000000	1000.0	N/A	
10/10/91		1				N/A	
1U5024A	COND A/E RAD	CPM	Analog	10.0	10.0	N/A	This point reflects the quality validation of CDSR air ejector gas radioactivity against the SAS constants of air ejector radiation which are currently set at 10 and 1,000,000.
ERCS #1	SAS air ejector radiation	P	QV	1.0 E6	5000.0	N/A	
07/06/91	Air ejector radiation	1		Failed		N/A	
1U5022A	CNTMNT RAD	R/HR	Analog	1.0	1.0	N/A	This point reflects the CV-AVG of high range CNTMT area monitor or high range CNTMT area monitor A or high range CNTMT area monitor B.
ERCS #1	SAS High CNTMT radiation	P	CV-AVG	1.0 E08	2.0 E4	N/A	
07/06/91	High Containment radiation	2		Failed		N/A	

PID	NRC ERDS PARAMETER	EU	ANLG/DIG	Lo/Hi		CONVERSION	Unique system description
				LO RANGE	ALRM/TRIP		
FEEDER	ERCS POINT DESCRIPTION	P/S	PROCESS	HI RANGE	SET-POINT	ZERO REF	
DATE	GENFRIC/COND DESCRIPTION	#SNSR	LOCATION	FAIL MODE		DP TEMP COMP	
1R0009A	RCS LTDN RAD	MR/Hr	Analog	0.1	N/A	N/A	
ERCS #1	RC letdown line radiation	S		10000.0	1000.0	N/A	
07/06/91		1		Failed		N/A	
1U5143A	MAIN SL 1/A	MR/Hr	Analog	1.0	N/A	N/A	This point reflects the quality validation of A stm line rad level against
ERCS #1	SAS main steamline A rad'n	P	RV	1.0 E5	N/A	N/A	the SAS constants of main steamline radiation Lo EU & Hi EU which are set at
07/06/91	Main steamline A radiation	1		Failed		N/A	1 & 100000.
1U5144A	MAIN SL 2/B	MR/Hr	Analog	1.0	N/A	N/A	This point reflects the quality validation of B stm line rad level against
ERCS #1	SAS main steamline B rad'n	P	RV	1.0 E5	N/A	N/A	the SAS constants of main steamline radiation Lo EU & Hi EU which are set at
07/06/91	Main steamline B radiation	1		Failed		N/A	1 & 100000.
1U5026A	SG BD RAD	CPM	Analog	10.0	10.0	N/A	This point reflects the quality validation of steam gen blowdown radiation
ERCS #1	SAS stm gen blowdown rad'n	P	RV	1.0 E4	1.0 E4	N/A	against the SAS constants of steam gen blowdown radiation Lo EU & Hi EU which
07/06/91	Stm gen blowdown radiation	1		Failed		N/A	are currently set at 10 & 1,000,000. Note: includes both SGs A and B.
1U5015A	CNTMNT PRESS	PSIG	Analog	-5.0	-5.0	N/A	This point reflects the CV-AVG of containment pressure MR 717 & 718 sensors.
ERCS #1	SAS avg containment press	P	CV-AVG	200.0	4.0	N/A	
07/06/91	Avg containment pressure	2		Failed		N/A	
1U5013A	CNTMNT TEMP	DegF	Analog	0.0	N/A	N/A	*1-High alarm is 10 DegF greater than rolling 5 min avg of containment temp.
ERCS #1	SAS avg containment temp	P	Mov AVG	400.0	note *1	N/A	This point reflects the CV-AVG of containment air temp elevation 697 and 738
07/06/91	Avg containment temp	3		Failed		N/A	and 755 sensors.
1U5021A	H2 CONC (concentration)	%	Analog	0.0	N/A	N/A	This point reflects the CV-AVG of containment H2 concentration sensors 719 &
ERCS #1	SAS avg containment H2 conc	P	CV-AVG	10.0	N/A	N/A	721.
07/06/91	Avg containment H2 concntrn	2		Failed		N/A	
1U5068A	BWST LEVEL	%	Analog	0.0	N/A	2522 Gal/%	This point reflects the CV-AVG of RWST (refueling water storage tank) level
ERCS #1	SAS avg RWST level	P	CV-AVG	100.0	N/A	1898 Gal	sensors 920 and 921.
07/06/91	Avg RWST level	2		Failed		N/A	
1U4105A	WIND SPEED	MPH	Analog	0.0	N/A	N/A	Sensor location = meteorological tower A 10 meter height.
ERCS #1	Met twr 10M avg wind spd A	P	none	100.0	N/A	N/A	15 minute moving average of 30sec readings.
10/16/91		1	10 meter	Failed		N/A	

PID	NRC ERDS PARAMETER	EU	ANLG/DIG	LO RANGE	Lo/Hi		CONVERSION	Unique system description
					ALRM/TRIP	SET-POINT		
FEEDER	ERCS POINT DESCRIPTION	P/S	PROCESS	HI RANGE			ZERO REF	
DATE	GENERIC/COND DESCRIPTION	#SNSR	LOCATION	FAIL MODE			DP TEMP COMP	
1U4106A	WIND SPEED	MPH	Analog	0.0	N/A		N/A	Sensor location = meteorological tower B 10 meter height.
ERCS #1	Met twr 10M avg wind spd B	P	none	100.0	N/A		N/A	15 minute moving average of 30sec readings.
10/16/91		1	10 meter	Failed			N/A	
1Y4109A	WIND DIR	Deg	Analog	0.0	N/A		N/A	Sensor location = meteorological tower A 10 meter height.
ERCS #1	Pri met twr 10M wind dir A	S		360.0	N/A		N/A	Instantaneous values updated in 30 sec intervals.
07/09/91		1	10 meter	Failed			N/A	Indication is in the from direction.
1Y4110A	WIND DIR	Deg	Analog	0.0	N/A		N/A	Sensor location = meteorological tower A 10 meter height.
ERCS #1	Pri met twr 10M wind dir B	S		540.0	N/A		N/A	Instantaneous values updated in 30 sec intervals.
07/09/91		1	10 meter	Failed			N/A	Indication is in the from direction.
1U2907A	STAB CLASS	DF/100	Analog	-7.0	N/A		N/A	Sensor location = meteorological tower 10 & 60 meter height.
ERCS #1	Met twr avg delta temp A	°	Diff	9.0	N/A		N/A	This value represents the difference in temperature in degF/100Ft.
10/16/91		2	10 & 60 M.	Failed			N/A	
1U2908A	STAB CLASS	DF/100	Analog	-9.0	N/A		N/A	Sensor location = meteorological tower 10 & 60 meter height.
ERCS #1	Met twr avg delta temp B	°	Diff	9.0	N/A		N/A	This value represents the difference in temperature in degF/100Ft.
10/16/91		2	10 & 60 M.	Failed			N/A	

ATTACHMENT 2

REVISION 1 TO

PRAIRIE ISLAND UNIT 2

EMERGENCY RESPONSE DATA SYSTEM

DATA POINT LIBRARY

Heading definitions used in this report are:		Other notes:
PID	= Point ID.	The data fields NI power supply cut off and turn on levels are not provided because the power supplies are not cut off.
EU	= Engineering units.	
P/S	= PROC or SENS. (Processed or sensor value)	Temperature compensation for DP transmitters is mentioned in the unique system description if applicable. Else the answer is no.
#SNSR	= Number of sensors.	
Analog/Dig	= Analog or digital point type.	Level reference leg only applies to SG LEVEL 1/A & 2/B. See unique system description for these two points.
P	= How processed.	
	CV-AVG = Chauvenet Validated Average of.	ERCS is the Emergency Response Computer System at the plant & is the feeder for all of the data used by ERDS.
	QV = Quality validation against constants.	
Location	= Sensor location.	
HI RANGE	= Instrument highest range.	
LO RANGE	= Instrument lowest range.	
ZERO REF	= Zero reference point.	

***** ERDS DPL SUMMARY *****

#	PID	NRC PARAMETER	ERCS POINT DESCRIPTION	#	PID	NRC PARAMETER	ERCS POINT DESCRIPTION	#	PID	NRC PARAMETER	ERCS POINT DESCRIPTION
1	2U5048A	NI POWER RNG	SAS avg pwr rng pwr level	16	2U5049A	HL TEMP 1/A	SAS hot leg 1 Temperature	31	2U5022A	CNTMNT RAD	SAS High CNTMT radiation
2	2U5082A	NI INTER RNG	Avg intermed rng power level	17	2U5051A	HL TEMP 2/B	SAS hot leg 2 Temperature	32	2R0009A	RCS LTDN RAD	RC letdown line radiation
3	2U5081A	NI SOURC RNG	Avg srce rng pwr level	18	2U5053A	CL TEMP 1/A	SAS cold leg 1 Temperature	33	2U5143A	MAIN SL 1/A	SAS main steamline A rad'n
4	2U5011A	REAC VES LEV	SAS avg reactor vessel level	19	2U5055A	CL TEMP 2/B	SAS cold leg 2 Temperature	34	2U5144A	MAIN SL 2/B	SAS main steamline B rad'n
5	2U5510A	TEMP CORE EX	SAS 1st hottest incore T/C	20	2U5001A	RCS PRESSURE	SAS avg RCS pressure	35	2U5026A	SG BD RAD	SAS stm gen blowdown rad'n
6	2U5077A	SUB MARGIN	SAS RCS subcooling margin	21	2U5007A	PRZR LEVEL	SAS avg PRZR H2O lvl (NR)	36	2U5015A	CNTMNT PRESS	SAS avg containment press
7	2U5152A	CORE FLOW	RC avg flow	22	2F0128A	RCS CHG/MU	Charge pmp disch hdr flow	37	2U5013A	CNTMNT TEMP	SAS avg containment temp
8	2U5032A	SG LEVEL 1/A	SAS avg stm gen 1 H2O level	23	2U5154A	HP SI FLOW	Total safety injection flow	38	2U5021A	H2 CONC	SAS avg containment H2 conc
9	2U5034A	SG LEVEL 2/B	SAS avg stm gen 2 H2O level	24	2U0651A	LP SI FLOW	Total RHR flow	39	2U5068A	RWST LEVEL	SAS avg RWST level
10	2U5036A	SG PRESS 1/A	SAS avg stm gen 1 presure	25	2U5153A	CTMNT SMP NR	Sump B avg level NR	40	1U4105A	WIND SPEED	Met twr 10M avg wind spd A
11	2U5038A	SG PRESS 2/B	SAS avg stm gen 2 presure	26	2U5017A	CTMNT SMP WR	SAS avg contnment sump lvl	41	1U4106A	WIND SPEED	Met twr 10M avg wind spd B
12	2U5040A	MN FD FL 1/A	SAS avg stm gen1 feed flow	26	2U5061A	EFF GAS RAD	Shld bld gas efflnt low rng	42	1Y4109A	WIND DIR	Met twr 10M wind dir A
13	2U5042A	MN FD FL 2/B	SAS avg stm gen2 feed flow	28	2U5062A	EFF GAS RAD	Shld bld gas efflnt hi rng	43	1Y4110A	WIND DIR	Met twr 10M wind dir B
14	2U5044A	AX FD FL 1/A	SAS avg stm gen1 aux fd fl	29	1R0021A	EFF LIQ RAD	Circ wtr disch rad mnt'r	44	1U2907A	STAB CLASS	Met twr 50M avg delta temp A
15	2U5045A	AX FD FL 2/B	SAS avg stm gen2 aux fd fl	30	2U5024A	COND A/E RAD	SAS air ejector radiation	45	1U2908A	STAB CLASS	Met twr 50M avg delta temp B

PID	NRC ERDS PARAMETER	EU	ANLG/DIG	LO RANGE	Lo/Hi		CONVERSION	Unique system description
					ALRM/TRIP	SET-POINT		
FEEDER	ERCS POINT DESCRIPTION	P/S	PROCESS	HI RANGE			ZERO REF	
DATE	GENERIC/COND DESCRIPTION	#SNSR	LOCATION	FAIL MODE			DP TEMP COMP	
2U5048A	NI POWER RNG	%	Analog	0.0	N/A		N/A	This point reflects the CV-AVG of N41, N42, N43 & N44 power range reactor
ERCS #2	SAS avg pwr rng pwr level	P	CV-AVG	120.0	N/A		N/A	power level sensors.
07/02/91	Avg power range pwr level	4	Excore	LOW			N/A	
2U5082A	NI INTER RNG	MCAMP	Analog	1.0E-5	N/A		N/A	This point reflects the CV-AVG of 358 & 368 neutron flux intermediate range
ERCS #2	Avg intermed rng power level	P	CV-AVG	1.0E03	N/A		N/A	level sensors.
10/16/91	Avg intermed range pwr level	2	Excore	LOW			N/A	Note: MCAMP EU = micro-amps.
2U5081A	NI SOURC RNG	CPS	Analog	0.1	N/A		N/A	This point reflects the CV-AVG of 31E & 32F neutron flux source range level.
ERCS #2	Avg srce rng pwr	P	CV-AVG	1.0E06	N/A		N/A	The power supply does not shut off for these sensors.
10/16/91	Avg source range pwr level	2	Excore	LOW			N/A	
2U5011A	REAC VES LEV	%	Analog	0.0	0.0	4.4 inch/%		This point reflects the CV-AVG of the reactor vessel level based on reactor
ERCS #2	SAS avg reactor vessel level	P	CV-AVG	120.0	120.0	note		coolant pump operation. If RCPs are off then wide range RVLIS sensors are
07/02/91	Avg reactor vessel level	4	Contnmt	Failed		FROM RVLIS		used. Else, dynamic head RVLIS sensors are used. RVLIS is Westinghouse
								reactor vessel level indication system.
								Note: DP temp compensation is provided in the RVLIS computer which supplies
								this value to the ERCS computer.
								Note: Top of fuel = 56.7%. Bottom of fuel = 24%.
2U5510A	TEMP CORE EX	DegF	Analog	32.0	N/A		N/A	This point reflects the CV-AVG hottest reactor incore thermocouple.
ERCS #2	SAS 1st hottest incore T/C	P	CV-AVG	2300.0	N/A		N/A	Note: T/C = thermocouple.
07/02/91		36	Incore	Failed			N/A	
2U5077A	SUB MARGIN	DegF	Analog	-200.0	N/A		N/A	This point reflects the result of a two term linear equation using RCS
ERCS #2	SAS RCS subcooling margin	P	See note	1000.0	N/A		N/A	saturation temperature (Temp. saturated vapor as a function of presure
07/02/91	RCS subcooling margin	3		Failed			N/A	based on the 1967 ASME steam tables) and avg core exit temp (CV-AVG of the
								incore thermocouples).
2U5152A	CORE FLOW	%	Analog	0.0	N/A		N/A	This point reflects the CV-AVG of these 6 flow values:
ERCS #2	RC avg flow	P	CV-AVG	115.0	N/A		N/A	(A-RC 411, PID=F0400A), (A-RC 412, PID=F0401A), (A-RC 413, PID=F0402A),
07/17/91		6		Failed			N/A	(B-RC 414, PID=F0420A), (B-RC 415, PID=F0421A), (B-RC 416, PID=F0422A)

PID	NRC ERDS PARAMETER	EU	ANLG/DIG	LO RANGE	Lo/Hi		CONVERSION	Unique system description
					ALRM/TRIP	SET-POINT		
FEEDER	FRCS POINT DESCRIPTION	P/S	PROCESS	HI RANGE			ZERO REF	
DATE	GENERIC/COND DESCRIPTION	#SNSR	LOCATION	FAIL MODE			DP TEMP COMP	
2U5032A	SG LEVEL 1/A	%	Analog	0.0	20.0	1X=180gal @STP	*1=Sensor located 433" above the tube sheet. NR sensors cover a span of 144"	
ERCS #2	SAS avg stm gen 1 H2O level	P	CV-AVG	100.0	67.0	Note #2	*2=Zero reference 23" above tube bundle, 420" = top of tube bundle.	
07/02/91	Avg stm gen 1 H2O level	3	Note #1	Failed		Note #5	*3=This point reflects CV-AVG of loop A stm gen level (NR461, NR462 & NR463)	
							*4=level reference leg=yes, water filled with condenser pot.	
							*5=DP temp compensation not used.	
2U5034A	SG LEVEL 2/B	%	Analog	0.0	20.0	1X=180gal @STP	*1=Sensor located 433" above the tube sheet. NR sensors cover a span of 144"	
ERCS #2	SAS avg stm gen 2 H2O lev	P	CV-AVG	100.0	67.0	Note #2	*2=Zero reference 23" above tube bundle, 420" = top of tube bundle.	
07/05/91	Avg stm gen 2 H2O level	3	Note #1	Failed		N/A	*3=This point reflects CV-AVG of loop B stm gen level (NR471, NR472 & NR473)	
							*4=level reference leg=yes, water filled with condenser pot.	
2U5036A	SG PRESS 1/A	PSIG	Analog	0.0	500.0		N/A CV-AVG of loop A stm gen pressure (468, 469, 482).	
ERCS #2	SAS avg stm gen 1 presure	P	CV-AVG	1400.0	1075.0		N/A	
07/05/91	Avg stm gen 1 pressure	3		Failed			N/A	
2U5038A	SG PRESS 2/B	PSIG	Analog	0.0	500.0		N/A CV-AVG of loop B stm gen pressure (478, 479, 483).	
ERCS #2	SAS avg stm gen 2 presure	P	CV-AVG	1400.0	1075.0		N/A	
07/05/91	Avg stm gen 2 pressure	3		Failed			N/A	
2U5040A	MN FD FL 1/A	Lb/Hr	Analog	0.0	N/A		N/A CV-AVG of loop A fw flow 466(xmtr) & 467(xmtr).	
ERCS #2	SAS avg stm gen1 feed flow	P	CV-AVG	4470000	N/A		N/A *1=DP comp not used.	
07/05/91	Avg steam gen 1 feed flow	2		Failed			Note #1	
2U5042A	MN FD FL 2/B	Lb/Hr	Analog	0.0	N/A		N/A CV-AVG of loop B fw flow 476(xmtr) & 477(xmtr).	
ERCS #2	SAS avg stm gen2 feed flow	P	CV-AVG	4470000	N/A		N/A *1=DP comp not used.	
07/05/91	Avg stm gen 2 feed flow	2		Failed			N/A	
2U5044A	AX FD FL 1/A	GPM	Analog	0.0	N/A		N/A This point reflects the quality validation of AFW flow to A steam generator	
ERCS #2	SAS avg stm gen1 aux fd fl	P	QV	200.0	N/A		N/A against the SAS constants of steam aux feed flow lo EU & Hi EU. The	
07/05/91	Stm gen 1 aux feed flow	1		Failed			N/A constants are currently set at 0.0 and 200.0.	
							*1=DP comp not used.	
2U5045A	AX FD FL 2/B	GPM	Analog	0.0	N/A		N/A This point reflects the quality validation of AFW flow to B steam generator	
ERCS #2	SAS avg stm gen2 aux fd fl	P	QV	200.0	N/A		N/A against the SAS constants of steam aux feed flow Lo EU & Hi EU. The	
07/05/91	stm gen 2 aux feed flow	1		Failed			N/A constants are currently set at 0.0 and 200.0.	
							*1=DP comp not used.	

PID	NRC ERDS PARAMETER	EU	ANLG/DIG	LO RANGE	Lo/Hi		CONVERSION	Unique system description
					ALRM/TRIP	SET-POINT		
FEEDER	ERCS POINT DESCRIPTION	P/S	PROCESS	HI RANGE			ZERO REF	
DATE	GENERIC/COND DESCRIPTION	#SNSR	LOCATION	FAIL MODE			DP TEMP COMP	
2U5049A	HL TEMP 1/A	DegF	Analog	50.0	N/A		N/A	This point reflects the quality validation of A-RC hot leg temp 450A against
ERCS #2	SAS hot leg 1 Temperature	P	QV	700.0	N/A		N/A	the SAS constants of hot leg temp Lo EU and Hi EU. The constants are
07/05/91	Hot leg 1 temperature	1		Failed			N/A	currently set at 50.0 and 700.0.
2U5051A	HL TEMP 2/B	DegF	Analog	50.0	N/A		N/A	This point reflects the quality validation of B-RC hot leg temp 451A against
ERCS #2	SAS hot leg 2 Temperature	P	QV	700.0	N/A		N/A	the SAS constants of hot leg temp Lo EU and Hi EU. The constants are
07/05/91	Hot leg 2 temperature	1		Failed			N/A	currently set at 50.0 and 700.0.
2U5053A	CL TEMP 1/A	DegF	Analog	50.0	@FP 520		N/A	This point reflects the quality validation of A-RC cold leg temp 450B against
ERCS #2	SAS cold leg 1 Temperature	P	QV	700.0	@FP 555		N/A	the SAS constants of cold leg temp Lo EU and Hi EU. The constants are
07/05/91	Cold leg 1 temperature	1		Failed			N/A	currently set at 50.0 and 700.0. Note: Alarm setpoints are at full power. In other modes, setpoints are calculated based on system pressure.
2U5055A	CL TEMP 2/B	DegF	Analog	50.0	@FP 520		N/A	This point reflects the quality validation of B-RC cold leg temp 451B against
ERCS #2	SAS cold leg 2 Temperature	P	QV	700.0	@FP 555		N/A	the SAS constants of cold leg temp Lo EU and Hi EU. The constants are
07/05/91	Cold leg 2 temperature	1		Failed			N/A	currently set at 50.0 and 700.0. Note: Alarm setpoints are at full power. In other modes, setpoints are calculated based on system pressure.
2U5001A	RCS PRESSURE	PSIG	Analog	0.0	@FP 1900		N/A	CV-AVG of the 4 narrow range pressure sensors. If the validated quality of
ERCS #2	SAS avg RCS pressure	P	CV-AVG	3000.0	@FP 2385		N/A	the sensors is bad, then use CV-AVG of 2 wide range pressure sensors.
07/06/91	Avg RCS pressure	6					N/A	Note: At other than full power mode, SAS calculates Hi and Lo alarm limits.
2U5007A	PRZR LEVEL	%	Analog	0.0	14.8	64.6 gal/%	N/A	This point represents the CV-AVG of PRZR 426, 427 & 428 level sensors.
ERCS #2	SAS avg PRZR H2O lvl (NR)	P	CV-AVG	100.0	90.0	527 gal @zro	N/A	*1=0P comp not used.
07/06/91	Avg pressurizer H2O level	3		Failed		Note *1	N/A	Note: Zero % level is 18'9" above top of fuel.
2F0128A	RCS CHG/MU	Gpm	Analog	0.0	N/A		N/A	Sensor located 20 feet above discharge pump.
ERCS #2	Charge pmp disch hdr flow	S		100.0	N/A		N/A	
07/06/91		1	note	Low			N/A	

PID	NRC ERDS PARAMETER	EU	ANLG/DIG	Lo/Hi		CONVERSION	Unique system description
				LO RANGE	ALRM/TRIP		
FEEDER	ERCS POINT DESCRIPTION	P/S	PROCESS	HI RANGE	SET-POINT	ZERO REF	
DATE	GENERIC/COND DESCRIPTION	#SNSP	LOCATION	FAIL MODE		DP TEMP COMP	
2R0009A	RCS LTDN RAD	MR/Hr	Analog	0.1	N/A	N/A	
ERCS #2	RC letdown line radiation	S		10000.0	1000.0	N/A	
07/06/91		1		Failed		N/A	
2U5143A	MAIN SL 1/A	MR/Hr	Analog	1.0	N/A	N/A	This point reflects the quality validation of A stm line rad level against
ERCS #2	SAS main steamline A rad'n	P	QV	1.0 E5	N/A	N/A	the SAS constants of main steamline radiation Lo EU & Hi EU which are set at
07/06/91	Main steamline A radiation	1		Failed		N/A	1 & 100000.
2U5144A	MAIN SL 2/B	MR/Hr	Analog	1.0	N/A	N/A	This point reflects the quality validation of B stm line rad level against
ERCS #2	SAS main steamline B rad'n	P	QV	1.0 E5	N/A	N/A	the SAS constants of main steamline radiation Lo EU & Hi EU which are set at
07/06/91	Main steamline B radiation	1		Failed		N/A	1 & 100000.
2U5026A	SG BD RAD 1A	CPM	Analog	10.0	10.0	N/A	This point reflects the quality validation of A steam gen blowdown radiation
ERCS #2	SAS stm gen blowdown rad'n	P	QV	1.0 E6	1.0 E4	N/A	against the SAS constr:its of steam gen blowdown radiation Lo EU & Hi EU which
07/06/91	Stm gen blowdown radiation	1		Failed		N/A	are currently set at 10 & 1,000,000.
2U5015A	CNTMNT PRESS	PSIG	Analog	-5.0	-5.0	N/A	This point reflects the CV-AVG of containment pressure WR 717 & 718 sensors.
ERCS #2	SAS avg containment press	P	CV-AVG	200.0	4.0	N/A	
07/06/91	Avg containment pressure	2		Failed		N/A	
2U5013A	CNTMNT TEMP	DegF	Analog	0.0	N/A	N/A	*1-High alarm is 10 DegF greater than rolling 5 min avg of containment temp.
ERCS #2	SAS avg containment temp	P	Mov AVG	400.0	note *1	N/A	This point reflects the CV-AVG of containment air temp elevation 697 and 736
07/06/91	Avg containment temp	3		Failed		N/A	and 755 sensors.
2U5021A	H2 CONC (concentration)	%	Analog	0.0	N/A	N/A	This point reflects the CV-AVG of containment H2 concentration sensors 719 &
ERCS #2	SAS avg containment H2 conc	P	CV-AVG	10.0	N/A	N/A	721.
07/06/91	Avg containment H2 concntrn	2		Failed		N/A	
2U5068A	BWST LEVEL	%	Analog	0.0	N/A	2922 Gal/%	This point reflects the CV-AVG of RWST (refueling water storage tank) level
ERCS #2	SAS avg RWST level	P	CV-AVG	100.0	N/A	1898 Gal	sensors 920 and 921.
07/06/91	Avg RWST level	2		Failed		N/A	
1U4105A	WIND SPEED	MPH	Analog	0.0	N/A	N/A	Sensor location = meteorological tower A 10 meter height.
ERCS #2	Met twr 10M avg wind spd A	P	none	100.0	N/A	N/A	15 minute moving average of 30sec readings.
10/16/91		1	10 meter	Failed		N/A	

PID	NRC ERDS PARAMETER	EU	ANLG/DIG	LO RANGE	Lo/Hi	CONVERSION	Unique system description
					ALRN/TRIP		
FEEDER	ERCS POINT DESCRIPTION	P/S	PROCESS	HI RANGE	SET-POINT	ZERO REF	
DATE	GENERIC/COND DESCRIPTION	#SNSR	LOCATION	FAIL MODE		DP TEMP COMP	
1U4106A	WIND SPEED	MPH	Analog	0.0	N/A	N/A	Sensor location = meteorological tower B 10 meter height.
ERCS #2	Met twr 10M avg wind spd B	P	none	100.0	N/A	N/A	15 minute moving average of 30sec readings.
10/16/91		1	10 meter	Failed		N/A	
1Y4109A	WIND DIR	Deg	Analog	0.0	N/A	N/A	Sensor location = meteorological tower A 10 meter height.
ERCS #2	Pri met twr 10M wind dir A	S		360.0	N/A	N/A	Instantaneous values updated in 30 sec intervals.
07/09/91		1	10 meter	Failed		N/A	Indication is in the from direction.
1Y4110A	WIND DIR	Deg	Analog	0.0	N/A	N/A	Sensor location = meteorological tower A 10 meter height.
ERCS #2	Pri met twr 10M wind dir B	S		540.0	N/A	N/A	Instantaneous values updated in 30 sec intervals.
07/09/91		1	10 meter	Failed		N/A	Indication is in the from direction.
1U2907A	STAB CLASS	DF/100	Analog	-9.0	N/A	N/A	Sensor location = meteorological tower 10 & 60 meter height.
ERCS #2	Met twr avg delta temp A	P	Diff	9.0	N/A	N/A	This value represents the difference in temperature in degF/100Ft.
10/16/91		2	10 & 60 M.	Failed		N/A	
1U2908A	STAB CLASS	DF/100	Analog	-9.0	N/A	N/A	Sensor location = meteorological tower 10 & 60 meter height.
ERCS #2	Met twr avg delta temp B	P	Diff	9.0	N/A	N/A	This value represents the difference in temperature in degF/100Ft.
10/16/91		2	10 & 60 M.	Failed		N/A	