

Channels subject only to "drift" errors induced within the instrumentation itself can tolerate longer intervals between calibrations. Process system instrumentation errors induced by drift can be expected to remain within acceptable tolerances if recalibration is performed at the intervals of each refueling period.

Substantial calibration shifts within a channel (essentially a channel failure) will be revealed during routine checking and testing procedures.

Thus, minimum calibration frequencies set forth are considered acceptable.

Testing

On-line testing of reactor protection channels is required once every four weeks on a rotational or perfectly staggered basis. The rotation scheme is designed to reduce the probability of an undetected failure existing within the system and to minimize the likelihood of the same systematic test errors being introduced into each redundant channel.

The rotation schedule for the reactor protection channels is as follows:

Channels A, B, C, & D	Before Startup, when shutdown greater than 24 hours
Channel A	One Week After Startup
Channel B	Two Weeks After Startup
Channel C	Three Weeks After Startup
Channel D	Four Weeks After Startup

The reactor protection system instrumentation test cycle is continued with one channel's instrumentation tested each week. Upon detection of a failure that prevents trip action in a channel, the instrumentation associated with the protection parameter failure will be tested in the remaining channels. If actuation of a safety channel occurs, assurance will be required that actuation was within the limiting safety system setting.

The protection channels coincidence logic, the control rod drive trip breakers and the regulating control rod power SCRs are trip tested every four weeks. The trip test checks all logic combinations and is to be performed on a rotational basis. The logic and breakers of the four protection channels and the regulating control rod power SCRs shall be trip tested prior to startup when the reactor has been shutdown for greater than 24 hours. Discovery of a failure that prevents trip action requires the testing of the instrumentation associated with the protection parameter failure in the remaining channels.

8502050414 850201
PDR ADOCK 05000289
P PDR

TABLE 4.1-1
INSTRUMENT SURVEILLANCE REQUIREMENTS

<u>CHANNEL DESCRIPTION</u>	<u>CHECK</u>	<u>TEST</u>	<u>CALIBRATE</u>	<u>REMARKS</u>
1. Protection Channel Coincidence Logic	NA	M	NA	
2. Control Rod Drive Trip Breaker & Regulating Rod Power SCRs	NA	M	NA	Includes independent testing of shunt trip and undervoltage trip features.
3. Power Range Amplifier	D(1)	NA	(2)	(1) When reactor power is greater than 15%. (2) When above 15% reactor power run a heat balance check once per shift. Heat balance calibration shall be performed whenever heat balance exceeds indicated neutron power by more than 2%.
4. Power Range Channel	S	M	M(1)(2)	(1) When reactor power is greater than 60% verify imbalance using incore instrumentation. (2) When above 15% reactor power calculate axial offset upper and lower chambers after each startup if not done within the previous 7 days.
5. Intermediate Range Channel	S(1)	P	NA	(1) When in service.
6. Source Range Channel	S(1)	P	NA	(1) When in service.
7. Reactor Coolant Temperature Channel	S	M	R	
8. High Reactor Coolant Pressure Channel	S	M	R	
9. Low Reactor Coolant Pressure Channel	S	M	R	

4-3

Amendment No. 4B, 102