

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of)
NEW YORK POWER AUTHORITY)Docket No. 50-333
James A. FitzPatrick Nuclear Power Plant)

APPLICATION FOR AMENDMENT TO
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the New York Power Authority, as holder of Facility operating Licensing No. DPR-59, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

The proposed changes corrects an error in Table 3.7-1 ("Process Pipeline Penetrating Primary Containment") on page 198 of Appendix A to the FitzPatrick Technical Specifications. Specifically, isolation signals for two reactor water sample valves (02-AOV-039 & 40) on drywell penetration X-41 are changed from "B, C, D, E, & P" to "B & C".

The purpose of these changes is to correct an error inadvertently introduced in Table 3.7-1 during the initial issuance of the FitzPatrick Technical Specifications (Appendix A).

The proposed changes to the Technical Specifications Appendix A are presented in Attachment I to the Application. The associated Safety Evaluation is included in Attachment II.

NEW YORK POWER AUTHORITY

By *George M. Wilvonding*
Corbin A. McNeill, Jr.
Senior Vice President
Nuclear Generation

State of New York
County of Westchester

Subscribed and sworn to before
me this 29 day of January 1985.

JEANNE LA LUNA
NOTARY PUBLIC, STATE OF NEW YORK
NO. 60-4614305
QUALIFIED IN WESTCHESTER COUNTY
TERM EXPIRES MARCH 30th 1986

Jeanne La Luna
Notary Public

8502050485 850130
PDR ADOCK 05000333
P PDR