

APPENDIX A

NOTICE OF VIOLATION

Duquesne Light Company
Beaver Valley, Unit 1

Docket No. 50-334
License No. DPR-66

As a result of the inspection conducted on December 10, 1984 - January 7, 1985, and in accordance with the NRC Enforcement Policy (10 CFR 2, Appendix C) published in the Federal Register on March 8, 1984, (47 FR 8583), the following violations were identified:

- A. 10 CFR 20.408, Reports of Personnel Monitoring on Termination of Work, requires the licensee to report an individual's exposure to radiation and radioactive materials, incurred during the period of employment or work assignment in the licensee's facility, within 30 days after the exposure has been determined or within 90 days after the date of termination, whichever is earlier.

Contrary to the above, the termination exposure report for a contractor radiation worker who terminated employment at Beaver Valley Power Station, Unit 1, on July 27, 1984, was not issued until the omission was discovered on December 18, 1984.

This is a Severity Level V Violation (Supplement 1).

- B. Technical Specification 6.8, Procedures, and Regulatory Guide 1.33-1972, Quality Assurance Program Requirements, Appendix A, requires the implementation of administrative procedures for equipment control. Station Administrative Procedures, Chapter 4, and OM Chapter 48, Conduct of Operations, requires the use of a caution tag to flag any temporary or abnormal condition to the attention of operations personnel.

Contrary to the above, the 1C steam generator atmospheric dump isolation valve was closed on December 30, 1984, as a temporary measure to facilitate plant heatup, without placing a caution tag on the atmospheric dump valve controller to indicate its isolated condition. This resulted in an unnecessary challenge to the main steam safety valves on December 31, 1984.

This is a Severity Level IV Violation (Supplement 1).

8502050516 850130
PDR ADOCK 05000334
G PDR

Pursuant to the provisions of 10 CFR 2.201, Duquesne Light Company is hereby required to submit to this office within 30 days of the date of the letter transmitting this Notice, a written statement or explanation in reply, including for each violation: (1) the corrective steps which have been taken and the results achieved; (2) the corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.