



Nuclear Division
P.O. Box 4
Shippingport, PA 15077-0004

Telephone (412) 393-6000

January 25, 1985

Director of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Attn: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Generic Letter 84-24

Gentlemen:

On January 11, 1985, Duquesne Light Company received Generic Letter 84-24 which requested a certification of compliance to 10 CFR 50.49, "Environmental Qualification of Electric Equipment Important to Safety for Nuclear Power Plants."

This is to certify that:

- (a) Duquesne Light Company has implemented the requirements of 10 CFR 50.49, as detailed in our submittals on Equipment Qualification, for Beaver Valley Unit 1 within the established schedule except for an extension requested on December 14, 1984 and granted by NRC correspondence dated December 31, 1984. This extension (until November 30, 1985) was requested in order to obtain additional documentation to fully establish qualification for Westinghouse motors associated with the 1A and 1B Low Head Safety Injection Pumps and the 1A, 1B, and 1C Charging Pumps.
- (b) Beaver Valley Unit 1 has at least one path to safe shutdown using fully qualified equipment except as noted above. Justification for continued safe operation has been submitted for these items pending the establishment of full qualification.
- (c) All other equipment considered to be within the scope of 50.49, as described in our submittals on Equipment Qualification, is fully qualified for the conditions under which its operation is required.

8502050523 850125
PDR ADOCK 05000334
PDR


A048
1/0
Add: Shields
EAD

January 25, 1985
Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Generic Letter 84-24
Page 2

These certifications do not apply to Regulatory Guide 1.97 equipment that was not listed in our previous EQ submittals. The schedule for qualification of Regulatory Guide 1.97 equipment is not governed by 10 CFR 50.49(g), but rather will be established in the Regulatory Guide 1.97 resolution process. NRC Confirmatory Order dated June 12, 1984 established a Regulatory Guide 1.97 submittal date of November 30, 1985 for Beaver Valley Unit 1.

This also certifies that all IE Bulletins and Information Notices that identify EQ problems are reviewed for their relevance to Beaver Valley Unit 1 and when applicable, are included in the EQ program.

Very truly yours,


J. D. Sieber
Senior Manager
Nuclear Group

cc: Mr. W. M. Troskoski, Resident Inspector
U.S. Nuclear Regulatory Commission
Beaver Valley Power Station
Shippingport, PA 15077

Mr. Peter Tam, Project Manager
U.S. Nuclear Regulatory Commission
Phillips Building
Washington, DC 20555
-Mail Stop 438-

U.S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, DC 20555

Director, Safety Evaluation and Control
Virginia Electric & Power Company
P.O. Box 26666
One James River Plaza
Richmond, VA 23261

