JUL 16 192 03149PM NUCLEAR ENG & L1C Southern Nuclear Operating Company Post Office Box 1295 Birmingham, Alabama 35201 Telephone 205 868-5086

> Southern Nuclear Operating Company the southern electric system

J. D. Woodard Vice President Farley Project

July 16, 1992

Docket Nos. 50-348 50-364

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555

> Joseph M. Farley Nuclear Plant Inoperable Fire Suppression Water System 24-Hour Special Report

Gentlemen:

In accordance with Technical Specification 3.7.11.1, Action Statement b., a 24-hour telephone notification was provided to the NRC on July 15, 1992, regarding the inoperability of the fire suppression water system. This letter serves as confirmation of the above notification.

At 1323 on July 15, 1992, a section of pipe in the fire main yard loop ruptured causing a loss of fire main water pressure. The fire protection water tank levels dropped below the required levels. The fire main rupture was isolated, the fire pumps restored, and the fire water tank levels were recovered to the Technical Specification required levels.

A Special Report will be submitted to the NRC within 14 days. If you have any questions, please advise.

Respectfully submitted,

Woodard

JDW/EFB:map 2857

cc: Mr. S. D. Ebneter Mr. S. T. Hoffman Mr. G. F. Maxwell

9207200126 920716 PDR ADOCK 05000340 S PDR

1632 !!