



Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038  
Hope Creek Generating Station

July 15, 1992


U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Dear Sir:

MONTHLY OPERATING REPORT  
HOPE CREEK GENERATION STATION UNIT 1  
DOCKET NO. 50-354

In compliance with Section 6.9, Reporting Requirements for the Hope Creek Technical Specifications, the operating statistics for June are being forwarded to you along with the summary of changes, tests, and experiments for June 1992 pursuant to the requirements of 10CFR50.59(b).

Sincerely yours,

  
J. J. Hagan  
General Manager -  
Hope Creek Operations

*RAR*  
*sent*  
RAR:ld  
Attachments  
C Distribution

*TEPA*  
*11*

INDEX

| <u>SECTION</u>                                      | <u>NUMBER<br/>OF PAGES</u> |
|---|----------------------------|
| Average Daily Unit Power Level. . . . .             | 1                          |
| Operating Data Report . . . . .                     | 2                          |
| Refueling Information . . . . .                     | 1                          |
| Monthly Operating Summary . . . . .                 | 1                          |
| Summary of Changes, Tests, and Experiments. . . . . | 3                          |

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-354  
UNIT Hope Creek  
DATE 7/15/92  
COMPLETED BY V. Zabielski  
TELEPHONE (609) 339-3506

*VZ*

MONTH June 1992

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

1. 790  
2. 1036  
3. 1041  
4. 1049  
5. 1040  
6. 1040  
7. 1014  
8. 1026  
9. 1038  
10. 1041  
11. 1058  
12. 1037  
13. 136  
14. 427  
15. 979  
16. 1044

17. 1041  
18. 1042  
19. 1037  
20. 1040  
21. 1015  
22. 1052  
23. 1049  
24. 1031  
25. 1048  
26. 1039  
27. 1036  
28. 1034  
29. 1036  
30. 1037  
31. N/A

OPERATING DATA REPORT

DOCKET NO. 50-354  
 UNIT Hope Creek  
 DATE 7/15/92  
 COMPLETED BY V. Zabielski  
 TELEPHONE (609) 339-3506

OPERATING STATUS

1. Reporting Period June 1992 Gross Hours in Report Period 720

2. Currently Authorized Power Level (MWt) 3293  
 Max. Depend. Capacity (MWe-Net) 1031  
 Design Electrical Rating (MWe-Net) 1067

3. Power Level to which restricted (if any) (MWe-Net) None

4. Reasons for restriction (if any)

|  | <u>This</u><br><u>Month</u> | <u>Yr To</u><br><u>Date</u> | <u>Cumulative</u>  |
|--|-----------------------------|-----------------------------|--------------------|
| 5. No. of hours reactor was critical   | <u>720.0</u>                | <u>4049.5</u>               | <u>41,210.8</u>    |
| 6. Reactor reserve shutdown hours  | <u>0.0</u>                  | <u>0.0</u>                  | <u>0.0</u>         |
| 7. Hours generator on line   | <u>701.1</u>                | <u>3987.4</u>               | <u>40,562.0</u>    |
| 8. Unit reserve shutdown hours   | <u>0.0</u>                  | <u>0.0</u>                  | <u>0.0</u>         |
| 9. Gross thermal energy generated (MWH)  | <u>2,231,387</u>            | <u>12,768,348</u>           | <u>128,765,491</u> |
| 10. Gross electrical energy generated (MWH)  | <u>736,650</u>              | <u>4,258,530</u>            | <u>42,611,024</u>  |
| 11. Net electrical energy generated  | <u>704,077</u>              | <u>4,070,028</u>            | <u>40,721,577</u>  |
| 12. Reactor service factor   | <u>100.0</u>                | <u>92.7</u>                 | <u>85.0</u>        |
| 13. Reactor availability factor  | <u>100.0</u>                | <u>92.7</u>                 | <u>85.0</u>        |
| 14. Unit service factor  | <u>97.4</u>                 | <u>91.3</u>                 | <u>83.7</u>        |
| 15. Unit availability factor   | <u>97.4</u>                 | <u>91.3</u>                 | <u>83.7</u>        |
| 16. Unit capacity factor (using MDC)   | <u>94.8</u>                 | <u>90.4</u>                 | <u>81.5</u>        |
| 17. Unit capacity factor (Using Design MWe)  | <u>91.6</u>                 | <u>87.3</u>                 | <u>78.7</u>        |
| 18. Unit forced outage rate  | <u>2.6</u>                  | <u>3.2</u>                  | <u>5.0</u>         |
| 19. Shutdowns scheduled over next 6 months (type, date, & duration):<br>Refueling outage, 9/12/92, 60 days |                             |                             |                    |
| 20. If shutdown at end of report period, estimated date of start-up:<br>N/A                                |                             |                             |                    |



OPERATING DATA REPORT  
UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-354  
UNIT Hope Creek  
DATE 7/15/92  
COMPLETED BY V. Zabielski *VZ*  
TELEPHONE (609) 339-3506

MONTH June 1992

| NO. | DATE | TYPE<br>F=FORCED<br>S=SCHEDULED | DURATION<br>(HOURS) | REASON<br>(1) | METHOD OF<br>SHUTTING<br>DOWN THE<br>REACTOR OR<br>REDUCING<br>POWER (2) | CORRECTIVE<br>ACTION/COMMENTS   |
|-----|------|---------------------------------|---------------------|---------------|--|---|
| 5   | 6/1  | F                               | 0                   | A             | 4  | Power ascension following May forced outage IER 354/92-006  |
| 6   | 6/13 | F                               | 18.9                | A             | 9  | Unit was taken off line to repair EHC leak. The Reactor was not shut down, but was kept at approximately 3% power for the duration of the outage. |

Summary

REFUELING INFORMATION

DOCKET NO. 50-354  
 UNIT Hope Creek  
 DATE 7/15/92  
 COMPLETED BY S. Hollingsworth  
 TELEPHONE (609) 339-1051

MONTH June 1992

1. Refueling information has changed from last month:

Yes  No

2. Scheduled date for next refueling: 9/12/92

3. Scheduled date for restart following refueling: 11/11/92

4. A. Will Technical Specification changes or other license amendments be required?

Yes No

B. Has the reload fuel design been reviewed by the Station Operating Review Committee?

Yes No

If no, when is it scheduled? not scheduled (on or prior to 10/28/92)

5. Scheduled date(s) for submitting proposed licensing action: N/A

6. Important licensing considerations associated with refueling:

- Same fresh fuel as current cycle: no new considerations

7. Number of Fuel Assemblies:

|   |             |
|---|-------------|
| A. Incore                                     | <u>764</u>  |
| B. In Spent Fuel Storage (prior to refueling) | <u>760</u>  |
| C. In Spent Fuel Storage (after refueling)    | <u>1008</u> |

8. Present licensed spent fuel storage capacity: 4006

Future spent fuel storage capacity: 4006

9. Date of last refueling that can be discharged to spent fuel pool assuming the present licensed capacity: 11/4, 2010  
 (EOC16)

(does not allow for full-core offload)

HOPE CREEK GENERATING STATION

MONTHLY OPERATING SUMMARY

June 1992

On June 1, power ascension was underway following a forced outage on May 26 due to the failure of the Drywell to Suppression Chamber Decay Test to meet its acceptance criteria. The unit reached approximately 100% power on June 1. On June 13, the unit was taken off line to repair an Electro-Hydraulic Control leak. The Reactor remained at approximately 3% power during this evolution, was brought back on line on June 14, and restored to 100% power on June 15. On June 30, the plant had been on line for 16 consecutive days.

SUMMARY OF CHANGES, TESTS, AND EXPERIMENTS  
FOR THE HOPE CREEK GENERATING STATION

JUNE 1992



The following item has been evaluated to determine:

1. If the probability of occurrence or the consequences of an accident or malfunction of equipment important to safety previously evaluated in the safety analysis report may be increased; or
2. If a possibility for an accident or malfunction of a different type than any evaluated previously in the safety analysis report may be created; or
3. If the margin of safety as defined in the basis for any technical specification is reduced.

The 10CFR50.59 Safety Evaluation showed that this item did not create a new safety hazard to the plant nor did it affect the safe shutdown of the reactor. This item did not change the plant effluent releases and did not alter the existing environmental impact. The 10CFR50.59 Safety Evaluation determined that no unreviewed safety or environmental questions are involved.

TMR

92-016

Description of Safety Evaluation

This TMR installed electrical jumpers across the Feedwater Heater's High High Level Trip Switches. These switches cause spurious high level trip signals during low power levels due to inleakage in the reference leg. The jumpers are only required until the level signals stabilize and were removed later in the month.

The Feedwater system is not safety related and is not required to be operable following a LOCA, other than for containment isolation. Failure of the Feedwater system does not compromise any safety related system or components. This TMR has no impact on the containment isolation function of the Feedwater system. Therefore, this TMR does not involve any Unreviewed Safety Questions.