



July 15, 1992

1CAN079203

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Stop P1-137
Washington, D.C. 20555

SUBJECT: Arkansas Nuclear One - Unit 1
Docket No. 50-313
License No. DPR-51
Monthly Operating Report

Gentlemen:

Monthly Operating Report statistics for Arkansas Nuclear One, Unit 1, for June, 1992 is attached. This report is submitted in accordance with ANO-1 Technical Specification 6.12.2.3.

Sincerely yours,

James J. Fisicaro
Director, Licensing

JJF/SAB/sjf
Attachment

210007

9207210102 9207210
PDR ADOCK 05000313
R PDR

LEDA
11

cc: Mr. James L. Milhcan
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Arkansas Nuclear One - ANO-1 & 2
Number 1, Nuclear Plant Road
Russellville, AR 72801

Mr. Thomas W. Alexion
NER Project Manager, Region IV/ANO-1
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

Ms. Sheri Peterson
NRR Project Manager, Region IV/ANO-2
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

OPERATING DATA REPORT

DOCKET NO: 50-313
 DATE: July 8, 1992
 COMPLETED BY: K. R. Hayes
 TELEPHONE: (501) 964-5535

OPERATING STATUS

1. Unit Name: Arkansas Nuclear One - Unit 1
2. Reporting Period: June 1-30, 1992
3. Licensed Thermal Power (Mwt): 5,568
4. Nameplate Rating (Gross MWe): 902.74
5. Design Electrical Rating (Net MWe): 850
6. Maximum Dependable Capacity (Gross MWe): 883
7. Maximum Dependable Capacity (Net MWe): 836
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons: _____
9. Power Level To Which Restricted. If Any (Net MWe): None
10. Reasons For Restrictions. If Any: None

	MONTH	YR-TO-DATE	CUMULATIVE
11. Hours in Reporting Period	720.0	4,367.0	153,690.0
12. Number of Hours Reactor was Critical	720.0	2,720.8	108,582.0
13. Reactor Reserve Shutdown Hours	0.0	0.0	5,044.0
14. Hours Generator On-Line	720.0	2,671.9	106,404.7
15. Unit Reserve Shutdown Hours ..	0.0	0.0	817.5
16. Gross Thermal Energy Generated (MWH)	1,847,446.0	6,652,175.0	241,833,613.0
17. Gross Electrical Energy Generated (MWH)	624,945.0	2,268,600.0	80,547,140.0
18. Net Electrical Energy Generated (MWH)	598,420.0	2,158,667.0	76,533,915.0
19. Unit Service Factor	100.0	61.2	69.2
20. Unit Availability Factor	100.0	61.2	69.8
21. Unit Capacity Factor (Using MDC Net)	99.4	59.1	59.6
22. Unit Capacity Factor (Using DEC Net)	97.3	58.2	58.6
23. Unit Forced Outage Rate	0.0	0.2	12.2
24. Shutdowns Scheduled Over Next 5 Months (Type, Date, and Duration of Each): <u>None</u>			
25. If Shut Down At End of Report Period. Estimated Date of Startup: _____			
26. Units in Test Status (Prior to Commercial Operation): _____			

	Forecast	Achieved
INITIAL CRITICALITY	_____	08/06/74
INITIAL ELECTRICITY	_____	08/17/74
COMMERCIAL OPERATION	_____	12/19/74

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-313
UNIT: One
DATE: July 8, 1992
COMPLETED BY: K. R. Hayes
TELEPHONE: (501) 964-5535

MONTH June, 1992

DAY AVERAGE DAILY POWER LEVEL
 (MWe-Net)

1	835
2	836
3	837
4	837
5	835
6	834
7	834
8	833
9	834
10	833
11	834
12	830
13	834
14	831
15	832
16	830
17	829
18	829
19	828
20	828
21	828
22	830
23	828
24	829
25	827
26	828
27	828
28	827
29	828
30	829

AVGS: 831

INSTRUCTION

On this format, list the average daily unit power level in MWe-Net for each day in reporting month. Compute to the nearest whole megawatt.

MONTHLY OPERATING REPORT

OPERATING SUMMARY

JUNE, 1992

UNIT ONE

Unit One began the month operating at 100% power. On the twelfth at 19:00 hours, the unit load was decreased to 92% to perform the scheduled turbine throttle/governor valve testing. The unit power was then returned to 100% at 20:53 hours on the same day. The unit operated at full power for the remainder of the month.

UNIT SHUTDOWNS AND POWER REDUCTIONS
REPORT FOR JUNE, 1992

DOCKET NO. 50-313
 UNIT NAME ANO Unit 1
 DATE July 9, 1992
 COMPLETED BY K. A. Hayes
 TELEPHONE (501) 964-5535

Cause & Corrective
Action to
Prevent Recurrence

No. None

<p>1 F: Forced S: Scheduled</p>	<p>2 Reason: A-Equipment Failure (Explain) B-Maintenance or Test C-Refueling D-Regulatory Restriction E-Operator Training & License Examination F-Administrative G-Operational Error (Explain) H-Other (Explain)</p>	<p>3 Method: 1-Manual 2-Manual Scram. 3-Automatic Scram. 4-Continuation 5-Load Reduction 9-Other</p>	<p>4 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-1022)</p>	<p>5 Exhibit I - Same Source</p>
---	--	--	--	--------------------------------------

DATE: June, 1992

REFUELING INFORMATION

1. Name of facility: Arkansas Nuclear One - Unit 1
2. Scheduled date for next refueling shutdown. September 17, 1993
3. Scheduled date for restart following refueling. November 12, 1993
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment? If answer is yes, what, in general, will there be? If answer is no, has the reload fuel design and core configuration been reviewed by your Plant Safety Review Committee to determine whether any unreviewed safety questions are associated with the core reload (Ref. 10 CFR Section 50.59)?
ies, Technical Specification change to increase fuel enrichment from 3.5% to 4.1%.
5. Scheduled date(s) for submitting proposed licensing action and supporting information. The Technical Specification change request was submitted to the NRC on June 27, 1991 (1CAN069108).
6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures.
None.
7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool. a) 177 b) 625
8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies.
present 968 increase size by 0
9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity.
DATE: 1995 (Loss of fullcore offload capability)