

# WOLF CREEK

NUCLEAR OPERATING CORPORATION

John A. Bailey  
Vice President  
Operations

July 15, 1992

NO 92-0199


U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, D. C. 20555

Subject: Docket No. 50-482: June 1992, Monthly  
Operating Report

Gentlemen:

Attached is the June, 1992, Monthly Operating Report for Wolf Creek  
Generating Station. This submittal is being made in accordance with the  
requirements of Technical Specification 6.9.1.8.

Very truly yours,




John A. Bailey  
Vice President  
Operations

JAB/aem

Attachment

cc: A. T. Howell (NRC), w/a  
J. L. Milhoan (NRC), w/a  
G. A. Pick (NRC), w/a  
W. D. Reckley (NRC), w/a

9207210110 920725  
PDR ADOCK 05000482  
R DR



WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

MONTHLY OPERATING REPORT

MONTH: June YEAR: 1992

Docket No.: 50-482

Facility Operating License No.: NPF-42

Report No. 88

Prepared by:

Merlin G. Williams

SUMMARY

The following report highlights the operating experience of Wolf Creek Generating Station for the month of June, 1992. This report is being provided pursuant to Technical Specification 6.2.1.8.

I. SUMMARY OF OPERATING EXPERIENCE

The unit operated at or near 100% power throughout the month of June.

II. MAJOR SAFETY RELATED MAINTENANCE ACTIVITIES

No major safety related maintenance activities were performed during the month of June.

## OPERATING DATA REPORT

DOCKET NO. 50-482  
 WOLF CREEK GENERATING STATION  
 WOLF CREEK NUCLEAR OPERATING CORPORATION  
 DATE 07-09-92  
 COMPLETED BY M. Williams  
 TELEPHONE 316-364-8831

## OPERATING STATUS

1. Reporting Period: June, 1992 Gross Hours in Reporting Period: 7202. Currently Authorized Power Level (MWT): 3411 Max. Depend. Capacity (MWe-Net): 1131Design Electrical Rating (MWe-Net): 11703. Power Level to Which Restricted (If Any) (MWe-Net): N/A4. Reasons for restriction (If Any): N/A

	This Month	Yr. to Date	Cumulative
5. Number of Hours Reactor was Critical	<u>720.0</u>	<u>3,221.1</u>	<u>46,911.2</u>
6. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>339.8</u>
7. Hours Generator on Line	<u>720.0</u>	<u>3,153.5</u>	<u>46,265.8</u>
8. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
9. Gross Thermal Energy Generated (MWH)	<u>2,453,249</u>	<u>10,548,870</u>	<u>150,642,461</u>
10. Gross Electrical Energy Generated (MWH)	<u>856,187</u>	<u>3,682,007</u>	<u>52,395,513</u>
11. Net Electrical Energy Generated (MWH)	<u>823,320</u>	<u>3,495,938</u>	<u>49,951,409</u>
12. Reactor Service Factor	<u>100.0</u>	<u>73.8</u>	<u>78.4</u>
13. Reactor Availability Factor	<u>100.0</u>	<u>73.8</u>	<u>79.0</u>
14. Unit Service Factor	<u>100.0</u>	<u>72.2</u>	<u>77.3</u>
15. Unit Availability Factor	<u>100.0</u>	<u>72.2</u>	<u>77.3</u>
16. Unit Capacity Factor (Using MDC)	<u>101.1</u>	<u>70.8</u>	<u>73.8</u>
17. Unit Capacity Factor (Using Design MWe)	<u>97.7</u>	<u>68.4</u>	<u>71.4</u>
18. Unit Forced Outage Rate	<u>0.0</u>	<u>27.8</u>	<u>6.9</u>
19. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of each):	<u>N/A</u>		
20. If Shut Down at End of Report Period, Estimated Date of Startup:	<u>N/A</u>		

## AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-482  
 WOLF CREEK GENERATING STATION  
 WOLF CREEK NUCLEAP OPERATING CORPORATION  
 DATE 07-09-92  
 COMPLETED BY M. Williams  
 TELEPHONE 316-364-8831

MONTH June, 1992

DAY AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY AVERAGE DAILY POWER LEVEL (MWe-Net)
1 <u>1147</u>	17 <u>1142</u>
2 <u>1148</u>	18 <u>1143</u>
3 <u>1148</u>	19 <u>1141</u>
4 <u>1148</u>	20 <u>1142</u>
5 <u>1145</u>	21 <u>1143</u>
6 <u>1147</u>	22 <u>1143</u>
7 <u>1147</u>	23 <u>1137</u>
8 <u>1146</u>	24 <u>1141</u>
9 <u>1145</u>	25 <u>1140</u>
10 <u>1144</u>	26 <u>1141</u>
11 <u>1144</u>	27 <u>1141</u>
12 <u>1145</u>	28 <u>1142</u>
13 <u>1144</u>	29 <u>1141</u>
14 <u>1144</u>	30 <u>1140</u>
15 <u>1144</u>	31 <u>N/A</u>
16 <u>1142</u>	

## UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO. 50-482  
 WOLF CREEK GENERATING STATION  
 WOLF CREEK NUCLEAR OPERATING CORPORATION  
 DATE 07-09-92  
 COMPLETED BY M. Williams  
 TELEPHONE 316-364-8831

REPORT MONTH June, 1992

No	Date	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHODS SHUTTING DOWN THE REACTOR OR REDUCING POWER(2)	CORRECTIVE ACTIONS/COMMENTYS

SUMMARY: The unit operated at or near 100% power throughout the month.

1) REASON: A: EQUIPMENT FAILURE (EXPLAIN) E: OPERATOR TRAINING AND LICENSE EXAMINATION (2) METHOD: 1. MANUAL  
 B: MAINTENANCE OR TEST F: ADMINISTRATIVE 2. MANUAL SCRAM  
 C: REFUELING G: OPERATIONAL ERROR (EXPLAIN) 3. AUTOMATIC SCRAM  
 D: REGULATORY RESTRICTION H: OTHER (EXPLAIN) 4. CONTINUED  
 5. REDUCED LOAD  
 9. OTHER

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

UNIT NO. 1

MONTH June, 1992

SUMMARY OF OPERATING EXPERIENCE

Listed below in chronological sequence is a summary of operating experiences for this month which required load reduction or resulted in significant non-load related incidents.

<u>DATE</u>	<u>TIME</u>	<u>EVENT</u>
June 1, 1992	0000 hours	Unit at 100% power.
June 30, 1992	2400 hours	Unit at 100% power.