



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

POWER AUTHORITY OF THE STATE OF NEW YORK

DOCKET NO. 50-333

JAMES A. FITZPATRICK NUCLEAR POWER PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 182
License No. DPR-59

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Power Authority of the State of New York (the licensee) dated May 21, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-59 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 182, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

Robert A. Capra

Robert A. Capra, Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 13, 1992

ATTACHMENT TO LICENSE AMENDMENT NO. 182

FACILITY OPERATING LICENSE NO. DPR-59

DOCKET NO. 50-333

Revise Appendix A as follows:

Remove Page
78

Insert Page
78

JAFNPP

TABLE 4.2-1

MINIMUM TEST AND CALIBRATION FREQUENCY FOR PCIS

Instrument Channel (8)	Instrument Functional Test	Calibration Frequency	Instrument Check (4)
1) Reactor High Pressure (Shutdown Cooling Permissive)	(1)	Once/3 months	None
2) Reactor Low-Low-Low Water Level	(1)(5)	(15)	Once/day
3) Main Steam High Temp.	(1)(5)	(15)	Once/day
4) Main Steam High Flow	(1)(5)	(15)	Once/day
5) Main Steam Low Pressure	(1)(5)	(15)	Once/day
6) Reactor Water Cleanup High Temp.	(1)	Once/3 months	None
7) Condenser Low Vacuum	(1)(5)	(15)	Once/day
Logic System Functional Test (7) (9)		Frequency	
1)	Main Steam Line Isolation valves Main Steam Line Drain Valves Reactor Water Sample Valves	Once/6 months	
2)	RHR - Isolation Valve Control Shutdown Cooling Valves	Once/6 months	
3)	Reactor Water Cleanup Isolation	Once/6 months	
4)	Drywell Isolation Valves TIP Withdrawal Atmospheric Control Valves	Once/6 months	
5)	Standby Gas Treatment System Reactor Building Isolation	Once/6 months	

NOTE: See listing of notes following Table 4.2-6 for the notes referred to herein.